

*No significant hazards consideration comments received:* No.

*Vistra Operations Company LLC, Docket Nos. 50-445 and 50-446, Comanche Peak Nuclear Power Plant, Unit Nos. 1 and 2 (CPNPP), Somervell County, Texas*

*Date of amendment request:* March 29, 2018.

*Brief description of amendments:* The amendments revised Technical Specification 3.3.2, "Engineered Safety Feature Actuation System (ESFAS) Instrumentation," to change the applicability of when the automatic auxiliary feedwater actuation due to the trip of all main feedwater pumps is required to be operable at CPNPP.

*Date of issuance:* November 30, 2018.

*Effective date:* As of the date of issuance and shall be implemented within 60 days from the date of issuance.

*Amendment Nos.:* Unit 1-171; Unit 2-171. A publicly-available version is in ADAMS under Accession No. ML18304A487; documents related to these amendments are listed in the Safety Evaluation enclosed with the amendments.

*Facility Operating License Nos. NPF-87 and NPF-89:* The amendments revised the Facility Operating Licenses and Technical Specifications.

*Date of initial notice in Federal Register:* June 5, 2018 (83 FR 26107). The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated November 30, 2018.

*No significant hazards consideration comments received:* No.

Dated at Rockville, Maryland, this 10th day of December 2018.

For the Nuclear Regulatory Commission.

**Kathryn M. Brock,**

*Deputy Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.*

[FR Doc. 2018-26968 Filed 12-17-18; 8:45 am]

**BILLING CODE 7590-01-P**

## **NUCLEAR REGULATORY COMMISSION**

[Docket No. 50-277-SLR and 50-278-SLR; ASLBP No. 19-960-01-SLR-BD01]

### **Establishment of Atomic Safety and Licensing Board: Exelon Generation Company, LLC**

Pursuant to delegation by the Commission, *see* 37 FR 28,710; December 29, 1972, and the Commission's regulations, *see, e.g.,* 10 CFR 2.104, 2.105, 2.300, 2.309, 2.313, 2.318, 2.321, notice is hereby given that

an Atomic Safety and Licensing Board (Board) is being established to preside over the following proceeding:

#### **Exelon Generation Company, LLC**

*(Peach Bottom Atomic Power Station, Units 2 and 3)*

This proceeding involves an application seeking a twenty-year subsequent license renewal of Renewed Facility Operating License Nos. DPR-44 and DPR-56, which currently authorize Exelon Generation Company, LLC to operate Peach Bottom Atomic Power Station Units 2 and 3 until, respectively, August 8, 2033 and July 2, 2034. In response to a notice published in the **Federal Register** announcing the opportunity to request a hearing, *see* 83 FR 45,285; September 6, 2018, a hearing request has been filed on behalf of Beyond Nuclear, Inc.

The Board is comprised of the following Administrative Judges:

- Michael M. Gibson, Chairman, Atomic Safety and Licensing Board Panel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.
- Dr. Michael F. Kennedy, Atomic Safety and Licensing Board Panel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.
- Dr. Sue H. Abreu, Atomic Safety and Licensing Board Panel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

All correspondence, documents, and other materials shall be filed in accordance with the NRC E-Filing rule. *See* 10 CFR 2.302.

Dated: December 12, 2018, in Rockville, Maryland.

**Edward R. Hawkins,**

*Chief Administrative Judge, Atomic Safety and Licensing Board Panel.*

[FR Doc. 2018-27276 Filed 12-17-18; 8:45 am]

**BILLING CODE 7590-01-P**

## **NUCLEAR REGULATORY COMMISSION**

[Docket No. 70-7005; NRC-2018-0281]

### **Waste Control Specialists LLC**

**AGENCY:** Nuclear Regulatory Commission.

**ACTION:** Environmental assessment and finding of no significant impact; issuance.

**SUMMARY:** The U.S. Nuclear Regulatory Commission (NRC) is issuing an Environmental Assessment (EA) and Finding of No Significant Impact (FONSI) in support of the NRC's consideration of a request from Waste

Control Specialists LLC (WCS) to continue to store transuranic waste that originated from the Los Alamos National Laboratory (LANL) without an NRC license under the terms of a 2014 order. The 2014 order exempted WCS from the NRC's regulations concerning special nuclear material (SNM). The current action is in response to a request by WCS dated August 30, 2018, to extend the possession time to temporarily store certain waste at specific locations at the WCS Site until December 23, 2020.

**DATES:** The EA and FONSI referenced in this document are available on December 18, 2018.

**ADDRESSES:** Please refer to Docket ID NRC-2018-0281 when contacting the NRC about the availability of information regarding this document. You may obtain publicly-available information related to this document using any of the following methods:

- *Federal Rulemaking website:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2018-0281. Address questions about Docket IDs in *Regulations.gov* to Krupskaya Castello; telephone: 301-287-9221; email: [Krupskaya.Castellon@nrc.gov](mailto:Krupskaya.Castellon@nrc.gov). For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to [pdr.resource@nrc.gov](mailto:pdr.resource@nrc.gov). The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document.

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

**FOR FURTHER INFORMATION CONTACT:** Harry Felsher, Office of Nuclear Material Safety and Safeguards, U.S. Nuclear Regulatory Commission, Washington DC 20555-0001; telephone: 301-415-6559; email: [Harry.Felsher@nrc.gov](mailto:Harry.Felsher@nrc.gov).

**SUPPLEMENTARY INFORMATION:**