

the legal effect of this document upon publication in the **Federal Register**.

Signed in Washington, DC, on July 8, 2021.

Treena V. Garrett,

Federal Register Liaison Officer, U.S. Department of Energy.

[FR Doc. 2021-14838 Filed 7-12-21; 8:45 am]

BILLING CODE 6450-01-P

DEPARTMENT OF ENERGY

[Case Number 2020-005; EERE-2020-BT-WAV-0022]

Energy Conservation Program: Decision and Order Granting a Waiver to Vinotemp International Corp. From the Department of Energy Walk-In Coolers and Walk-In Freezers Test Procedure

AGENCY: Office of Energy Efficiency and Renewable Energy, Department of Energy.

ACTION: Notification of decision and order.

SUMMARY: The U.S. Department of Energy (“DOE”) gives notification of a Decision and Order (Case Number 2020-005) that grants to Vinotemp International Corp. (“Vinotemp”) a waiver from specified portions of the DOE test procedure for determining the energy efficiency of specified walk-in cooler refrigeration systems. Due to the design of the specific basic models of walk-in refrigeration systems subject to this Decision and Order, the current test procedure evaluates such models in a manner that is unrepresentative of their energy use. Under the Decision and Order, Vinotemp is required to test and rate the specified basic models of its walk-in cooler refrigeration systems in accordance with the alternate test procedure set forth in the Decision and Order.

DATES: The Decision and Order is effective on July 13, 2021. The Decision and Order will terminate upon the compliance date of any future amendment to the test procedure for walk-in coolers and walk-in freezers located at title 10 of the Code of Federal Regulations (“CFR”), part 431, subpart R, appendix C that addresses the issues presented in this waiver. At such time, Vinotemp must use the relevant test procedure for this equipment for any testing to demonstrate compliance with the applicable standards, and any other representations of energy use.

FOR FURTHER INFORMATION CONTACT: Ms. Lucy deButts, U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, Building Technologies Office, EE-5B, 1000

Independence Avenue SW, Washington, DC 20585-0121. Email: AS_Waiver_Requests@ee.doe.gov.

Mr. Michael Kido, U.S. Department of Energy, Office of the General Counsel, Mail Stop GC-33, Forrestal Building, 1000 Independence Avenue SW, Washington, DC 20585-0103. Telephone: (202) 586-8145. Email: Michael.Kido@hq.doe.gov.

SUPPLEMENTARY INFORMATION: In accordance with § 431.401(f)(2) of title 10 of the Code of Federal Regulations (“CFR”) (10 CFR 431.401(f)(2)), DOE gives notification of the issuance of its Decision and Order as set forth below. The Decision and Order grants Vinotemp a waiver from the applicable test procedure at 10 CFR part 431, subpart R, appendix C for specified basic models of walk-in cooler refrigeration systems, and provides that Vinotemp must test and rate such walk-in cooler refrigeration systems using the alternate test procedure specified in the Decision and Order. Vinotemp’s representations concerning the energy efficiency of the specified basic models must be based on testing according to the provisions and restrictions in the alternate test procedure set forth in the Decision and Order, and the representations must fairly disclose the test results. Distributors, retailers, and private labelers are held to the same requirements when making representations regarding the energy efficiency of these products. (42 U.S.C. 6314(d))

Manufacturers not currently distributing equipment in commerce in the United States that employ a technology or characteristic that results in the same need for a waiver from the applicable test procedure must petition for and be granted a waiver prior to the distribution in commerce of that equipment in the United States. Manufacturers may also submit a request for interim waiver pursuant to the requirements of 10 CFR 431.401. (10 CFR 431.401(j))

Case # 2020-005

Decision and Order

I. Background and Authority

The Energy Policy and Conservation Act, as amended (“EPCA”),¹ authorizes the U.S. Department of Energy (“DOE”) to regulate the energy efficiency of a number of consumer products and certain industrial equipment. (42 U.S.C. 6291-6317) Title III, Part C² of EPCA

¹ All references to EPCA in this document refer to the statute as amended through the Energy Act of 2020, Public Law 116-260 (Dec. 27, 2020).

² For editorial reasons, upon codification in the U.S. Code, Part C was redesignated as Part A-1.

established the Energy Conservation Program for Certain Industrial Equipment, which sets forth a variety of provisions designed to improve the energy efficiency for certain types of industrial equipment. This equipment includes walk-in coolers and walk-in freezers (collectively, “walk-ins”), the focus of this document. (42 U.S.C. 6311(1)(G))

The energy conservation program under EPCA consists essentially of four parts: (1) Testing, (2) labeling, (3) Federal energy conservation standards, and (4) certification and enforcement procedures. Relevant provisions of EPCA include definitions (42 U.S.C. 6311), test procedures (42 U.S.C. 6314), labeling provisions (42 U.S.C. 6315), energy conservation standards (42 U.S.C. 6313), and the authority to require information and reports from manufacturers (42 U.S.C. 6316; 42 U.S.C. 6299).

The Federal testing requirements consist of test procedures that manufacturers of covered equipment must use as the basis for: (1) Certifying to DOE that their equipment complies with the applicable energy conservation standards adopted pursuant to EPCA (42 U.S.C. 6316(a); 42 U.S.C. 6295(s)), and (2) making representations about the efficiency of that equipment (42 U.S.C. 6314(d)). Similarly, DOE must use these test procedures to determine whether the equipment complies with relevant standards promulgated under EPCA. (42 U.S.C. 6316(a); 42 U.S.C. 6295(s))

Under 42 U.S.C. 6314, EPCA sets forth the criteria and procedures DOE is required to follow when prescribing or amending test procedures for covered walk-ins. EPCA requires that any test procedures prescribed or amended under this section must be reasonably designed to produce test results which reflect energy efficiency, energy use or estimated annual operating cost of walk-ins during a representative average use cycle and requires that test procedures not be unduly burdensome to conduct. (42 U.S.C. 6314(a)(2)) The test procedure for walk-ins is set forth in the Code of Federal Regulations (“CFR”) at 10 CFR part 431, subpart R, appendix C, *Uniform Test Method for the Measurement of Net Capacity and AWEF of Walk-in Cooler and Walk-in Freezer Refrigeration Systems* (“Appendix C”).

Any interested person may submit a petition for waiver from DOE’s test procedure requirements. 10 CFR 431.401(a)(1). DOE will grant a waiver from the test procedure requirements if DOE determines either that the basic model for which the waiver was requested contains a design

characteristic that prevents testing of the basic model according to the prescribed test procedures, or that the prescribed test procedures evaluate the basic model in a manner so unrepresentative of its true energy consumption characteristics as to provide materially inaccurate comparative data. 10 CFR 431.401(f)(2). DOE may grant the waiver subject to conditions, including adherence to alternate test procedures. *Id.*

As soon as practicable after the granting of any waiver, DOE will publish in the **Federal Register** a notice of proposed rulemaking to amend its regulations so as to eliminate any need for the continuation of such waiver. 10 CFR 431.401(l). As soon thereafter as practicable, DOE will publish in the **Federal Register** a final rule to that effect. *Id.* When DOE amends the test procedure to address the issues presented in a waiver, the waiver will automatically terminate on the date on which use of that test procedure is required to demonstrate compliance. 10 CFR 431.401(h)(3).

II. Vinotemp's Petition for Waiver: Assertions and Determinations

DOE received correspondence from Vinotemp, docketed on June 29, 2020, seeking an interim waiver from the DOE test procedure applicable to walk-ins set forth in Appendix C for certain basic models Vinotemp characterized as "wine cellar" systems. (Vinotemp, No. 1³) By letter docketed on December 10, 2020, Vinotemp submitted a petition for waiver for certain basic models of walk-in cooler refrigeration systems to supplement its original interim waiver request (Vinotemp, No. 3).⁴ The December 10, 2020 submission also explicitly stated that none of the basic models could operate below 45 °F and provided external static pressure ("ESP") values for the subject basic models.⁵ Vinotemp included additional basic models and clarified the specified external static pressure values as

³ A notation in the form "Vinotemp, No. 1" identifies a written submission: (1) Made by Vinotemp; and (2) recorded in document number 1 that is filed in the docket of this petition for waiver (Docket No. EERE-2020-BT-WAV-0022) and available at www.regulations.gov.

⁴ The waiver process under 10 CFR 431.401 requires that a petition for interim waiver must reference the related petition for waiver. (10 CFR 431.401(b)(2))

⁵ The December 10, 2020 update was consistent with a letter from the Air-Conditioning, Heating, and Refrigeration Institute ("AHRI") recommending that a 45 °F minimum temperature be used for testing wine cellar cooling systems, and that testing be conducted at an external static pressure ("ESP") value equal to 50 percent of the maximum ESP to be specified by manufacturers for each basic model. The AHRI letter is available at Docket No. EERE-2020-BT-WAV-0022-0002.

maximum values (rather than tested values) for the specified basic models in an updated petition for interim waiver, received on March 11, 2021 (Vinotemp, No. 10). Vinotemp stated that the specified basic models of walk-in cooler refrigeration systems operate at a temperature range of 45 °F to 65 °F and 50 to 70 percent relative humidity ("RH"), rather than the 35 °F with less than 50 percent RH test conditions prescribed by the test procedure for walk-in cooler applications. Vinotemp stated that the units operate at temperature and relative humidity ranges optimized for long-term storage of wine, reflecting conditions in natural caves, and that they are usually located in air-conditioned spaces. Vinotemp asserted that the specified units cannot operate at 35 °F.

On May 4, 2021, DOE published a notification announcing its receipt of the petition for waiver and granted Vinotemp an interim waiver. 86 FR 23692 ("Notification of Petition for Waiver"). In the Notification of Petition for Waiver, DOE noted that the "Self-contained" and "Self-packaged" basic models of walk-in refrigeration systems identified by Vinotemp in its petition are self-contained, single-package systems. Although not specifically addressed in Vinotemp's request for waiver, DOE notes that operating a wine cellar at the 35 °F condition would adversely mechanically alter the intended performance of the system, which would include icing of the evaporator coil that could potentially damage the compressor, and would not result in an accurate representation of the performance of the cooling unit. 86 FR 23692, 23695. Additionally, although not explicitly identified by Vinotemp, DOE recognized that because of their single-package design, these basic models have insufficient space within the units and insufficient lengths of liquid line and evaporator outlet line for the dual mass flow meters (*i.e.*, two independent meters) and the dual temperature and pressure measurements (*i.e.*, two independent sets of measuring equipment) required by the test procedure's refrigerant enthalpy method. *Id.* AHRI 1250-2009 ("Standard for Performance Rating of Walk-in Coolers and Freezers"⁶)—the industry testing standard on which DOE's test procedure is based—does not include specific provisions for testing single-package systems, and testing these basic models using the refrigerant enthalpy method as required by Appendix C would require extensive

⁶ This also includes the related Errata sheet published by AHRI, dated December 2015.

additional piping to route the pipes out of the system—where the components could be installed—and then back in. This additional piping would impact unit performance, would likely be inconsistent between test labs, and would result in unrepresentative test values for the unit under test. AHRI has published a revised version of the test standard that provides provisions for single-package systems without requiring extensive additional piping (AHRI 1250-2020, *2020 Standard for Performance Rating of Walk-in Coolers and Freezers*).

In the Notification of Petition for Waiver, DOE established an alternate test procedure that was a modified version of the alternate test procedure suggested by Vinotemp. 86 FR 23692, 23698-23700. The alternate test procedure prescribed in the Notification of Petition for Waiver is the same as the alternate test procedure established in other waivers and interim waivers granted by DOE for similarly situated equipment.⁷ Specifically, the required alternate test procedure establishes unit cooler air inlet conditions of 55 °F and 55 percent RH, specifies primary and secondary capacity measurement methods for single-package systems, requires testing at 50 percent of maximum external static pressure for ducted units, and defines wine cellar box load and evaporator cycle periods for calculation of Annual Walk-in Energy Factor ("AWEF") for the specified basic models of walk-in cooler refrigeration systems. *Id.* DOE solicited comments from interested parties on all aspects of the petition and the modified alternate test procedure. *Id.*

DOE received one comment, which was submitted by the Pacific Gas and Electric Company, San Diego Gas and Electric, and Southern California Edison (collectively, "the CA IOUs").⁸ The CA IOUs stated their agreement with DOE that since the subject basic models are unable to operate below 45 °F, there is limited opportunity for market confusion from labeling the products tested according to the test procedure waivers as walk-in coolers. (CA IOUs, No. 12)

For the reasons explained here and in the Notification of Petition for Waiver, absent a waiver the basic models identified by Vinotemp in its petition

⁷ See Notice of Decision and Order granting a waiver to Vinotheque (Case No. 2019-011; 86 FR 26504 (May 14, 2021)); Notice of Decision and Order granting a waiver to CellarPro (Case No. 2019-009; 86 FR 26496 (May 14, 2021)); and Notice of Decision and Order granting a waiver to Air Innovations (Case No. 2019-010; 86 FR 23702 (May 4, 2021)).

⁸ Comment available in Docket No. EERE-2020-BT-WAV-0022 at www.regulations.gov.

cannot be tested and rated for energy consumption on a basis representative of their true energy consumption characteristics. As noted previously, the alternate test procedure prescribed in the Interim Waiver modified Vinotemp's suggested alternate test procedure by including ESP provisions for certain systems that can be installed with (1) ducted evaporator air, (2) with or without ducted evaporator air, (3) ducted condenser air, or (4) with or without ducted condenser air. For such systems, testing is conducted at 50 percent of the maximum ESP specified by the manufacturer, subject to a tolerance of $-0.00/+0.05$ inches of water column ("in. wc."). (Vinotemp, No. 2)

Selection of a representative ESP equal to half the maximum ESP is based on the expectation that most installations will require less than the maximum allowable duct length. In the absence of field data, DOE expects that a range of duct lengths from the minimal length to the maximum allowable length would be used; thus, half of the maximum ESP would be representative of most installations.

If the basic model provides multiple condenser or unit cooler fan speed settings, the speed setting used is as instructed in the unit's installation instructions. However, if the installation instructions do not specify a fan speed setting for ducted installation, systems that can be installed with ducts would be tested with the highest available fan speed. The ESP is set for testing either by symmetrically restricting the outlet duct or, if using the indoor air enthalpy method, by adjusting the airflow measurement apparatus blower.

The alternate test procedure also specifies the requirements for measuring ESP consistent with the provisions provided in AHRI 1250–2020 when using the indoor air enthalpy method with unit coolers.

Additionally, the alternate test procedure requires that specified basic models that are split systems must be tested as matched pairs. According to Vinotemp's petition, the walk-in refrigeration system basic models that are split-systems are sold as full systems (*i.e.*, matched pairs) rather than as individual unit cooler and condensing unit components. This Order provides no direction regarding refrigerant line connection operating conditions, and as such is inapplicable to testing the basic models as individual components.

Consequently, this Order addresses only matched-pair testing of the specified basic models that are split-systems.

Contrary to Vinotemp's request, the Order does not modify the condenser air entering dry bulb temperature for outdoor condensers. 86 FR 23692, 23697. Vinotemp had suggested a 90 °F condenser air entering dry bulb temperature in its waiver request; however, the company did not provide technical justification for this request, and DOE has determined that outdoor wine cellar refrigeration units must be tested at 95 °F, 59 °F, and 35 °F, consistent with the current DOE test procedure.

For the reasons explained in the Notification of Petition for Waiver, the Order does not include a 0.55 correction factor in the alternate test procedure as suggested by Vinotemp. 86 FR 23692, 23697–23698. The company had observed that the test procedure in appendix A to subpart B of 10 CFR part 430 ("Appendix A"), which applies to miscellaneous refrigeration products, includes such a factor to adjust for average use, and sought to include such a factor as part of its petition. As explained in the Notice of Petition for Waiver, the closed-door conditions on which the miscellaneous refrigeration correction factor is based are not present in the test procedure for walk-in cooler refrigeration systems, and the referenced AHRI 1250–2009 provisions assume a load factor of 50 percent, consistent with Appendix C. *Id.* As a result, applying the 0.55 correction factor as suggested by Vinotemp is not appropriate for the specified basic models.

DOE is requiring that Vinotemp test and rate specified wine cellar walk-in refrigeration system basic models according to the alternate test procedure specified in this Decision and Order. This alternate procedure is a modified version of the one suggested by Vinotemp. The alternate test procedure required under this Order is the same alternate test procedure prescribed in the Interim Waiver Order.

This Decision and Order applies only to the basic models listed and does not extend to any other basic models. DOE evaluates and grants waivers for only those basic models specifically set out in the petition, not future models that may be manufactured by the petitioner. Vinotemp may request that DOE extend the scope of this waiver to include additional basic models that employ the

same technology as those listed in this waiver. 10 CFR 431.401(g). Vinotemp may also submit another petition for waiver from the test procedure for additional basic models that employ a different technology and meet the criteria for test procedure waivers. 10 CFR 431.401(a)(1).

DOE notes that it may modify or rescind the waiver at any time upon DOE's determination that the factual basis underlying the petition for waiver is incorrect, or upon a determination that the results from the alternate test procedure are unrepresentative of the basic models' true energy consumption characteristics. 10 CFR 431.401(k)(1). Likewise, Vinotemp may request that DOE rescind or modify the waiver if the company discovers an error in the information provided to DOE as part of its petition, determines that the waiver is no longer needed, or for other appropriate reasons. 10 CFR 431.401(k)(2).

As set forth previously, the test procedure specified in this Decision and Order is not the same as the test procedure suggested by Vinotemp. If Vinotemp believes that the alternate test method it suggested provides representative results and is less burdensome than the test method required by this Decision and Order, Vinotemp may submit a request for modification under 10 CFR 431.401(k)(2) that addresses the concerns that DOE has specified with that procedure. Vinotemp may also submit another less burdensome alternative test procedure not expressly considered in this notification under the same provision.

III. Order

After careful consideration of all the material that was submitted by Vinotemp, the various public-facing materials (*e.g.*, marketing materials, product specification sheets, and installation manuals) for the units identified in the petition, information provided by Vinotemp and other wine cellar walk-in refrigeration system manufacturers in meetings with DOE, and the comment received, in this matter, it is *ordered* that:

(1) Vinotemp must, as of the date of publication of this Order in the **Federal Register**, test and rate the following Wine Mate-branded wine cellar walk-in cooler refrigeration system basic models with the alternate test procedure as set forth in paragraph (2):

VINOTEMP BASIC MODELS

Brand name	Configuration	Basic model No.
Wine Mate	Single-Packaged	WM-2500HZD.
Wine Mate	Single-Packaged	WM-4500HZD.
Wine Mate	Single-Packaged	WM-6500HZD.
Wine Mate	Single-Packaged	WM-8500HZD.
Wine Mate	Single-Packaged	WM-4510HZD.
Wine Mate	Single-Packaged	WM-6510HZD.
Wine Mate	Single-Packaged	WM-8510HZD.
Wine Mate	Single-Packaged	WM-4500DS.
Wine Mate	Single-Packaged	WM-6500DS.
Wine Mate	Single-Packaged	WM-8500DS.
Wine Mate	Single-Packaged	WM-12030DS.
Wine Mate	Matched	WM-2500SSA.
Wine Mate	Matched	WM-2500SSD.
Wine Mate	Matched	WM-2500SSH.
Wine Mate	Matched	WM-2500SSL.
Wine Mate	Matched	WM-2500SSI.
Wine Mate	Matched	WM-2500SSO.
Wine Mate	Matched	WM-2500SSR.
Wine Mate	Matched	WM-2500SSV.
Wine Mate	Matched	WM-2500SSW.
Wine Mate	Matched	WM-4500SSA.
Wine Mate	Matched	WM-4500SSD.
Wine Mate	Matched	WM-4500SSH.
Wine Mate	Matched	WM-4500SSL.
Wine Mate	Matched	WM-4500SSI.
Wine Mate	Matched	WM-4500SSO.
Wine Mate	Matched	WM-4500SSR.
Wine Mate	Matched	WM-4500SSS.
Wine Mate	Matched	WM-4500SSV.
Wine Mate	Matched	WM-4500SSW.
Wine Mate	Matched	WM-6500SSA.
Wine Mate	Matched	WM-6500SSD.
Wine Mate	Matched	WM-6500SSH.
Wine Mate	Matched	WM-6500SSL.
Wine Mate	Matched	WM-6500SSR.
Wine Mate	Matched	WM-6500SSV.
Wine Mate	Matched	WM-8500SSA.
Wine Mate	Matched	WM-8500SSD.
Wine Mate	Matched	WM-8500SSH.
Wine Mate	Matched	WM-8500SSL.
Wine Mate	Matched	WM-8500SSS.
Wine Mate	Matched	WM-12000SSA.
Wine Mate	Matched	WM-12000SSD.
Wine Mate	Matched	WM-12000SSH.
Wine Mate	Matched	WM-12000SSS.

(2) The alternate test procedure for the Vinotemp basic models listed in paragraph (1) of this Order is the test procedure for Walk-in Cooler Refrigeration Systems prescribed by DOE at 10 CFR part 431, subpart R, appendix C, (“Appendix C to Subpart R”) with the modifications provided below. All other requirements of Appendix C and DOE’s other relevant regulations remain applicable.

In Appendix C to Subpart R, revise section 3.1.1 (which specifies modifications to AHRI 1250–2009 (incorporated by reference; see § 431.303)) to read:

3.1.1. In Table 1, Instrumentation Accuracy, refrigerant temperature measurements shall have an accuracy of ±0.5 °F for unit cooler in/out. Measurements used to determine temperature or water vapor content of the air (*i.e.*, wet bulb or dew point) shall be accurate to within ±0.25 °F; all other

temperature measurements shall be accurate to within ±1.0 °F.

In Appendix C to Subpart R, revise section 3.1.4 (which specifies modifications to AHRI 1250–2009) and add modifications of AHRI 1250–2009 Tables 3 and 4 to read:

3.1.4. In Tables 3 and 4 of AHRI 1250–2009, Section 5, the Condenser Air Entering Wet-Bulb Temperature requirement applies only to single-packaged dedicated systems. Tables 3 and 4 shall be modified to read:

TABLE 3—FIXED CAPACITY MATCHED REFRIGERATOR SYSTEM AND SINGLE-PACKAGED DEDICATED SYSTEM, CONDENSING UNIT LOCATED INDOOR

Test description	Unit cooler air entering dry-bulb, °F	Unit cooler air entering relative humidity, % ¹	Condenser air entering dry-bulb, °F	Maximum condenser air entering wet-bulb, °F	Compressor status	Test objective
Evaporator Fan Power	55	55	Measure fan input wattage ² .
Refrigeration Capacity	55	55	90	³ 65	Compressor On	Determine Net Refrigeration Capacity of Unit Cooler, input power, and EER at Rating Condition.

Notes:

¹ The test condition tolerance (maximum permissible variation of the average value of the measurement from the specified test condition) for relative humidity is 3%.

² Measure fan input wattage either by measuring total system power when the compressor and condenser are turned off or by separately submetering the evaporator fan.

³ Maximum allowable value for Single-Packaged Systems that do not use evaporative Dedicated Condensing Units, where all or part of the equipment is located in the outdoor room.

TABLE 4—FIXED CAPACITY MATCHED REFRIGERATOR SYSTEM AND SINGLE-PACKAGED DEDICATED SYSTEM, CONDENSING UNIT LOCATED OUTDOOR

Test description	Unit cooler air entering dry-bulb, °F	Unit cooler air entering relative humidity, % ¹	Condenser air entering dry-bulb, °F	Maximum condenser air entering wet-bulb, °F	Compressor status	Test objective
Evaporator Fan Power	55	55	Measure fan input wattage ² .
Refrigeration Capacity A ...	55	55	95	³ 68	Compressor On	Determine Net Refrigeration Capacity of Unit Cooler, input power, and EER at Rating Condition.
Refrigeration Capacity B ...	55	55	59	³ 46	Compressor On	Determine Net Refrigeration Capacity of Unit Cooler and system input power at moderate condition.
Refrigeration Capacity C ...	55	55	35	³ 29	Compressor On	Determine Net Refrigeration Capacity of Unit Cooler and system input power at cold condition.

Notes:

¹ The test condition tolerance (maximum permissible variation of the average value of the measurement from the specified test condition) for relative humidity is 3%.

² Measure fan input wattage either by measuring total system power when the compressor and condenser are turned off or by separately submetering the evaporator fan.

³ Maximum allowable value for Single-Packaged Dedicated Systems that do not use evaporative Dedicated Condensing Units, where all or part of the equipment is located in the outdoor room.

In Appendix C to Subpart R, following section 3.2.5 (instructions regarding modifications to AHRI 1250–2009), add sections 3.2.6 and 3.2.7 to read:

3.2.6 The purpose in section C1 of appendix C is modified by extending it to include Single-Packaged Dedicated Systems.

3.2.7 For general test conditions and data recording (appendix C, section C7), the test acceptance criteria in Table 2 and the data to be recorded in Table C2 apply to the Dual Instrumentation and Calibrated Box methods of test.

In Appendix C to Subpart R, revise section 3.3 to read:

3.3. *Matched systems, single-packaged dedicated systems, and unit coolers tested alone:* Test any split system walk-in refrigeration system as a matched pair. Any condensing unit or unit cooler component must be matched with a corresponding counterpart for testing. Use the test method in AHRI 1250–2009 (incorporated by reference; see § 431.303), appendix C as the method of test for matched refrigeration systems, single-packaged dedicated systems, or unit coolers tested alone, with the following modifications:

* * * * *

In Appendix C to Subpart R, revise sections 3.3.3 through 3.3.3.2 to read:

3.3.3 *Evaporator fan power.*

3.3.3.1 The unit cooler fan power consumption shall be measured in accordance with the requirements in Section C3.5 of AHRI 1250–2009. This measurement shall be made with the fan operating at full speed, either measuring unit cooler or total system power input upon the completion of the steady state test when the compressors and condenser fan of the walk-in system is turned off, or by submetered measurement of the evaporator fan power during the steady state test.

Section C3.5 of AHRI 1250–2009 is revised to read:

Unit Cooler Fan Power Measurement. The following shall be measured and recorded during a fan power test.

$EF_{comp,on}$ Total electrical power input to fan motor(s) of Unit Cooler, W

FS Fan speed (s), rpm

N Number of motors

P_b Barometric pressure, in. Hg

T_{db} Dry-bulb temperature of air at inlet, °F

T_{wb} Wet-bulb temperature of air at inlet, °F

V Voltage of each phase, V

For a given motor winding configuration, the total power input shall be measured at the highest nameplated voltage. For three-phase power, voltage imbalance shall be no more than 2%.

3.3.3.2 Evaporator fan power for the off-cycle is equal to the on-cycle evaporator fan power with a run time of ten percent of the off-cycle time.

$EF_{comp,off} = 0.1 \times EF_{comp,on}$

In Appendix C to Subpart R, following section 3.3.7.2, add new sections 3.3.8, 3.3.9, and 3.3.10 to read:

3.3.8. Measure power and capacity of single-packaged dedicated systems as described in sections C4.1.2 and C9 of AHRI 1250–2020. The third and fourth sentences of Section C9.1.1.1 of AHRI 1250–2020 (“Entering air is to be sufficiently dry as to not produce frost on the Unit Cooler coil. Therefore, only sensible capacity measured by dry bulb change shall be used to calculate capacity.”) shall not apply.

3.3.9. For systems with ducted evaporator air, or that can be installed with or without ducted evaporator air: Connect ductwork on both the inlet and outlet connections and determine external static pressure as described in ASHRAE 37–2009, sections 6.4 and 6.5. Use pressure measurement instrumentation as described in ASHRAE 37–2009 section 5.3.2. Test at the fan speed specified in manufacturer installation instructions—if there is more than one fan speed setting and the installation instructions do not specify which speed to use, test at the highest speed. Conduct tests with the external static pressure equal to 50 percent of the maximum external static pressure allowed by the manufacturer for system installation within a tolerance of $-0.00/+0.05$ in. wc. If testing with the indoor air enthalpy method, adjust the airflow measurement apparatus fan to set the external static pressure—otherwise, set the external static pressure by symmetrically restricting the outlet of the test duct. In case of conflict, these requirements for setting evaporator airflow take precedence over airflow values specified in manufacturer installation instructions or product literature.

3.3.10. For systems with ducted condenser air, or that can be installed with or without ducted condenser air: Connect ductwork on both the inlet and outlet connections and determine external static pressure as described in ASHRAE 37–2009, sections 6.4 and 6.5. Use pressure measurement instrumentation as described in ASHRAE 37–2009 section 5.3.2. Test at the fan speed specified in manufacturer

installation instructions—if there is more than one fan speed setting and the installation instructions do not specify which speed to use, test at the highest speed. Conduct tests with the external static pressure equal to 50 percent of the maximum external static pressure allowed by the manufacturer for system installation within a tolerance of $-0.00/+0.05$ in. wc. If testing with the outdoor enthalpy method, adjust the airflow measurement apparatus fan to set the external static pressure—otherwise, set the external static pressure by symmetrically restricting the outlet of the test duct. In case of conflict, these requirements for setting condenser airflow take precedence over airflow values specified in manufacturer installation instructions or product literature. If testing using the outdoor air enthalpy method, the requirements of section 8.6 of ASHRAE 37–2009 are not applicable.

In Appendix C to Subpart R, revise section 3.3.6 (which specifies modifications to AHRI 1250–2009) to read:

3.3.6. AWEF is calculated on the basis that walk-in box load is equal to half of the system net capacity, without variation according to high and low load periods and without variation with outdoor air temperature for outdoor refrigeration systems, and the test must be done as a matched or single-package refrigeration system, as follows:

BILLING CODE 6450-01-P

For Indoor Condensing Units:

$$\dot{B}L = 0.5 \cdot \dot{q}_{ss}(90^\circ F)$$

$$LF = \frac{\dot{B}L + 3.412 \cdot \dot{E}F_{comp,off}}{\dot{q}_{ss}(90^\circ F) + 3.412 \cdot \dot{E}F_{comp,off}}$$

$$AWEF = \frac{\dot{B}L}{\dot{E}_{ss}(90^\circ F) \cdot LF + \dot{E}F_{comp,off} \cdot (1 - LF)}$$

For Outdoor Condensing Units:

$$\dot{B}L = 0.5 \cdot \dot{q}_{ss}(95^\circ F)$$

$$LF(t_j) = \frac{\dot{B}L + 3.412 \cdot \dot{E}F_{comp,off}}{\dot{q}_{ss}(t_j) + 3.412 \cdot \dot{E}F_{comp,off}}$$

$$AWEF = \frac{\sum_{j=1}^n BL(t_j)}{\sum_{j=1}^n E(t_j)}$$

$$BL(t_j) = \dot{B}L \cdot n_j$$

$$E(t_j) = \left[\dot{E}_{ss}(t_j) \cdot LF(t_j) + \dot{E}F_{comp,off} \cdot (1 - LF(t_j)) \right] \cdot n_j$$

Where:

$\dot{B}L$ is the non-equipment-related box load

LF is the load factor

And other symbols are as defined in AHRI 1250–2009.

(3) *Representations.* Vinotemp may not make representations about the efficiency of a basic model listed in paragraph (1) of this Order for compliance, marketing, or other purposes unless the basic model has been tested in accordance with the provisions set forth above and such representations fairly disclose the results of such testing.

(4) This waiver shall remain in effect according to the provisions of 10 CFR 431.401.

(5) This Order is issued on the condition that the statements, representations, and information provided by Vinotemp are valid. If Vinotemp makes any modifications to the controls or configurations of a basic model subject to this Order, such modifications will render the waiver invalid with respect to that basic model, and Vinotemp will either be required to

use the current Federal test method or submit a new application for a test procedure waiver. DOE may rescind or modify this waiver at any time if it determines the factual basis underlying the petition for waiver is incorrect, or the results from the alternate test procedure are unrepresentative of a basic model's true energy consumption characteristics. 10 CFR 431.401(k)(1). Likewise, Vinotemp may request that DOE rescind or modify the waiver if Vinotemp discovers an error in the information provided to DOE as part of its petition, determines that the waiver is no longer needed, or for other appropriate reasons. 10 CFR 431.401(k)(2).

(6) Vinotemp remains obligated to fulfill any applicable requirements set forth at 10 CFR part 429.

DOE makes decisions on waivers and interim waivers for only those basic models specifically set out in the petition, not future models that may be manufactured by the petitioner. Vinotemp may submit a new or amended petition for waiver and request

for grant of interim waiver, as appropriate, for additional basic models of walk-in cooler refrigeration systems. Alternatively, if appropriate, Vinotemp may request that DOE extend the scope of a waiver or an interim waiver to include additional basic models employing the same technology as the basic model(s) set forth in the original petition consistent with 10 CFR 431.401(g).

Signing Authority

This document of the Department of Energy was signed on July 7, 2021, by Kelly Speakes-Backman, Principal Deputy Assistant Secretary and Acting Assistant Secretary for Energy Efficiency and Renewable Energy, pursuant to delegated authority from the Secretary of Energy. That document with the original signature and date is maintained by DOE. For administrative purposes only, and in compliance with requirements of the Office of the Federal Register, the undersigned DOE Federal Register Liaison Officer has been authorized to sign and submit the

document in electronic format for publication, as an official document of the Department of Energy. This administrative process in no way alters the legal effect of this document upon publication in the **Federal Register**.

Signed in Washington, DC, on July 8, 2021.

Treena V. Garrett,

*Federal Register Liaison Officer, U.S.
Department of Energy.*

[FR Doc. 2021-14836 Filed 7-12-21; 8:45 am]

BILLING CODE 6450-01-C

DEPARTMENT OF ENERGY

Agency Information Collection Extension

AGENCY: U.S. Department of Energy.

ACTION: Notice and request for OMB review and comment.

SUMMARY: The Department of Energy (DOE) invites public comment on a proposed collection of information that DOE is developing for submission to the Office of Management and Budget (OMB) pursuant to the Paperwork Reduction Act of 1995. The information collection requests a three-year extension of its Labor Relations Report collection. The collection requests information from the Department of Energy Management and Operation (M&O) and Facilities Management Contractors for contract administration, management oversight, and cost control. The information collection will assist the Department in evaluating the implementation of the contractors' work force collective bargaining agreements, and apprise the Department of significant labor-management developments at DOE contractor sites. This information is used to ensure that Department contractors maintain good labor relations and retain a workforce in accordance with the terms of their contract and in compliance with statutory and regulatory requirements as identified by contract.

DATES: Comments regarding this collection must be received on or before September 13, 2021. If you anticipate that you will be submitting comments, but find it difficult to do so within the period of time allowed by this notice, please contact the person listed in **ADDRESSES** as soon as possible.

ADDRESSES: Written comments should be sent to: John M. Sullivan, GC-63, U.S. Department of Energy, 1000 Independence Avenue SW, Washington, DC 20585, or by fax at (202) 586-0971; or by email to john.m.sullivan@hq.doe.gov.

FOR FURTHER INFORMATION CONTACT:

Requests for additional information or copies of the information collection instrument and instructions should be directed to: John M. Sullivan, Attorney-Advisor (Labor), GC-63, U.S. Department of Energy, 1000 Independence Avenue SW, Washington, DC 20585, or by fax at (202) 586-0971 or by email to john.m.sullivan@hq.doe.gov.

SUPPLEMENTARY INFORMATION: This information collection request contains: (1) *OMB No.*: 1910-5143; (2)

Information Collection Request Title:

Labor Relations Report; (3) *Type of Request:* *Renewal*; (4) *Purpose:* The proposed collection will request information from the Department of Energy M&O and Facilities Management Contractors for contract administration, management oversight, and cost control. This information is used to ensure that Department contractors maintain good labor relations and retain a workforce in accordance with the terms of their contract and in compliance with statutory and regulatory requirements as identified by contract. The respondents are Department M&O and Facility Management Contractors; (5) *Annual Estimated Number of Respondents:* 35; (6) *Annual Estimated Number of Total Responses:* 35; (7) *Annual Estimated Number of Burden Hours:* 1.84 per respondent for total of 64.4 per year; (8) *Annual Estimated Reporting and Recordkeeping Cost Burden:* \$5,964.95.

Statutory Authority: 42 U.S.C. 7254, 7256.

Signing Authority

This document of the Department of Energy was signed on July 6, 2021, by John T. Lucas, Deputy General Counsel for Transactions, Technology and Contractor Human Resources, pursuant to delegated authority from the Secretary of Energy. That document with the original signature and date is maintained by DOE. For administrative purposes only, and in compliance with requirements of the Office of the Federal Register, the undersigned DOE Federal Register Liaison Officer has been authorized to sign and submit the document in electronic format for publication, as an official document of the Department of Energy. This administrative process in no way alters the legal effect of this document upon publication in the **Federal Register**.

Signed in Washington, DC, on July 8, 2021.

Treena V. Garrett,

*Federal Register Liaison Officer, U.S.
Department of Energy.*

[FR Doc. 2021-14855 Filed 7-12-21; 8:45 am]

BILLING CODE 6450-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Docket No. CP18-103-000]

Rockies Express Pipeline LLC; Notice of Extension of Time Request

Take notice that on June 23, 2021, Rockies Express Pipeline LLC (Rockies Express) requested that the Federal Energy Regulatory Commission (Commission) grant an extension of time, until September 20, 2023, to complete the construction of six new 5,350 horsepower (hp) natural gas reciprocating compressor units (32,100 hp total) at its existing Cheyenne Compressor Station (Cheyenne Hub Enhancement Project) in Weld County, Colorado, as authorized as part of the Cheyenne Hub Enhancement Project in the September 20, 2019 Order Issuing Certificates¹ (September 20 Order). The September 20 Order required Rockies Express to complete construction and make the facilities available for service within two years of the Order date. Rockies Express has since completed construction of four of the six authorized compressor units, placing units 1-3 into service on July 26, 2020,² and unit 4 into service on December 17, 2020.³ Compressor units 5 and 6 remain unconstructed.

Rockies Express states it has been delayed in reaching full commercialization for compressor units 5 and 6, with the economic slowdown and fallout from the COVID-19 pandemic. The final two compressor units that have not yet been constructed will be installed at the existing Cheyenne Compressor Station on land already owned by Rockies Express under the terms and conditions of the existing certificate. Rockies Express states that the extension of time will not result in any environmental impacts not already examined on the record in the certificate proceeding and will provide Rockies Express with the time necessary to install these remaining two units.

This notice establishes a 15-calendar day intervention and comment period deadline. Any person wishing to comment on Rockies Express' request for an extension of time may do so. No

¹ *Cheyenne Connector, LLC*, 168 FERC ¶ 61,180 (2019), *order amending certificate*, 171 FERC ¶ 61,055 (2020). In the Order the Commission also approved the Cheyenne Connector Pipeline Project in Docket No. CP18-102-000.

² Notice of Commencement of Service of Rockies Express Pipeline LLC, Docket No. CP18-103-000 (July 13, 2020).

³ Notice of Commencement of Service of Rockies Express Pipeline LLC, Docket No. CP18-103-000 (December 17, 2020).