

between 746 feet and 764 feet msl; (5) a 186-foot-long, 150-foot-high concrete powerhouse, integral with the dam, housing two vertical Francis turbines with a maximum hydraulic capacity of 8,000 cubic feet per second (cfs) and a rated total installed capacity of 135 megawatts (MW); (6) two 115 kilovolt transmission lines, which extend 1.5 miles from the dam to the Crooked Creek Transmission sub-station; and (7) appurtenant facilities.

Alabama Power proposes to install, operate, and maintain a Francis-type minimum flow unit to provide a continuous minimum flow of approximately 300 cfs in the Tallapoosa River downstream from Harris Dam. Based on preliminary design, the proposed minimum flow unit would

have a generating capacity of about 2.5 MW.

The Harris Project is a peaking facility that generates about 151,878 megawatt-hours of electricity annually. Alabama Power operates the project to target lake surface elevations as guided by the project's operating curve. In addition, the U.S. Army Corps of Engineers' Alabama-Coosa-Tallapoosa River Basin Water Control Manual describes flood management regulations, drought management provisions, and navigation requirements for the Harris Project.

I. A copy of the application can be viewed on the Commission's website at <http://www.ferc.gov>, using the "eLibrary" link. Enter the docket number, excluding the last three digits in the docket number field, to access the document. At this time, the Commission has suspended access to the

Commission's Public Reference Room due to the proclamation declaring a National Emergency concerning the Novel Coronavirus Disease (COVID-19) issued on March 13, 2020. For assistance, contact FERC at [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov), or call toll-free, (866) 208-3676 or (202) 502-8659 (TTY).

m. You may also register online at <http://www.ferc.gov/docs-filing/esubscription.asp> to be notified via email of new filings and issuances related to this or other pending projects. For assistance, contact FERC Online Support.

n. *Procedural schedule:* The application will be processed according to the following preliminary schedule. Revisions to the schedule will be made as appropriate.

Milestone	Target date
Issue Deficiency Letter (if necessary) .....	December 2021.
Request Additional Information .....	January 2022.
Notice of Acceptance/Notice of Ready for Environmental Analysis .....	April 2022.

o. Final amendments to the application must be filed with the Commission no later than 30 days from the issuance date of the notice of ready for environmental analysis.

Dated: December 7, 2021.

**Kimberly D. Bose,**  
*Secretary.*

[FR Doc. 2021-26898 Filed 12-10-21; 8:45 am]  
BILLING CODE 6717-01-P

**DEPARTMENT OF ENERGY**

**Federal Energy Regulatory Commission**

[Docket No. NJ22-3-000]

**City of Anaheim, California; Notice of Filing**

Take notice that on November 30, 2021, the City of Anaheim, California submitted its tariff filing: Revised Transmission Revenue Requirement and Transmission Revenue Balancing Account Adjustment with an effective date of January 1, 2022.

Any person desiring to intervene or to protest this filing must file in accordance with Rules 211 and 214 of the Commission's Rules of Practice and Procedure (18 CFR 385.211, 385.214). Protests will be considered by the Commission in determining the appropriate action to be taken but will not serve to make protestants parties to the proceeding. Any person wishing to become a party must file a notice of

intervention or motion to intervene, as appropriate. Such notices, motions, or protests must be filed on or before the comment date. On or before the comment date, it is not necessary to serve motions to intervene or protests on persons other than the Applicant.

In addition to publishing the full text of this document in the **Federal Register**, the Commission provides all interested persons an opportunity to view and/or print the contents of this document via the internet through the Commission's Home Page (<http://www.ferc.gov>) using the "eLibrary" link. Enter the docket number excluding the last three digits in the docket number field to access the document. At this time, the Commission has suspended access to the Commission's Public Reference Room, due to the proclamation declaring a National Emergency concerning the Novel Coronavirus Disease (COVID-19), issued by the President on March 13, 2020. For assistance, contact the Federal Energy Regulatory Commission at [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov) or call toll-free, (866) 208-3676 or TYY, (202) 502-8659.

The Commission strongly encourages electronic filings of comments, protests and interventions in lieu of paper using the "eFiling" link at <http://www.ferc.gov>. Persons unable to file electronically may mail similar pleadings to the Federal Energy Regulatory Commission, 888 First Street NE, Washington, DC 20426. Hand

delivered submissions in docketed proceedings should be delivered to Health and Human Services, 12225 Wilkins Avenue, Rockville, Maryland 20852.

*Comment Date:* 5:00 p.m. Eastern Time on December 14, 2021.

Dated: December 7, 2021.

**Kimberly D. Bose,**  
*Secretary.*

[FR Doc. 2021-26900 Filed 12-10-21; 8:45 am]  
BILLING CODE 6717-01-P

**ENVIRONMENTAL PROTECTION AGENCY**

[EPA-R09-OAR-2021-0629; FRL 9252-01-R9]

**Final Agency Action To Issue a Prevention of Significant Deterioration Non-Applicability Determination for the AltAir Renewable Fuels Project**

**AGENCY:** Environmental Protection Agency (EPA).

**ACTION:** Notice of final agency action.

**SUMMARY:** This notice announces that the Environmental Protection Agency (EPA) issued a final agency action for a Clean Air Act Prevention of Significant Deterioration (PSD) Non-Applicability Determination to AltAir Paramount, LLC ("AltAir"), for its Renewable Fuels Project in California's South Coast Air Basin. AltAir plans to convert the remainder of the existing Paramount Crude Oil Refinery into a renewable