

criteria in the combined license for Vogtle Electric Generating Plant (VEGP), Unit 3 are met. Because of this action, operation of the facility is allowed in accordance with the terms and conditions of the license.

DATES: The finding that the acceptance criteria in the combined license are met became effective on August 3, 2022.

ADDRESSES: Please refer to Docket ID NRC–2008–0252 when contacting the NRC about the availability of information regarding this document. You may obtain publicly available information related to this document using any of the following methods:

- *Federal Rulemaking Website:* Go to <https://www.regulations.gov> and search for Docket ID NRC–2008–0252. Address questions about Docket IDs in *Regulations.gov* to Stacy Schumann; telephone: 301–415–0624; email: Stacy.Schumann@nrc.gov. For technical questions, contact the individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC’s Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly available documents online in the ADAMS Public Documents collection at <https://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “Begin Web-based ADAMS Search.” For problems with ADAMS, please contact the NRC’s Public Document Room (PDR) reference staff at 1–800–397–4209, 301–415–4737, or by email to PDR.Resource@nrc.gov. For the convenience of the reader, instructions about obtaining materials referenced in this document are provided in the “Availability of Documents” section.

- *NRC’s PDR:* You may examine and purchase copies of public documents,

by appointment, at the NRC’s PDR, Room P1 B35, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852. To make an appointment to visit the PDR, please send an email to PDR.Resource@nrc.gov or call 1–800–397–4209 or 301–415–4737, between 8:00 a.m. and 4:00 p.m. Eastern Time (ET), Monday through Friday, except Federal holidays.

FOR FURTHER INFORMATION CONTACT: Cayetano Santos, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001; telephone: 301–415–7270; email: Cayetano.Santos@nrc.gov.

SUPPLEMENTARY INFORMATION: Under Section 2.106 of title 10 of the *Code of Federal Regulations* (10 CFR), “Notice of issuance,” the NRC is providing notice that it has found that the acceptance criteria in the combined license for VEGP, Unit 3 are met. Section 185b. (42 U.S.C. 2235(b)) of the Atomic Energy Act of 1954, as amended (AEA), and 10 CFR 52.97(b) require that the Commission identify within the combined license the inspections, tests, and analyses, including those applicable to emergency planning, that the licensee shall perform, and the acceptance criteria that, if met, are necessary and sufficient to provide reasonable assurance that the facility has been constructed and will be operated in conformity with the license, the provisions of the AEA, and the Commission’s rules and regulations. In compliance with these requirements, the Commission included inspections, tests, analyses, and acceptance criteria (ITAAC) in Appendix C to VEGP, Unit 3 combined license No. NPF–91.

Section 185b. of the AEA also requires, in part, that following issuance

of the combined license, the Commission shall ensure that the prescribed inspections, tests, and analyses are performed, and before operation of the facility, find that the prescribed acceptance criteria are met. The NRC codified the requirement to ensure completion of the inspections, tests, and analyses in 10 CFR 52.99(e) and codified the requirement regarding the finding that the acceptance criteria are met in 10 CFR 52.103(g).

The NRC staff has determined that the inspections, tests, and analyses have been successfully completed and found that all specified acceptance criteria in the VEGP, Unit 3 combined license No. NPF–91 are met. This finding was made on August 3, 2022, and was effective on August 3, 2022. The principal basis for the staff’s 10 CFR 52.103(g) finding was the staff’s review of the licensee’s ITAAC notifications under 10 CFR 52.99(c) and the staff’s inspection of ITAAC-related activities conducted by the licensee. The staff explained the basis for its finding in the document titled “10 CFR 52.103(g) Basis Document Vogtle Electric Generating Plant, Unit 3.” Because of the NRC’s finding that the acceptance criteria are met, operation of the facility is allowed in accordance with the terms and conditions of the license.

I. Availability of Documents

The documents identified in the following table are available to interested persons through the ADAMS Public Documents collection and the NRC’s PDR. The files are also available online at <https://www.nrc.gov/reactors/new-reactors/col-holder/vog3.html>.

Document	ADAMS accession No.
VEGP, Unit 3 Combined License No. NPF–91	ML14100A106.
VEGP, Unit 3 Finding that the Acceptance Criteria in the Combined License Are Met	ML20290A282.
10 CFR 52.103(g) Basis Document Vogtle Electric Generating Plant, Unit 3	ML20290A276.

Dated: August 3, 2022.
 For the Nuclear Regulatory Commission.
Andrea D. Veil,
Director, Office of Nuclear Reactor Regulation.
 [FR Doc. 2022–16928 Filed 8–5–22; 8:45 am]
BILLING CODE 7590–01–P

NUCLEAR REGULATORY COMMISSION

[NRC–2022–0036]

Water Sources for Long-Term Recirculation Cooling Following a Loss-of-Coolant Accident

AGENCY: Nuclear Regulatory Commission.

ACTION: Regulatory guide; issuance.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is issuing Revision 5 of Regulatory Guide (RG) 1.82, “Water Sources for Long-Term Cooling

Following a Loss-of-Coolant Accident.” This revised guidance updates the guidance for sumps and suppression pools that provide water sources for emergency core cooling, containment heat removal, or containment atmosphere cleanup systems. It also provides guidelines for evaluating the adequacy and the availability of the sump or suppression pool for long-term recirculation cooling following a loss-of-coolant accident, and the use of containment accident pressure in determining the net positive suction

head for the emergency core cooling and containment heat removal pumps.

DATES: Revision 5 to RG 1.82 is available on August 8, 2022.

ADDRESSES: Please refer to Docket ID NRC-2022-0036 when contacting the NRC about the availability of information regarding this document. You may obtain publicly available information related to this document using any of the following methods:

- *Federal Rulemaking Website:* Go to <https://www.regulations.gov> and search for Docket ID NRC-2022-0036. Address questions about Docket IDs in *Regulations.gov* to Stacy Schumann; telephone: 301-415-0624; email: Stacy.Schumann@nrc.gov. For technical questions, contact the individuals listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly available documents online in the ADAMS Public Documents collection at <https://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "Begin Web-based ADAMS Search." For questions regarding use of ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to PDR.Resource@nrc.gov. The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document.

- *NRC's PDR:* You may examine and purchase copies of public documents, by appointment, at the NRC's PDR, Room P1 B35, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852. To make an appointment to visit the PDR, please send an email to PDR.Resource@nrc.gov or call 1-800-397-4209 or 301-415-4737, between 8:00 a.m. and 4:00 p.m. Eastern Time (ET), Monday through Friday, except Federal holidays

Revision 5 to RG 1.82 may be found in ADAMS under Accession No. ML22152A114.

Regulatory guides are not copyrighted, and NRC approval is not required to reproduce them.

FOR FURTHER INFORMATION CONTACT: Ahsan Sallman, Office of Nuclear Reactor Regulation, telephone: 301-415-2380, email: Ahsan.Sallman@nrc.gov, and James Steckel, Office of Nuclear Regulatory Research, telephone: 301-415-1026, email: James.Steckel@nrc.gov. Both are staff of the U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

SUPPLEMENTARY INFORMATION:

I. Discussion

The NRC is issuing a revision to an existing guide in the NRC's "Regulatory Guide" series. This series was developed to describe and make available to the public information regarding methods that are acceptable to the NRC staff for implementing specific parts of the agency's regulations, to explain techniques that the staff uses in evaluating specific issues or postulated events, and to describe information that the staff needs in its review of applications for permits and licenses.

Revision 5 of RG 1.82 was issued with a temporary identification number of DG-1385 (ADAMS Accession No. ML21266A185).

Revision 5 of RG 1.82, describes an approach that may be used to determine quality standards acceptable to the NRC staff to meet the regulatory requirements for sumps and suppression pools that provide water sources for emergency core cooling, containment heat removal, or containment atmosphere cleanup systems. Revision 5 of RG 1.82 also provides acceptable methods for evaluating the adequacy and the availability of the sump or suppression pool for long-term recirculation cooling following a loss-of-coolant accident, and the use of containment accident pressure in determining the net positive suction head for the emergency core cooling and containment heat removal pumps.

II. Additional Information

In January 2015 the staff conducted a periodic review of Revision 4 to RG 1.82, and on January 21, 2015, the staff reported the results of the periodic review, "Result of Periodic Review of Regulatory Guide 1.82," (ADAMS Accession No. ML14345A333). Based on the results of the periodic review, the staff concluded that a revision of RG 1.82 was warranted.

The NRC published a notice of availability of DG-1385 in the **Federal Register** on February 8, 2022 (87 FR 7209) for a 30-day public comment period. A request from the Nuclear Energy Institute to allow more time for members of the public to submit their comments was accepted, and the public comment period was extended to April 8, 2022 (87 FR 13019). Public comments and staff responses to those comments are available in ADAMS under Accession No. ML22145A479. In addition, staff considered and addressed technical issues related to the periodic review of RG 1.82, Revision 4.

III. Congressional Review Act

This RG is a rule as defined in the Congressional Review Act (5 U.S.C.

801-808). However, the Office of Management and Budget has not found it to be a major rule as defined in the Congressional Review Act.

IV. Backfitting, Forward Fitting, and Issue Finality

The issuance of this regulatory guide does not constitute backfitting as defined in section 50.109 of title 10 of the *Code of Federal Regulations* (10 CFR), "Backfitting," and as described in NRC Management Directive 8.4, "Management of Backfitting, Forward Fitting, Issue Finality, and Information Requests," or affect issue finality of any approval issued under 10 CFR part 52, "Licenses, Certificates, and Approvals for Nuclear Power Plants," because, as explained in this regulatory guide, licenses are not required to comply with the positions set forth in this regulatory guide.

V. Submitting Suggestions for Improvement of Regulatory Guides

A member of the public may, at any time, submit suggestions to the NRC for improvement of existing RGs or for the development of new RGs. Suggestions can be submitted on the NRC's public website at <https://www.nrc.gov/reading-rm/doc-collections/reg-guides/contactus.html>. Suggestions will be considered in future updates and enhancements to the "Regulatory Guide" series.

Dated: August 3, 2022.

For the Nuclear Regulatory Commission.

Meraj Rahimi,

Chief, Regulatory Guide and Programs Management Branch, Division of Engineering, Office of Nuclear Regulatory Research.

[FR Doc. 2022-16960 Filed 8-5-22; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 05000184; EA-21-148; NRC-2022-0150]

Confirmatory Order Modifying License of National Institute of Standards and Technology, Center for Neutron Research

AGENCY: Nuclear Regulatory Commission.

ACTION: Confirmatory Order; issuance.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is issuing a Confirmatory Order to the National Institute of Standards and Technology, Center for Neutron Research, as a result of a successful alternative dispute resolution mediation session. The commitments outlined in the