

Rules and Regulations

Federal Register

Vol. 89, No. 81

Thursday, April 25, 2024

This section of the FEDERAL REGISTER contains regulatory documents having general applicability and legal effect, most of which are keyed to and codified in the Code of Federal Regulations, which is published under 50 titles pursuant to 44 U.S.C. 1510.

The Code of Federal Regulations is sold by the Superintendent of Documents.

DEPARTMENT OF HOMELAND SECURITY

Office of the Secretary

6 CFR Part 126

[Docket No. DHS–2022–0039]

RIN 1601–AB09

Procedures of the Transportation Security Oversight Board Review Panel Concerning Federal Aviation Administration Airman Certificates; Correction

AGENCY: Office of the Secretary, DHS.

ACTION: Final rule; correction.

SUMMARY: In a final rule published March 12, 2024, DHS codified the procedures that apply to appeals before the Transportation Security Oversight Board concerning Federal Aviation Administration Airmen Certificates. The rule misstated the editorial action taking place. This document corrects that error. **DATES:** This correction is effective May 13, 2024.

FOR FURTHER INFORMATION CONTACT: Randall Kaplan, Attorney, Office of the General Counsel, Department of Homeland Security, Washington, DC 20528–0485. PHONE: 202 282–9822.

SUPPLEMENTARY INFORMATION: In the final rule published March 12, 2024, at 89 FR 17693, DHS amended 6 CFR chapter 1 by revising part 126. However, the words of issuance instructing the amendment erroneously stated the Department is adding part 126. Part 126 already exists, and therefore the instruction should have been that the Department is revising it.

Correction

In FR Rule Doc. No. 2024–05131 appearing on page 17693 in the **Federal Register** of Tuesday, March 12, 2024, the following correction is made:

1. On page 17702, in the third column under the heading “The Amendments,” the words of issuance “For the reasons

set forth in the preamble, the Department of Homeland Security adds part 126 to Title 6, Code of Federal Regulations, to read as follows:” is corrected to read “For the reasons set forth in the preamble, the Department of Homeland Security revises part 126 to Title 6, Code of Federal Regulations, to read as follows:”.

Christina E. McDonald,

Associate General Counsel for Regulatory Affairs, U.S. Department of Homeland Security.

[FR Doc. 2024–08530 Filed 4–24–24; 8:45 am]

BILLING CODE 9110–9B–P

NUCLEAR REGULATORY COMMISSION

10 CFR Parts 50 and 52

[NRC–2024–0019]

Regulatory Guide: Installation Design and Installation of Vented Lead-Acid Storage Batteries for Production and Utilization Facilities

AGENCY: Nuclear Regulatory Commission.

ACTION: Final guide; issuance.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is issuing Revision 3 to Regulatory Guide (RG) 1.128, “Installation Design and Installation of Vented Lead-Acid Storage Batteries for Production and Utilization Facilities.” This RG describes an approach that is acceptable to the NRC staff to meet regulatory requirements for the installation design and installation of vented lead-acid storage batteries in production and utilization facilities. **DATES:** Revision 3 to RG 1.128 is available April 25, 2024.

ADDRESSES: Please refer to Docket ID NRC–2024–0019 when contacting the NRC about the availability of information regarding this document. You may obtain publicly available information related to this document using any of the following methods:

- *Federal Rulemaking Website:* Go to <https://www.regulations.gov> and search for Docket ID NRC–2024–0019. Address questions about Docket IDs in *Regulations.gov* to Stacy Schumann; telephone: 301–415–0624; email: Stacy.Schumann@nrc.gov. For technical questions, contact the individuals listed

in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC’s Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly available documents online in the ADAMS Public Documents collection at <https://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “Begin Web-based ADAMS Search.” For problems with ADAMS, please contact the NRC’s Public Document Room (PDR) reference staff at 1–800–397–4209, at 301–415–4737, or by email to PDR.Resource@nrc.gov. The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document.

- *NRC’s PDR:* The PDR, where you may examine and order copies of publicly available documents, is open by appointment. To make an appointment to visit the PDR, please send an email to PDR.Resource@nrc.gov or call 1–800–397–4209 or 301–415–4737, between 8 a.m. and 4 p.m. eastern time (ET), Monday through Friday, except Federal holidays.

Revision 3 to RG 1.128 and the regulatory analysis may be found in ADAMS under Accession Nos. ML24052A077 and ML23277A279, respectively.

Regulatory guides are not copyrighted, and NRC approval is not required to reproduce them.

FOR FURTHER INFORMATION CONTACT: Michael Eudy, Office of Nuclear Regulatory Research, telephone: 301–415–3104, email: Michael.Eudy@nrc.gov and Sheila Ray, Office of Nuclear Reactor Regulation, telephone: 301–415–3653, email: Sheila.Ray@nrc.gov. Both are staff of the NRC, Washington, DC 20555–0001.

SUPPLEMENTARY INFORMATION:

I. Discussion

The NRC is issuing a revision in the NRC’s “Regulatory Guide” series. This series was developed to describe methods that are acceptable to the NRC staff for implementing specific parts of the agency’s regulations, to explain techniques that the staff uses in evaluating specific issues or postulated events, and to describe information that the staff needs in its review of applications for permits and licenses.

The proposed Revision 3 to RG 1.128 was issued with a temporary

identification of Draft Regulatory Guide, (DG)-1421 (ADAMS Accession No. ML23277A276.) This revision of this guide (Revision 3) describes an approach that is acceptable to the NRC staff to meet the regulatory requirements for installation, inspection, and testing for Class 1E power, instrumentation, and control equipment at production and utilization facilities. RG 1.128, Revision 3 endorses, with clarifications, Institute of Electrical and Electronics Engineers (IEEE) Standard 484–2019, “IEEE Recommended Practice for Installation Design and Installation of Vented Lead-Acid Batteries for Stationary Applications.”

II. Additional Information

The NRC published a notice of the availability of DG–1421 in the **Federal Register** on January 8, 2024 (89 FR 895) for a 30-day public comment period. The public comment period closed on February 7, 2024. Public comments on DG–1421 and the staff responses to the public comments are available in ADAMS under Accession No. ML24052A078.

As noted in the **Federal Register** on December 9, 2022 (87 FR 75671), this document is being published in the “Rules” section of the **Federal Register** to comply with publication requirements under chapter 1 of title 1 of the *Code of Federal Regulations* (CFR).

III. Congressional Review Act

This RG is a rule as defined in the Congressional Review Act (5 U.S.C. 801–808). However, the Office of Management and Budget has not found it to be a major rule as defined in the Congressional Review Act.

IV. Backfitting, Forward Fitting, and Issue Finality

Issuance of RG 1.128, Revision 3, does not constitute backfitting as that term is defined in 10 CFR 50.109, “Backfitting,” and as described in NRC Management Directive (MD) 8.4, “Management of Backfitting, Forward Fitting, Issue Finality, and Information Requests;” does not affect the issue finality of an approval issued under 10 CFR part 52, “Licenses, Certifications, and Approvals for Nuclear Power Plants;” and does not constitute forward fitting as that term is defined and described in MD 8.4 because, as explained in RG 1.128, Revision 3, licensees would not be required to comply with the positions set forth in the RG.

V. Submitting Suggestions for Improvement of Regulatory Guides

A member of the public may, at any time, submit suggestions to the NRC for improvement of existing RGs or for the development of new RGs. Suggestions can be submitted on the NRC’s public website at <https://www.nrc.gov/reading-rm/doc-collections/reg-guides/contactus.html>. Suggestions will be considered in future updates and enhancements to the “Regulatory Guide” series.

Dated: April 19, 2024.

For the Nuclear Regulatory Commission.

Meraj Rahimi,

Chief, Regulatory Guide and Programs Management Branch, Division of Engineering, Office of Nuclear Regulatory Research.

[FR Doc. 2024–08866 Filed 4–24–24; 8:45 am]

BILLING CODE 7590–01–P

NUCLEAR REGULATORY COMMISSION

10 CFR Parts 50 and 52

[NRC–2023–0216]

Regulatory Guide: Installation, Inspection, and Testing for Class 1E Power, Instrumentation, and Control Equipment at Production and Utilization Facilities

AGENCY: Nuclear Regulatory Commission.

ACTION: Final guide; issuance.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is issuing Revision 1 to Regulatory Guide (RG) 1.30, “Installation, Inspection, and Testing for Class 1E Power, Instrumentation, and Control Equipment at Production and Utilization Facilities.” This RG describes an approach that is acceptable to the NRC staff to meet the regulatory requirements for installation, inspection, and testing for Class 1E power, instrumentation, and control equipment at production and utilization facilities.

DATES: Revision 1 to RG 1.30 is available on April 25, 2024.

ADDRESSES: Please refer to Docket ID NRC–2023–0216 when contacting the NRC about the availability of information regarding this document. You may obtain publicly available information related to this document using any of the following methods:

- *Federal Rulemaking Website:* Go to <https://www.regulations.gov> and search for Docket ID NRC–2023–0216. Address questions about Docket IDs in *Regulations.gov* to Stacy Schumann; telephone: 301–415–0624; email:

Stacy.Schumann@nrc.gov. For technical questions, contact the individuals listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *NRC’s Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly available documents online in the ADAMS Public Documents collection at <https://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “Begin Web-based ADAMS Search.” For problems with ADAMS, please contact the NRC’s Public Document Room (PDR) reference staff at 1–800–397–4209, at 301–415–4737, or by email to *PDR.Resource@nrc.gov*. The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document.

- *NRC’s PDR:* The PDR, where you may examine and order copies of publicly available documents, is open by appointment. To make an appointment to visit the PDR, please send an email to *PDR.Resource@nrc.gov* or call 1–800–397–4209 or 301–415–4737, between 8 a.m. and 4 p.m. eastern time (ET), Monday through Friday, except Federal holidays.

Revision 1 to RG 1.30 and the regulatory analysis may be found in ADAMS under Accession Nos. ML24040A161 and ML23235A321, respectively.

Regulatory guides are not copyrighted, and NRC approval is not required to reproduce them.

FOR FURTHER INFORMATION CONTACT: Michael Eudy, Office of Nuclear Regulatory Research, telephone: 301–415–3104; email: *Michael.Eudy@nrc.gov* and Darrell Murdock, Office of Nuclear Regulatory Research, telephone: 301–415–1591; email: *Darrell.Murdock@nrc.gov*. Both are staff of the U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001.

SUPPLEMENTARY INFORMATION:

I. Discussion

The NRC is issuing a revision in the NRC’s “Regulatory Guide” series. This series was developed to describe methods that are acceptable to the NRC staff for implementing specific parts of the agency’s regulations, to explain techniques that the staff uses in evaluating specific issues or postulated events, and to describe information that the staff needs in its review of applications for permits and licenses.

The proposed Revision 1 to RG 1.30 was issued with a temporary identification of Draft Regulatory Guide (DG)-1419 (ADAMS Accession No. ML23222A182). This revision of this