

NIST GCR 14-978

Electricity storage in buildings for residential sector demand response: Control algorithms and economic viability evaluation

Menglian Zheng

Christoph J. Meinrenken

Klaus S. Lackner

Lenfest Center for Sustainable Energy, Earth Institute

Department of Earth and Environmental Engineering, Columbia University

<http://dx.doi.org/10.6028/NIST.GCR.14-978>

NIST GCR 14-978

Electricity storage in buildings for residential sector demand response: Control algorithms and economic viability evaluation

Prepared for
*U.S. Department of Commerce
Engineering Laboratory
National Institute of Standards and Technology
Gaithersburg, MD 20899*

By
Menglian Zheng
Christoph J. Meinrenken
Klaus S. Lackner
*Lenfest Center for Sustainable Energy, Earth Institute
Department of Earth and Environmental Engineering, Columbia University*

This publication is available free of charge from:
<http://dx.doi.org/10.6028/NIST.GCR.14-978>

June 2014



U.S. Department of Commerce
Penny Pritzker, Secretary

National Institute of Standards and Technology
Willie May, Acting Under Secretary of Commerce for Standards and Technology and Acting Director

Any opinions, findings, conclusions, or recommendations expressed in this publication do not necessarily reflect the views of the National Institute of Standards and Technology (NIST). Additionally, neither NIST nor any of its employees make any warranty, expressed or implied, nor assume any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, product, or process included in this publication.

This report was prepared under Contract number grant 60NANB11D192 between the National Institute of Standards and Technology and Columbia University. The statements and conclusions contained in this report are those of the authors and do not imply recommendations or endorsements by the National Institute of Standards and Technology.

Abstract

“Smart grid”-enabled demand response (DR) provides significant opportunities to improve today’s electricity grids’ reliability, efficiency, affordability and security. In contrast to conventional DR, electricity storage in buildings (residential or commercial) can provide essential, flexible and reliable DR service without requiring consumers to operate their appliances on shifted or reduced schedules. With a number of DR tariffs and DR-enabling technologies available (e.g., storage technologies and two-way-inverters), one of the key current barriers for higher penetration of DR is consumers’ understanding of the cost-benefit issue. To address this question, and focusing on the residential sector, we (i) devised an agent-based appliance-level stochastic model to simulate the electricity demand of an average U.S. household; (ii) developed control strategies to shift loads from the peak periods to the off-peak periods (i.e., loadshifting strategy) and to shed the peaks of the power demand loads (i.e., peak reduction strategy); (iii) suggested the potential profits for the consumers, i.e., the reduced electricity cost of the modified demand with realistic tariffs (Con Edison, New York) minus storage costs. We optimized DR operation for the above two DR strategies to maximize the profits for consumers and determined the economic viabilities for a range of traditional and advanced storage technologies. We concluded that annual profits range from \$61 to \$1365 per year per household by utilizing the loadshifting strategy and from \$161 to \$1058 per year per household by using the peak reduction strategy. These profits can be achieved without changing the actual consumption patterns of appliances. Of the two DR strategies, the peak reduction strategy can render more storage technologies economically viable.

Keywords

Demand response; Smartgrid; Electricity storage; Agent-based modeling; Arbitrage; Peak shedding

Table of contents

Abstract.....	iii
Keywords	iii
Table of figures.....	v
Table of tables	vi
Glossary	vii
1 Introduction.....	1
1.1 Background	1
1.2 Residential DR and residential demand profile modeling	1
1.3 Existing DR optimization research	2
1.4 Motivations and objectives of present study	2
1.5 DR scheme overview	3
2 DR tariffs	4
2.1 TOU kWh tariff.....	5
2.2 TOU kW tariff.....	7
3 Electricity storage technologies, framework of storage cost model and scenarios.....	9
3.1 Electricity flow model and definitions.....	9
3.2 Uncertainties, financing cost model and scenarios	10
4 Agent-based stochastic residential demand model	11
4.1 Presentation of data and steps to build up the demand model	12
4.1.1 Approach to air conditioning	14
4.1.2 Approach to lighting	14
4.1.3 Other appliances.....	14
4.1.4 Calibration (all appliances)	14
4.2 Testing.....	17
4.2.1 Individual appliance level and model convergence	18
4.2.2 Household level.....	21
5 Storage dispatch strategy, operating optimization and economic viability evaluation results (loadshifting).....	23
5.1 Storage dispatch strategy (loadshifting strategy)	23
5.1 Operation optimization and economic viability evaluation model	25
5.2 Results.....	25
5.2.1 Base case (no storage): Composition of electricity bill and seasonal effects.....	25
5.2.2 Optimal effective storage size	26
5.2.3 Economic viability	28
5.3 Analytic approach to optimal size of storage	28
6 Storage dispatch strategy, operating optimization and economic viability evaluation results (peak reduction)	30
6.1 Storage dispatch strategy (peak reduction strategy).....	30
6.2 Operating optimization and economic viability evaluation model	31
6.3 Results.....	32
6.3.1 Base case (no storage): Composition of electricity bill and seasonal effects.....	32
6.3.2 Optimal effective storage size and optimal operating upper limit	33

6.3.3	Economic viability	39
7	Discussion	40
7.1	Demand tariffs versus energy tariffs	40
7.2	Technological improvement and storage cost reduction.....	41
7.3	Lowering installation costs	42
7.4	Impact of interest rates	42
7.5	Technological viability of PHS and CAES.....	42
8	Conclusions.....	42
	Acknowledgements	43
	References (main document).....	44
	Appendix A. Operating characteristics of storage technologies and cost estimations.....	49
	Appendix B. Demand profile model testing results	54

Table of figures

Figure 1.	DR scheme and flows of relevant data and electricity.....	4
Figure 2.	Con Edison rate structure (summarized from [45, 46])	4
Figure 3.	Daily electricity charge rates (supply and delivery, excluding monthly service fees).	5
Figure 4.	Illustration of the electricity flow	10
Figure 5.	Illustration of the stochastic demand profile model.....	12
Figure 6.	Flow chart of agent-based logic in the appliance demand profile model.	16
Figure 7.	An example of one household demand profile generated by aggregating appliances demand profiles	17
Figure 8.	Mean load curve from simulations and in-use probability profile from ATUS [57]......	19
Figure 9.	Mean load curve from simulations and in-use probability profile for air-conditioning.	20
Figure 10.	Mean load curve from simulations and flat in-use probability profile	20
Figure 11.	Mean load curve from simulations and respondents being at home and awake probability profile.....	21
Figure 12.	Pie chart comparison between RECS 2005 data and simulation results.....	22
Figure 13.	Mean load curve from simulations versus aggregated demand curves reproduced from EMET[60]......	22
Figure 14.	Data traces generated by the loadshifting strategy	24
Figure 15.	<i>Annual payments</i> breakdowns (under the kWh tariff)	26
Figure 16.	<i>Annual payments</i> for various storage technologies and capacities (loadshifting). Error bars represent one standard deviation above and below the mean.	27
Figure 17.	Data traces generated by the peak reduction strategy.	31
Figure 18.	<i>Annual payments</i> breakdowns (under the kW tariff).	33
Figure 19.	Surface plot of annual payments with varying <i>ECs</i> and varying <i>ULs</i> (peak reduction)......	34
Figure 20.	<i>Annual payments</i> variations at controlled <i>ECs</i> or controlled <i>ULs</i> (peak reduction).....	34
Figure 21.	Demand profile simulations and storage (dis) charging patterns by implementing different operating <i>ULs</i> (<i>EC</i> = 4.6 kWh).	35
Figure 22.	Demand profile simulations and storage (dis)charging patterns by implementing different operating <i>ULs</i> (<i>EC</i> = 23.7 kWh).....	36

Figure 23. Optimal <i>ECs</i> for a variety of storage costs in the average-case scenario (peak reduction). Error bars represent one standard deviation above and below the mean.....	38
Figure 24. <i>Annual payments</i> and optimal <i>ULs</i> for a variety of storage options in the average case scenario (peak reduction). Error bars represent one standard deviation above and below the mean.	38

Table of tables

Table 1. Electric rates for residential customers initial requirements less than 10 kW.....	6
Table 2. Electric rates for residential customers with initial requirements in excess of 10 kW.....	8
Table 3. Cashflows [\$] for a \$1,000 upfront for equipment with a life time of 5 years.....	11
Table 4. List of <i>FCRs</i> (10% interest rate) used in the study.....	11
Table 5. Parameters of storage operating characteristics and purchase cost.....	11
Table 6. Operating characteristics of typical electric appliances in the residential sector in the U.S.	13
Table 7. Optimal effective capacity and maximum profits for two scenarios (loadshifting).....	28
Table 8. Optimal <i>EC</i> , optimal <i>UL</i> and maximum <i>profits</i> for the average-case scenario (peak reduction)	39
Table 9. Optimal <i>EC</i> , optimal <i>UL</i> and maximum <i>profits</i> for the best-case scenario (peak reduction)	40
Table 10. Economic evaluation results comparison between two strategies.....	41

Glossary

ATUS	American Time Use Survey
CAES	Compressed Air Energy Storage
CF	Calibration factor
DADRP	Day Ahead Demand Reduction Program
DoD	Healthy depth of discharge
DOE	U.S. Department of Energy
DR	Demand response
DSASP	Demand Side Ancillary Service Program
EC	Effective capacity
EDRP	Emergency Demand Response Program
EPRI	Electric Power Research Institute
ES	Shifted electricity
FCR	Financing cost rate
FERC	Federal Energy Regulatory Commission
GHG	Green House Gas
MAC	Monthly Adjustment Clause
MFC	Merchant Function Charge
MSC	Market Supply Charge
NaS	Sodium Sulfur batteries
NiCd	Nickel Cadmium batteries
NiZn	Nickel Zinc batteries
NYISO	New York Independence System Operator
Pb-acid	Lead-acid batteries
PEV	Plug-in Electric Vehicle
PHS	Pumped Hydro Storage
RECS	Residential Energy Consumption Survey
RSEM	Relative standard deviation of the mean
SETIS	Strategic Energy Technology Information System
SMES	Superconducting Magnetic Energy Storage
SoC	State of charge
TOU	Time of use
UL	Upper limit
VRB	Vanadium Redox Batteries
ZEBRA	Sodium nickel chloride batteries
ZnBr	Zinc Bromide batteries
ZnMnO ₂	Zinc Manganese Dioxide batteries

1 Introduction

1.1 Background

Facing time-varying and overall increasing demand, today's electricity grid is struggling to balance supply and demand on a moment-to-moment basis reliably. Even in the relatively modern grid in the U.S., black-outs and brown-outs still occur and cost \$500 per person per year [1]. Typical and traditional grids employ peak generating capacities, frequency regulation, and (some) grid-based storage [2-4] to follow a time-varying demand profile. Sitting idle during off-peak periods, peak generators typically increase overall cost as well as life cycle greenhouse gas(GHG) emissions per unit of consumed electricity [1, 5].

The novel "smart grid" provides significant opportunities for improving the grid's reliability, efficiency, affordability and security. One of the core characteristics of a "smart grid" is two-way flow of electricity and information between the supply side and the demand side [1]. In this context, rather than approaching the supply-demand mismatch from the supply side only, the demand side also plays an essential role in the future electricity grids. This set of solutions is broadly referred to as demand side management or simply demand response (DR). DR attempts to smoothen (in time) the electricity demand profiles themselves and thus enable the near-instantaneous balance of supply and demand at the device level. A large variety of DR approaches exist [6], which can be loosely categorized into incentive- or time-based schemes [7]. Potential benefits include reducing electricity prices, resolving transmission line congestion, and enhancing grid reliability [8]. Given appropriate incentives via DR tariffs, DR can also facilitate integrating higher percentages of intermittent capacity such as from solar and wind into the grid [9, 10]. A variety of DR programs are now available in different electricity markets to achieve the above benefits [11]. Two common ones are to shift load from peak periods to off peak periods (often referred to as loadshifting) [12, 13] and to reduce the peak power demand (often referred to as peak reduction) (e.g., [14]). Other DR approaches include loadfollowing in the real time market or the day-ahead market, providing regulation services or spinning reserves in the ancillary service market (e.g., [15]).

Conventional DR, typically employed in commercial/industrial buildings, involves temporally interrupting or delaying a building's various appliances to adjust their overall loads in response to incentive- or time-based DR signals. This however creates the challenge of having to balance DR benefits to the grid with a level of service commensurate with customer expectation [16]. If instead, buildings (whether commercial or residential) employ electricity storage, the demand side can provide DR vis-à-vis the grid without requiring a change in actual consumption patterns in the building.

1.2 Residential DR and residential demand profile modeling

In contrast to commercial or grid based storage, DR via many, small residential consumers can be more manageable than via fewer, larger consumers because failure of a single consumer will not substantially disrupt the overall DR response. In addition, since residential consumers are typically more homogenously distributed spatially than industrial consumers, residential-based (as well as other geographically distributed) storage can respond to spatial contingencies more precisely [16]. Similarly, availability of residential-based storage would facilitate integration of building-based (rather than grid-based) decentralized renewables (not the focus of this study). Finally, residential storage schemes could also create synergies with plug-in electric vehicles (PEV). For example, Denholm and Short concluded

that with proper charging schedules and coordination between PEVs, their batteries could improve the quality of electricity supply rather than burden it by imposing higher peak loads [17, 18]. However, a possible adoption barrier resulting from more frequent charging/discharging of the vehicles compared to driving alone and thus accelerated battery degradation would have to be carefully evaluated (e.g., [19]). Finally, in the US, about 38% of total electricity consumption is by residential consumers [20]. If a large portion of these were to engage in DR, this could smoothen the total load profiles substantially.

Since there are above benefits by installing storage devices in the residential sector, understanding residential load profiles will be required to conduct DR optimization work for the residential sector. Wright and Firth suggested measurements with 1 or 2 minute resolution in order to capture the peaks of individual households [21]. However, such appliance-level, high time resolution, measured residential demand data for individual households in the U.S. are largely unavailable. An exception is the recent data set made available by the Pecan Street Research Institute (www.pecanstreet.org). Bottom-up modeling was therefore proposed to complement the costly data collection process [22]. Such studies often use survey data of household activities (e.g., when do residential consumers cook, wash, watch television, etc.) [23, 24]. Richardson et al. then extended such mapping to a high-resolution stochastic model to simulate domestic demand profiles and compared the aggregated appliance demand profiles with measured residential sector demand profiles [25, 26].

1.3 Existing DR optimization research

A large body of DR optimization research exists throughout the world. Alongside the growing body of research on pertinent tariffs (e.g., [27]), more DR programs have been offered in electricity markets [11]. When optimizing electricity cost under relatively straight forward time-of-use (TOU) tariffs (which typically provides different rates per kWh for different periods of the day), one key question in optimizing the overall system is how to size the storage so as to maximize the profits to consumers. And variations in consumption (from one day to the next or between seasons) make it more difficult to predict the optimal size of storage [28]. Another approach to DR is to reduce the peak power demand (in kW) specifically (rather than total kWh drawn during times of high kWh prices). This is relevant for tariffs, already available in the U.S. and other countries, that charge customers based on a combination of kW and kWh drawn from the grid [29, 30].

Other control schemes focus on arbitrage through real-time, day-ahead markets, or ancillary service markets (or combinations). For example, Byrne and Silva-Monroy estimated the maximum potential revenues in California via a linear programming approach [31]. Where linear programming was deemed too inflexible (e.g., because it typically does not capture the stochastic nature of load profiles), dynamic programming was deployed in order to capture uncertainties of electricity prices and load profiles [15, 32-34].

1.4 Motivations and objectives of present study

Over the past decades, economics and operating performance of electricity storage technologies have improved [35-41]. However, in the U.S., today's existing DR programs represent less than 25% of the total market potential for DR [42, 43] and barriers to wider use of these technologies for DR in residential settings remain: For example, Mokrian and Stephen pointed out that storage technologies still lack practical control strategies and deeper understanding of cost-effectiveness [15]. Dunn et al. also raised the

issue of economic viability [36]. Provided consumers will act based on economic criteria [44], the question arises whether the additional cost of installing storage (and the necessary inverters and controllers) in someone's house will be lower than the potential savings available via participating in DR-aimed tariffs. Analysis to answer this question is expected to lead to deeper understanding of cost-effectiveness and, where proven economically viable, wider adoption of storage-based DR.

Few of the above mentioned studies involve the use of storage, and fewer yet are applicable to storage-based DR schemes in the residential sector. However, recognizing the overall promise and possible benefits of such schemes, we set out to investigate whether consumers interested in such schemes could install DR systems that are both technologically feasible and economically viable under currently available tariffs. Here, we define economically viable specifically as meaning that the cost of battery and control systems, including financing, maintenance, and operating expenses, is smaller than electricity bill savings via arbitrage that the storage can enable over the lifetime of the storage system. And if such break-even can be achieved, which storage technology on one hand and dispatch strategy on the other hand (i.e., when and how to discharge/charge the storage) creates the lowest overall cost to the residential consumer?

To answer this question, we developed an agent-based stochastic demand model to randomly generate demand profiles for a single, representative household in the U.S. We developed two dispatch strategies for two currently available DR tariffs from Consolidated Edison Company of New York, Inc. (henceforth "Con Edison") respectively. We then evaluated the economic viability of various available storage technologies using a simulation-based approach. Finally, we further validated and understood the simulation results based on given load profiles.

1.5 DR scheme overview

In the above context, a basic scheme to exercise DR is illustrated in Figure 1. As shown in the figure, the control unit supplies electricity to the appliances as required, however this electricity can be taken from the grid, the battery (discharging mode), or both. In addition, the unit passes electricity from the grid to the battery (charging mode). Note that although we only investigated two DR tariffs in this report, the term "tariff" in Figure 1 denotes tariffs more generally as other DR tariffs can be adopted within the scheme illustrated in Figure 1. We first explained the specific tariffs used in this work (Sec. 2), then overviewed electricity storage technologies, built up the framework of the cost model and scenarios (Sec. 3), followed by the agent-based stochastic bottom-up demand model (Sec. 4). Then in Sec. 5, we introduced the chosen dispatch strategy and rationale for the kWh tariff, explained how the model was used to determine optimal storage capacities and displayed results. In Sec. 6, the dispatch strategy and results based on the kW tariff were written. Finally, discussions and conclusions were addressed in Sec. 7 and Sec. 8 respectively.




Figure 1. DR scheme and flows of relevant data and electricity.

2 DR tariffs

In contrast to other electricity storage analyses which are based on more general tariffs (e.g., [35]), we based our economic viability analysis on actual DR-relevant tariffs available from Con Edison. As typical in the U.S. electricity pricing, the monthly cost to residential consumers comprises (i) supply charges, (ii) delivery charges and (iii) taxes and other fees. Dependent on the specification class (SC), supply charges and delivery charges can charge in \$ per kWh drawn from the grid (kWh tariff) or in both \$ per monthly peak demand (maximum demand during one billing month) and \$ per kWh drawn from the grid (kW tariff). The structure of the electric bill is illustrated in Figure 2.




Figure 2. Con Edison rate structure (summarized from [45, 46])

A number of demand response tariffs are available from Con Edison. Among them, Emergency Demand Response Program (EDRP), Day Ahead Demand Reduction program (DADRP) and Demand Side Ancillary Service Program (DSASP) are incentivized by New York Independent System Operator (NYISO). Besides these programs, time-of-use tariffs (based on the kWh tariff or the kW tariff), distribution load relief program, commercial system relief program and curtailable electric service are also available for Con Edison's customers on a voluntary or mandatory basis. More information can be found on the NYISO website (<http://www.nyiso.com>) and Con Edison website (<http://www.coned.com>). In this study, actual TOU tariffs available from Con Edison were investigated.

2.1 TOU kWh tariff

For residential consumers with less than 10 kW peak demand monthly, SC1 is the specific classification assigned by Con Edison. Under SC1, both delivery charges and supply charges are charged in \$ per kWh. Two rates are available for SC1 customers: Rate I (basic, Con Edison Rate I; Page 387-388 in [45]) and Rate II (TOU, Con Edison Rate II; Page 389 in [45]). The TOU kWh tariff charges differing rates for peak periods (Monday to Friday, 10 am-10 pm) and off-peak (all other hours). Rates further differ between summer (June to September) and other months. For comparison, the time-invariant "basic tariff", which charges the same \$ per kWh rate irrespective of the time of day but varied by season, was also incorporated in the model.

Table 1 gives a full list of the charge items and the corresponding charge rates. Note that rates listed below don't reflect changes made by Con Edison after 02/25/2013. The relevant electric rate documents and definitions can be found on the Con Edison website: <http://www.coned.com/rates/elec.asp>. The market supply charge calculator (https://apps1.coned.com/csol/msc_cc.asp) was used to obtain historical market supply charge rates for each month. Charges for metering services are not included. Assume low-voltage services. MSC adjustment factor, MFC, Monthly Adjustment Clause (MAC) and MAC adjustment factor vary between months but variations are small. Therefore, for the sake of simplicity, average values over one year (02/2012-01/2013) was used for each charge rate mentioned above.




Figure 3. Daily electricity charge rates (supply and delivery, excluding monthly service fees).

Figure 3 depicts the values of charge rates for both TOU and basic kWh tariff. Solid lines represent rates under the TOU tariff while dashed lines represent rates under the basic tariff. Summer months (June to

September, heavy lines) are different from other months (light lines). Basic service charges (\$15.76 per month for the basic tariff and \$24.30 per month for the TOU kWh tariff) are only a small portion of the total electricity bill (Figure 15) and not plotted in Figure 3 .

During summer months, the TOU kWh tariff provides a lower charge rate during off peak hours while a much higher charge rate is observed during peak hours in comparison with the basic tariff. In other months, the charge rate increase during peak hours under the TOU kWh tariff, however is less than the charge rate decrease during off-peak hours. There is a slight increase in the charge rate under the basic tariff in summer months, but not significantly. Complete details are shown in Table 1.

Table 1. Electric rates for residential customers initial requirements less than 10 kW

SC1-Rate I (basic kWh tariff)							
Supply charges	MSC	See peak/off peak prices below					
	MSC adjustment factor	-0.4341	¢/kWh	Averaged			
	MFC	0.5659	¢/kWh	Averaged			
Delivery charges	Basic service charge (customer charge)	15.76	\$ per month				
	Energy delivery charge	See peak/off peak prices below					
	MAC	1.7123	¢/kWh	Averaged			
	Adjustment factor-MAC	0.2013	¢/kWh	Averaged			
	System benefits charge	0.34	¢/kWh				
	Renewable portfolio standard program	0.23	¢/kWh				
	Surcharge to collect PSL 18-a assessments	0.4674	¢/kWh				
	Revenue decoupling mechanism adjustment	0.2150	¢/kWh				
Summary (excl. basic service charge)							
Total			Energy delivery charge		MSC		
Jun-Sep	First 250 kWh	21.542	¢/kWh	8.899	¢/kWh	9.3455	¢/kWh
	Over 250 kWh	22.867	¢/kWh	10.224	¢/kWh		
Other months	All kWh	19.692	¢/kWh	8.899	¢/kWh	7.4948	¢/kWh
SC1-Rate II Voluntary time-of-use (TOU kWh tariff)							
Supply charges	MSC	See peak/off peak prices below					
	MSC adjustment factor	-0.4341	¢/kWh	Averaged			
	MFC	0.5659	¢/kWh	Averaged			
Delivery charges	Basic service charge (customer charge)	24.30	\$ per month				
	Energy delivery charge	See peak/off peak prices below					
	MAC	1.712	¢/kWh	Averaged			
	Adjustment factor-MAC	0.2013	¢/kWh	Averaged			
	System benefits charge	0.34	¢/kWh				
	Renewable portfolio standard program	0.23	¢/kWh				
	Surcharge to collect PSL 18-a assessments	0.4674	¢/kWh				
	Revenue decoupling mechanism adjustment	0.2150	¢/kWh				
Summary (excl. basic service charge)							
Total			MSC		Energy delivery charge		
Jun-Sep	Mon-Fri 10AM-10PM	51.60	¢/kWh	18.0313	¢/kWh	30.27	¢/kWh
	All other hours	8.52	¢/kWh	4.0660	¢/kWh	1.16	¢/kWh
Other months	Mon-Fri 10AM-10PM	26.97	¢/kWh	12.6878	¢/kWh	10.98	¢/kWh
	All other hours	8.74	¢/kWh	4.2838	¢/kWh	1.16	¢/kWh

2.2 TOU kW tariff

If residential customer's initial requirements¹ are expected to be in excess of 10 kW, SC8 will be assigned to these customers instead of SC1. Under SC8, delivery and supply charges are charged in both \$ per kWh energy usage and \$ per kW peak demand² (i.e. maximum demand during one billing period). Three rates are available for SC8 customers: Rate I (basic), Rate II (mandatory TOU) and Rate III (voluntary TOU). In this study, customers are assumed to select tariffs on a voluntary basis. Therefore, the mandatory TOU kW tariff is outside the scope of this study. In this kW tariff set, electricity bills consist of the cost of energy (charged in \$ per kWh energy use) and the cost of demand (charged in \$ per kW peak demand). For summer months, the TOU kW tariff records three maximum demands (i.e. three peaks) in three time periods: Monday to Friday, 8 am-6 pm; Monday to Friday, 8 am-10 pm; all hours of all days. For the remaining months, the tariff records only two peaks: Monday to Friday, 8 am-10 pm and all hours of all days. Different peaks are assessed different charge rates, and the monthly demand cost is the sum of these three (two) demand costs. The energy cost part charges differing rates for peak periods (Monday to Friday, 10 am-10 pm) and off-peak periods (all other hours). Both energy charge rates and demand charge rates further differ between summer months (June to September) and other months. In comparison, the time-invariant basic kW tariff charges the same \$ per kWh rate and \$ per kW rate, irrespective of the time of day but varied by season. One further difference between the basic kW tariff and the TOU one is that, according to [45] "the minimum charge for any monthly billing period shall be the charge for 10 kW of demand" under the basic kW tariff while there is no such "10 kW rule" embedded in the TOU one. The details of the charging rates are given by Table 2. The same sources and methods used to obtain kWh tariff details were used here too.

To illustrate how the TOU kW tariff works, one household whose maximum demand in June is 15 kW occurring at 12 am was employed as an example. By using the rates in Table 2, the demand cost charged by the TOU kW tariff would be:

$$15 \times 7.58 + 15 \times 17.92 + 15 \times 24.84 = \$755.1$$

If the consumer could wait till 9 pm to use appliances with high power ratings, the maximum demand (or peak demand) would be reduced to 9 kW during 8 am – 6 pm and 15 kW during 8 am -10 pm. The demand cost would be:

$$9 \times 7.58 + 15 \times 17.92 + 15 \times 24.84 = \$709.62$$

If the peak demand could be further postponed to occur after 10 pm, the peaks could be: 9 kW during 8 am-6 pm, 10 kW during 8 am -10 pm and 15 kW during all the hours. In other word, the peak of 15 kW occurs before 8 am or after 10 pm. The demand cost could be further decreased to:

$$9 \times 7.58 + 10 \times 17.92 + 15 \times 24.84 = \$620.02$$

From the above simple example, one's bill can be reduced by postponing the usage of high power rated appliances to off-peak periods under the TOU kW tariff. Alternatively, one can reduce the peaks (e.g., not

¹ According to personal communications with representatives from Con Edison, the initial requirements are determined by installing demand meters.

² Demand charges are measured and billed according to 30-minute increments according to Con Edison.

using high power rated appliances simultaneously) or smooth his/her demand profile to achieve a lower electricity bill under either the basic kW tariff or the TOU kW tariff.

Table 2. Electric rates for residential customers with initial requirements in excess of 10 kW

SC8-Rate I (basic kW tariff)							
Supply charges	MSC						
	Demand supply charge(capacity)	8.33	\$/kW				
	MSC adjustment factor	-0.4341	¢/kWh	Averaged			
	MFC	0.1626	¢/kWh	Averaged			
Delivery charges	Demand delivery charge	See prices below.					
	Energy delivery charge	1.76	¢/kWh				
	MAC	1.7123	¢/kWh	Averaged			
	Adjustment factor-MAC	0.2013	¢/kWh	Averaged			
	System benefits charge	0.34	¢/kWh				
	Charge for renewable portfolio standard program	0.23	¢/kWh				
	Surcharge to collect PSL 18-a assessments	0.3304	¢/kWh				
	Revenue decoupling mechanism adjustment	-0.7920	¢/kWh				
Summary							
		Demand delivery charge		Subtotal (demand charges)		MSC	Subtotal (energy charges)
Jun-Sep		27.14	\$/kW	35.47	\$/kW	5.010 ¢/kWh	8.52 ¢/kWh
Other months		20.98	\$/kW	29.31	\$/kW	4.901 ¢/kWh	8.41 ¢/kWh
Minimum charge: The minimum delivery charge for any monthly billing period shall be the charge for 10 kW of demand.							
SC8-Rate III Voluntary time-of-use (TOU kW tariff)							
Supply charges	MSC	See peak/off peak prices below					
	Demand supply charge(capacity)	8.33	\$/kW				
	MSC adjustment factor	0.4341	¢/kWh	Averaged			
	MFC	0.1626	¢/kWh	Averaged			
Delivery charges	Demand delivery charge	See peak/off peak prices below					
	Energy delivery charge	0.82	¢/kWh				
	MAC	1.7123	¢/kWh	Averaged			
	Adjustment factor-MAC	0.2013	¢/kWh	Averaged			
	System benefits charge	0.34	¢/kWh				
	Charge for renewable portfolio standard program	0.23	¢/kWh				
	Surcharge to collect PSL 18-a assessments	0.3304	¢/kWh				
	Revenue decoupling mechanism adjustment	-0.7920	¢/kWh				
Summary							
		Demand delivery charge		Subtotal(\$/kW)		MSC(excl. demand supply charge)	Subtotal(excl. demand charges)
Jun-Sep	Mon-Fri 8AM-6PM	7.58	\$/kW	7.58	\$/kW	6.3976 ¢/kWh	8.9682 ¢/kWh
	Mon-Fri 8AM-10PM	17.92	\$/kW	17.92	\$/kW		
	All hours of all days	16.51	\$/kW	24.84	\$/kW	3.93 ¢/kWh	6.5006 ¢/kWh
Other months	Mon-Fri 8AM-10PM	13.27	\$/kW	13.27	\$/kW	5.6230 ¢/kWh	8.1936 ¢/kWh
	All hours of all days	5.33	\$/kW	13.66	\$/kW	4.2249 ¢/kWh	6.7954 ¢/kWh

3 Electricity storage technologies, framework of storage cost model and scenarios

A variety of currently available technologies were investigated in this study, ranging from the conventional ones, e.g., Lead-acid (Pb-acid) batteries to relatively advanced ones, e.g., the novel Zinc Manganese dioxide (ZnMnO_2) batteries developed by City College of New York (CUNY). Some operating parameters and cost parameters are essential to perform a detailed comparison of the storage options and to incorporate the storage devices in the model. The general definitions are available in the following cost model. The main sources used here include the Electric Power Research Institute (EPRI) report [35], reports from Sandia National Laboratories [37, 38], European Commission's Strategic Energy Technologies Information System (SETIS) report [47], and study by Chen et al. [40]. The complete list of the operating characteristics, cost estimations of storage options are detailed in Table A.1. Note that technical properties and cost estimations of the devices can be different from one source to another and also depends on the specific applications and the angle of the analysis. The uncertainties of the data will be addressed in the financing model. Additionally, two scenarios were analyzed to address the inherent data uncertainties.

3.1 Electricity flow model and definitions

Figure 4 illustrated the electricity flow starting from the grid to the storage and finally being discharged to appliance(s) along with losses during power conversion (PCS1 and PCS2, involving inverter and/or converter) and charging/discharging processes (CH1 and CH2).

Some definitions of the operating parameters are also useful in the model:

- $Eff_{G \rightarrow S}$ is defined as the ratio of electricity stored to electricity drawn from the grid, reflecting both loss through the first power conversion unit (PS1 in Figure 4) and charging process.
- $Eff_{S \rightarrow A}$ is defined as the efficiency of energy stored to electricity consumption by appliances, reflecting discharging loss and loss through the second power conversion unit (PS2 in Figure 4). In our model, $Eff_{G \rightarrow S}$ and $Eff_{S \rightarrow A}$ are equal in value.
- DoD is healthy depth of discharge.

The concept "power density" (kW/kWh) was used when the data collected from literature were converted to specific parameters used in the model (detailed values are listed in Table A.1). Power density is the maximum continuous (dis)charging power for a storage module of one kWh nominal capacity. In this report, sometimes, another similar term is used: "charging at, e.g., 1C", meaning, 1 kW per kWh nominal capacity. Certain storage can withstand pulse discharging, i.e. discharging at as several times the power of its nominal power rating. In this study, only the continuous (dis)charging power (i.e. nominal power rating at the normal (dis)charging mode) was considered in the model.

Figure 4 illustrates the concept of "effective capacity" (EC) as used throughout our analysis: EC reflects the maximum amount of electricity stored that can be withdrawn and used by appliances after discharging (CH2) and power conversion loss (PC2). We thus used cost for a given kWh effective capacity (per year) to provide a useful metric to levelize the costs of technologies of different lifespans and/or dis(charging) efficiencies:




Figure 4. Illustration of the electricity flow

3.2 Uncertainties, financing cost model and scenarios

Financing costs, here referring to the principal and 10% interest payments for the storage and control unit combined over their lifetime, were broken down into two parts: One part scales proportional to the storage capacity (kWh). The other, a one-time home installation fee, is (approximately) independent of the storage size (here assumed to be \$2,000). To account for price variations by vendor as well as possible future price reductions and/or improvements in storage life time, we used ranges (low, high) of financing costs. Some uncertainties in storage cost and lifetime are due to their level of technological maturity. For example, the limited operational field experience for newer storage technologies, such as flow batteries and Li-ion batteries, make it difficult to obtain accurate cost values from current literature. In contrast, cost uncertainties for e.g., Pb-acid batteries and sodium sulfur (NaS) batteries, both more proven technologies [48], are smaller. Because of the inherent uncertainties in financing costs, relatively smaller operational and maintenance costs were not treated separately, but rather considered already included in the financing costs.

$$Cost = (PC \cdot \frac{EC}{Eff_{S to A} \cdot DoD} + IC) \cdot FCR \quad (1)$$

Where PC denotes the purchase cost of storage per kWh nominal capacity (excl. installation),
 EC denotes the effective capacity of storage,
 IC denotes the installation fee (assumed to be \$2,000),
 FCR denotes the annual finance cost rate (principal repayment plus 10% interest, see Table 3).

Financing cost (interest rate and principal repayment) over the lifespan of the storage equipment (storage unit (costs incl. control unit) and installation cost) was calculated with an assumption of 10% interest rate. For the sake of simplicity, storage technologies were roughly categorized into four lifespans: The average lifespans of each storage technology were rounded to generally 5, 10, 15, or 20 years by assuming one cycle per day (one cycle includes charging and discharging storage once).

Example cashflows for equipment of 5-year life time and an initial \$1,000 investment are listed in Table 3. Financing cost rates (*FCRs*) for any given interest rate and lifetime are given by equation 2 and the specific values used in the model are listed in Table 4.

$$FCR = \frac{r(1+r)^k}{(1+r)^k - 1} \quad (2)$$

Where r denotes the interest rate,

k denotes the number of *annual payments* (e.g., for a life time of 5 years, $k=5$).

Table 3. Cashflows [\$] for a \$1,000 upfront for equipment with a life time of 5 years

Year ("stock" values are end of year)	0	1	2	3	4	5
Interest		-100	-84	-66	-46	-24
Repayment of principal ^a		-164	-180	-198	-218	-240
Total financing cost		264	264	264	264	264
Annual <i>FCR</i> (% of upfront)		26.4%	26.4%	26.4%	26.4%	26.4%
Remaining debt	-1000	-836	-656	-458	-240	0

^a Repayment of principal = -Initial investment**FCR*-Accumulated interest. *FCR* is solved by setting zero remaining debt at the end of the fifth year.

Table 4. List of *FCRs* (10% interest rate) used in the study

<i>FCR</i> [% of upfront cost]	per year	per day
5 years	26.4%	0.072%
10 years	16.3%	0.045%
15 years	13.1%	0.036%
20 years	11.7%	0.032%

Table 5. Parameters of storage operating characteristics and purchase cost

		Purchase cost of storage (\$/kWh-capacity)		DoD	Round-trip efficiency ^a	Life time (cycles)		Power conversion system efficiency	
		Best-case scenario	Average (geometric mean)			Average (arithmetic mean)	(year)	PS1	PS2
Flywheel		1,000	2236	88%	90%	30,000	20	95%	95%
Conventional batteries	Metal air battery	10	40	100%	45%	800	5		
	Lead-acid (Pb-acid)	106	489	75%	78%	2,350	10		
	Nickel-cadmium (NiCd)	600	949	75%	76%	2,000	10		
Advanced batteries	Lithium-ion (Li-ion)	500	1342	80%	88%	5,500	15		
	Sodium sulfur (NaS)	250	826	80%	81%	3,250	10		
	NaNiCl ZEBRA	100	141	80%	90%	2,500	10		
Flow batteries	Zinc bromine (ZnBr)	150	541	100%	68%	6,000	15		
	Vanadium redox (VRB)	150	433	100%	75%	10,000	20		
	Nickel zinc	700	700	90%	80%	7,000	15		
	ZnMnO ₂	100	141	90%	80%	4,000	15		
Super capacitor		500	707	100%	95%	5E+07	20		
CAES		2	29	70%	55%	12,500	20		
PHS		5	22	100%	80%	35,000	20		
SMES		1,000	3162	100%	95%	55,000	20		

^a The round-trip efficiency takes into account the charging loss through CH1 and the discharging loss through CH2.

Recognizing above parameter ranges, we analyzed economic viability under two scenarios: 1) Best-case; and 2) average-case. The best-case scenario uses the lowest cost cited in the literature for a specific

storage technology. The average-case uses the average (geometric mean) of lowest and highest costs in the literature. For all other parameters such as lifetime (here specifically number of daily cycles), (dis)charging efficiencies, and *DoD*, we used arithmetic means of low and high literature values (same in both scenarios). Scenarios with low storage cost and long lifetime were not considered. Since cost often correlates with performance-related parameters such as lifetime or efficiency, such scenarios are much less realistic. The operating characteristics and cost estimations for storage options under two scenarios are summarized in Table 5.

4 Agent-based stochastic residential demand model

An agent-based, appliance-level demand model to randomly generate demand profiles (1 minute time resolution) for a typical household in the U.S. was devised based on the scheme illustrated in Figure 5.




Figure 5. Illustration of the stochastic demand profile model.

Simulating one year of minute-by-minute demand, storage dispatch, and resulting electricity cost takes about 8 minutes on a laptop computer with 2.5 GHz Intel Core i5-2520M CPU and 4 GB RAM). The model generally follows the approach introduced by Widén [24]. The strategy of mapping time-use data

of activities to corresponding appliances was explained and validated by Capasso et al. [22]. The simulated demand profiles, of each appliance individually as well as the household in aggregate, were subjected to various tests to confirm the fidelity of the model.

4.1 Presentation of data and steps to build up the demand model

Step 1: Household configuration and Step 2: Appliance operating characteristics

We selected appliances according to two rules: 1) Match the total electricity consumption (in kWh) and demand profile (in kW) of a typical U.S. household; 2) match the consumption make-up from various appliance types (e.g., air conditioning vs. lights vs. heating, etc.).

For each appliance, typical power rating, cycle length, and cycles per year were selected and slightly adjusted simultaneously within ranges cited in the literature (mostly from the Department of Energy (DOE) 2011 Building Energy Data Book, Table 2.1.16 [49] and the DOE Energy Saver [50], see Table 6 for details) so as to render the corresponding annual usage (in kWh) consistent with literature sources (mostly from the Residential Energy Consumption Survey (RECS), see Table 6 for details).

Table 6. Operating characteristics of typical electric appliances in the residential sector in the U.S.

Appliance	Power draw (W)	Electricity consumption per cycle per household (kWh)	Annual usage per household (calculated) (kWh)	Annual usage per household (lookup) (kWh)	ON time (min)	Cycles (n/yr)	Calibration factor (CF)	Activity code ^a	Sources
Dishwasher ^b	1,457	0.69	253	120-512	54	365	4.12547	020203	[24, 49-52]
Microwave oven	1,500	0.15	170	131-209	6	1133	3.71951	020201	[49-52]
Toaster oven	1,400	0.47	52	50-54	20	111	0.36182	020201	[49-51, 53]
Refrigerator	250	0.08	1007	660-1359	20	12089 ^c	0.04085		[49, 50, 52, 54-56]
Freezer	155	0.05	1120	470-1150	20	21681	0.19075		[49, 51, 52, 56]
Lighting-Bathroom	317	0.16	162	940	31	989	2.23461	010201	[51, 57, 58]
Lighting-Bedroom	200	0.20	124		60	621	0.74326	TEWHERE=1	[51, 58]
Lighting-Living Room	256	0.26	215		60	840	1.03289	TEWHERE=1	[51, 58]
Lighting-Dining Room	235	0.12	163		30	1387	3.07522	110101	[51, 57, 58]
Lighting-Hallways	207	0.05	91		15	1752	2.04803	TEWHERE=1	[51, 58]
Lighting-Kitchen	250	0.13	228		32	1711	6.17806	020201	[51, 57, 58]
Clothes dryer	2895	2.90	1039	1000-1079	60	359	3.33162	020102	[24, 49-52]
Clothes washer ^d	2150	0.77	303	110-420	48	392	3.61809	020102	[24, 49-52]
Television	185	0.35	267	222-313	115	752	1.85108	120303	[24, 49-52, 57]
Air conditioning	3500	0.58	3220	2822	10	5520 ^e	96		[50, 54]
Space heater	1,447	1.45	2136	2136	60	1476	0.01639		[49, 50, 54]
Vacuum	1,440	0.84	53	55	35	63	0.56724	020101	[24, 49, 50, 57]
Computers and others	100	2.4	876	810	1440	365	1		[49]

^a Activity code in the above table is coded by 2011 American Time Use Survey 2011 [57]. Descriptions can be found in the coding document. <http://www.bls.gov/tus/lexicons.htm>

^b Dishwasher operated in 4 stages: P₁=1457 W, P₂=220 W, P₃=1457 W, P₄=220 W; T₁=18 min, T₂=18 min, T₃=6 min, T₄=12 min.

^c All 14 and 16 cu. ft. (TBX/CTX models vs. TBF models of past) will have an average run time of between 40 and 52% as do compact models, (TA2,4,6). Chest & Upright freezers run 75% to 90% of the time [56].

^d Clothes washer is operated on three stages: P₁=2150 W, P₂=210 W, P₃=450 W; T₁=18 min, T₂=24 min, T₃=6 min.

^e Assume space heater runs 12 hours per day and mean cycle length is 60 minutes. In use during the winter, i.e. in November, December, January and February.

Step 3: Mapping corresponding activity profiles to appliances

For activity profiles, we used 2011 American Time Use Survey (ATUS) data reported by 13,260 respondents [57]. Each appliance was linked to a corresponding activity with an activity code in Table 6. The column of activity codes were obtained from the ATUS. The full lexicons can be found in <http://www.bls.gov/tus/lexicons.htm>. Those with blank activity codes are discussed below. Activity probability profiles are displayed in

Figure 8-11. To smooth out artificial spikes, a rolling window of 11 minutes was applied.

4.1.1 Approach to air conditioning

No suitable ATUS activity profile could be found for air-conditioning. Instead, a starting probability profile of air-conditioning was reproduced from Reddy, T. A., Figure.1 [59]. Note that the reproduced profile is not a starting probability profile but rather an in-use probability profile (while for all the other appliances, starting probability profiles are available from ATUS). Without time-varying air-conditioning demand profile, the aggregated demand profile for one whole household would have two (Figure 13(a)) instead of one (Figure 13(b)) peak over the course of one day. In other words, we cannot map a flat starting probability profile to air-conditioning because the time-variance of using air-conditioning is significant. Therefore, the in-use probability profile reproduced from Ref. [59] was assigned to air-conditioning as an approximation.

4.1.2 Approach to lighting

A similar difficulty occurs with respect to lighting for which finding a directly related ATUS activity is difficult. Addressing lighting in bedroom, living room and hallways, the starting probability profile of occupancy being at home and awake (coded as TEWHERE =1) was used as an approximation. Unlike air-conditioning, the underlying assumption is that the load demanded by lighting will not contribute to shaping the demand profile of one whole household to a large degree.

4.1.3 Other appliances

Uniform probability profiles were assigned to refrigerator, freezer and space heater under the assumption that using these three appliances is not occupancy related. They do however stochastically turn on and off, adding significant noise to the aggregate household profile (see Figure 7). Since power ratings of computer and some other rechargeable electronic devices such as mobile phone chargers are all relatively low, they will not contribute to a peak during the day but only contribute some base-load 24 hours a day. Therefore, in this model, computer and other typical electronic devices were grouped into a single appliance. The minimum ON time was set to 1440 minutes making it a base load without ever turning off.

Step 4 & Step 5: Calibration and programming

4.1.4 Calibration (all appliances)

Since parameters were drawn from multiple sources, it is necessary to calibrate (or normalize) the on probability profiles to render the total starting probabilities over one year consistent with typical total

annual cycle times for each appliance. Average number of cycles per day and duration of each cycle, for each appliance separately, were calibrated to follow data from the Buildings Energy Data Book (Table 2.1.16; [49]) and the RECS report [51].

$$Starting Prob_i(t) = \frac{N_{i,home}(t)}{13260} \quad (3)$$

$$In - use Prob_i(t) = \frac{M_{i,home}(t)}{13260} \quad (4)$$

Where $N_{i,home}(t)$ denotes #respondents to START activity i (at home/yard) at time step t ,
 $M_{i,home}(t)$ denotes #respondents to DO activity i (at home/yard) at time step t ,
 13260 is the total number of participants in the survey.

$$CF_i = \frac{CYC_i}{\frac{1440 - (CL_i - 1) \times CYC_i}{1440} \sum_{t=1}^{t=1440} Starting Prob_i(t)} \quad (5)$$

Where CF_i denotes the calibration factor of appliance i ,
 CYC_i denotes reference cycles per day for appliance i ,
 CL_i denotes the cycle length of appliance i .

The flow chart in Figure 6 is used to illustrate the agent-based logic to randomly generate a demand profile for one household.




Figure 6³. Flow chart of agent-based logic in the appliance demand profile model.

³ Continues until the total set time T (e.g., 525,600 minutes for one year or 1440 minutes for one day) is reached.

Step 6: Aggregate appliances demand profiles to form household demand profiles

Figure 7 shows an example how appliances demand profiles are aggregated to form the demand profile for one typical household in the U.S. in one random summer day.




Figure 7. An example of one household demand profile generated by aggregating appliances demand profiles

4.2 Testing

For individual appliances, we tested (i) on/off cycling; (ii) power and electricity draw, cycles per year, and total electricity consumption per year; and (iii) the average daily demand time profile. For the household aggregate demand, we tested (iv) average demand time profile (differentiated by season); (v) total kWh draw per year; and (vi) % contribution of appliance types to total annual kWh consumption (air conditioning vs. lighting vs. heating, etc.). The model was found to capture above features (i)-(vi) adequately.

Three groups of tests were performed. (1) On individual appliance level (Sec. 4.2.1), simulations for a large number of days should yield, for each appliance, the same average cycles per year and the average daily electricity consumption as the input parameters listed in Table 6. In addition, the average daily load profiles for each appliance were compared with the corresponding in-use probability profiles from ATUS (


Figure 8-11). (2) On household level (Sec. 4.2.2), the simulated average daily electricity usage profile (simulated over hundreds of days and thus reflecting the aggregate profiles of hundreds of households on a single day) was compared to RECS [54] (Figure 12) as well as sector-level daily demand profiles reproduced from EMET Consultants Pty Ltd, Figure 4.1 and Figure 4.2 [60] (Figure 13). (3) Finally, cycle lengths observed for a subset of appliances available from the Pecan Street Research Institute [61] were compared with the corresponding simulated cycle lengths. The comparison results confirmed that the simulated cycle lengths are within the measured ranges (not shown).

4.2.1 Individual appliance level and model convergence

As shown in Table B.1 individual appliance demand loads were averaged over a large number of days to yield the results on a “converged” day. For each minute individually, the relative standard deviation of the mean (RSEM) power draw is less than 5%. Generally, the shapes of modeled mean curve loads for each appliance are in agreement with the shapes of in-use probability profiles from ATUS (

Figure 8). Peaks are reproduced well. Figure 9 for air-conditioning is of particular interest here. Instead of the starting probability profile, in-use probability profile was used as an approximation. The simulated mean load curve displays a slight right-shift in comparison to its in-use probability profile. Still, the overall time-preference is captured well. One methodological source of the small mismatches visible e.g., in Figure 10 is the CF. The current way to calculates CFs involves an approximation made for available minutes in Eq.(5). However, instead incorporating accurate minute-by-minute CFs would be too time-consuming computationally. Lastly, the resulting mean load curves for lighting in the bedroom, living room, and hallways were compared to the probability profile reflecting when occupants were at home and awake. Due to the mismatch between appliance cycle lengths (no more than 1 hour for these three appliances, see Table 6 and the activity (being at home and awake) lengths (commonly more than 1 hour), the simulated curves and the comparison curves display mismatches in Figure 11. This mismatch however does not substantially affect our results and conclusions because the kW draw of lighting appliances is small in comparison to overall power demand.

In summary, the model is able to capture the time-preferences well and the daily electricity consumption value from literatures (see Table B.1) is reproduced well. Possible future refinement lies in the improvement of starting probability profiles. Other sources of starting probability profiles for air-conditioning and lightings are desirable. A model to generate lighting load curve based on the indoor luminance may be included in the model in the future.






Figure 8⁴. Mean load curve from simulations and in-use probability profile from ATUS [57].

⁴ The probability profiles are plotted on the secondary axis. The solid lines represent the mean load curves from simulations while the long-dashed lines represent the in-use probabilities.




Figure 9⁵. Mean load curve from simulations and in-use probability profile for air-conditioning.




Figure 10⁶. Mean load curve from simulations and flat in-use probability profile

⁵ The in-use probability profile was reproduced from Reddy, T. A., Figure 1 [59] Reddy TA. Statistical analyses of electricity use during the hottest and coolest days of summer for groups of residences with and without air-conditioning. *Energy*. 1990;15:45-61.

⁶ No ATUS [57] US Bureau of Labor Statistics. 2012 American Time Use Survey. United Department of Labor; 2013. data are available for the appliances in Figure 8. Therefore, flat starting probability profiles were created. For these appliances, the in-use probability profile is also flat. For an average demand profile, the impact from these appliances are small because demands from them are not time-variant and thus will not change the shape of the demand profile a lot. For one single day, these appliances compromise a large portion of the single household daily electricity consumption.




Figure 11⁷. Mean load curve from simulations and respondents being at home and awake probability profile.

4.2.2 Household level

The main purpose here was to test the aggregate appliance demand profiles in comparison with the RECS data for per average household in U.S. (Table CE 2.1 [62]). From Table B.1, the average daily electricity consumption per household is 30.6 kWh which is only 1% less than data given by 2009 RECS data (31 kWh). The pie chart in Figure 12 also displays a good agreement between 2005 RECS results (Table US14 [54]) and simulation results from the model. Numbers are portions of total annual electricity consumption in the residential sector. 2009 RECS data were only partly available in 2012 when the comparison was conducted. Therefore 2005 RECS data were used instead where 2009 RECS data were not available.

⁷ No ATUS data are available. Here, probability profiles simply reflect the likelihood of respondents being at home and awake. Mismatches exist but lighting only comprises a small portion of the daily electricity consumption per household (see Table 6).




Figure 12. Pie chart comparison between RECS 2005 data and simulation results

In Figure 13, average demand profile from simulations are plotted vis-à-vis with EMET reported aggregated demand curves [60] for summer days and winter days, respectively. Note that the simulation model correctly predicts two demand peaks per day during non-summer months (Figure 13 (b)) while the additional air conditioning during the summer results in only one obvious peak (Figure 13 (a)).




Figure 13.⁸ Mean load curve from simulations versus aggregated demand curves reproduced from EMET[60].

⁸ Solid lines represent the yielded mean load curves while the long-dashed lines represent the reference demand curves.

5 Storage dispatch strategy, operating optimization and economic viability evaluation results (loadshifting)⁹

5.1 Storage dispatch strategy (loadshifting strategy)

Figure 14 shows examples (example for Li-ion battery with 15kWh EC , 80% DoD) of simulated data traces for two randomly chosen days. Solid lines represent a random spring summer day while dashed lines represent a random spring day. Dotted lines in Figure 14 (b) indicate max. (dis)charging rate (1C for Li-ion battery). Implementing a straight forward arbitrage strategy, storage charging commences at 10pm (indicated by "[A]" in Figure 14; all letter markers are for solid lines), at the lowest possible charge rate such that storage reaches full capacity by 10am (see [B]) without however causing unnecessary burden on the grid (Eq.(2)). From 10am onwards, any appliance – e.g., demand at 12 pm (see [C]) reflects the aggregate demand of the air conditioning, freezer, and clothes washer (other appliances are off) – is first supplied by discharging storage (see [D]), thus minimizing purchase of costlier electricity from the grid. Whenever the maximum discharge rate (1C, i.e. 1kW per kWh nominal capacity) is reached (not in Figure 14) or the storage's state of charge (SoC , Eq. (3)) reaches DoD (see [E]), the control unit supplements electricity from the grid (see [F]). Breaching either maximum discharge rates or DoD have been demonstrated to lead to early degradation (e.g., [63]) and are thus avoided.

$$Charge\ rate = \frac{EC}{\frac{Eff_{S\ to\ A} \cdot Eff_{A\ to\ S}}{12}} \quad (6)$$

$$SoC(t) = SoC(t - 1) - \frac{\frac{DischE(t)}{Eff_{S\ to\ A}}}{EC} \geq DoD \quad (7)$$

Where EC denotes the effective capacity of storage (see section 3.1),
 $Eff_{G\ to\ S}$ denotes the ratio of electricity stored versus drawn from grid,
 $Eff_{S\ to\ A}$ denotes the efficiency of energy stored to consumption by appliances,
 DoD denotes the healthy depth of discharge,
 $SoC(t)$ denotes the state of charge of storage at time step t ,
 $DischE(t)$ denotes the amount of electricity discharged at time step t .

⁹ In Sec.5, the basic and TOU tariff mentioned are both kWh tariff if not stated otherwise.




Figure 14. Data traces generated by the loadshifting strategy

5.1 Operation optimization and economic viability evaluation model

Using the above model, the storage capacity was varied to maximize profit to the consumer:

$$\text{Max profit} = \text{Electricity bill}_{\text{basic w/o S}} - (\text{Cost} + \text{Electricity bill}_{\text{DR with S}}) \quad (8)$$

Where $\text{Electricity bill}_{\text{DR tariff with S}}$ denotes electricity bill for 1 year under the DR tariff (with storage), $\text{Electricity bill}_{\text{basic w/o S}}$ denotes electricity bill for 1 year under the basic tariff (without storage), Cost denotes the financing costs of storage (see Sec. 3.1).

The maximum *profit* was determined simply by stepwise increasing the effective storage capacity from zero to two times the average electricity consumption during peak periods (E_{peak}). At each increase (10% of E_{peak}), *annual payment* (=storage cost plus electricity bill) was recorded by the model. Two baselines (i.e., cost without storage) were used: (a) Electricity bill for one whole year under the basic tariff before installing storage ($\text{Electricity bill}_{\text{basic w/o S}}$, shown in Eq.(8)); (b) electricity bill for one whole year under the TOU tariff (also without storage) ($\text{Electricity bill}_{\text{DR w/o S}}$, not shown in Eq.(8)). The rationale for considering two baselines is the fact that consumers, even before installing storage, could be on either the basic tariff or the TOU tariff. Under certain circumstances such as the specific appliance configuration in our model, simply switching from the basic to the TOU tariff (before installing storage) can significantly increase the electricity bill (in our case due to much higher day time electricity use from using air conditioning in the summer months, see Figure 15). One could argue that for such circumstances the savings from arbitrage must be high enough to offset not only the installation and cost of storage but also the electricity bill increase that results from switching to the TOU tariff that enables the arbitrage savings in the first place. We therefore present economic viability results for both baselines.

5.2 Results

The "typical residential household" devised in our model consumes 11,164 kWh electricity per year, with an average daily consumption (all seasons over one year) of 31 kWh (50 kWh/day during summer months). We first investigated the cost composition for the two baselines, then optimized the size of storage, followed by evaluating the economic viabilities of different storage options. Finally, an analytic approach was developed to identify the optimal capacity size and analytic results were compared with the empirical results.

5.2.1 Base case (no storage): Composition of electricity bill and seasonal effects

We first broke down annual electricity bill into eight parts: 1) Cost during peak periods in summer; 2) off-peak periods in summer; 3) peak periods in winter; 4) off-peak periods in winter; 5) peak periods in other months (no space heater or air-conditioning is used); 6) off-peak periods in other months; 7) basic monthly service charges; and finally 8) financing costs of storage system (including installation).

Figure 15 uses the example of ZnMnO_2 battery with 30kWh *EC*, average-case scenario) to show annual payments without storage (the first and second columns); the third column shows payments when buying and operating storage. Figure 15 shows a net increase of ~\$650 in *annual payments* (from \$2,523, or 26%) when switching from basic to TOU tariff (no storage yet installed). The increase is mostly due to raised electricity bills for peak periods in the summer. For other months, there is no significant increase or

decrease in the electricity bill under the two tariffs. In the summer, peak consumption under TOU is ~\$800 higher than those charged under the basic tariff while the less expensive off peak consumption under TOU only results in a ~\$250 decrease. Higher basic service charges for TOU contribute the remaining \$100 to the net \$650. Generally, basic service charges contribute only a small portion to total electricity cost; therefore consumption and load shifting patterns and the supply and delivery portions of each tariff are crucial drivers of overall cost and potential arbitrage savings.

Figure 15 also shows a TOU cost structure when using (profit optimized) 30 kWh *EC* of ZnMnO₂ batteries that can supply the entire daily electricity consumption during peak hours in non-summer months (and a portion during summer months). This leads to annual arbitrage savings of ~\$700 compared to the TOU base case (\$20 for the basic tariff base case). Since during summer months only a portion of peak-consumption can be loadshifted to off-peak times, installing more *EC* than 30 kWh would decrease the annual electricity cost. However, since such additional capacity would essentially remain idle during non-summer months (no return on investment), annual profit would decrease. Therefore, 30 kWh *EC*, for this particular battery technology, (dis)charging losses and *DoD*, is the optimal size. This is illustrated further in Sec. 5.2.2.




Figure 15. Annual payments breakdowns (under the kWh tariff)

5.2.2 Optimal effective storage size

Figure 16 shows the impact of increasing *EC* on *annual payments* (best-case scenario) for a selection of storage technologies. Payments include financing for storage purchase (best-case scenario) and installation as well as electricity bills. Error bars indicate residual uncertainty of the stochastic simulation (standard error of the mean). See Sec. 5.2.3 for other storage technologies not displayed in the figure.

Li-ion batteries exhibit a continuous increase in *annual payments* while NaS batteries, after a step-increase in *annual payments* (due to installation costs), exhibit a small decrease, followed again by an increase. For ZnBr, ZEBRA (NaNiCl batteries), Metal air and ZnMnO₂ batteries, significant decreases in *annual payments* can be achieved. NiCd batteries, flywheel, Superconducting Magnetic Energy Storage (SMES) and NiZn batteries (not shown in Figure 16) exhibit payments higher than Li-ion batteries. The super capacitor option shows trends similar to NaS batteries. Payments simulated for Pb-acid batteries are almost identical to those for ZnBr batteries. For Compressed Air Energy Storage (CAES), see Sec.7.4.

Figure 16 suggests three broad classes of storage technologies when determining the optimal storage size to achieve lowest costs: (1) Li-ion or NaS batteries do not provide any economic benefits (even in the best case scenario). (2) For Pumped Hydro Storage (PHS) and Metal air batteries, the exact size is not crucial: As seen in Figure 16, an increase in *EC* from 30 kWh to 50 kWh leads to only minor increases in *annual payments* (see explanation in Sec. 5.3). (3) For the remaining storage technologies, sizing should be conducted accurately. For example, increasing *EC* of ZnBr batteries from 30 kWh to 50 kWh would cause ~\$800 additional *annual payments*.




Figure 16. Annual payments for various storage technologies and capacities (loadshifting). Error bars represent one standard deviation above and below the mean.

5.2.3 Economic viability

Table 7 summarizes the optimization results for best-case and average-case scenarios for all storage technologies. *Profits* from arbitrage savings versus the basic tariff and the TOU tariff baselines are also shown. Optimal effective storage capacity span a wide range depending on the storage technology, 12 kWh~37 kWh in the best-case scenario and 7~35 kWh in the average-case scenario. For economically viable technologies, *annual profits* range from as low as \$8 for the super capacitor (0.3% of annual electricity cost without storage, TOU baseline) to \$1,465 for PHS (46%). Because of the additional cost increase when first switching from the basic to the TOU tariff (before installing storage, Sec. 5.2.1), more technology options are economically viable when assuming the TOU baseline versus the basic tariff baseline. Only PHS and CAES are economically viable in both scenarios and both baselines. This raises the question of their technological viability for residential settings (see Sec. 7.5). Finally, flywheel, SMES, NiZn, NiCd, NaS and Li-ion batteries are not economically viable for either scenario or baseline, and the aforementioned \$8 profit for super capacitors is below the accuracy of the stochastic simulation (see Figure 16). We thus concluded that – for the average U.S. household consumption profile and Con Edison tariffs used in this study – short-term storage technologies (flywheel, super capacitor, and SMES) as well as some emerging batteries are not economically viable.

Table 7. Optimal effective capacity and maximum profits for two scenarios (loadshifting)

	Best-case scenario ^a				Average-case scenario ^b			
	Optimal capacity ^c (kWh)	Annual payment (\$/year)	Profit ^d (\$/year)	Profit ^e (\$/year)	Optimal capacity ^c (kWh)	Annual payment (\$/year)	Profit ^d (\$/year)	Profit ^e (\$/year)
Flywheel	-	3542	-1013	-344	-	3847	-1315	-664
Conventional batteries								
Metal air	33	2742	-213	456	30	3121	-590	61
Lead-acid (Pb-acid)	28	2690	-161	509	-	3590	-1058	-407
Nickel-cadmium (NiCd)	-	3661	-1132	-462	-	3805	-1273	-622
Advanced batteries								
Lithium-ion (Li-ion)	-	3474	-945	-275	-	3729	-1198	-546
Sodium sulfur (NaS)	12	3302	-774	-104	-	3707	-1176	-525
Sodium nickel chloride (NaNiCl ZEBRA)	30	2442	87	757	28	2704	-172	479
Flow batteries								
Zinc bromine (ZnBr)	28	2677	-149	521	-	3476	-945	-294
Vanadium redox (VRB)	30	2450	79	749	10	3261	-729	-78
Nickel zinc (NiZn)	-	3529	-1000	-330	-	3513	-982	-330
Zinc manganese dioxide (ZnMnO ₂)	30	2303	226	896	30	2510	22	673
Super capacitor								
	12	3191	-662	8	7	3412	-880	-229
CAES	37	2073	456	1126	33	2292	239	890
PHS	37	1733	796	1465	35	1818	713	1365
SMES	-	3500	-971	-302	-	3974	-1442	-791

^a The best-case scenario uses the lowest cost available in the literature.

^b The average-case scenario uses the average (geometric mean) of lowest and highest costs in the literature.

^c ‘-’ indicates optimal storage is zero because any storage would only increase overall cost. Optimal storage size above zero but negative profits indicate cases where larger storage means lower cost, however not low enough to offset cost from change in tariff and installation.

^d Compared with the payment charged by the basic tariff without installing storage. Positive values of profit indicate the evaluated storage option is economically viable and vice versa.

^e Compared with the payment charged by the TOU tariff without installing storage.

5.3 Analytic approach to optimal size of storage

The above model determines the economic viability and optimal *EC* via a trial-and-error approach. To understand the underlying effects more fundamentally we derived an analytical formula that can predict

optimal EC directly, based on statistical parameters obtained from simulating only the demand profile (without also simulating storage dispatch and electricity cost).

Within the above scheme, the number of kWh shifted (ES), which drive cost savings via arbitrage, cannot exceed the effective capacity (EC), which drives financing costs for storage. Therefore, optimal EC can be expected to be approximately equal to the daily-average consumption during peak times E_{peak} ($\sim 30\text{kWh}$, see Table 1). Crucially, however, E_{peak} varies stochastically from one day to the next and systematically between seasons. Optimal EC , therefore, is driven by the trade-off between gaining more arbitrage savings during days with relatively high E_{peak} and wasting idle capacity during days with low E_{peak} . Now assume a set E comprised of N days' E_{peak} (across all seasons) and let yet-to-be-determined optimal EC be denoted by E_{peak}^m . m indicates the m -th E_{peak} in the set when sorted from smallest to largest. This means that for m days of the set, EC can shift 100% of the E_{peak} to off-peak hours. For the remaining $(N-m)$ days, only a portion of E_{peak} can be shifted. If EC is increased to $E_{\text{peak}}^m + \Delta E$, then additional $(N-m)$ days in the set can shift an additional portion of their E_{peak} , namely ΔE , from peak to off-peak hours. Resulting incremental arbitrage savings are $(N-m) \cdot S^* \cdot \Delta E$. Resulting incremental storage costs are $N \cdot C^* \cdot \Delta E$, where S^* and C^* , both in $\$/\text{kWh}$, are given by:

$$S^* = P_{\text{peak}} - \frac{P_{\text{off-peak}}}{\text{Eff}_{S \text{ to A}} \cdot \text{Eff}_{G \text{ to S}}} \quad (9)$$

$$C^* = \frac{PC \cdot FCR}{\text{Eff}_{S \text{ to A}} \cdot DoD} \quad (10)$$

Where P_{peak} and $P_{\text{off-peak}}$ denote the costs per kWh during peak and off-peak hours, respectively, $\text{Eff}_{G \text{ to S}}$ denotes the ratio of the amount of electricity stored over the amount of electricity drawn from the grid (see Figure 4 for more details), $\text{Eff}_{S \text{ to A}}$ denotes the efficiency of converting energy from storage to appliances, DoD denotes the healthy depth of discharge, PC denotes the purchase cost of storage per kWh nominal capacity (excl. installation), FCR denotes the annual finance cost rate (principal repayment plus 10% interest, see Sec. 3.2).

Now recognizing that *profit* can be increased so long as additional arbitrage savings for any incremental ΔE are higher than additional storage costs, we find the optimal EC by requiring:

$$F(E_{\text{peak}}^m) = 1 - \frac{C^*}{S^*} \quad (11)$$

Where $F(E)$ denotes the portion of E_{peak} in set E that are smaller than E_{peak}^m .

E_{peak}^m can be solved by referring to the m -th E_{peak} in the sample ranking from smallest to largest when

$$m = N \cdot \left(1 - \frac{C^*}{S^*}\right) \quad (12)$$

The value of C^* varies substantially across storage technologies, due to varying costs and operating characteristics. In contrast, S^* does not vary much across storage technologies. For example, Metal air batteries ($C^* = 0.011$ in best-case scenario) and PHS ($C^* = 0.002$) exhibit nearly flat cost after EC reaches

30 kWh (Figure 16). For comparison, C^* for ZnBr batteries is 0.069 (best-case scenario), leading to a marked rise in *annual payments* once EC is increased beyond the optimal capacity (Figure 16). Generally, higher ratios of C^* to S^* will lead to smaller optimal EC (Eq.(11)). Note that storage size is optimized across one year. Tradeoffs occur between different seasons because demand profiles and tariffs are different. For NaS batteries for example, optimal EC in the summer is 31 kWh (in best-case scenario). But in other seasons S^* is smaller and therefore any EC increase in seasons other than summer will lead to smaller profits. As a result of this tradeoff, the optimal EC for NaS batteries, across the full year, is 12 kWh (Table 7).

In summary, optimal EC can be determined as a function of the histogram of E_{peak} , the operating characteristics and cost of storage, and the peak versus off-peak kWh charges. In contrast, installation cost and fixed monthly electricity fees affect the achievable profit (Eq.(8)) but not optimal EC .

6 Storage dispatch strategy, operating optimization and economic viability evaluation results (peak reduction)¹⁰

6.1 Storage dispatch strategy (peak reduction strategy)

Figure 17 illustrates the storage dispatch strategy for the kW tariff (example for ZnMnO₂ battery with 10 kWh EC , 90% DoD , the upper limit (UL) is set as 2.5 kW) The long dashed line in Figure 17(a) indicates the UL . In Figure 17(b), the short dashed lines indicate max. (dis)charging (1C for ZnMnO₂ battery. In Figure 17(c), the dotted line is measured on the basis of 1 minute while the solid line is averaged on the basis of 30 minutes.

The goal is to reduce the peak demands for each month to the pre-assigned UL by utilizing storage. When the aggregate demand from the appliances exceeds the UL (e.g., at [A] in In Figure 17; all letter markers are for solid lines), the grid only supplies it with the power equaling the UL (see [C]); the remaining demand is supplied by discharging storage (see [B]). On the contrary, when the aggregate demand from appliances is below the UL (e.g., at [D]), storage (if not full) is charged at the dynamically calculated charging rate (see [E]): The combined power draw from the storage charging and the appliances demands could not exceed the UL (see [F]). Whenever the maximum discharge rate (1C i.e. 1 kW per kWh nominal capacity) is reached (not in Figure 17) or the storage's state of charge reaches DoD (see [G]), the control unit supplements electricity from the grid. In the end, the measured synthetic demand from appliances and storage is averaged over a 30-minute window as specified by Con Edison (see [H]; the dashed line is the minute-by-minute demand profile while the solid line the averaged demand profile).

¹⁰ In Sec. 6, both the basic and the TOU tariff are kW tariff, unless stated otherwise.




Figure 17. Data traces generated by the peak reduction strategy.

6.2 Operating optimization and economic viability evaluation model

In contrast to the loadshifting control strategy which works only in the context of the TOU tariff, this specific peak reduction control strategy is not time-of-use constrained and can possibly reduce the peak demands, thus reducing the electricity bills under both the TOU tariff and the basic tariff. However, note that there is the “10 kW rule” specified by the basic tariff: The minimum peak demand during the billing period is 10 kW. Consider that monthly peak demands (averaged every 30 minutes) simulated by our model are less than 10 kW. The peak demand reduction will not lead to a reduction in the electricity bill charged under the basic kW tariff, still charged for 10 kW. On the contrary, since there is no such “10 kW

rule” in the TOU tariff, for a typical U.S. household as modeled in this study, the peak reduction control strategy is used under the TOU tariff only.

Using the above agent-based demand model and control strategy, the storage *EC* and the operating *UL* were varied separately to maximize *profit* (Eq. (8)) to the consumer under the TOU tariff. The maximum *profit* was determined by stepwise increasing the effective storage capacity geometrically from zero to the average daily electricity consumption (20% increase at each step) and adjusting the *UL* geometrically from 2 kW to 6.3 kW (10% increase at each step) for each *EC*. The steps were selected based on the preliminary results. For each case, *annual payments* were recorded and compared with two baselines: (a) The electricity bill for one whole year under the basic tariff before installing storage (b) the electricity bill for one whole year under the TOU tariff before installing storage.

6.3 Results

The "typical residential household" devised in our model consumes 11,164 kWh electricity per year, with the average peak demand (averaged over 30 minutes) of 6.5¹¹ kW (during summer months) and 5.7 kW (during the remaining months). We first investigated the cost composition for the two baselines, then optimized the size of storage and the operating *UL*, followed by evaluating the economic viabilities of different storage options.

6.3.1 Base case (no storage): Composition of electricity bill and seasonal effects

Similar to what we have done for the loadshifting model, we broke down two baselines into seven parts to investigate their cost composition: 1) Demand cost in summer; 2) energy cost in summer; 3) demand cost in winter; 4) energy cost in winter; 5) demand cost in other months; 6) energy cost in other months; 7) financing costs of storage system (incl. installation cost).

In Figure 18, the first and second column show payments without storage. The third column shows *annual payments* when buying and operating storage under the TOU tariff (by using peak reduction strategy described in Sec. 6.1). Figure 18 shows a decrease of ~\$1,500 when one switches from the basic tariff to the TOU tariff with no storage installed. The difference mainly comes from the ~\$560 decrease in the demand cost in winter and the ~\$800 decrease in the demand cost in spring and fall months. This big difference may be partly due to the “10 kW rule” embedded in the basic tariff. Rather than seeing a decrease under the TOU tariff, the summer demand costs remain almost unchanged. For summer months, the average peak demand is still less than 10 kW (averaged over the course of 30 minutes), indicating that that the 10 kW rule’s impact should still remain but be offset by the costlier summer TOU tariff, without storage being installed or the consumer’s electricity consumption habits being altered.

Unlike the TOU kWh tariff, which incurs an increase in the *annual payments* when a consumer switches from the basic kWh tariff and no storage is installed, the TOU kW tariff costs less in terms of energy cost throughout the year. Nevertheless, the reduction in the annual energy consumption cost is only \$81 in total for one whole year.

¹¹ Although the simulated peak demand for one household is less than 10 kW, SC 8 is still considered to be available for the modeled household because two or more households can choose to hold one single account, which is possibly eligible to use SC 8.




Figure 18. Annual payments breakdowns (under the kW tariff).

The third column in Figure 18 is based on the ZnMnO_2 battery of 10 kWh *EC* with an *UL* of 2.5 kW. By utilizing this storage and the control algorithm elaborated above, we expect a ~\$700 reduction in the *annual payments* per year: The summer demand cost is expected to be reduced by ~\$600 and followed by a ~\$320 reduction for winter months, then a \$300 reduction for spring/fall months. Energy charges are slightly increased (\$20) compared with those charged under the TOU tariff before storage is used.

6.3.2 Optimal effective storage size and optimal operating upper limit

The surface plot of Figure 19 shows an example of the varying *annual payments* by installing ZnMnO_2 batteries with varying *EC* and *UL*. The *EC* geometrically increases from 0.1 kWh to 34 kWh at 20% increase at each step. The *UL* geometrically increases from 2 kW to 6.5 kW at 10% increase at each step. The optimal *EC* and the optimal operating *UL* were identified by the lowest point on the surface. Figure 20 plots a selection of lines (obtained from Figure 19) at controlled *ECs* or controlled *ULs*.




Figure 19. Surface plot of annual payments with varying EC s and varying UL s (peak reduction).

Figure 20(a) shows how the *annual payments* change with the UL on the horizontal axis. In the figure, each line represents one case with one specific EC . A general trend can be found that the *annual payments* first decrease, followed by increases when the UL increases gradually from 2 kW to 6.5 kW. This can be explained by looking into how the demand profiles would respond by implementing different UL s (Figure 21 and Figure 22).




Figure 20. Annual payments variations at controlled EC s or controlled UL s (peak reduction)

When EC s are small (e.g., $EC = 0.3$ or 0.4 kWh in Figure 20(a)), the annual payments are reduced by installing small size storage operated at the UL around 4 kW. When EC is moderate (e.g., $EC = 2.7, 4.6, 6.6$ kWh in Figure 20 (a)), on certain days, lower UL (e.g., 2 kW) may lead to lower peaks during the day,

but the capacity constraint prevents it from lowering the peaks for other days during the month: The monthly peak demand to be charged will still remain the same. For example, Figure 21 displays the measured loads by using ZnMnO_2 battery sized at the *EC* equaling 4.6 kWh but implementing different *ULs* (2 kW, 3.2 kW and 6.3 kW). For the purpose of comparison, the original minute-by-minute aggregate appliances demand profile (solid grey line) and the averaged one (dashed black line) without using storage are also plotted. Around 5 PM – 6 PM, however, the 2 kW *UL* results in a demand of 4 kW due to the insufficient available capacity of storage. In contrast, with batteries that have not yet been dumped, the case with the *UL* of 3.2 kW successfully reduces the peak to 3.2 kW. In this case, the higher *UL* results in lower peaks in comparison to those that result from a lower *UL*. However, when the *UL* is higher than the optimal one, the ruled demand is higher (e.g., when *UL* is 6.3 kW (green line) in Figure 21 (a)), thus the electricity bills increase.

Note that instead of reducing the daily peak demands, a high *UL* (e.g., 6.3 kW) may result in a load higher than the original load without using storage (see the green line in Figure 21(a)), when the original load is below the *UL*. During that time slot (30 minutes before 12 AM in Figure 21(a)), the grid refills the storage which had been discharged previously. In addition, some extra electricity goes into losses during the (dis)charging processes.




Figure 21. Demand profile simulations and storage (dis) charging patterns by implementing different operating *ULs* (*EC* = 4.6 kWh).

When the EC is higher (e.g., $EC = 23.7, 34.2$ kWh in Figure 22), the optimal UL s are reduced with increased EC s. However, although the EC is as high as 23.7 kWh, the 2 kW UL target is not yet fulfilled (see Figure 22). In both Figure 21 and Figure 22, the demand loads are equaling or above 2 kW most of the time in both cases, indicating that when the UL is as low as 2 kW, the storage has taken every chance to get charged. Further reducing the loads requires a much higher capacity which stays idle for most of time because no available time slots can be found to re-charge this amount of capacity.




Figure 22. Demand profile simulations and storage (dis)charging patterns by implementing different operating UL s ($EC = 23.7$ kWh)

Looking into the plots with the axis of EC (Figure 20(b)), each line represents a case with a certain UL . The *annual payments* first decrease, then increase. As discussed above, the higher capacity can effectively reduce the peaks during days and months, thus resulting in lower peaks, which comes with a penalty of the higher storage cost. Note that although in Figure 20(a), optimal UL generally decreases with higher EC , optimal EC does not always increase with lower UL (see Figure 20(b), blue versus red trace). As explained above, in order to further reduce the loads to remain below 2 kW from 2.42 kW, possibly much more capacity is needed. By weighing the largely incurred financing cost of storage against the relatively small potential electricity bill reduction, the model determines that a smaller capacity which is insufficient to get the loads below or closer to the UL is the optimal solution.

In the end, the energy cost can decrease or increase the *annual payments* in two ways: It can 1) increase the *annual payments* due to the additional cost for the energy losses during the storage

charging/discharging processes, or 2) possibly decrease the annual payments due to the arbitrage savings from loadshifting. For the latter, the peak reduction control algorithm possibly reduces the loads and the electricity consumption during peak periods simultaneously. However, the potential of the arbitrage savings is limited: Under the TOU kW tariff, the difference between the peak energy charge rate and the off peak charge rate is only 2.5 cents per kWh shifted electricity in summer months, and 1.4 cents per kWh shifted electricity in other months (Table 2). Assuming storage of 30 kWh *EC*, the maximum potential for arbitrage savings under the TOU kW tariff is:

$$2.5 \times 30 \times 92 + 1.4 \times 18 \times 120 + 1.4 \times 9 \times 153 = 11851.8 \text{ cents/year} = \$118.5/\text{year}^{12}$$

\$118.5 per year is considerably smaller than the *annual payments* (more than \$2000 per year). In terms of energy losses, the energy cost is between 6 to 8 cents per kWh electricity consumption (Table 2), which should be paid attention to when the storage has low efficiencies. Seen from Figure 21(b), when the *EC* is 4.6 kWh the lower *UL* tends to result in more frequent charging/discharging, thus more energy losses. However, when the *EC* is 23.7 kWh in Figure 22(b), the optimal *UL* (2.42 kW) leads to higher energy losses in comparison with the *UL* of 2 kW. Besides, by comparing Figure 21(b) and Figure 22(b), more energy losses occur when *EC* is larger.

In summary, with higher storage *EC*, the loads can be smoothed effectively with lower optimal *UL*. However, to further reduce the loads, the *EC* should be increased exponentially. Otherwise, given an insufficient storage capacity (e.g., Figure 22), lowering the *UL* would result in higher loads after the storage reaches its *DoD* in comparison with loads measured by implementing a higher *UL*. The optimal *EC* and the optimal *UL* are thus determined by weighing the reduced electricity bills coming with higher *EC* and potentially lower optimal *UL* against the increased financing cost of storage. The *optimal annual payments* are thus a function of the charging/discharging efficiencies, the financing cost of storage (Eq. (1)) and the demand profiles. Table 8 and Table 9 summarize the optimal *EC*, the optimal *UL* and the minimum *annual payments* for a variety of storage options in the average-case scenario (Table 8) and in the best-case scenario (Table 9), respectively.

Figure 23 shows the impact of the rising financing cost on the corresponding optimal *EC* for various storage options (average-case scenario). Each marker represents one storage option. Detailed financing costs are given in Table 5. An exponential reduction trend can be seen in that decreasing financing costs leads to increasing optimal *EC*s. When the financing costs are less than \$50 per kWh per year, the optimal *EC*s are more than 5 kWh. With small financing costs, CAES and PHS are optimized at *EC*s of more than 20 kWh. The exponential trend observed can be explained that with low financing costs, the model determines that the marginal savings from lowering *UL* and enlarging *EC* exceed the marginal financing cost of storage. Above, we have explained that in order to get down to a low optimal *UL*, e.g., 2 kW, the increase in *EC* is remarkable and exponential. On the other hand, after the financing costs grow into more than \$50 kWh per year, the variations of the optimal *EC*s with increasing financing costs become less obvious.

¹² According to the testing results of our agent-based demand profile model (see Table B.1), the average electricity consumption during peak periods (i.e. the maximum amount of electricity that can be shifted for the purpose of arbitrage savings) is 30 kWh for summer days (92 days out of one year), 18 kWh for winter days (120 days out of one year) and 9 kWh for the remaining days.




Figure 23. Optimal ECs for a variety of storage costs in the average-case scenario (peak reduction). Error bars represent one standard deviation above and below the mean.




Figure 24. Annual payments and optimal ULs for a variety of storage options in the average case scenario (peak reduction). Error bars represent one standard deviation above and below the mean.

Figure 24 shows the impact of increasing *EC* on the corresponding optimal operating *ULs* and the *annual payments* (average-case scenario) yielded by installing a variety of storage options. As discussed above, generally, the higher optimal *EC* comes with a lower *UL*, except for metal air batteries (circled points in Figure 24). Note that according to Table 5, the round-trip efficiency of metal air batteries is 45%, the lowest one on the list. It is shown above that when the optimal *EC* is of a moderate amount, a higher *UL* would lead to less electricity getting into/out of storage, and thus also to fewer (dis)charging losses. In this sense, the model determines a higher *UL* for metal air batteries to reduce the energy losses in comparison to the expected *UL* following the trend.

The minimal *annual payments* also exhibit a decreasing trend with higher optimal *ECs* in Figure 24, except for the point representing metal air batteries. It is possibly due to the low lifetime of metal air batteries (5 years, see Table 5). The low lifetime would result in the high annualized installation fee, which makes the *annual payments* of metal air batteries become higher than the points on the left side. When the annualized installation fee is subtracted from the annual payments, the *annual payments* of metal air batteries drop remarkably.

In summary, the decreasing financing cost of storage leads to the optimal *EC* increasing. When the financing cost is less than \$50 per effective kWh per year, the optimal *EC* increases exponentially. Generally, for the optimal *UL*, a larger optimal *EC* comes with a lower optimal *UL*, but exceptions exist due to the impact of interactions between energy losses and the operating *UL*. In the end, the lower annual payments can be approached by the lower financing cost of storage (thus the higher optimal *EC*) and the lower optimal *UL*.

6.3.3 Economic viability

Table 8 summarizes the optimization results for the average-case scenario for all storage technologies. Optimal *EC*s span a wide range depending on the storage technology, 0.38 kWh – 26.84 kWh in the average-case scenario. The optimal *UL*s range from 2.4 to 4.1 kW in the average-case scenario. As shown in Figure 18, the TOU kW tariff costs less compared to the basic kW tariff for the typical consumer modeled in this study. Assume that the SC8 consumers would select the kW tariff, which costs less, as their base tariff. The modeled minimal *annual payments* therefore are compared against the TOU kW tariff baseline: Storage yielding negative *profit* against the TOU kW tariff baseline is determined as “not economically viable”. Table 8 shows that for economically viable technologies, annual *profits* (also determined by using the TOU kW tariff baseline) range from \$161 for the Pb-acid batteries (5% of annual electricity cost without storage, TOU baseline) to \$1058 for PHS (33%). Flywheel, SMES, NiCd, Li-ion and NaS batteries, all sized at small *EC*s (0.38 kWh – 2.6 kWh), are not economically viable in the average-case scenario. Nevertheless, the gaps are all below \$200/year. In the end, though PHS and CAES are determined as economically viable storage options, their technological viabilities for residential settings are discussed in Sec. 7.

Table 8. Optimal *EC*, optimal *UL* and maximum *profits* for the average-case scenario (peak reduction)

		Annual payments (\$/year)	SEM ^a	Optim al <i>EC</i> (kWh)	SEM	Optim al <i>UL</i> (kW)	SEM	Basic w/o storag e	SEM	Profit ^b (\$/yea r)	TOU w/o storag e	SEM	Profit ^c (\$/year)
Flywheel		3406	23.16	0.778	0.15	3.724	0.08	4692	2.54	1287	3248	17.30	-158
Conventional batteries	Metal air battery	2852	20.94	11.63	1.09	2.934	0.06	4692	2.54	1840	3248	17.30	396
	Pb-acid	3087	23.64	3.065	0.17	3.511	0.03	4692	2.54	1606	3248	17.30	161
	NiCd	3394	26.10	1.819	0.18	3.482	0.07	4692	2.54	1299	3248	17.30	-146
Advanced batteries	Li-ion	3320	26.67	1.900	0.20	3.418	0.07	4692	2.54	1372	3248	17.30	-72
	NaS	3273	25.87	2.571	0.17	3.546	0.05	4692	2.54	1419	3248	17.30	-25
	ZEBRA	2666	16.66	9.271	0.70	2.827	0.07	4692	2.54	2026	3248	17.30	582
Flow batteries	ZnBr	2922	20.10	3.550	0.21	3.479	0.04	4692	2.54	1770	3248	17.30	326
	VRB	2769	16.17	4.069	0.30	3.382	0.05	4692	2.54	1924	3248	17.30	479
	ZnNi	2999	22.36	3.129	0.18	3.479	0.04	4692	2.54	1694	3248	17.30	249
	ZnMnO ₂	2550	18.20	10.23	0.83	2.779	0.09	4692	2.54	2142	3248	17.30	698
Super capacitor		2842	20.43	3.625	0.22	3.350	0.05	4692	2.54	1850	3248	17.30	406
CAES		2376	13.75	20.79	2.19	2.616	0.05	4692	2.54	2316	3248	17.30	872
PHS		2190	9.18	26.84	2.12	2.398	0.02	4692	2.54	2502	3248	17.30	1058
SMES		3438	21.19	0.380	0.06	4.082	0.19	4692	2.54	1255	3248	17.30	-190

^a Standard deviation of the mean.

^b Compared with the payment charged by the basic kW tariff without installing storage.

^c Compared with the payment charged by the TOU kW tariff without installing storage. Positive values of profit indicate the evaluated storage option is economically viable and vice versa.

In the best-case scenario, all storage technologies are economically viable (see Table 9). The optimal *EC*s range from 2.636 kWh to 27.744 kWh depending on the storage technology in the best-case scenario. The

optimal *ULs* range from 2.4 to 3.6 kW, which are generally lower than the corresponding ones in the average-case scenario. In the best-case scenario, annual *profits* range from \$63 for NiCd to \$1,119 for PHS (TOU baseline).

Table 9. Optimal *EC*, optimal *UL* and maximum *profits* for the best-case scenario (peak reduction)

		Annual paymen ts (\$/year)	SEM ^a	Optimal EC (kWh)	SEM	Optim al UL (kW)	SEM	Basic w/o storag e	SEM	Profit ^b (\$/yea r)	TOU w/o storag e	SEM	Profit ^c (\$/year)
Flywheel		3052	29.13	2.968	0.18	3.450	0.07	4692	2.54	1641	3248	17.30	197
Conventional batteries	Metal air battery	2663	11.35	23.494	2.23	2.662	0.00	4692	2.54	2029	3248	17.30	585
	Pb-acid	2670	22.14	9.520	0.80	2.885	0.09	4692	2.54	2022	3248	17.30	578
	NiCd	3185	28.34	2.636	0.11	3.582	0.06	4692	2.54	1507	3248	17.30	63
Advanced batteries	Li-ion	2903	27.32	3.525	0.14	3.382	0.05	4692	2.54	1789	3248	17.30	345
	NaS	2850	24.28	4.356	0.29	3.318	0.05	4692	2.54	1842	3248	17.30	398
	ZEBRA	2588	22.87	11.791	0.58	2.693	0.06	4692	2.54	2104	3248	17.30	660
Flow batteries	ZnBr	2607	22.06	9.689	0.82	2.907	0.06	4692	2.54	2085	3248	17.30	641
	VRB	2523	21.93	11.594	0.59	2.776	0.08	4692	2.54	2170	3248	17.30	725
	ZnNi	3011	27.49	3.012	0.17	3.514	0.06	4692	2.54	1681	3248	17.30	237
	ZnMnO ₂	2485	23.18	12.760	0.79	2.693	0.06	4692	2.54	2208	3248	17.30	763
Super capacitor		2753	25.82	4.230	0.34	3.288	0.06	4692	2.54	1940	3248	17.30	495
CAES		2227	15.07	24.655	2.17	2.565	0.04	4692	2.54	2466	3248	17.30	1021
PHS		2129	8.93	27.744	2.08	2.398	0.02	4692	2.54	2563	3248	17.30	1119
SMES		2979	27.92	3.227	0.15	3.382	0.05	4692	2.54	1713	3248	17.30	269

^a Standard deviation of the mean.

^b Compared with the payment charged by the basic kW tariff without installing storage.

^c Compared with the payment charged by the TOU kW tariff without installing storage. Positive values of profit indicate the evaluated storage option is economically viable and vice versa.

7 Discussion

In this section, we first compare results from two DR strategies devised in this study: Loadshifting strategy and peak reduction strategy (Sec. 7.1). The a variety of options were discussed that could render DR via residential storage (even) more economically attractive, gain wider adoption, and thus provide more benefits to the grid as a whole (Sec. 7.2-7.4). Finally, the technological viabilities of installing PHS and CAES in residential buildings are addressed in Sec. 7.5.

7.1 Demand tariffs versus energy tariffs

The Con Edison tariff used in our analyses charge both the delivery and the supply portion of monthly electricity bills according to the kWh drawn from the grid (Sec. 2.1). For residential customers with at least 10kW peak demand (over any 30min window, at least once a month), Con Edison offers another TOU kW tariff (SC8-Rate II; see Sec. 2.2) that charges both by demand (kW) and by energy consumption (kWh). The results for these two tariffs (and two strategies) are compared in Table 10 in terms of economic viabilities of storage options.

As seen in Table 10, the TOU kW tariff can render more storage technologies economically viable: Not economically viable under the TOU kWh tariff and by using the loadshifting strategy (see Sec. 5.1), a number of batteries, incl. metal air, Pb-acid, ZEBRA, ZnBr, VRB and ZnNi batteries, and super capacitor become economically viable by implementing the peak reduction strategy (see Sec. 6.1) in the average-case scenario. However, “short term” technologies such as flywheels and SMES are not economically

viable (average-case scenario); their cost per kWh capacity is simply too high. In the best-case scenario, all the storage technologies can generate positive profits by using the peak reduction strategy while only five storage technologies are economically viable by using the loadshifting strategy.

Another tariff model, participating in the frequency regulation market (likely via aggregating multiple residences into a single contractor), may generate alternative or additional savings also (future work, not in this study) [15, 18].

Table 10. Economic evaluation results comparison between two strategies

		TOU kWh tariff ^a		TOU kW tariff ^b	
		Average-case scenario	Best-case scenario	Average-case scenario	Best-case scenario
Flywheel		NO	NO	NO	YES
Conventional batteries	Metal air battery	NO	YES	YES	YES
	Pb-acid	NO	NO	YES	YES
	NiCd	NO	NO	NO	YES
Advanced batteries	Li-ion	NO	NO	NO	YES
	NaS	NO	NO	NO	YES
	ZEBRA	NO	YES	YES	YES
Flow batteries	ZnBr	NO	NO	YES	YES
	VRB	NO	NO	YES	YES
	ZnNi	NO	NO	YES	YES
	ZnMnO ₂	YES	YES	YES	YES
Super capacitor		NO	NO	YES	YES
CAES		YES	YES	YES	YES
PHS		YES	YES	YES	YES
SMES		NO	NO	NO	YES

^a Determined by comparing the minimum annual payments by implementing the loadshifting strategy (see Sec.5.1) to the basic kWh tariff baseline (see Table 7).

^b Determined by comparing the minimum annual payments by implementing the peak reduction strategy (see Sec. 6.1) to the TOU kW tariff baseline (see Table 8).

7.2 Technological improvement and storage cost reduction

Roundtrip efficiencies reported in various literature on metal-air batteries, ZnBr batteries and Vanadium Redox Batteries (VRB) are relatively low (45% for metal-air, 60%-75% for ZnBr, 65%-85% for VRB, see Table 5). However, research is underway to improve efficiencies of metal-air and flow batteries [41, 64]. This would significantly increase achievable profits for residential customers. For example for metal-air batteries, assuming a doubling of roundtrip efficiency from 45% to 90% (achievable in the future [65]), *annual profits* could be increased by 22% (average-case scenario, loadshifting strategy).

In contrast, the efficiencies of flywheel storage and SMES are already high (see Table 5). With high power rating but low energy capacity (and thus short discharge duration), device costs of flywheel and SMES are expensive (per kWh capacity). For these devices, potential cost reductions to consumers would result from manufacturing cost reductions rather than efficiency increases.

For not yet fully matured battery technologies, future manufacturing cost reduction (and/or life time improvement) may be achieved in the coming years due to the modularity and scalability of battery systems and technology breakthroughs, for example the use of less costly Na as an alternative to Li in Li-ion batteries [36]. In contrast, Pb-acid batteries have been cost-competitive in the market for a long time. Instead of manufacturing cost, the main limiting factor for Pb-acid batteries is the relatively limited lifetime (number of cycles). Another common disadvantage of Pb-acid batteries, their low-energy density

[48], will likely not constitute material issue for residential use. For Pb-acid batteries sized at 45 kWh (optimal nominal capacity for Pb-acid (best-case scenario, loadshifting strategy) in this study), the required volume is 0.38-0.9 m³ (energy density of 50-120 Wh/l, Table A.1). Even when including additional space for the control unit, this can be easily fit into a single family home.

7.3 Lowering installation costs

Besides the storage manufacturing cost (Sec. 4.2), lowering the fixed one-time home installation costs also has potential to improve economic viability. Some storage technologies and scenarios, while not economically viable in our model, are so close to break-even that a reduction in installation costs would render them economically viable. For example, as can be seen from Table 7, the best-case scenario for super capacitors has a gap to break-even of only \$149 per year (loadshifting strategy). With assumed installation cost reduction of 50%, the super capacitor would become economically viable. Still, by using the loadshifting strategy, for flywheel, Li-ion batteries, NiCd batteries, NiZn batteries, and SMES, storage manufacturing costs and/or (dis)charging losses are so high that gaps to provide profit are more than \$900 per year, i.e. higher than the savings possible from lowered installation costs. In the contrast, the break-even gaps yielded by utilizing the peak reduction strategy are all below \$190 per year (Table 8, average-case scenario), indicating that they are likely to become economically viable or get closer to be break-even if the assumed installation cost would be reduced by 50%.

7.4 Impact of interest rates

Considering 5% instead of 10% interest rate would result in 27% lower total financing costs of the storage system (interest and principal repayments). Conversely, a more conservative 15% instead of 10% would increase financing costs by 50% (for examples for 15 years lifetime). However, considering average instead of best case storage costs leads to much higher cost increases (between 41% (super capacitor) and 362% (Pb-acid batteries)). In other words, the sensitivity of economic viability to the exact interest rate is low compared to the large uncertainty in storage manufacturing costs themselves. Varying interest rates are therefore not further considered in this study.

7.5 Technological viability of PHS and CAES

With regards to economic viability, PHS and CAES show the highest possible profit (Table 1). However, from a practical perspective, applications of PHS and CAES will be limited by site conditions. Although emerging PHS and CAES technologies have been proposed or demonstrated to work as compact systems [66], their low energy density still poses obstacles: For PHS, the optimal *EC* of 12kWh (average-case scenario, loadshifting strategy) would require 488m³ (~500 tons) of water stored in two separate tanks at 10m altitude difference. This will be possible only for select residential buildings and specific architecture. For CAES, however, recent commercially available systems have been shown to be suitable for installation e.g., in the basement of single-family homes [66].

8 Conclusions and future work

We found that, when choosing suitable storage technologies and carefully sizing capacity, typical U.S. households can achieve considerable profits when load-shifting their electricity consumption or reduce their peak power demands. The annual profits range from \$61 to \$1365 per year per household by

utilizing the load-shifting strategy and from \$161 to \$1058 per year per household by using the peak reduction strategy. These profits can be achieved without changing the actual consumption patterns of appliances. The peak reduction strategy can render more storage technologies economically viable than the loadshifting strategy. Note that the demand model represents the U.S. average household (see test results in Sec. 4.2). For other households – with different appliance configuration (e.g., a second television or air conditioning unit) or tariffs other than the specific *Con Edison* tariff used here – profits may change.

An important further investigation into the benefits of DR would be a quantification of possible greenhouse gas emissions savings (on a lifecycle bases, [67-70]). Further optimized or new dispatch strategies may be found by analyzing patterns of demand profiles in the frequency rather than the time domain [71].

Acknowledgements

The work presented herein was supported by the National Institute of Standards and Technology (NIST) Grant No 60NANB11D192. Parts have been published elsewhere [72, 73].

References (main document)

- [1] U.S. Department of Energy. The Smartgrid: An introduction. 2008.
- [2] Allen D, Brown C, Hickey J, Le V, Safuto R. Energy Storage in the New York Electricity Markets. New York Independent system operator; 2010.
- [3] Denholm P, Ela E, Kirby B, Milligan M. The Role of Energy Storage with Renewable Electricity Generation. National Renewable Energy Laboratory; 2010.
- [4] Singer P. Energy Storage and The Grid. Renewable Energy World.COM 2010.
- [5] U.S. Environmental Protection Agency. Assessing the Multiple Benefits of Clean Energy. U.S. Environmental Protection Agency; 2011. p. 110.
- [6] Wissner M. The Smart Grid – A saucerful of secrets? Applied Energy. 2011;88:2509-18.
- [7] Aalami HA, Moghaddam MP, Yousefi GR. Demand response modeling considering Interruptible/Curtailable loads and capacity market programs. Applied Energy. 2010;87:243-50.
- [8] Moghaddam MP, Abdollahi A, Rashidinejad M. Flexible demand response programs modeling in competitive electricity markets. Applied Energy. 2011;88:3257-69.
- [9] Charles D. Renewables Test IQ of the Grid. Science. 2009;324:172-5.
- [10] Moura PS, de Almeida AT. The role of demand-side management in the grid integration of wind power. Applied Energy. 2010;87:2581-8.
- [11] Walawalkar R, Fernands S, Thakur N, Chevva KR. Evolution and current status of demand response (DR) in electricity markets: Insights from PJM and NYISO. Energy. 2010;35:1553-60.
- [12] Caves DW, Herriges JA, Kuester KA. Load shifting under voluntary residential time-of-use rates. The Energy Journal. 1989;10:83-99.
- [13] Pellegrino JL. Measurement Science Roadmap for Net-zero Energy Buildings Workshop: Summary Report. National Institute of Standards and Technology; 2010.
- [14] Kurucz CN, Brandt D, Sim S. A linear programming model for reducing system peak through customer load control programs. Power Systems, IEEE Transactions on. 1996;11:1817-24.
- [15] Mokrian P, Stephen M. A Stochastic Programming Framework for the Valuation of Electricity Storage. 26th USAEE/IAEE North American Conference: USAEE; 2006. p. 24-7.
- [16] Callaway DS, Hiskens IA. Achieving Controllability of Electric Loads. Proceedings of the IEEE. 2011;99:184-99.
- [17] Denholm P, Short W. Evaluation of Utility System Impacts and Benefits of Optimally Dispatched Plug-In Hybrid Electric Vehicles (Revised). NREL; 2006. p. 30 pp.
- [18] Valentine K, Temple WG, Zhang KM. Intelligent electric vehicle charging: Rethinking the valley-fill. Journal of Power Sources. 2011;196:10717-26.

- [19] Peterson SB, Apt J, Whitacre JF. Lithium-ion battery cell degradation resulting from realistic vehicle and vehicle-to-grid utilization. *Journal of Power Sources*. 2010;195:2385-92.
- [20] U.S. Energy Information Administration. Electric Power Annual 2011 Table 1.1. Total electric power industry summary statistics. U.S. Energy Information Administration; 2013.
- [21] Wright A, Firth S. The nature of domestic electricity-loads and effects of time averaging on statistics and on-site generation calculations. *Applied Energy*. 2007;84:389-403.
- [22] Capasso A, Grattieri W, Lamedica R, Prudenzi A. A bottom-up approach to residential load modeling. *Power Systems, IEEE Transactions on*. 1994;9:957-64.
- [23] Richardson I, Thomson M, Infield D. A high-resolution domestic building occupancy model for energy demand simulations. *Energy and Buildings*. 2008;40:1560-6.
- [24] Widén J, Lundh M, Vassileva I, Dahlquist E, Ellegård K, Wäckelgård E. Constructing load profiles for household electricity and hot water from time-use data—Modelling approach and validation. *Energy and Buildings*. 2009;41:753-68.
- [25] Richardson I, Thomson M, Infield D, Clifford C. Domestic electricity use: A high-resolution energy demand model. *Energy and Buildings*. 2010;42:1878-87.
- [26] Widén J, Wäckelgård E. A high-resolution stochastic model of domestic activity patterns and electricity demand. *Applied Energy*. 2010;87:1880-92.
- [27] Newsham GR, Bowker BG. The effect of utility time-varying pricing and load control strategies on residential summer peak electricity use: A review. *Energy Policy*. 2010;38:3289-96.
- [28] Tsung-Ying L, Nanming C. Determination of optimal contract capacities and optimal sizes of battery energy storage systems for time-of-use rates industrial customers. *Energy Conversion, IEEE Transactions on*. 1995;10:562-8.
- [29] Kishore S, Snyder LV. Control Mechanisms for Residential Electricity Demand in SmartGrids. *Smart Grid Communications (SmartGridComm)*, 2010 First IEEE International Conference on Smart Grid. Gaithersburg, MD2010. p. 443-8.
- [30] Dlamini NG, Cromieres F. Implementing peak load reduction algorithms for household electrical appliances. *Energy Policy*. 2012;44:280-90.
- [31] Byrne RH, Silva-Monroy CA. Estimating the maximum potential revenue for grid connected electricity storage: arbitrage and regulation. 2012.
- [32] Samadi P, Mohsenian-Rad AH, Schober R, Wong VWS, Jatskevich J. Optimal Real-Time Pricing Algorithm Based on Utility Maximization for Smart Grid. *Smart Grid Communications (SmartGridComm)*, 2010 First IEEE International Conference on Smart Grid. Gaithersburg, MD2010. p. 415-20.
- [33] Lujano-Rojas JM, Monteiro C, Dufo-López R, Bernal-Agustín JL. Optimum residential load management strategy for real time pricing (RTP) demand response programs. *Energy Policy*. 2012;45:671-9.

- [34] Conejo AJ, Morales JM, Baringo L. Real-Time Demand Response Model. Smart Grid, IEEE Transactions on. 2010;1:236-42.
- [35] Electric Power Research Institute. Electric Energy Storage Technology Options: A Primer on Applications, Costs & Benefits - An EPRI Executive Summary. Electric Power Research Institute (EPRI); 2010.
- [36] Dunn B, Kamath H, Tarascon J-M. Electrical Energy Storage for the Grid: A Battery of Choices. Science. 2011;334:928-35.
- [37] Schoenung SM, Hassenzahl WV. Long- vs. Short-Term Energy Storage Technologies Analysis A Life-Cycle Cost Study. Sandia National Laboratories; 2003.
- [38] Schoenung S. Energy Storage Systems Cost Update. Sandia National Laboratories; 2011.
- [39] Naish C, McCubbin I, Edberg O, Harfoot M. Outlook of Energy Storage Technologies. 2008.
- [40] Chen H, Cong TN, Yang W, Tan C, Li Y, Ding Y. Progress in electrical energy storage system: A critical review. Progress in Natural Science. 2009;19:291-312.
- [41] Skyllas-Kazacos M, Chakrabarti M, Hajimolana S, Mjalli F, Saleem M. Progress in flow battery research and development. Journal of The Electrochemical Society. 2011;158:R55-R79.
- [42] The Federal Energy Regulatory Commission Staff. National Action Plan on Demand Response. the Federal Energy Regulatory Commission; 2010.
- [43] U.S. Department of Energy. Communications Requirements of Smart Grid Technologies. U.S. Department of Energy; 2010.
- [44] Stadler M, Marnay C, Siddiqui A, Lai J, Aki H. Integrated Building Energy Systems Design Considering Storage Technologies. 2009 ECEEE Summery Study. La Colle sure Loup, France: Lawrence Berkeley National Laboratory; 2009.
- [45] Consolidated Edison Company of New York Inc. Schedule for Electricity Service, P.S.C. No.10 - Electricity.
- [46] Consolidated Edison Company of New York Inc. Supply charges.
- [47] European Commission. 2011 Technology Map of the European Strategic Energy Technology Plan (SET-Plan). European Commission,Joint Research Centre,Institute for Energy and Transport; 2011.
- [48] Baker J. New technology and possible advances in energy storage. Energy Policy. 2008;36:4368-73.
- [49] D&R International Ltd. 2011 Buildings Energy Data Book Table 2.1.16 Operating Characteristics of Electric Appliances in the Residential Sector. Prepared for the Buildings Technologies Program, Energy Efficiency and Renewable Energy, U.S. Department of Energy under contract to Pacific Northwest National Laboratory; 2012.
- [50] U.S. Department of Energy. Estimating Appliance and Home Electric Energy Use. Energy.Gov.

- [51] U.S. Energy Information Administration. 2001 Residential Energy Consumption Survey (RECS) Data Table HC3. Space Heating, Table HC4. Air-Conditioning, Table HC5. Appliances, Million U.S. Households. U.S. Energy Information Administration.
- [52] Paatero JV, Lund PD. A model for generating household electricity load profiles. *International Journal of Energy Research*. 2006;30:273-90.
- [53] U.S. Environmental Protection Agency. ENERGY STAR Market & Industry Scoping Report: Toaster Ovens. 2011.
- [54] U.S. Energy Information Administration. 2005 Residential Energy Consumption Survey (RECS) Data Table SH1. Total Households Using a Space Heating Fuel, Table AC1. Total Households Using Air-Conditioning Equipment, Table WH1. Total Households Using Water Heating Equipment, Table AP1. Total Households Using Home Appliances and Lighting by Fuel Used.: U.S. Energy Information Administration.
- [55] Cavallo J, Mapp J, Systems E, Bureau WE. Monitoring refrigerator energy usage. *Home Energy Mag*. 2000;17:32-6.
- [56] General Electric Company. Refrigerator-Normal Run Time. GE Appliances.
- [57] US Bureau of Labor Statistics. 2012 American Time Use Survey. United Department of Labor; 2013.
- [58] California Utilities Statewide Codes and Standards Team. Codes and Standards Enhancement Initiative (CASE) Residential Lighting. 2011.
- [59] Reddy TA. Statistical analyses of electricity use during the hottest and coolest days of summer for groups of residences with and without air-conditioning. *Energy*. 1990;15:45-61.
- [60] EMET. The Impact of Commercial and Residential Sectors' EEI's on Electricity Demand. 2004.
- [61] Pecan Street Research Institute.
- [62] U.S. Energy Information Administration. 2009 Residential Energy Consumption Survey (RECS) Data Table CE2.1 Fuel Consumption Totals and Averages, U.S. Homes. U.S. Energy Information Administration.
- [63] Lunz B, Yan Z, Gerschler JB, Sauer DU. Influence of plug-in hybrid electric vehicle charging strategies on charging and battery degradation costs. *Energy Policy*. 2012;46:511-9.
- [64] Armand M, Tarascon J-M. Building better batteries. *Nature*. 2008;451:652-7.
- [65] Girishkumar G, McCloskey B, Luntz A, Swanson S, Wilcke W. Lithium– air battery: Promise and challenges. *The Journal of Physical Chemistry Letters*. 2010;1:2193-203.
- [66] Agrawal P, Nourai A, Markel L, Fioranvanti R, Gordon P, Tong N, et al. Characterization and Assessment of Novel Bulk Storage Technologies. Sandia National Laboratories; 2011.
- [67] Draucker L, Kaufman SM, ter Kuile R, Meinrenken CJ. Moving forward on carbon footprinting standards. *J Ind Ecol*. 2011;15:169-71.

- [68] ISO. ISO 14064-1:2006 - Greenhouse gases - Part 1: Specification with guidance at the organization level for quantification and reporting of greenhouse gas emissions and removals. International Organization For Standardization. 2006.
- [69] Meinrenken CJ, Garvan AN, Lackner KS. "Fast LCA" to apply life cycle methodologies and supply chain management at scale. Proceedings, 7th International Society for Industrial Ecology Conference. 2013.
- [70] Meinrenken CJ, Kaufmann SM, Ramesh S, Lackner KS. Fast carbon footprinting for large product portfolios. *Journal of Industrial Ecology* 16(5); DOI: 101111/j1530-9290201200463x. 2012.
- [71] Meinrenken CJ, Gillespie WD, Macheret S, Lempert WR, Miles RB. Time domain modeling of spectral collapse in high density molecular gases. *J Chem Phys.* 1997;106:8299-309.
- [72] Zheng M, Meinrenken CJ. Electricity demand and storage dispatch modeling for buildings and implications for the smartgrid. April Meeting of the American Physical Society. Denver, Colorado 2013.
- [73] Zheng M, Meinrenken CJ, Lackner KS. Agent-based model for electricity consumption and storage to evaluate economic viability of tariff arbitrage for residential sector demand response. *Applied Energy.* 2014;126:297-306.

Appendix A. Operating characteristics of storage technologies and cost estimations**Table A. 1.** Characteristics of storage technologies and cost estimations, incl. data sources

	Description	Power density (kW/kWh) ¹		Healthy depth of discharge (%)	Round-trip efficiency (%)	Energy density		Operating temperature	Self-discharge (%/day)	Cost	Life time (cycles)	Commercial availability
		Continuously discharging power	Pulse power			(Wh/kg)	(Wh/l)			Capital cost (\$ /kWh)		
Conventional batteries												
Metal air	Anode: Metals with high energy density like Al or Zn Cathode: A porous carbon structure or a metal mesh covered with proper catalysts Electrolytes: Good OH-ion conductor	0-10 ²	NA	100 ³	40-50 ⁴	110-420 ⁵	200 ³	NA	small	10-60 ² 160 ³	100-300 ² ~1,500 ³	Mature in conventional generation Demo to increase lifetime and efficiency
Lead acid (Pb-acid) ⁶	Anode: Pb+SO4 ²⁻ ↔PbSO4+2e- Cathode: PbO2+SO4 ²⁻ +4H ⁺ +2e-↔PbSO4+2H2O	0.05-3.4	11.2-15	70-80	75-80	30-50	50-120 ⁷	(-20) - 50°C ⁷	0.1-0.3	106-400 950-2260 for advanced batteries	200-1000 4500 for advanced batteries	Mature
Nickel cadmium (NiCd) ⁸	2NiO(OH)+Cd+2H2O↔2Ni(OH)2+Cd(OH)2	0.05-2.77	30	NA	60-91	40-75	171.6	NA	0.2-0.6	600-1500	1000-3000	Mature
Advanced batteries												
Lithium-ion (Li-ion) ⁹		0.12-6.17	0.3-15.64	80 ¹⁰	75-100	50-200	100-500	-20-+45/60°C	0.1-0.3	500-3600	1000-6000 >10,000 ¹¹	Mature portable market
Sodium sulfur (NaS) ¹²	2Na+4S↔Na2S4	0.03-0.14	NA	NA	70-92	150-240	150-370	300-350°C	20	250-555 1100-2730 ¹³	2000-4500	Mature in Japan; Demo in USA
Sodium nickel chloride (NaNiCl ZEBRA) ¹⁴	2NaCl+Ni↔NiCl2+2Na	NA	NA	NA	90	100-120	150-180	-40-+70°C	15	100-200	2500	Demo and trial
Flow batteries (additional electrolyte is stored externally, which is usually pumped through the cell (or cells) of the reactor)												
Zinc bromine (ZnBr) ¹⁵	Positive electrode: 2Br ⁻ ↔ Br2(aq)+2e ⁻ Negative electrode: Zn2 ⁺ +2e ⁻ ↔ Zn	0.2-0.5	NA	100	60-75	30-85	30-60	-30 -+50°C	1	150-1000 725-1950	2000 5000 10,000	Mature?
Vanadium redox (VRB) ¹⁶	Negative electrode: V2+/V3+ Positive electrode: V4+/V5+ Electrolyte: Mild sulphuric acid solutions	0.25-0.33	NA	100	65-85	4-33	10-30	Ambient conditions	Small	150-1250	10,000+	Immature, a few examples worldwide
Nickel zinc ¹⁷	Water-based flow-assisted batteries.	2.78	NA	90	80	31.49	28.6		Low	700	5000	
Zinc manganese dioxide ¹⁷				90	80				Low	100-200	3000-5000	

Table A.1. (continued) Characteristics of storage technologies and cost estimations, incl. data sources

	Description	Power density (kW/kWh)		Healthy depth of discharge (%)	Round-trip efficiency (%)	Energy density		Operating temperature	Self-discharge (%/day)	Cost	Life time (cycles)	Commercial availability
		Continuously discharging power	Pulse power			(Wh/kg)	(Wh/l)			Capital cost (\$/kWh)		
Flywheel ¹⁸	To store energy mechanically in the form of kinetic energy by rotating a mass around an axis. In charging periods, the mass speeds up by electricity transformed by the motor. When discharging, the flywheel slows down.	4 56-160 ¹⁹	117	75-100 ²⁰	85-95	3-30 ²¹	10-80 ²¹	-20 ~ +40°C	20-100	1000-5000 ²²	10,000-25,000	Demo, few plants under construction
Super capacitor ²³	Make use of high surface area activated carbons as electrolyte solutions between two solid conductors	70-220	1524-2454	100	95	0.05-15	2-10	-40~+85°C	2-40	500-1000 30,000	10E4-10E8	Developing in transport applications
Compressed air energy storage (CAES) ²⁴	The energy is stored as the compressed air in tanks or underground geologic formations. When the demand turns to peak, the compressed air is released into a gas-fired turbine generator system.	0.002-1	-	70	42-54 65-95 ²⁵	30-60	3-6	-	0	2-430 ²⁶	5,000~20,000	Mature in conventional generation demo to increase efficiency and decrease size
Pumped hydro storage (PHS) ²⁷	To store energy by means of two reservoirs located at different elevations				75-85	0.5-1.5	0.5-1.5	-	0	5-100	20,000-50,000	Mature
Superconducting magnetic energy storage (SMES) ²⁷	Energy is to be stored in the magnetic field created by injecting a DC electric current into a superconducting coil				95	0.5-5	0.2-2.5	1.8-4.1K	10-15	1,000-10,000	10,000-100,000	Immature, few power quality applications

¹ Certain storage technologies can withstand so called pulse discharge modes at peak discharging power which is considerably higher than its normal (dis)charging power. Continuous discharging power here refers to the maximum continuously discharging power.

² Taken from Chen, et al. [1].

³ Taken from EOS Energy Storage [2].

⁴ Taken from Edberg and Naish [3].

⁵ Usually referred to the weight at the charged state (oxygen included). Taken from Naish, et al. [4].

⁶ Summarized from Chen, et al. [1,5-8], unless stated otherwise.

⁷ Taken from Naish, et al. [4].

⁸ Summarized from Chen, et al. [1, 5, 7, 9], unless stated otherwise.

⁹ Summarized from Chen, et al. [1, 5-7, 9-12], unless stated otherwise.

¹⁰ Available sources indicate that the healthy DoD is 80% for Li-ion batteries with one exception of 60%.

¹¹ The enlarged life cycles are achieved at 50% DoD and by strictly controlling (dis)charging processes.

¹² Summarized from Chen, et al. [1, 5-7, 12, 13], unless stated otherwise.

¹³ \$1100-2700/kWh is indicated by the NGK company. According to the NAS battery cost projection by NGK, the cost is expected to be reduced to \$140/kWh if massively produced (1600 MWh/year).

¹⁴ Summarized from Chen, et al. [1, 5].

¹⁵ Summarized from Chen, et al. [1, 5-7, 14, 15].

¹⁶ Summarized from Chen, et al. [1, 4-7, 12, 16, 17].

¹⁷ Personal communication, CUNY Energy Institute, NY.

¹⁸ Summarized from Chen, et al. [1, 4-7, 12, 18-21], unless stated otherwise.

¹⁹ The range reflects different flywheel models. The latest generation of flywheels using magnetic bearings and the ring, which increases the energy capacity of flywheel thus reduces the relative power density (kW/kWh). On the other hand, the model of the high power rating and the low energy capacity reflects the first generation of flywheels, which can be applied in the power quality regulation market.

²⁰ Conventional flywheels are limited to drop 59% of the maximum rator speed due to the industrial “fail-safe” standard, while the new generation can dump 100% of the maximum rator speed [22].

²¹ The high end in the range takes into account the integrated power conversion system, cooling system and pumped vacuum system while the low end reflects the energy density of the rator only.

²² A high speed flywheel costs as high as five times the manufacturing cost of a low speed flywheel.

²³ Summarized from Chen, et al. [1, 5, 7, 23].

²⁴ Summarized from Chen, et al. [1, 5, 7, 24].

²⁵ The round-trip efficiencies of CAES from literatures vary due to the different definitions used for the CAES round-trip efficiency. On the condition that the waste energy utilization is taken into account, the round-trip efficiency of CAES could be increased. The emerging CAES technology is claimed to be able to increase the efficiency from 40% to 70%. According to Ref. [24], the advanced CAES could be materialized by 2015.

²⁶ The costs of CAES system varies with different scales or kW capacities.

²⁷ Summarized from Chen, et al. [1, 5].

References (appendices)

- [1] H. Chen, T. N. Cong, W. Yang, C. Tan, Y. Li, and Y. Ding, Progress in electrical energy storage system: A critical review, Progress in Natural Science. **19**(3), 291-312(2009). <http://dx.doi.org/10.1016/j.pnsc.2008.07.014>.
- [2] Eos Energy Storage, http://www.eosenergystorage.com/download/Eos_Tech0611.pdf [accessed 12/21/2011].
- [3] O. Edberg, and C. Naish, Energy Storage and Management Study, ED47766- Issue 4, Prepared for the Scottish Government by AEA technology group, October 2010.
- [4] C. Naish, I. McCubbin, O. Edberg, and M. Harfoot, Outlook of Energy Storage Technologies, IP/A/ITRE/ST/2007-07, Prepared for the European Parliament's committee on Industry, Research and Energy, February 2008.
- [5] European Commission, 2011 Technology Map of the European Strategic Energy Technology Plan (SET-Plan), EUR 24979 EN, doi:10.2790/37519, European Commission, Joint Research Centre, Institute for Energy and Transport, 2011.
- [6] Electric Power Research Institute, Electric Energy Storage Technology Options: A Primer on Applications, Costs & Benefits - An EPRI Executive Summary, 1020676, Electric Power Research Institute (EPRI), December 2010.
- [7] S. M. Schoenung, and W. V. Hassenzahl, Long- vs. Short-Term Energy Storage Technologies Analysis A Life-Cycle Cost Study, SAND2003-2783, Sandia National Laboratories, August 2003.
- [8] ATBATT, Sealed Lead Acid Batteries, http://www.atbatt.com/sealed-lead-acid-batteries.asp?gclid=CLGR6ZG_i68CFQTd4AodwxekDg. [accessed 1/22/2014].
- [9] SAFT, High Energy Series Nickel-Cadmium VSE 4/5 A, http://saft.mussonmarine.com/pdf/VSE_4-5_A.pdf [accessed 1/22/2014].
- [10] Exide Technology, <http://www.gnb.com>. [accessed 12/21/2011].
- [11] Altairnano, <http://www.altairnano.com>. [accessed 1/22/2014].
- [12] S. Schoenung, Energy Storage Systems Cost Update, SAND2011-2730, Sandia National Laboratories, April 2011.
- [13] NGK Insulators LTD., NAS Batteries, <http://www.ngk.co.jp/english/products/power/nas/>. [accessed 1/22/2014].
- [14] ZBB Energy Corporation, Advanced Energy Storage, <http://www.zbbenergy.com/products/flow-battery/>. [accessed 1/22/2014].
- [15] Red flow Advanced Energy Storage, ZBM Brochure, <http://redflow.com/redflowproducts/zbm-overview/>. [accessed 1/22/2014].
- [16] REDT Renewable Energy Storage, Key Features of the REDT Renewable Energy Storage System, <http://www.redtenergy.com/energystorageproducts>. [accessed 1/22/2014].
- [17] Cell cube-the battery system of the system, <http://en.cellcube.com>. [accessed 1/22/2014].
- [18] Beacon Power Corporation, BHE-6 Series Flywheel Energy Storage System Product Specification, <http://istochnik-13.narod.ru/head/eab/flywheel6.pdf>. [accessed 1/22/2014].
- [19] Active Power, <http://www.activepower.com/>. [accessed 1/22/2014].

- [20] Flywheel energy system Inc., Performance Verification of a Flywheel Energy Storage System for Heavy Hybrid Vehicles, <http://www.flywheelenergysystems.com/Downloads/2010-0121%20Performance%20verification.pdf>. [accessed 1/22/2014].
- [21] J. Eyer, and G. Corey, Energy Storage for the Electricity Grid: Benefits and Market Potential Assessment Guide, SAND2010-0815, Sandia National Laboratories, February 2010.
- [22] F. N. Werfel, U. Floegel-Delor, T. Riedel, R. Rothfeld, D. Wippich, B. Goebel, et al., Towards High-Capacity HTS Flywheel Systems, Applied Superconductivity, IEEE Transactions on. **20**(4), 2272-5(2010).
<http://dx.doi.org/10.1109/tasc.2010.2048708>.
- [23] Maxwell Technologies Enabling Energy's Future, Ultracapacitor Downloads, <http://www.maxwell.com/products/ultracapacitors/downloads>. [accessed 1/22/2014].
- [24] P. Agrawal, A. Nourai, L. Markel, R. Fioranvanti, P. Gordon, N. Tong, et al., Characterization and Assessment of Novel Bulk Storage Technologies, SAND2011-3700, Sandia National Laboratories, May 2011.

Appendix B. Demand profile model testing results**Table B.1.** Testing results of the appliance demand profile model

		Single day					Converged day													
		Operating parameters				RS E M ²⁸	Duty cycles per year			Daily electricity consumption						RSE M ²⁹	Power draw on first/last minute			Overall shape of the demand profile
		Max. power	Min. power	Cycle length			From simulations	Expected	Relative error	From simulations	Expected	Relative error	E_{peak}	$E_{off\ peak}$	$E_{peak}/E_{off\ peak}$		P(1)	P(14 40)	Relative error	
		(W)	(W)	(min)						(Wh)	(Wh)		(Wh)	(Wh)			(W)	(W)		
Individual appliance	Dishwasher	1457	0	54	OK	5%	344	365	-5.81%	653	692.8	-5.81%	497	156	3.20	12%	5.5	6.6	-17.86%	OK
	Microwave oven	1500	0	6	OK	5%	1171	1133	3.30%	481	466	3.30%	314	168	1.87	50%	0.3	0.5	-42.86%	OK
	Toaster oven	1400	0	20	OK	5%	112	111	1.16%	144	142	1.16%	90	54	1.67	100%	0.1	0.1	0%	OK
	Refrigerator	250	0	20	OK	2%	12087	12089	-0.02%	2760	2760	-0.01%	1393	1367	1.02	5%	115	108	6%	OK
	Freezer	155	0	20	OK	0%	21699	21681	0.08%	3072	3069	0.09%	1538	1534	1.00	5%	122	129	-5%	OK
	Lighting-Bathroom	317	0	31	OK	5%	920	989	-7.00%	413	444	-7.00%	185	227	0.81	6%	10.1	10.5	-4%	OK
	Lighting-Bedroom	200	0	60	OK	5%	623	621	0.35%	341	340	0.35%	190	151	1.26	7%	4.5	4.5	-1%	NOT YET
	Lighting-Living room	256	0	60	OK	5%	816	840	-2.75%	573	589	-2.75%	328	244	1.35	5%	8.4	8.5	-1%	NOT YET
	Lighting-Dining room	235	0	30	OK	5%	1336	1387	-3.68%	430	447	-3.68%	295	135	2.18	12%	1.7	1.7	1%	OK
	Lighting-Hallways	207	0	15	OK	5%	1705	1752	-2.71%	242	248	-2.71%	136	105	1.30	11%	1.8	1.8	0%	NOT YET
	Lighting-Kitchen	250	0	32	OK	5%	1650	1711	-3.57%	603	625	-3.57%	391	211	1.85	14%	1.3	1.3	-2%	OK
	Clothes dryer	2895	0	60	OK	5%	353	359	-1.60%	2802	2847	-1.60%	1775	1026	1.73	13%	16.2	16.5	-2%	OK
	Clothes washer	2150	0	48	OK	5%	388	392	-1.09%	822	831	-1.09%	500	322	1.55	21%	4.1	4.5	-9%	OK
	Television	185	0	115	OK	5%	704	752	-6.30%	684	730	-6.30%	489	195	2.51	5%	21.9	22.3	-2%	OK
	Air conditioning	3500	0	10	OK	1%	5270	5520	-4.53%	33414	30667	8.96%	20879	12535	1.67	5%	1335	1405	-5%	OK?
	Space heater	1447	0	60	OK	2%	1465	1476	-0.71%	17432	17364	0.39%	8757	8676	1.01	5%	683	677	1%	OK
Vacuum	1440	0	35	OK	5%	63	63	-0.12%	146	146	-0.12%	89	57	1.55	19%	1.3	0.6	132%	OK	
	Computers and other rechargeable electronic devices	100	100	1440	OK	0%	365	365	0.00%	2400	2400	0.00%	1200	1200	1.00	0%	100	100	0%	OK
Whole household																				
	Summer	12207	100	-	OK	2%	-	-		50306	57392 ³⁰	-	30235	20071	1.51	5%	1829	1797	2%	
	Winter	9003	100	-	OK	2%	-	-		33705	-	-	17862	15843	1.13	5%	1111	1115	0%	
	Spring or fall	8242	100	-	OK	3%	-	-		16259	-	-	9348	6911	1.35	5%	419	420	0%	NA
	Average day						-		30586	31011 ³¹	-1%	17408								

²⁸ RSEM denotes the relative standard deviation of the mean. Here, the RSEM is the maximum RSEM among RESMs of fully cycles per year, daily electricity consumption, electricity consumption during peak hours and electricity consumption during off-peak hours.

²⁹ Here, RSEM is the larger one between RSEM of the power draw at the first minute of the day and RSEM of the power draw at the last minute of the day.

³⁰ The average daily electricity consumption for summer days is obtained from Pecan Street Research Institute, <http://www.pecanstreet.org/>. [accessed 5/13/2013].

³¹ The average daily electricity consumption per household in U.S. is obtained from U.S. Energy Information Administration, 2009 Residential Energy Consumption Survey (RECS) Data Table CE2.1 Fuel Consumption Totals and Averages, U.S. Homes, U.S. Energy Information Administration. <http://www.eia.gov/consumption/residential/data/2009/index.cfm?view=consumption#fuel-consumption>. [accessed 1/22/2014].