AUTHENTICATED
U.S. GOVERNMENT
INFORMATION
GPO

(f)(1) Compare the sample mean to the control limit.

(i) The basic model is in compliance and testing is at an end if:

(A) For an energy or water efficiency standard, the sample mean is equal to or greater than the lower control limit, or

(B) For an energy or water consumption standard, the sample mean is equal to or less than the upper control limit.

APPENDIX C TO SUBPART C OF PART 429—SAMPLING PLAN FOR ENFORCEMENT TESTING OF DISTRIBUTION TRANSFORMERS

(a) When testing distribution transformers, the number of units in the sample (m_1) shall be in accordance with §429.47(a) and DOE shall perform the following number of tests:

(1) If DOE tests four or more units, it will test each unit once;

(2) If DOE tests two or three units, it will test each unit twice; or

(3) If DOE tests one unit, it will test that unit four times.

(b) DOE shall determine compliance as follows:

(1) Compute the mean (X_1) of the measured energy performance of the n_1 tests in the first sample as follows:

$$X_1 = \frac{1}{n_1}\sum_{i=1}^{n_1} X_i \qquad [1]$$

where X_i is the measured efficiency of test i.

(2) Compute the sample standard deviation (S_1) of the measured efficiency of the n_1 tests in the first sample as follows:

$$S_1 = \sqrt{\sum_{i=1}^{n_1} \frac{(X_i - X_1)^2}{n_1 - 1}} \qquad [2]$$

(3) Compute the standard error ($SE(X_1)$) of the mean efficiency of the first sample as follows:

$$SE(X_1) = \frac{S_1}{\sqrt{n_1}} \qquad [3]$$

(4) Compute the sample size discount ($SSD(m_1)$) as follows:

$$SSD(m_1) = \frac{100}{1 + \left(1 + \frac{0.08}{\sqrt{m_1}}\right)\left(\frac{100}{RE} - 1\right)} \qquad [4]$$

where m_1 is the number of units in the sample, and RE is the applicable DOE efficiency when the test is to determine compliance with the applicable energy conservation standard, or is the labeled efficiency when the test is to determine compliance with the labeled efficiency value.

(5) Compute the lower control limit (LCL_1) for the mean of

$$LCL_1 = SSD(m_1) - tSE(\bar{X}_1) \qquad [5]$$

Where t is statistic based on a 97.5 percent one-tailed t test with degrees of freedom (from Appendix A) $n_1 - 1$.

(6) Compare the mean of the first sample (X_1) with the lower control limit (LCL_1) to determine one of the following:

(i) If the mean of the first sample is below the lower control limit, then the basic model is not compliant and testing is at an end.

(ii) If the mean is equal to or greater than the lower control limit, no final determination of compliance or noncompliance can be made; proceed to Step (7).

(7) Determine the recommended sample size (n) as follows:

$$n = \left[\frac{tS_1(108 - 0.08RE)}{RE(8 - 0.08RE)}\right]^2 \qquad [6]$$

Given the value of n, determine one of the following:

(i) If the value of n is less than or equal to n_1 and if the mean energy efficiency of the first sample (X_1) is equal to or greater than the lower control limit (LCL_1), the basic model is in compliance and testing is at an end.

(ii) If the value of n is greater than n_1, the basic model is not compliant. The size of a second sample n_2 is determined to be the smallest integer equal to or greater than the difference $n - n_1$. If the value of n_2 so calculated is greater than $21 - n_1$, set n_2 equal to $21 - n_1$.

(8) Compute the combined (X_2) mean of the measured energy performance of the n_1 and n_2 units of the combined first and second samples as follows:

$$\bar{X}_2 = \frac{1}{n_1 + n_2} \sum_{i=1}^{n_1+n_2} X_i \qquad [7]$$

(9) Compute the standard error ($SE(X_2)$) of the mean full-load efficiency of the n_1 and n_2 units in the combined first and second samples as follows:

$$SE(\bar{X}_2) = \frac{S_1}{\sqrt{n_1 + n_2}} \qquad [8]$$

(Note that S_1 is the value obtained above in (2).)

(10) Set the lower control limit (LCL_2) to,

$$LCL_2 = SSD(m_1) - tSE(\bar{X}_2) \quad [9]$$

where t has the value obtained in (5) and $SSD(m_1)$ is sample size discount determined in (4), and compare the combined sample mean (X_2) to the lower control limit (LCL_2) to determine one of the following:

(i) If the mean of the combined sample (X_2) is less than the lower control limit (LCL_2), the basic model is not compliant and testing is at an end.

(ii) If the mean of the combined sample (X_2) is equal to or greater than the lower control limit (LCL_2), the basic model is in compliance and testing is at an end.

[76 FR 12451, Mar. 7, 2011; 76 FR 24781, May 2, 2011]

APPENDIX D TO SUBPART C OF PART 429—SAMPLING PLAN FOR ENFORCEMENT TESTING OF UNINTERRUPTIBLE POWER SUPPLIES

(a) The minimum sample size for enforcement testing will be one unit.

(b) Compute the average load adjusted efficiency (Eff_{avg}) of the unit in the sample.

(c) Determine the applicable DOE energy efficiency standard (EES).

(d) If all Eff_{avg} are equal to or greater than EES, then the basic model is in compliance and testing is at an end.

(e) If any Eff_{avg} is less than EES, then the basic model is in noncompliance and testing is at an end.

[81 FR 89822, Dec. 12, 2016]

PART 430—ENERGY CONSERVATION PROGRAM FOR CONSUMER PRODUCTS

Subpart A—General Provisions

Sec.

430.1 Purpose and scope.
430.2 Definitions.
430.3 Materials incorporated by reference.
430.4 Sources for information and guidance.
430.5 Error correction procedures for energy conservation standards rules.

Subpart B—Test Procedures

430.21 Purpose and scope.
430.23 Test procedures for the measurement of energy and water consumption.
430.24 [Reserved]
430.25 Laboratory Accreditation Program.
430.27 Petitions for waiver and interim waiver.

APPENDIX A TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF REFRIGERATORS, REFRIGERATOR-FREEZERS, AND MISCELLANEOUS REFRIGERATION PRODUCTS

APPENDIX B TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF FREEZERS

APPENDIX C1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF DISHWASHERS

APPENDIX C2 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF DISHWASHERS

APPENDIX D1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CLOTHES DRYERS

APPENDIX D2 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CLOTHES DRYERS

APPENDIX E TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF WATER HEATERS

APPENDIX F TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF ROOM AIR CONDITIONERS

APPENDIX G TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF UNVENTED HOME HEATING EQUIPMENT

APPENDIX H TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE POWER CONSUMPTION OF TELEVISION SETS

APPENDIX I TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF MICROWAVE OVENS

APPENDIX I1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CONVENTIONAL COOKING PRODUCTS

APPENDIX J TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF AUTOMATIC AND SEMI-AUTOMATIC CLOTHES WASHERS

APPENDIX J1 TO SUBPART B OF PART 430 [RESERVED]

APPENDIX J2 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF AUTOMATIC AND SEMI-AUTOMATIC CLOTHES WASHERS

APPENDIX J3 TO SUBPART B OF PART 430—ENERGY TEST CLOTH SPECIFICATIONS AND PROCEDURES FOR DETERMINING CORRECTION COEFFICIENTS OF NEW ENERGY TEST CLOTH LOTS

APPENDIXES K–L TO SUBPART B OF PART 430 [RESERVED]

APPENDIX M TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CENTRAL AIR CONDITIONERS AND HEAT PUMPS
APPENDIX M1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CENTRAL AIR CONDITIONERS AND HEAT PUMPS
APPENDIX N TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CONSUMER FURNACES OTHER THAN BOILERS
APPENDIX O TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF VENTED HOME HEATING EQUIPMENT
APPENDIX P TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF POOL HEATERS
APPENDIX Q TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF FLUORESCENT LAMP BALLASTS
APPENDIX R TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING ELECTRICAL AND PHOTOMETRIC CHARACTERISTICS OF GENERAL SERVICE FLUORESCENT LAMPS, INCANDESCENT REFLECTOR LAMPS, AND GENERAL SERVICE INCANDESCENT LAMPS
APPENDIX S TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE WATER CONSUMPTION OF FAUCETS AND SHOWERHEADS
APPENDIX T TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE WATER CONSUMPTION OF WATER CLOSETS AND URINALS
APPENDIX U TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CEILING FANS
APPENDIX V TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CEILING FAN LIGHT KITS PACKAGED WITH OTHER FLUORESCENT LAMPS (NOT COMPACT FLUORESCENT LAMPS OR GENERAL SERVICE FLUORESCENT LAMPS), PACKAGED WITH CONSUMER-REPLACEABLE SSL (NOT INTEGRATED LED LAMPS), PACKAGED WITH NON-CONSUMER-REPLACEABLE SSL, OR PACKAGED WITH OTHER SSL LAMPS THAT HAVE AN ANSI STANDARD BASE (NOT INTEGRATED LED LAMPS)
APPENDIX W TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF COMPACT FLUORESCENT LAMPS
APPENDIX X TO SUBPART B OF PART 430 [RESERVED]
APPENDIX X1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF DEHUMIDIFIERS
APPENDIX Y TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF BATTERY CHARGERS
APPENDIX Y1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF BATTERY CHARGERS
APPENDIX Z TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF EXTERNAL POWER SUPPLIES
APPENDIX AA TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF FURNACE FANS
APPENDIX BB TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE INPUT POWER, LUMEN OUTPUT, LAMP EFFICACY, CORRELATED COLOR TEMPERATURE (CCT), COLOR RENDERING INDEX (CRI), POWER FACTOR, TIME TO FAILURE, AND STANDBY MODE POWER OF INTEGRATED LIGHT-EMITTING DIODE (LED) LAMPS
APPENDIX CC TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF PORTABLE AIR CONDITIONERS
APPENDIX CC1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF PORTABLE AIR CONDITIONERS
APPENDIX DD TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION AND ENERGY EFFICIENCY OF GENERAL SERVICE LAMPS THAT ARE NOT GENERAL SERVICE INCANDESCENT LAMPS, COMPACT FLUORESCENT LAMPS, OR INTEGRATED LED LAMPS
APPENDIX EE TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CONSUMER BOILERS
APPENDIX FF TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF AIR CLEANERS
APPENDIX GG TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF PORTABLE ELECTRIC SPAS

Subpart C—Energy and Water Conservation Standards

430.31 Purpose and scope.
430.32 Energy and water conservation standards and their compliance dates.
430.33 Preemption of State regulations.
430.34 Energy and water conservation standards amendments.
430.35 Petitions with respect to general service lamps.
APPENDIX A TO SUBPART C OF PART 430—PROCEDURES, INTERPRETATIONS, AND POLICIES FOR CONSIDERATION OF NEW OR REVISED ENERGY CONSERVATION STANDARDS AND

TEST PROCEDURES FOR CONSUMER PRODUCTS AND CERTAIN COMMERCIAL/INDUSTRIAL EQUIPMENT

Subpart D—Petitions To Exempt State Regulation From Preemption; Petitions To Withdraw Exemption of State Regulation

430.40 Purpose and scope.
430.41 Prescriptions of a rule.
430.42 Filing requirements.
430.43 Notice of petition.
430.44 Consolidation.
430.45 Hearing.
430.46 Disposition of petitions.
430.47 Effective dates of final rules.
430.48 Request for reconsideration.
430.49 Finality of decision.

Subpart E—Small Business Exemptions

430.50 Purpose and scope.
430.51 Eligibility.
430.52 Requirements for applications.
430.53 Processing of applications.
430.54 Referral to the Attorney General.
430.55 Evaluation of application.
430.56 Decision and order.
430.57 Duration of temporary exemption.

Subpart F [Reserved]

AUTHORITY: 42 U.S.C. 6291–6309; 28 U.S.C. 2461 note.

SOURCE: 42 FR 27898, June 1, 1977, unless otherwise noted.

Subpart A—General Provisions

§ 430.1 Purpose and scope.

This part establishes the regulations for the implementation of part B of title III (42 U.S.C. 6291–6309) of the Energy Policy and Conservation Act (Pub. L. 94–163), as amended by Pub. L. 95–619, Pub. L. 100–12, Pub. L. 100–357, and Pub. L. 102–486 which establishes an energy conservation program for consumer products other than automobiles.

[62 FR 29237, May 29, 1997]

§ 430.2 Definitions.

For purposes of this part, words shall be defined as provided for in section 321 of the Act and as follows—

3-Way incandescent lamp means an incandescent lamp that—

(1) Employs two filaments, operated separately and in combination, to provide three light levels; and

(2) Is designated on the lamp packaging and marketing materials as being a 3-way incandescent lamp.

700 series fluorescent lamp means a fluorescent lamp with a color rendering index (measured according to the test procedures outlined in Appendix R to subpart B of this part) that is in the range (inclusive) of 70 to 79.

Act means the Energy Policy and Conservation Act of 1975, as amended, 42 U.S.C. 6291–6316.

Activation lock means a control mechanism (either by a physical device directly on the water heater or a control system integrated into the water heater) that is locked by default and contains a physical, software, or digital communication that must be activated with an activation key to enable to the product to operate at its designed specifications and capabilities and without which the activation of the product will provide not greater than 50 percent of the rated first hour delivery of hot water certified by the manufacturer.

Active mode means the condition in which an energy-using product—

(1) Is connected to a main power source;

(2) Has been activated; and

(3) Provides one or more main functions.

Air cleaner means a product for improving indoor air quality, other than a central air conditioner, room air conditioner, portable air conditioner, dehumidifier, or furnace, that is an electrically-powered, self-contained, mechanically encased assembly that contains means to remove, destroy, or deactivate particulates, VOC, and/or microorganisms from the air. It excludes products that operate solely by means of ultraviolet light without a fan for air circulation.

All-refrigerator means a refrigerator that does not include a compartment capable of maintaining compartment temperatures below 32 °F (0 °C) as determined according to the provisions in § 429.14(d)(2) of this chapter. It may include a compartment of 0.50 cubic-foot capacity (14.2 liters) or less for the freezing and storage of ice.

Annual fuel utilization efficiency means the efficiency descriptor for furnaces and boilers, determined using

test procedures prescribed under section 323 and based on the assumption that all—

(1) Weatherized warm air furnaces or boilers are located out-of-doors;

(2) Warm air furnaces which are not weatherized are located indoors and all combustion and ventilation air is admitted through grill or ducts from the outdoors and does not communicate with air in the conditioned space;

(3) Boilers which are not weatherized are located within the heated space.

ANSI means the American National Standards Institute.

Appliance lamp means any lamp that—

(1) Is specifically designed to operate in a household appliance and has a maximum wattage of 40 watts (including an oven lamp, refrigerator lamp, and vacuum cleaner lamp); and

(2) When sold at retail, is designated and marketed for the intended application, with

(i) The designation on the lamp packaging; and

(ii) Marketing materials that identify the lamp as being for appliance use.

ASME means the American Society of Mechanical Engineers.

Automatic clothes washer means a class of clothes washer which has a control system which is capable of scheduling a preselected combination of operations, such as regulation of water temperature, regulation of the water fill level, and performance of wash, rinse, drain, and spin functions without the need for user intervention subsequent to the initiation of machine operation. Some models may require user intervention to initiate these different segments of the cycle after the machine has begun operation, but they do not require the user to intervene to regulate the water temperature by adjusting the external water faucet valves.

Back-up battery charger means a battery charger excluding UPSs:

(1) That is embedded in a separate end-use product that is designed to continuously operate using mains power (including end-use products that use external power supplies); and

(2) Whose sole purpose is to recharge a battery used to maintain continuity of power in order to provide normal or partial operation of a product in case of input power failure.

Ballast means a device used with an electric discharge lamp to obtain necessary circuit conditions (voltage, current, and waveform) for starting and operating.

Ballast efficacy factor means the relative light output divided by the power input of a fluorescent lamp ballast, as measured under test conditions specified in ANSI Standard C82.2–1984.

Ballast luminous efficiency means the total fluorescent lamp arc power divided by the fluorescent lamp ballast input power multiplied by the appropriate frequency adjustment factor, as defined in appendix Q of subpart B of this part.

Baseboard electric heater means an electric heater which is intended to be recessed in or surface mounted on walls at floor level, which is characterized by long, low physical dimensions, and which transfers heat by natural convection and/or radiation.

Basic model means all units of a given type of covered product (or class thereof) manufactured by one manufacturer; having the same primary energy source; and, which have essentially identical electrical, physical, and functional (or hydraulic) characteristics that affect energy consumption, energy efficiency, water consumption, or water efficiency; and

(1) With respect to general service fluorescent lamps, general service incandescent lamps, and incandescent reflector lamps: Lamps that have essentially identical light output and electrical characteristics—including lamp efficacy and color rendering index (CRI).

(2) With respect to faucets and showerheads: Have the identical flow control mechanism attached to or installed within the fixture fittings, or the identical water-passage design features that use the same path of water in the highest flow mode.

(3) With respect to furnace fans: Are marketed and/or designed to be installed in the same type of installation; and

(4) With respect to central air conditioners and central air conditioning

heat pumps essentially identical electrical, physical, and functional (or hydraulic) characteristics means:

(i) For split systems manufactured by outdoor unit manufacturers (OUMs): all individual combinations having the same model of outdoor unit, which means comparably performing compressor(s) [a variation of no more than five percent in displacement rate (volume per time) as rated by the compressor manufacturer, and no more than five percent in capacity and power input for the same operating conditions as rated by the compressor manufacturer], outdoor coil(s) [no more than five percent variation in face area and total fin surface area; same fin material; same tube material], and outdoor fan(s) [no more than ten percent variation in air flow and no more than twenty percent variation in power input];

(ii) For split systems having indoor units manufactured by independent coil manufacturers (ICMs): all individual combinations having comparably performing indoor coil(s) [plus or minus one square foot face area, plus or minus one fin per inch fin density, and the same fin material, tube material, number of tube rows, tube pattern, and tube size]; and

(iii) For single-package systems: all individual models having comparably performing compressor(s) [no more than five percent variation in displacement rate (volume per time) rated by the compressor manufacturer, and no more than five percent variations in capacity and power input rated by the compressor manufacturer corresponding to the same compressor rating conditions], outdoor coil(s) and indoor coil(s) [no more than five percent variation in face area and total fin surface area; same fin material; same tube material], outdoor fan(s) [no more than ten percent variation in outdoor air flow], and indoor blower(s) [no more than ten percent variation in indoor air flow, with no more than twenty percent variation in fan motor power input];

(iv) Except that,

(A) for single-package systems and single-split systems, manufacturers may instead choose to make each individual model/combination its own basic model provided the testing and represented value requirements in 10 CFR 429.16 of this chapter are met; and

(B) For multi-split, multi-circuit, and multi-head mini-split combinations, a basic model may not include both individual small-duct, high velocity (SDHV) combinations and non-SDHV combinations even when they include the same model of outdoor unit. The manufacturer may choose to identify specific individual combinations as additional basic models.

Basic-voltage external power supply means an external power supply that is not a low-voltage external power supply.

Batch means a collection of production units of a basic model from which a batch sample is selected.

Batch sample means the collection of units of the same basic model from which test units are selected.

Batch sample size means the number of units in a batch sample.

Batch size means the number of units in a batch.

Battery charger means a device that charges batteries for consumer products, including battery chargers embedded in other consumer products.

Black light lamp means a lamp that is designed and marketed as a black light lamp and is an ultraviolet lamp with the highest radiant power peaks in the UV–A band (315 to 400 nm) of the electromagnetic spectrum.

Blowout action means a means of flushing a water closet whereby a jet of water directed at the bowl outlet opening pushes the bowl contents into the upleg, over the weir, and into the gravity drainage system.

Blowout bowl means a non-siphonic water closet bowl with an integral flushing rim, a trap at the rear of the bowl, and a visible or concealed jet that operates with a blowout action.

BPAR incandescent reflector lamp means a reflector lamp as shown in figure C78.21–278 of ANSI C78.21–2016 (incorporated by reference; see § 430.3).

BR30 means a BR incandescent reflector lamp with a diameter of 30/8ths of an inch.

BR40 means a BR incandescent reflector lamp with a diameter of 40/8ths of an inch.

BR incandescent reflector lamp means a reflector lamp that has a bulged section below the bulb's major diameter and above its approximate base line as shown in Figure 1 (RB) of ANSI C78.79–2020. A BR30 lamp has a lamp wattage of 85 or less than 66 and a BR40 lamp has a lamp wattage of 120 or less.

Btu means British thermal unit, which is the quantity of heat required to raise the temperature of one pound of water one degree Fahrenheit.

Bug lamp means a lamp that is designed and marketed as a bug lamp, has radiant power peaks above 550 nm on the electromagnetic spectrum, and has a visible yellow coating.

Built-in compact cooler means any cooler with a total refrigerated volume less than 7.75 cubic feet and no more than 24 inches in depth, excluding doors, handles, and custom front panels, that is designed, intended, and marketed exclusively to be:

(1) Installed totally encased by cabinetry or panels that are attached during installation;

(2) Securely fastened to adjacent cabinetry, walls or floor;

(3) Equipped with unfinished sides that are not visible after installation; and

(4) Equipped with an integral factory-finished face or built to accept a custom front panel.

Built-in cooler means any cooler with a total refrigerated volume of 7.75 cubic feet or greater and no more than 24 inches in depth, excluding doors, handles, and custom front panels; that is designed, intended, and marketed exclusively to be:

(1) Installed totally encased by cabinetry or panels that are attached during installation;

(2) Securely fastened to adjacent cabinetry, walls or floor;

(3) Equipped with unfinished sides that are not visible after installation; and

(4) Equipped with an integral factory-finished face or built to accept a custom front panel.

Built-in refrigerator/refrigerator-freezer/freezer means any refrigerator, refrigerator-freezer or freezer with 7.75 cubic feet or greater total volume and 24 inches or less depth not including doors, handles, and custom front panels; with sides which are not finished and not designed to be visible after installation; and that is designed, intended, and marketed exclusively (1) To be installed totally encased by cabinetry or panels that are attached during installation, (2) to be securely fastened to adjacent cabinetry, walls or floor, and (3) to either be equipped with an integral factory-finished face or accept a custom front panel.

Candelabra base incandescent lamp means a lamp that uses a candelabra screw base as described in ANSI C81.61, Specifications for Electric Bases, common designations E11 and E12 (incorporated by reference; see § 430.3).

Casement-only means a room air conditioner designed for mounting in a casement window with an encased assembly with a width of 14.8 inches or less and a height of 11.2 inches or less.

Casement-slider means a room air conditioner with an encased assembly designed for mounting in a sliding or casement window with a width of 15.5 inches or less.

Ceiling electric heater means an electric heater which is intended to be recessed in, surface mounted on, or hung from a ceiling, and which transfers heat by radiation and/or convection (either natural or forced).

Ceiling fan means a nonportable device that is suspended from a ceiling for circulating air via the rotation of fan blades. For the purpose of this definition:

(1) Circulating air means the discharge of air in an upward or downward direction. A ceiling fan that has a ratio of fan blade span (in inches) to maximum rotation rate (in revolutions per minute) greater than 0.06 provides circulating air.

(2) For all other ceiling fan related definitions, see appendix U to this subpart.

Ceiling fan light kit means equipment designed to provide light from a ceiling fan that can be—

(1) Integral, such that the equipment is attached to the ceiling fan prior to the time of retail sale; or

(2) Attachable, such that at the time of retail sale the equipment is not physically attached to the ceiling fan, but may be included inside the ceiling

fan at the time of sale or sold separately for subsequent attachment to the fan.

Central air conditioner or central air conditioning heat pump means a product, other than a packaged terminal air conditioner, packaged terminal heat pump, single-phase single-package vertical air conditioner with cooling capacity less than 65,000 Btu/h, single-phase single-package vertical heat pump with cooling capacity less than 65,000 Btu/h, computer room air conditioner, or unitary dedicated outdoor air system as these equipment categories are defined at 10 CFR 431.92, which is powered by single phase electric current, air cooled, rated below 65,000 Btu per hour, not contained within the same cabinet as a furnace, the rated capacity of which is above 225,000 Btu per hour, and is a heat pump or a cooling unit only. A central air conditioner or central air conditioning heat pump may consist of: A single-package unit; an outdoor unit and one or more indoor units; an indoor unit only; or an outdoor unit with no match. In the case of an indoor unit only or an outdoor unit with no match, the unit must be tested and rated as a system (combination of both an indoor and an outdoor unit). For all central air conditioner and central air conditioning heat pump-related definitions, see appendix M or M1 of subpart B of this part.

Central system humidifier means a class of humidifier designed to add moisture into the air stream of a heating system.

Circulating water heater means a water heater that does not have an operational scheme in which the burner, heating element, or compressor initiates and/or terminates heating based on sensing flow; has a water temperature sensor located at the inlet or the outlet of the water heater or in a separate storage tank that is the primary means of initiating and terminating heating; and must be used in combination with a recirculating pump to circulate water and either a separate storage tank or water circulation loop in order to achieve the water flow and temperature conditions recommended in the manufacturer's installation and operation instructions. A circulating water heater constitutes a storage-type water heater.

Class A external power supply—

(1) Means a device that—

(i) Is designed to convert line voltage AC input into lower voltage AC or DC output;

(ii) Is able to convert to only one AC or DC output voltage at a time;

(iii) Is sold with, or intended to be used with, a separate end-use product that constitutes the primary load;

(iv) Is contained in a separate physical enclosure from the end-use product;

(v) Is connected to the end-use product via a removable or hard-wired male/female electrical connection, cable, cord, or other wiring; and

(vi) Has nameplate output power that is less than or equal to 250 watts;

(2) But, does not include any device that—

(i) Requires Federal Food and Drug Administration listing and approval as a medical device in accordance with section 513 of the Federal Food, Drug, and Cosmetic Act (21 U.S.C. 360(c)); or

(ii) Powers the charger of a detachable battery pack or charges the battery of a product that is fully or primarily motor operated.

Clothes washer means a consumer product designed to clean clothes, utilizing a water solution of soap and/or detergent and mechanical agitation or other movement, and must be one of the following classes: automatic clothes washers, semi-automatic clothes washers, and other clothes washers.

Cold temperature fluorescent lamp means a fluorescent lamp specifically designed to start at −20 °F when used with a ballast conforming to the requirements of ANSI C78.81 (incorporated by reference; see §430.3) and ANSI C78.901 (incorporated by reference; see §430.3), and is expressly designated as a cold temperature lamp both in markings on the lamp and in marketing materials, including catalogs, sales literature, and promotional material.

Color Rendering Index or CRI means the measured degree of color shift objects undergo when illuminated by a light source as compared with the color of those same objects when illuminated

by a reference source of comparable color temperature.

Colored fluorescent lamp means a fluorescent lamp designated and marketed as a colored lamp and not designed or marketed for general illumination applications with either of the following characteristics:

(1) A CRI less than 40, as determined according to the method set forth in CIE Publication 13.3 (incorporated by reference; *see* § 430.3); or

(2) A correlated color temperature less than 2,500K or greater than 7,000K as determined according to the method set forth in IES LM–9 (incorporated by reference; *see* § 430.3).

Colored incandescent lamp means an incandescent lamp designated and marketed as a colored lamp that has—

(1) A color rendering index of less than 50, as determined according to the test method given in CIE 13.3 (incorporated by reference; see § 430.3); or

(2) A correlated color temperature of less than 2,500K, or greater than 4,600K, where correlated temperature is computed according to the ''Computation of Correlated Color Temperature and Distribution Temperature,'' Journal of the Optical Society of America, (incorporated by reference; see § 430.3).

Colored lamp means a colored fluorescent lamp, a colored incandescent lamp, or a lamp designed and marketed as a colored lamp with either of the following characteristics (if multiple modes of operation are possible [such as variable CCT], either of the below characteristics must be maintained throughout all modes of operation):

(1) A CRI less than 40, as determined according to the method set forth in CIE 13.3 (incorporated by reference; see § 430.3); or

(2) A CCT less than 2,500 K or greater than 7,000 K.

Combination cooler refrigeration product means any cooler-refrigerator, cooler-refrigerator-freezer, or cooler-freezer.

Combined-duct portable air conditioner means a portable air conditioner for which condenser inlet and outlet air streams flow through separate ducts housed in a single duct structure.

Commercial and industrial power supply means a power supply that is used to convert electric current into DC or lower-voltage AC current, is not distributed in commerce for use with a consumer product, and may include any of the following characteristics:

(1) A power supply that requires 3-phase input power and that is incapable of operating on household mains electricity;

(2) A DC–DC-only power supply that is incapable of operating on household mains electricity;

(3) A power supply with a fixed, non-removable connection to an end-use device that is not a consumer product as defined under the Act;

(4) A power supply whose output connector is uniquely shaped to fit only an end-use device that is not a consumer product;

(5) A power supply that cannot be readily connected to an end-use device that is a consumer product without significant modification or customization of the power supply itself or the end-use device;

(6) A power supply packaged with an end-use device that is not a consumer product, as evidenced by either:

(i) Such device being certified as, or declared to be in conformance with, a specific standard applicable only to non-consumer products. For example, a power supply model intended for use with an end-use device that is certified to the following standards would not meet the EPCA definition of an EPS:

(A) CISPR 11 (Class A Equipment), ''Industrial, scientific and medical equipment—Radio-frequency disturbance—Limits and methods of measurement'';

(B) UL 1480A, ''Standard for Speakers for Commercial and Professional Use'';

(C) UL 813, ''Standard for Commercial Audio Equipment''; and

(D) UL 1727, ''Standard for Commercial Electric Personal Grooming Appliances''; or

(ii) Such device being excluded or exempted from inclusion within, or conformance with, a law, regulation, or broadly-accepted industry standard where such exclusion or exemption applies only to non-consumer products;

(7) A power supply distributed in commerce for use with an end-use device where:

(i) The end-use device is not a consumer product, as evidenced by either

the circumstances in paragraph (6)(i) or (ii) of this definition; and

(ii) The end-use device for which the power supply is distributed in commerce is reasonably disclosed to the public, such as by identification of the end-use device on the packaging for the power supply, documentation physically present with the power supply, or on the manufacturer's or private labeler's public website; or

(8) A power supply that is not marketed for residential or consumer use, and that is clearly marked (or, alternatively, the packaging of the individual power supply, the shipping container of multiple such power supplies, or associated documentation physically present with the power supply when distributed in commerce is clearly marked) ''FOR USE WITH COMMERCIAL OR INDUSTRIAL EQUIPMENT ONLY'' or ''NOT FOR RESIDENTIAL OR CONSUMER USE,'' with the marking designed and applied so that the marking will be visible and legible during customary conditions for the item on which the marking is placed.

Compact fluorescent lamp (CFL) means an integrated or non-integrated single-base, low-pressure mercury, electric-discharge source in which a fluorescing coating transforms some of the ultraviolet energy generated by the mercury discharge into light; the term does not include circline or U-shaped lamps.

Compact refrigerator/refrigerator-freezer/freezer means any refrigerator, refrigerator-freezer or freezer with a total refrigerated volume of less than 7.75 cubic feet (220 liters). (Total refrigerated volume shall be determined using the applicable test procedure appendix prescribed in subpart B of this part.)

Component video means a video display interface as defined in the Consumer Electronics Association's (CEA) standard, CEA–770.3–D (incorporated by reference; see § 430.3).

Composite video means a video display interface that uses Radio Corporation of America (RCA) connections carrying a signal defined by the Society of Motion Picture and Television Engineers' (SMPTE) standard, SMPTE 170M–2004 (incorporated by reference; see § 430.3) for regions that support a power frequency of 59.94 Hz or International Telecommunication Union's (ITU) standard, ITU–R BT 470–6 (incorporated by reference; see § 430.3) for regions that support a power frequency of 50 Hz.

Consumer product means any article (other than an automobile, as defined in Section 501(1) of the Motor Vehicle Information and Cost Savings Act):

(1) Of a type—

(i) Which in operation consumes, or is designed to consume, energy or, with respect to showerheads, faucets, water closets, and urinals, water; and

(ii) Which, to any significant extent, is distributed in commerce for personal use or consumption by individuals;

(2) Without regard to whether such article of such type is in fact distributed in commerce for personal use or consumption by an individual, except that such term includes fluorescent lamp ballasts, general service fluorescent lamps, incandescent reflector lamps, showerheads, faucets, water closets, and urinals distributed in commerce for personal or commercial use or consumption.

Consumer refrigeration product means a refrigerator, refrigerator-freezer, freezer, or miscellaneous refrigeration product.

Contractor means a person (other than the manufacturer or distributor) who sells to and/or installs for an end user a central air conditioner subject to regional standards. The term ''end user'' means the entity that purchases or selects for purchase the central air conditioner. Some examples of typical ''end users'' are homeowners, building owners, building managers, and property developers.

Controlling parameter means a measurable quantity or an algorithm (such as temperature or usage pattern) used for inferring heating load to a residential boiler, which would then result in incremental changes in boiler supply water temperature.

Convection microwave oven means a microwave oven that incorporates convection features and any other means of cooking in a single compartment.

Conventional cooking top means a category of cooking products which is a household cooking appliance consisting of a horizontal surface containing one

or more surface units that utilize a gas flame, electric resistance heating, or electric inductive heating. This includes any conventional cooking top component of a combined cooking product.

Conventional oven means a category of cooking products which is a household cooking appliance consisting of one or more compartments intended for the cooking or heating of food by means of either a gas flame or electric resistance heating. It does not include portable or countertop ovens which use electric resistance heating for the cooking or heating of food and are designed for an electrical supply of approximately 120 volts. This includes any conventional oven(s) component of a combined cooking product.

Conventional room air cleaner means an air cleaner that—

(1) Is a portable or wall mounted (fixed) unit, excluding ceiling mounted unit, that plugs into an electrical outlet;

(2) Operates with a fan for air circulation; and

(3) Contains means to remove, destroy, and/or deactivate particulates. The term portable is as defined in section 2.1.3.1 of AHAM AC–7–2022 (incorporated by reference; see § 430.3) and fixed is as defined in section 2.1.3.2 of AHAM AC–7–2022.

Cooking products means consumer products that are used as the major household cooking appliances. They are designed to cook or heat different types of food by one or more of the following sources of heat: Gas, electricity, or microwave energy. Each product may consist of a horizontal cooking top containing one or more surface units and/or one or more heating compartments.

Cooler means a cabinet, used with one or more doors, that has a source of refrigeration capable of operating on single-phase, alternating current and is capable of maintaining compartment temperatures either:

(1) No lower than 39 °F (3.9 °C); or

(2) In a range that extends no lower than 37 °F (2.8 °C) but at least as high as 60 °F (15.6 °C) as determined according to the applicable provisions in § 429.61(d)(2) of this chapter.

Cooler-all-refrigerator means a cooler-refrigerator that does not include a compartment capable of maintaining compartment temperatures below 32 °F (0 °C) as determined according to the provisions in § 429.61(d)(2) of this chapter. It may include a compartment of 0.50 cubic-foot capacity (14.2 liters) or less for the freezing and storage of ice.

Cooler-freezer means a cabinet, used with one or more doors, that has a source of refrigeration that requires single-phase, alternating current electric energy input only, and consists of two or more compartments, including at least one cooler compartment as defined in appendix A of subpart B of this part, where the remaining compartment(s) are capable of maintaining compartment temperatures at 0 °F (−17.8 °C) or below as determined according to the provisions in § 429.61(d)(2) of this chapter.

Cooler-refrigerator means a cabinet, used with one or more doors, that has a source of refrigeration that requires single-phase, alternating current electric energy input only, and consists of two or more compartments, including at least one cooler compartment as defined in appendix A of subpart B of this part, where:

(1) At least one of the remaining compartments is not a cooler compartment as defined in appendix A of subpart B of this part and is capable of maintaining compartment temperatures above 32 °F (0 °C) and below 39 °F (3.9 °C) as determined according to § 429.61(d)(2) of this chapter;

(2) The cabinet may also include a compartment capable of maintaining compartment temperatures below 32 °F (0 °C) as determined according to § 429.61(d)(2) of this chapter; but

(3) The cabinet does not provide a separate low temperature compartment capable of maintaining compartment temperatures below 8 °F (−13.3 °C) as determined according to § 429.61(d)(2) of this chapter.

Cooler-refrigerator-freezer means a cabinet, used with one or more doors, that has a source of refrigeration that requires single-phase, alternating current electric energy input only, and consists of three or more compartments, including at least one cooler

compartment as defined in appendix A of subpart B of this part, where:

(1) At least one of the remaining compartments is not a cooler compartment as defined in appendix A of subpart B of this part and is capable of maintaining compartment temperatures above 32 °F (0 °C) and below 39 °F (3.9 °C) as determined according to § 429.61(d)(2) of this chapter; and

(2) At least one other compartment is capable of maintaining compartment temperatures below 8 °F (−13.3 °C) and may be adjusted by the user to a temperature of 0 °F (−17.8 °C) or below as determined according to § 429.61(d)(2) of this chapter.

Correlated color temperature (CCT) means the absolute temperature of a blackbody whose chromaticity most nearly resembles that of the light source.

Covered product means a consumer product—

(1) Of a type specified in section 322 of the Act; or

(2) That is an air cleaner, battery charger, ceiling fan, ceiling fan light kit, dehumidifier, external power supply, medium base compact fluorescent lamp, miscellaneous refrigeration product, portable air conditioner, portable electric spa, or torchiere.

Dealer means a type of contractor, generally with a relationship with one or more specific manufacturers.

Decorative hearth product means a gas-fired appliance that—

(1) Simulates a solid-fueled fireplace or presents a flame pattern;

(2) Includes products designed for indoor use, outdoor use, or either indoor or outdoor use;

(3) Is not for use with a thermostat;

(4) For products designed for indoor use, is not designed to provide space heating to the space in which it is installed; and

(5) For products designed for outdoor use, is not designed to provide heat proximate to the unit.

Dehumidifier means a product, other than a portable air conditioner, room air conditioner, or packaged terminal air conditioner, that is a self-contained, electrically operated, and mechanically encased assembly consisting of—

(1) A refrigerated surface (evaporator) that condenses moisture from the atmosphere;

(2) A refrigerating system, including an electric motor;

(3) An air-circulating fan; and

(4) A means for collecting or disposing of the condensate.

Design voltage with respect to an incandescent lamp means:

(1) The voltage marked as the intended operating voltage;

(2) The mid-point of the voltage range if the lamp is marked with a voltage range; or

(3) 120 V if the lamp is not marked with a voltage or voltage range.

Designed and marketed means exclusively designed to fulfill the indicated application and, when distributed in commerce, designated and marketed solely for that application, with the designation prominently displayed on the packaging and all publicly available documents (*e.g.*, product literature, catalogs, and packaging labels). This definition applies to the following covered lighting products: Fluorescent lamp ballasts; fluorescent lamps; general service fluorescent lamps; general service incandescent lamps; general service lamps; incandescent lamps; incandescent reflector lamps; compact fluorescent lamps (including medium base compact fluorescent lamps); LED lamps; and specialty application mercury vapor lamp ballasts.

Detachable battery means a battery that is—

(1) Contained in a separate enclosure from the product; and

(2) Intended to be removed or disconnected from the product for recharging.

Direct heating equipment means vented home heating equipment and unvented home heating equipment.

Direct operation external power supply means an external power supply that can operate a consumer product that is not a battery charger without the assistance of a battery.

Direct vent system means a system supplied by a manufacturer which provides outdoor air or air from an unheated space (such as an attic or crawl space) directly to a furnace or vented heater for combustion and for

draft relief if the unit is equipped with a draft control device.

Dishwasher means a cabinet-like appliance which with the aid of water and detergent, washes, rinses, and dries (when a drying process is included) dishware, glassware, eating utensils, and most cooking utensils by chemical, mechanical and/or electrical means and discharges to the plumbing drainage system.

Distributor means a person (other than a manufacturer or retailer) to whom a consumer appliance product is delivered or sold for purposes of distribution in commerce.

DOE means the Department of Energy.

Dual-duct portable air conditioner means a portable air conditioner that draws some or all of the condenser inlet air from outside the conditioned space through a duct attached to an adjustable window bracket, may draw additional condenser inlet air from the conditioned space, and discharges the condenser outlet air outside the conditioned space by means of a separate duct attached to an adjustable window bracket.

Dual-flush water closet means a water closet incorporating a feature that allows the user to flush the water closet with either a reduced or a full volume of water.

Electric boiler means an electrically powered furnace designed to supply low pressure steam or hot water for space heating application. A low pressure steam boiler operates at or below 15 pounds per square inch gauge (psig) steam pressure; a hot water boiler operates at or below 160 psig water pressure and 250 °F. water temperature.

Electric central furnace means a furnace designed to supply heat through a system of ducts with air as the heating medium, in which heat is generated by one or more electric resistance heating elements and the heated air is circulated by means of a fan or blower.

Electric circulating water heater means a circulating water heater with an input of 12 kW or less (including heat pump-only units with power inputs of no more than 24 A at 250 V).

Electric clothes dryer means a cabinet-like appliance designed to dry fabrics in a tumble-type drum with forced air circulation. The heat source is electricity and the drum and blower(s) are driven by an electric motor(s).

Electric heater means an electric appliance which is a class of unvented home heating equipment in which heat is generated from electrical energy and dissipated by convection and radiation and includes baseboard electric heaters, ceiling electric heaters, floor electric heaters, portable electric heaters, and wall electric heaters.

Electric instantaneous water heater means a water heater that uses electricity as the energy source, has a nameplate input rating of 12 kW or less, and contains no more than one gallon of water per 4,000 Btu per hour of input.

Electric pool heater means a pool heater other than an electric spa heater that uses electricity as its primary energy source.

Electric spa heater means a pool heater that—

(1) Uses electricity as its primary energy source;

(2) Has an output capacity (as measured according to appendix P to subpart B of part 430) of 11 kW or less; and

(3) Is designed to be installed within a portable electric spa.

Electric storage water heater means a water heater that uses electricity as the energy source, has a nameplate input rating of 12 kW or less, and contains more than one gallon of water per 4,000 Btu per hour of input.

Electromechanical hydraulic water closet means any water closet that utilizes electrically operated devices, such as, but not limited to, air compressors, pumps, solenoids, motors, or macerators in place of or to aid gravity in evacuating waste from the toilet bowl.

Electronic ballast means a device that uses semiconductors as the primary means to control lamp starting and operation.

Energy conservation standard means any standards meeting the definitions of that term in 42 U.S.C. 6291(6) and 42 U.S.C. 6311(18) as well as any other water conservation standards and design requirements found in this part or parts 430 or 431.

Energy use of a type of consumer product which is used by households means the energy consumed by such product

within housing units occupied by households (such as energy for space heating and cooling, water heating, the operation of appliances, or other activities of the households), and includes energy consumed on any property that is contiguous with a housing unit and that is used primarily by the household occupying the housing unit (such as energy for exterior lights or heating a pool).

ER incandescent reflector lamp means a reflector lamp that has an elliptical section below the major diameter of the bulb and above the approximate base line of the bulb, as shown in Figure 1 (RE) of ANSI C78.79–2020 (incorporated by reference; see § 430.3) and product space drawings shown in ANSI C78.21–2016 (incorporated by reference; see § 430.3).

ER30 means an ER incandescent reflector lamp with a diameter of 30/8ths of an inch.

ER40 means an ER incandescent reflector lamp with a diameter of 40/8ths of an inch.

Estimated annual operating cost means the aggregate retail cost of the energy which is likely to be consumed annually, and in the case of showerheads, faucets, water closets, and urinals, the aggregate retail cost of water and wastewater treatment services likely to be incurred annually, in representative use of a consumer product, determined in accordance with Section 323 of EPCA (42 U.S.C. 6293).

External power supply means an external power supply circuit that is used to convert household electric current into DC current or lower-voltage AC current to operate a consumer product. However, the term does not include any ''commercial and industrial power supply'' as defined in this section, or a power supply circuit, driver, or device that is designed exclusively to be connected to, and power—

(1) Light-emitting diodes providing illumination;

(2) Organic light-emitting diodes providing illumination; or

(3) Ceiling fans using direct current motors.

External power supply design family means a set of external power supply basic models, produced by the same manufacturer, which share the same circuit layout, output power, and output cord resistance, but differ in output voltage.

Faucet means a lavatory faucet, kitchen faucet, metering faucet, or replacement aerator for a lavatory or kitchen faucet, excluding low-pressure water dispensers and pot fillers.

Fitting means a device that controls and guides the flow of water.

Floor electric heater means an electric heater which is intended to be recessed in a floor, and which transfers heat by radiation and/or convection (either natural or forced).

Fluorescent lamp means a low pressure mercury electric-discharge source in which a fluorescing coating transforms some of the ultraviolet energy generated by the mercury discharge into light, including only the following:

(1) Any straight-shaped lamp (commonly referred to as 4-foot medium bipin lamps) with medium bipin bases of nominal overall length of 48 inches and rated wattage of 25 or more;

(2) Any U-shaped lamp (commonly referred to as 2-foot U-shaped lamps) with medium bipin bases of nominal overall length between 22 and 25 inches and rated wattage of 25 or more;

(3) Any rapid start lamp (commonly referred to as 8-foot high output lamps) with recessed double contact bases of nominal overall length of 96 inches;

(4) Any instant start lamp (commonly referred to as 8-foot slimline lamps) with single pin bases of nominal overall length of 96 inches and rated wattage of 49 or more;

(5) Any straight-shaped lamp (commonly referred to as 4-foot miniature bipin standard output lamps) with miniature bipin bases of nominal overall length between 45 and 48 inches and rated wattage of 25 or more; and

(6) Any straight-shaped lamp (commonly referred to 4-foot miniature bipin high output lamps) with miniature bipin bases of nominal overall length between 45 and 48 inches and rated wattage of 44 or more.

Fluorescent lamp ballast means a device which is used to start and operate fluorescent lamps by providing a starting voltage and current and limiting the current during normal operation.

Fluorescent lamp designed for use in reprographic equipment means a fluorescent lamp intended for use in equipment used to reproduce, reprint, or copy graphic material.

Flushometer tank means a device whose function is defined in flushometer valve, but integrated within an accumulator vessel affixed and adjacent to the fixture inlet so as to cause an effective enlargement of the supply line immediately before the unit.

Flushometer valve means a valve attached to a pressurized water supply pipe and so designed that when actuated, it opens the line for direct flow into the fixture at a rate and quantity to properly operate the fixture, and then gradually closes to provide trap reseal in the fixture in order to avoid water hammer. The pipe to which this device is connected is in itself of sufficient size, that when open, will allow the device to deliver water at a sufficient rate of flow for flushing purposes.

Forced air central furnace means a gas or oil burning furnace designed to supply heat through a system of ducts with air as the heating medium. The heat generated by combustion of gas or oil is transferred to the air within a casing by conduction through heat exchange surfaces and is circulated through the duct system by means of a fan or blower.

Freestanding compact cooler means any cooler, excluding built-in compact coolers, with a total refrigerated volume less than 7.75 cubic feet.

Freestanding cooler means any cooler, excluding built-in coolers, with a total refrigerated volume of 7.75 cubic feet or greater.

Freezer means a cabinet, used with one or more doors, that has a source of refrigeration that requires single-phase, alternating current electric energy input only and is capable of maintaining compartment temperatures of 0 °F (−17.8 °C) or below as determined according to the provisions in § 429.14(d)(2) of this chapter. It does not include any refrigerated cabinet that consists solely of an automatic ice maker and an ice storage bin arranged so that operation of the automatic icemaker fills the bin to its capacity. However, the term does not include:

(1) Any product that does not include a compressor and condenser unit as an integral part of the cabinet assembly; or

(2) Any miscellaneous refrigeration product that must comply with an applicable miscellaneous refrigeration product energy conservation standard.

Furnace means a product which utilizes only single-phase electric current, or single-phase electric current or DC current in conjunction with natural gas, propane, or home heating oil, and which—

(1) Is designed to be the principal heating source for the living space of a residence;

(2) Is not contained within the same cabinet with a central air conditioner whose rated cooling capacity is above 65,000 Btu per hour;

(3) Is an electric central furnace, electric boiler, forced-air central furnace, gravity central furnace, or low-pressure steam or hot water boiler; and

(4) Has a heat input rate of less than 300,000 Btu per hour for electric boilers and low-pressure steam or hot water boilers and less than 225,000 Btu per hour for forced-air central furnaces, gravity central furnaces, and electric central furnaces.

Furnace fan means an electrically-powered device used in a consumer product for the purpose of circulating air through ductwork.

Gas means either natural gas or propane.

Gas clothes dryer means a cabinet-like appliance designed to dry fabrics in a tumble-type drum with forced air circulation. The heat source is gas and the drum and blower(s) are driven by an electric motor(s).

Gas-fired circulating water heater means a circulating water heater with a nominal input of 75,000 Btu/h or less.

Gas-fired instantaneous water heater means a water heater that uses gas as the main energy source, has a nameplate input rating less than 200,000 Btu/h, and contains no more than one gallon of water per 4,000 Btu per hour of input.

Gas-fired pool heater means a pool heater that uses gas as its primary energy source.

Gas-fired storage water heater means a water heater that uses gas as the main

energy source, has a nameplate input rating of 75,000 Btu/h or less, and contains more than one gallon of water per 4,000 Btu per hour of input.

General lighting application means lighting that provides an interior or exterior area with overall illumination.

General service fluorescent lamp means any fluorescent lamp which can be used to satisfy the majority of fluorescent lighting applications, but does not include any lamp designed and marketed for the following nongeneral application:

(1) Fluorescent lamps designed to promote plant growth;

(2) Fluorescent lamps specifically designed for cold temperature applications;

(3) Colored fluorescent lamps;

(4) Impact-resistant fluorescent lamps;

(5) Reflectorized or aperture lamps;

(6) Fluorescent lamps designed for use in reprographic equipment;

(7) Lamps primarily designed to produce radiation in the ultra-violet region of the spectrum; and

(8) Lamps with a Color Rendering Index of 87 or greater.

General service incandescent lamp means a standard incandescent or halogen type lamp that is intended for general service applications; has a medium screw base; has a lumen range of not less than 310 lumens and not more than 2,600 lumens or, in the case of a modified spectrum lamp, not less than 232 lumens and not more than 1,950 lumens; and is capable of being operated at a voltage range at least partially within 110 and 130 volts; however, this definition does not apply to the following incandescent lamps—

(1) An appliance lamp;

(2) A black light lamp;

(3) A bug lamp;

(4) A colored lamp;

(5) A G shape lamp with a diameter of 5 inches or more as defined in ANSI C78.79–2020 (incorporated by reference; see § 430.3);

(6) An infrared lamp;

(7) A left-hand thread lamp;

(8) A marine lamp;

(9) A marine signal service lamp;

(10) A mine service lamp;

(11) A plant light lamp;

(12) An R20 short lamp;

(13) A sign service lamp;

(14) A silver bowl lamp;

(15) A showcase lamp; and

(16) A traffic signal lamp.

General service lamp means a lamp that has an ANSI base; is able to operate at a voltage of 12 volts or 24 volts, at or between 100 to 130 volts, at or between 220 to 240 volts, or of 277 volts for integrated lamps (as set out in this definition), or is able to operate at any voltage for non-integrated lamps (as set out in this definition); has an initial lumen output of greater than or equal to 310 lumens (or 232 lumens for modified spectrum general service incandescent lamps) and less than or equal to 3,300 lumens; is not a light fixture; is not an LED downlight retrofit kit; and is used in general lighting applications. General service lamps include, but are not limited to, general service incandescent lamps, compact fluorescent lamps, general service light-emitting diode lamps, and general service organic light emitting diode lamps. General service lamps do not include:

(1) Appliance lamps;

(2) Black light lamps;

(3) Bug lamps;

(4) Colored lamps;

(5) G shape lamps with a diameter of 5 inches or more as defined in ANSI C78.79–2020 (incorporated by reference; see § 430.3);

(6) General service fluorescent lamps;

(7) High intensity discharge lamps;

(8) Infrared lamps;

(9) J, JC, JCD, JCS, JCV, JCX, JD, JS, and JT shape lamps that do not have Edison screw bases;

(10) Lamps that have a wedge base or prefocus base;

(11) Left-hand thread lamps;

(12) Marine lamps;

(13) Marine signal service lamps;

(14) Mine service lamps;

(15) MR shape lamps that have a first number symbol equal to 16 (diameter equal to 2 inches) as defined in ANSI C78.79–2020 (incorporated by reference; see § 430.3), operate at 12 volts, and have a lumen output greater than or equal to 800;

(16) Other fluorescent lamps;

(17) Plant light lamps;

(18) R20 short lamps;

(19) Reflector lamps (as set out in this definition) that have a first number symbol less than 16 (diameter less than 2 inches) as defined in ANSI C78.79–2020 (incorporated by reference; see § 430.3) and that do not have E26/E24, E26d, E26/50x39, E26/53x39, E29/28, E29/53x39, E39, E39d, EP39, or EX39 bases;

(20) S shape or G shape lamps that have a first number symbol less than or equal to 12.5 (diameter less than or equal to 1.5625 inches) as defined in ANSI C78.79–2014 (R2020) (incorporated by reference; see § 430.3);

(21) Sign service lamps;

(22) Silver bowl lamps;

(23) Showcase lamps;

(24) Specialty MR lamps;

(25) T shape lamps that have a first number symbol less than or equal to 8 (diameter less than or equal to 1 inch) as defined in ANSI C78.79–2020 (incorporated by reference; see § 430.3), nominal overall length less than 12 inches, and that are not compact fluorescent lamps (as set out in this definition);

(26) Traffic signal lamps.

General service light-emitting diode (LED) lamp means an integrated or non-integrated LED lamp designed for use in general lighting applications (as defined in this section) and that uses light-emitting diodes as the primary source of light.

General service organic light-emitting diode (OLED) lamp means an integrated or non- integrated OLED lamp designed for use in general lighting applications (as defined in this section) and that uses organic light-emitting diodes as the primary source of light.

Gravity central furnace means a gas fueled furnace which depends primarily on natural convection for circulation of heated air and which is designed to be used in conjunction with a system of ducts.

Gravity flush tank water closet means a water closet designed to flush the bowl with water supplied by gravity only.

Grid-enabled water heater means an electric resistance water heater that—

(1) Has a rated storage tank volume of more than 75 gallons;

(2) Is manufactured on or after April 16, 2015;

(3) Is equipped at the point of manufacture with an activation lock and;

(4) Bears a permanent label applied by the manufacturer that—

(i) Is made of material not adversely affected by water;

(ii) Is attached by means of non-water-soluble adhesive; and

(iii) Advises purchasers and end-users of the intended and appropriate use of the product with the following notice printed in 16.5 point Arial Narrow Bold font: ''IMPORTANT INFORMATION: This water heater is intended only for use as part of an electric thermal storage or demand response program. It will not provide adequate hot water unless enrolled in such a program and activated by your utility company or another program operator. Confirm the availability of a program in your local area before purchasing or installing this product.''

Hand-held showerhead means a showerhead that can be held or fixed in place for the purpose of spraying water onto a bather and that is connected to a flexible hose.

High-definition multimedia interface or HDMI® means an audio and video interface as defined by HDMI® Specification Informational Version 1.0 or greater (incorporated by reference; see § 430.3).

Home heating equipment, not including furnaces means vented home heating equipment and unvented home heating equipment.

Household means an entity consisting of either an individual, a family, or a group of unrelated individuals, who reside in a particular housing unit. For the purpose of this definition:

(1) *Group quarters* means living quarters that are occupied by an institutional group of 10 or more unrelated persons, such as a nursing home, military barracks, halfway house, college dormitory, fraternity or sorority house, convent, shelter, jail or correctional institution.

(2) *Housing unit* means a house, an apartment, a group of rooms, or a single room occupied as separate living quarters, but does not include group quarters.

(3) *Separate living quarters* means living quarters:

(i) To which the occupants have access either:

(A) Directly from outside of the building, or

(B) Through a common hall that is accessible to other living quarters and that does not go through someone else's living quarters, and

(ii) Occupied by one or more persons who live and eat separately from occupant(s) of other living quarters, if any, in the same building.

Immersed heating element means an electrically powered heating device which is designed to operate while totally immersed in water in such a manner that the heat generated by the device is imparted directly to the water.

Impact-resistant fluorescent lamp means a lamp that:

(1) Has a coating or equivalent technology that is compliant with NSF/ANSI 51 (incorporated by reference; see § 430.3) and is designed to contain the glass if the glass envelope of the lamp is broken; and

(2) Is designated and marketed for the intended application, with:

(i) The designation on the lamp packaging; and

(ii) Marketing materials that identify the lamp as being impact-resistant, shatter-resistant, shatter-proof, or shatter-protected.

Import means to import into the customs territory of the United States.

Incandescent lamp means a lamp in which light is produced by a filament heated to incandescence by an electric current, including only the following:

(1) Any lamp (commonly referred to as lower wattage non-reflector general service lamps, including any tungsten halogen lamp) that has a rated wattage between 30 and 199, has an E26 medium screw base, has a rated voltage or voltage range that lies at least partially in the range of 115 and 130 volts, and is not a reflector lamp.

(2) Any incandescent reflector lamp.

(3) Any general service incandescent lamp (commonly referred to as a high- or higher-wattage lamp) that has a rated wattage above 199 (above 205 for a high wattage reflector lamp).

Incandescent reflector lamp (commonly referred to as a reflector lamp) means any lamp in which light is produced by a filament heated to incandescence by an electric current, which: contains an inner reflective coating on the outer bulb to direct the light; is not colored; is not designed for rough or vibration service applications; is not an R20 short lamp; has an R, PAR, ER, BR, BPAR, or similar bulb shapes with an E26 medium screw base; has a rated voltage or voltage range that lies at least partially in the range of 115 and 130 volts; has a diameter that exceeds 2.25 inches; and has a rated wattage that is 40 watts or higher.

Indirect operation external power supply means an external power supply that cannot operate a consumer product that is not a battery charger without the assistance of a battery as determined by the steps in paragraphs (1)(i) through (v) of this definition:

(1) If the external power supply (EPS) can be connected to an end-use consumer product and that consumer product can be operated using battery power, the method for determining whether that EPS is incapable of operating that consumer product directly is as follows:

(i) If the end-use product has a removable battery, remove it for the remainder of the test and proceed to the step in paragraph (1)(v) of this definition. If not, proceed to the step in paragraph (1)(ii).

(ii) Charge the battery in the application via the EPS such that the application can operate as intended before taking any additional steps.

(iii) Disconnect the EPS from the application. From an off mode state, turn on the application and record the time necessary for it to become operational to the nearest five second increment (5 sec, 10 sec, etc.).

(iv) Operate the application using power only from the battery until the application stops functioning due to the battery discharging.

(v) Connect the EPS first to mains and then to the application. Immediately attempt to operate the application. If the battery was removed for testing and the end-use product operates as intended, the EPS is not an indirect operation EPS and paragraph 2 of this definition does not apply. If the battery could not be removed for testing, record the time for the application to become operational to the nearest five second increment (5 seconds, 10 seconds, etc.).

(2) If the time recorded in paragraph (1)(v) of this definition is greater than the summation of the time recorded in paragraph (1)(iii) of this definition and five seconds, the EPS cannot operate the application directly and is an indirect operation EPS.

Infrared lamp means a lamp that is designed and marketed as an infrared lamp; has its highest radiant power peaks in the infrared region of the electromagnetic spectrum (770 nm to 1 mm); has a rated wattage of 125 watts or greater; and which has a primary purpose of providing heat.

Installation of a central air conditioner means the connection of the refrigerant lines and/or electrical systems to make the central air conditioner operational.

Integrated lamp means a lamp that contains all components necessary for the starting and stable operation of the lamp, does not include any replaceable or interchangeable parts, and is connected directly to a branch circuit through an ANSI base and corresponding ANSI standard lamp-holder (socket).

Integrated light-emitting diode lamp means an integrated LED lamp as defined in ANSI/IES RP–16 (incorporated by reference; see § 430.3).

Intermediate base incandescent lamp means a lamp that uses an intermediate screw base as described in ANSI C81.61, Specifications for Electric Bases, common designation E17 (incorporated by reference; see § 430.3).

Kerosene means No. 1 fuel oil with a viscosity meeting the specifications as specified in UL–730–1974, section 36.9 and in tables 2 and 3 of ANSI Standard Z91.1–1972.

Lamp Efficacy (LE) means the measured lumen output of a lamp in lumens divided by the measured lamp electrical power input in watts expressed in units of lumens per watt (LPW).

Lamps primarily designed to produce radiation in the ultraviolet region of the spectrum means fluorescent lamps that primarily emit light in the portion of the electromagnetic spectrum where light has a wavelength between 10 and 400 nanometers.

LED downlight retrofit kit means a product designed and marketed to install into an existing downlight, replacing the existing light source and related electrical components, typically employing an ANSI standard lamp base, either integrated or connected to the downlight retrofit by wire leads, and is a retrofit kit classified or certified to UL 1598C–2016 (incorporated by reference; see § 430.3). LED downlight retrofit kit does not include integrated lamps or non-integrated lamps.

Left-hand thread lamp means a lamp with direction of threads on the lamp base oriented in the left-hand direction.

Lifetime with respect to an incandescent reflector lamp or general service incandescent lamp means the length of operating time between first use and failure of 50 percent of the sample units (as specified in 10 CFR 429.55 and 429.66), determined in accordance with the test procedures described in appendix R to subpart B of this part.

Lifetime of a compact fluorescent lamp means the length of operating time between first use and failure of 50 percent of the sample units (as specified in § 429.35(a)(1) of this chapter), determined in accordance with the test procedures described in section 3.3 of appendix W to subpart B of this part.

Lifetime of an integrated light-emitting diode lamp means the length of operating time between first use and failure of 50 percent of the sample units (as required by § 429.56(a)(1) of this chapter), when measured in accordance with the test procedures described in section 4 of appendix BB to subpart B of this part.

Light-emitting diode or *LED* means a p-n junction solid state device of which the radiated output, either in the infrared region, the visible region, or the ultraviolet region, is a function of the physical construction, material used, and exciting current of the device.

Light fixture means a complete lighting unit consisting of light source(s) and ballast(s) or driver(s) (when applicable) together with the parts designed to distribute the light, to position and protect the light source, and to connect the light source(s) to the power supply.

Low consumption has the meaning given such a term in ASME A112.19.2–2008. (*see* § 430.3)

Low pressure steam or hot water boiler means an electric, gas or oil burning furnace designed to supply low pressure steam or hot water for space heating application. A low pressure steam boiler operates at or below 15 pounds psig steam pressure; a hot water boiler operates at or below 160 psig water pressure and 250 °F. water temperature.

Low-pressure water dispenser means a terminal fitting that dispenses drinking water at a pressure of 105 kPA (15 psi) or less.

Low-temperature water heater means an electric instantaneous water heater that is not a circulating water heater and cannot deliver water at a temperature greater than or equal to the set point temperature specified in section 2.5 of appendix E to subpart B of this part when supplied with water at the supply water temperature specified in section 2.3 of appendix E to subpart B of this part and the flow rate specified in section 5.2.2.1 of appendix E to subpart B of this part.

Low-voltage external power supply means an external power supply with a nameplate output voltage less than 6 volts and nameplate output current greater than or equal to 550 milliamps.

LP-gas means liquified petroleum gas, and includes propane, butane, and propane/butane mixtures.

Major cooking component means either a conventional cooking top, a conventional oven or a microwave oven.

Manufacture means to manufacture, produce, assemble, or import.

Manufacturer means any person who manufactures a consumer product.

Marine lamp means a lamp that is designed and marketed for use on boats and can operate at or between 12 volts and 13.5 volts.

Marine signal service lamp means a lamp that is designed and marketed for marine signal service applications.

Medium base compact fluorescent lamp means an integrally ballasted fluorescent lamp with a medium screw base, a rated input voltage range of 115 to 130 volts and which is designed as a direct replacement for a general service incandescent lamp; however, the term does not include—

(1) Any lamp that is—

(i) Specifically designed to be used for special purpose applications; and

(ii) Unlikely to be used in general purpose applications, such as the applications described in the definition of ''General Service Incandescent Lamp'' in this section; or

(2) Any lamp not described in the definition of ''General Service Incandescent Lamp'' in this section that is excluded by the Secretary, by rule, because the lamp is—

(i) Designed for special applications; and

(ii) Unlikely to be used in general purpose applications.

Medium screw base means an Edison screw base identified with the prefix E–26 in the ''American National Standard for Electric Lamp Bases'', ANSI_IEC C81.61–2003, published by the American National Standards Institute.

Microwave oven means a category of cooking products which is a household cooking appliance consisting of a compartment designed to cook or heat food by means of microwave energy, including microwave ovens with or without thermal elements designed for surface browning of food and convection microwave ovens. This includes any microwave oven(s) component of a combined cooking product.

Mine service lamp means a lamp that is designed and marketed for mine service applications.

Miscellaneous gas products mean decorative hearth products and outdoor heaters.

Miscellaneous refrigeration product means a consumer refrigeration product other than a refrigerator, refrigerator-freezer, or freezer, which includes coolers and combination cooler refrigeration products.

Mobile home furnace means a direct vent furnace that is designed for use only in mobile homes.

Modified spectrum means, with respect to an incandescent lamp, an incandescent lamp that—

(1) Is not a colored incandescent lamp; and

(2) When operated at the rated voltage and wattage of the incandescent lamp—

(A) Has a color point with (x,y) chromaticity coordinates on the C.I.E. 1931 chromaticity diagram, figure 2, page 3

of IESNA LM–16 (incorporated by reference; *see* § 430.3) that lies below the black-body locus; and

(B) Has a color point with (x,y) chromaticity coordinates on the C.I.E. 1931 chromaticity diagram, figure 2, page 3 of IESNA LM–16 (incorporated by reference; *see* § 430.3) that lies at least 4 MacAdam steps, as referenced in IESNA LM–16, distant from the color point of a clear lamp with the same filament and bulb shape, operated at the same rated voltage and wattage.

Natural gas means natural gas as defined by the Federal Power Commission.

Non-integrated lamp means a lamp that is not an integrated lamp.

Off mode means the condition in which an energy using product—

(1) Is connected to a main power source; and

(2) Is not providing any stand-by or active mode function.

Oil means heating oil grade No. 2 as defined in American Society for Testing and Materials (ASTM) D396–71.

Oil-fired circulating water heater means a circulating water heater with a nominal input of 105,000 Btu/h or less.

Oil-fired instantaneous water heater means a water heater that uses oil as the main energy source, has a nameplate input rating of 210,000 Btu/h or less, and contains no more than one gallon of water per 4,000 Btu per hour of input.

Oil-fired pool heater means a pool heater that uses oil as its primary energy source.

Oil-fired storage water heater means a water heater that uses oil as the main energy source, has a nameplate input rating of 105,000 Btu/h or less, and contains more than one gallon of water per 4,000 Btu per hour of input.

Organic light-emitting diode or O*LED* means a thin-film light-emitting device that typically consists of a series of organic layers between 2 electrical contacts (electrodes).

Other clothes washer means a class of clothes washer which is not an automatic or semi-automatic clothes washer.

Other cooking products means any category of cooking products other than conventional cooking tops, conventional ovens, and microwave ovens.

Other fluorescent lamp means low pressure mercury electric-discharge sources in which a fluorescing coating transforms some of the ultraviolet energy generated by the mercury discharge into light and include circline lamps and include double-ended lamps with the following characteristics: Lengths from one to eight feet; designed for cold temperature applications; designed for use in reprographic equipment; designed to produce radiation in the ultraviolet region of the spectrum; impact-resistant; reflectorized or aperture; or a CRI of 87 or greater.

Outdoor heater means a gas-fired appliance designed for use in outdoor spaces only, and which is designed to provide heat proximate to the unit.

Packaged terminal air conditioner means a wall sleeve and a separate unencased combination of heating and cooling assemblies specified by the builder and intended for mounting through the wall. It includes a prime source of refrigeration, separable outdoor louvers, forced ventilation, and heating availability energy.

Packaged terminal heat pump means a packaged terminal air conditioner that utilizes reverse cycle refrigeration as its prime heat source and should have supplementary heating availability by builder's choice of energy.

PAR incandescent reflector lamp means a reflector lamp formed by the sealing together during the lamp-making process of a pressed glass parabolic section and a pressed lens section as shown in Figure 1 (PAR) of ANSI C78.79–2020, (incorporated by reference; see § 430.3). The pressed lens section may be either plain or configured.

Person includes any individual, corporation, company, association, firm, partnership, society, trust, joint venture or joint stock company, the government, and any agency of the United States or any State or political subdivision thereof.

Pin base lamp means a lamp that uses a base type designated as a single pin base or multiple pin base system.

Pin-based means (1) the base of a fluorescent lamp, that is not integrally ballasted and that has a plug-in lamp base, including multi-tube, multibend,

spiral, and circline types, or (2) a socket that holds such a lamp.

Plant light lamp means a lamp that is designed to promote plant growth by emitting its highest radiant power peaks in the regions of the electromagnetic spectrum that promote photosynthesis: Blue (440 nm to 490 nm) and/or red (620 to 740 nm), and is designed and marketed for plant growing applications.

Pool heater means an appliance designed for heating nonpotable water contained at atmospheric pressure, including heating water in swimming pools, spas, hot tubs and similar applications.

Portable air conditioner means a portable encased assembly, other than a ''packaged terminal air conditioner,'' ''room air conditioner,'' or ''dehumidifier,'' that delivers cooled, conditioned air to an enclosed space, and is powered by single-phase electric current. It includes a source of refrigeration and may include additional means for air circulation and heating.

Portable dehumidifier means a dehumidifier that, in accordance with any manufacturer instructions available to a consumer, operates within the dehumidified space without the attachment of additional ducting, although means may be provided for optional duct attachment.

Portable electric heater means an electric heater which is intended to stand unsupported, and can be moved from place to place within a structure. It is connected to electric supply by means of a cord and plug, and transfers heat by radiation and/or convention (either natural or forced).

Portable electric spa means a factory-built electric spa or hot tub, supplied with equipment for heating and circulating water at the time of sale or sold separately for subsequent attachment.

Portable indoor conventional cooking top means a conventional cooking top designed—

(1) For indoor use; and

(2) To be moved from place to place.

Pot filler means a terminal fitting that can accommodate only a single supply water inlet, with an articulated arm or the equivalent that allows the product to reach to fill vessels when in use and allows the product to be retracted when not in use.

Primary electric heater means an electric heater that is the principal source of heat for a structure and includes baseboard electric heaters, ceiling electric heaters, floor electric heaters, and wall electric heaters.

Private labeler means an owner of a brand or trademark on the label of a consumer product which bears a private label. A consumer product bears a private label if:

(1) Such product (or its container) is labeled with the brand or trademark of a person other than a manufacturer of such product;

(2) The person with whose brand or trademark such product (or container) is labeled has authorized or caused such product to be so labeled; and

(3) The brand or trademark of a manufacturer of such product does not appear on such label.

Propane means a hydrocarbon whose chemical composition is predominantly C_3H_8, whether recovered from natural gas or crude oil.

R incandescent reflector lamp means a reflector lamp that includes a parabolic or elliptical section below the major diameter as shown in Figure 1 (R) of ANSI C78.79–2020 (incorporated by reference; see § 430.3).

R20 incandescent reflector lamp means an R incandescent reflector lamp that has a face diameter of approximately 2.5 inches, as shown in Figure C78.21–254 of ANSI C78.21–2016 (incorporated by reference; see § 430.3).

R20 short lamp means a lamp that is an R20 incandescent reflector lamp that has a rated wattage of 100 watts; has a maximum overall length of 3 and 5/8, or 3.625, inches; and is designed, labeled, and marketed specifically for pool and spa applications.

Rated voltage with respect to incandescent lamps means:

(1) The design voltage if the design voltage is 115 V, 130 V or between 115V and 130 V:

(2) 115 V if the design voltage is less than 115 V and greater than or equal to 100 V and the lamp can operate at 115 V; and

(3) 130 V if the design voltage is greater than 130 V and less than or

equal to 150 V and the lamp can operate at 130 V.

Rated wattage means:

(1) With respect to fluorescent lamps and general service fluorescent lamps:

(i) If the lamp is listed in ANSI C78.81 (incorporated by reference; *see* § 430.3) or ANSI C78.901 (incorporated by reference; *see* § 430.3), the rated wattage of a lamp determined by the lamp designation of Clause 11.1 of ANSI C78.81 or ANSI C78.901;

(ii) If the lamp is a residential straight-shaped lamp, and not listed in ANSI C78.81 (incorporated by reference; *see* § 430.3), the wattage of a lamp when operated on a reference ballast for which the lamp is designed; or

(iii) If the lamp is neither listed in one of the ANSI standards referenced in paragraph (1)(i) of this definition, nor a residential straight-shaped lamp, a represented value of electrical power for a basic model, determined according to 10 CFR 429.27, and derived from the measured initial input power of a lamp tested according to appendix R to subpart B of this part.

(2) With respect to general service incandescent lamps, a represented value of electrical power for a basic model, determined according to 10 CFR 429.27, and derived from the measured initial input power of a lamp tested according to appendix R to subpart B of this part.

(3) With respect to incandescent reflector lamps, a represented value of electrical power for a basic model, determined according to 10 CFR 429.55, and derived from the measured initial input power of a lamp tested according to appendix R to subpart B of this part.

Reflector lamp means a lamp that has an R, PAR, BPAR, BR, ER, MR, or similar bulb shape as defined in ANSI C78.79–2020 (incorporated by reference; see § 430.3) and is used to provide directional light.

Reflectorized or aperture lamp means a fluorescent lamp that contains an inner reflective coating on the bulb to direct light.

Refrigerant-desiccant dehumidifier means a whole-home dehumidifier that removes moisture from the process air by means of a desiccant material in addition to a refrigeration system.

Refrigerator means a cabinet, used with one or more doors, that has a source of refrigeration that requires single-phase, alternating current electric energy input only and is capable of maintaining compartment temperatures above 32 °F (0 °C) and below 39 °F (3.9 °C) as determined according to § 429.14(d)(2) of this chapter. A refrigerator may include a compartment capable of maintaining compartment temperatures below 32 °F (0 °C), but does not provide a separate low temperature compartment capable of maintaining compartment temperatures below8 °F (−13.3 °C) as determined according to § 429.14(d)(2). However, the term does not include:

(1) Any product that does not include a compressor and condenser unit as an integral part of the cabinet assembly;

(2) A cooler; or

(3) Any miscellaneous refrigeration product that must comply with an applicable miscellaneous refrigeration product energy conservation standard.

Refrigerator-freezer means a cabinet, used with one or more doors, that has a source of refrigeration that requires single-phase, alternating current electric energy input only and consists of two or more compartments where at least one of the compartments is capable of maintaining compartment temperatures above 32 °F (0 °C) and below 39 °F (3.9 °C) as determined according to § 429.14(d)(2) of this chapter, and at least one other compartment is capable of maintaining compartment temperatures of 8 °F (−13.3 °C) and may be adjusted by the user to a temperature of 0 °F (−17.8 °C) or below as determined according to § 429.14(d)(2). However, the term does not include:

(1) Any product that does not include a compressor and condenser unit as an integral part of the cabinet assembly; or

(2) Any miscellaneous refrigeration product that must comply with an applicable miscellaneous refrigeration product energy conservation standard.

Replacement ballast means a ballast that—

(1) Is designed for use to replace an existing fluorescent lamp ballast in a previously installed luminaire;

(2) Is marked ''FOR REPLACEMENT USE ONLY'';

(3) Is shipped by the manufacturer in packages containing not more than 10 fluorescent lamp ballasts; and

(4) Has output leads that when fully extended are a total length that is less than the length of the lamp with which the ballast is intended to be operated.

Residential straight-shaped lamp means a low pressure mercury electric-discharge source in which a fluorescing coating transforms some of the ultraviolet energy generated by the mercury discharge into light, including a straight-shaped fluorescent lamp with medium bi-pin bases of nominal overall length of 48 inches and is either designed exclusively for residential applications; or designed primarily and marketed exclusively for residential applications.

(1) A lamp is designed exclusively for residential applications if it will not function for more than 100 hours with a commercial high-power-factor ballast.

(2) A lamp is designed primarily and marketed exclusively for residential applications if it:

(i) Is permanently and clearly marked as being for residential use only;

(ii) Has a life of 6,000 hours or less when used with a commercial high-power-factor ballast;

(iii) Is not labeled or represented as a replacement for a fluorescent lamp that is a covered product; and

(iv) Is marketed and distributed in a manner designed to minimize use of the lamp with commercial high-power-factor ballasts.

(3) A manufacturer may market and distribute a lamp in a manner designed to minimize use of the lamp with commercial high-power-factor ballasts by:

(i) Packaging and labeling the lamp in a manner that clearly indicates the lamp is for residential use only and includes appropriate instructions concerning proper and improper use; if the lamp is included in a catalog or price list that also includes commercial/industrial lamps, listing the lamp in a separate residential section accompanied by notes about proper use on the same page; and providing as part of any express warranty accompanying the lamp that improper use voids such warranty; or

(ii) Using other comparably effective measures to minimize use with commercial high-power-factor ballasts.

Room air conditioner means a window-mounted or through-the-wall-mounted encased assembly, other than a ''packaged terminal air conditioner,'' that delivers cooled, conditioned air to an enclosed space, and is powered by single-phase electric current. It includes a source of refrigeration and may include additional means for ventilating and heating.

Rough or vibration service incandescent reflector lamp means a reflector lamp: in which a C–11 (5 support), C–17 (8 support), or C–22 (16 support) filament is mounted (the number of support excludes lead wires); in which the filament configuration is as shown in Chapter 6 of the 1993 *Illuminating Engineering Society of North America Lighting Handbook,* 8th Edition (see 10 CFR 430.22); and that is designated and marketed specifically for rough or vibration service applications.

Rough service lamp means a lamp that—

(1) Has a minimum of 5 supports with filament configurations that are C–7A, C–11, C–17, and C–22 as listed in Figure 6–12 of the IESNA Lighting Handbook (incorporated by reference; *see* § 430.3), or similar configurations where lead wires are not counted as supports; and

(2) Is designated and marketed specifically for 'rough service' applications, with

(i) The designation appearing on the lamp packaging; and

(ii) Marketing materials that identify the lamp as being for rough service.

S-video means a video display interface that transmits analog video over two channels: luma and chroma as defined by IEC 60933–5 Ed. 1.0 (incorporated by reference; see § 430.3).

Safety shower showerhead means a showerhead designed to meet the requirements of ISEA Z358.1 (incorporated by reference, see § 430.3).

Secretary means the Secretary of the Department of Energy.

Security or life safety alarm or surveillance system means:

(1) Equipment designed and marketed to perform any of the following functions (on a continuous basis):

(i) Monitor, detect, record, or provide notification of intrusion or access to real property or physical assets or notification of threats to life safety.

(ii) Deter or control access to real property or physical assets, or prevent the unauthorized removal of physical assets.

(iii) Monitor, detect, record, or provide notification of fire, gas, smoke, flooding, or other physical threats to real property, physical assets, or life safety.

(2) This term does not include any product with a principal function other than life safety, security, or surveillance that:

(i) Is designed and marketed with a built-in alarm or theft-deterrent feature; or

(ii) Does not operate necessarily and continuously in active mode.

Semi-automatic clothes washer means a class of clothes washer that is the same as an automatic clothes washer except that user intervention is required to regulate the water temperature by adjusting the external water faucet valves.

Shatter-resistant lamp, shatter-proof lamp, or *shatter-protected lamp* means a lamp that—

(1) Has a coating or equivalent technology that is compliant with NSF/ANSI 51 (incorporated by reference; *see* § 430.3) and is designed to contain the glass if the glass envelope of the lamp is broken; and

(2) Is designated and marketed for the intended application, with

(i) The designation on the lamp packaging; and

(ii) Marketing materials that identify the lamp as being shatter-resistant, shatter-proof, or shatter-protected.

Showcase lamp means a lamp that has a T shape as specified in ANSI C78.79–2020 (incorporated by reference; see § 430.3), is designed and marketed as a showcase lamp, and has a maximum rated wattage of 75 watts.

Showerhead means a component or set of components distributed in commerce for attachment to a single supply fitting, for spraying water onto a bather, typically from an overhead position, excluding safety shower showerheads.

Sign service lamp means a vacuum type or gas-filled lamp that has sufficiently low bulb temperature to permit exposed outdoor use on high-speed flashing circuits, is designed and marketed as a sign service lamp, and has a maximum rated wattage of 15 watts.

Silver bowl lamp means a lamp that has an opaque reflective coating applied directly to part of the bulb surface that reflects light toward the lamp base and that is designed and marketed as a silver bowl lamp.

Single-duct portable air conditioner means a portable air conditioner that draws all of the condenser inlet air from the conditioned space without the means of a duct, and discharges the condenser outlet air outside the conditioned space through a single duct attached to an adjustable window bracket.

Siphonic action means the movement of water through a flushing fixture by creating a siphon to remove waste material.

Siphonic bowl means a water closet bowl that has an integral flushing rim, a trap at the front or rear, and a floor or wall outlet, and operates with a siphonic action (with or without a jet).

Small-duct high-velocity (SDHV) electric furnace means an electric furnace that:

(1) Is designed for, and produces, at least 1.2 inches of external static pressure when operated at the certified air volume rate of 220–350 CFM per rated ton of cooling in the highest default cooling airflow-control setting; and

(2) When applied in the field, uses high velocity room outlets generally greater than 1,000 fpm that have less than 6.0 square inches of free area.

Small-duct high-velocity (SDHV) modular blower means a modular blower that:

(1) Is designed for, and produces, at least 1.2 inches of external static pressure when operated at the certified air volume rate of 220–350 CFM per rated ton of cooling in the highest default cooling airflow-controls setting; and

(2) When applied in the field, uses high velocity room outlets generally greater than 1,000 fpm that have less than 6.0 square inches of free area.

Space constrained product means a central air conditioner or heat pump:

(1) That has rated cooling capacities no greater than 30,000 BTU/hr;

(2) That has an outdoor or indoor unit having at least two overall exterior dimensions or an overall displacement that:

(i) Is substantially smaller than those of other units that are:

(A) Currently usually installed in site-built single family homes; and

(B) Of a similar cooling, and, if a heat pump, heating capacity; and

(ii) If increased, would certainly result in a considerable increase in the usual cost of installation or would certainly result in a significant loss in the utility of the product to the consumer; and

(3) Of a product type that was available for purchase in the United States as of December 1, 2000.

Specialty application mercury vapor lamp ballast means a mercury vapor lamp ballast that—

(1) Is designed and marketed for operation of mercury vapor lamps used in quality inspection, industrial processing, or scientific use, including fluorescent microscopy and ultraviolet curing; and

(2) In the case of a specialty application mercury vapor lamp ballast, the label of which—

(i) Provides that the specialty application mercury vapor lamp ballast is 'For specialty applications only, not for general illumination'; and

(ii) Specifies the specific applications for which the ballast is designed.

Specialty MR lamp means a lamp that has an MR shape as defined in ANSI C78.79–2020 (incorporated by reference; see § 430.3), a diameter of less than or equal to 2.25 inches, a lifetime of less than or equal to 300 hours, and that is designed and marketed for a specialty application.

Standby mode means the condition in which an energy-using product—

(1) Is connected to a main power source; and

(2) Offers one or more of the following user-oriented or protective functions:

(i) To facilitate the activation or deactivation of other functions (including active mode) by remote switch (including remote control), internal sensor, or timer; or

(ii) Continuous functions, including information or status displays (including clocks) or sensor-based functions.

State means a State, the District of Columbia, Puerto Rico, or any territory or possession of the United States.

State regulation means a law or regulation of a State or political subdivision thereof.

Supplementary electric heater means an electric heater that provides heat to a space in addition to that which is supplied by a primary electric heater and includes portable electric heaters.

Surface unit means either a heating unit mounted in a cooking top, or a heating source and its associated heated area of the cooking top, on which vessels are placed for the cooking or heating of food.

Tabletop water heater means a water heater in a rectangular box enclosure designed to slide into a kitchen countertop space with typical dimensions of 36 inches high, 25 inches deep, and 24 inches wide, and with a certified first-hour rating that results in either the very small draw pattern or the low draw pattern, as specified in Table I in section 5.4.1 of appendix E to subpart B of this part.

Television set or TV means a product designed to produce dynamic video, contains an internal TV tuner encased within the product housing, and that is capable of receiving dynamic visual content from wired or wireless sources including but not limited to:

(1) Broadcast and similar services for terrestrial, cable, satellite, and/or broadband transmission of analog and/or digital signals; and/or

(2) Display-specific data connections, such as HDMI, Component video, S-video, Composite video; and/or

(3) Media storage devices such as a USB flash drive, memory card, or a DVD; and/or

(4) Network connections, usually using Internet Protocol, typically carried over Ethernet or Wi-Fi.

Through-the-wall central air conditioner means a central air conditioner that is designed to be installed totally or partially within a fixed-size opening in an exterior wall, and:

(1) Is not weatherized;

(2) Is clearly and permanently marked for installation only through an exterior wall;

(3) Has a rated cooling capacity no greater than 30,000 Btu/hr;

(4) Exchanges all of its outdoor air across a single surface of the equipment cabinet; and

(5) Has a combined outdoor air exchange area of less than 800 square inches (split systems) or less than 1,210 square inches (single packaged systems) as measured on the surface described in paragraph (4) of this definition.

Through-the-wall central air conditioning heat pump means a heat pump that is designed to be installed totally or partially within a fixed-size opening in an exterior wall, and:

(1) Is not weatherized;

(2) Is clearly and permanently marked for installation only through an exterior wall;

(3) Has a rated cooling capacity no greater than 30,000 Btu/hr;

(4) Exchanges all of its outdoor air across a single surface of the equipment cabinet; and

(5) Has a combined outdoor air exchange area of less than 800 square inches (split systems) or less than 1,210 square inches (single packaged systems) as measured on the surface described in paragraph (4) of this definition.

Torchiere means a portable electric lamp with a reflector bowl that directs light upward to give indirect illumination.

Traffic signal lamp means a lamp that is designed and marketed for traffic signal applications and has a lifetime of 8,000 hours or greater.

Trough-type urinal means a urinal designed for simultaneous use by two or more people.

Unvented gas heater means a class of unvented home heating equipment which is a self-contained, free-standing, nonrecessed gas-burning appliance that furnishes heated air by gravity or fan circulation.

Unvented home heating equipment or unvented heater means a class of home heating equipment, not including furnaces, designed to furnish heated air to a space proximate to such heater, directly from the heater, without inlet duct connections and without exhaust venting, and includes: Electric heater, unvented gas heater, and unvented oil heater.

Unvented oil heater means a class of unvented home heating equipment which is a self-contained, free-standing, nonrecessed oil-burning appliance that furnishes heated air by gravity or fan circulation.

Urinal means a plumbing fixture which receives only liquid body waste and, on demand, conveys the waste through a trap seal into a gravity drainage system, except such term does not include fixtures designed for installations in prisons.

Vented floor furnace means a self-contained vented heater suspended from the floor of the space being heated, taking air for combustion from outside this space. The vented floor furnace supplies heated air circulated by gravity or by a fan directly into the space to be heated through openings in the casing.

Vented home heating equipment or vented heater means a class of home heating equipment, not including furnaces, designed to furnish heated air to a space proximate to such heater, directly from the heater, without inlet duct connections (except that boots not to exceed 10 inches beyond the casing may be permitted), and with exhaust venting, and includes: Vented wall furnace, vented floor furnace, and vented room heater.

Vented room heater means a self-contained, free standing, nonrecessed, vented heater for furnishing heated air to the space in which it is installed. The vented room heater supplies heated air circulated by gravity or by a fan directly into the space to be heated through openings in the casing.

Vented wall furnace means a self-contained vented heater complete with grilles or the equivalent, designed for incorporation in, or permanent attachment to, a wall of a residence and furnishing heated air circulated by gravity or by a fan directly into the space to be heated through openings in the casing.

Vibration service lamp means a lamp that—

(1) Has filament configurations that are C–5, C–7A, or C–9, as listed in Figure 6–12 of the IESNA Lighting Handbook (incorporated by reference; *see* § 430.3) or similar configurations;

(2) Has a maximum wattage of 60 watts;

(3) Is sold at retail in packages of 2 lamps or less; and

(4) Is designated and marketed specifically for vibration service or vibration-resistant applications, with—

(i) The designation appearing on the lamp packaging; and

(ii) Marketing materials that identify the lamp as being vibration service only.

Voltage range means a band of operating voltages as marked on an incandescent lamp, indicating that the lamp is designed to operate at any voltage within the band.

Wall electric heater means an electric heater (excluding baseboard electric heaters) which is intended to be recessed in or surface mounted on walls, which transfers heat by radiation and/or convection (either natural or forced) and which includes forced convectors, natural convectors, radiant heaters, high wall or valance heaters.

Water closet means a plumbing fixture that has a water-containing receptor which receives liquid and solid body waste, and upon actuation, conveys the waste through an exposed integral trap seal into a gravity drainage system, except such term does not include fixtures designed for installation in prisons.

Water heater means a product which utilizes oil, gas, or electricity to heat potable water for use outside the heater upon demand, including—

(1) Storage type units which heat and store water at a thermostatically controlled temperature, including gas storage water heaters with an input of 75,000 Btu per hour or less, oil storage water heaters with an input of 105,000 Btu per hour or less, and electric storage water heaters with an input of 12 kilowatts or less;

(2) Instantaneous type units which heat water but contain no more than one gallon of water per 4,000 Btu per hour of input, including gas instantaneous water heaters with an input of 200,000 Btu per hour or less, oil instantaneous water heaters with an input of 210,000 Btu per hour or less, and electric instantaneous water heaters with an input of 12 kilowatts or less; and

(3) Heat pump type units, with a maximum current rating of 24 amperes at a voltage no greater than 250 volts, which are products designed to transfer thermal energy from one temperature level to a higher temperature level for the purpose of heating water, including all ancillary equipment such as fans, storage tanks, pumps, or controls necessary for the device to perform its function.

Water use means the quantity of water flowing through a showerhead, faucet, water closet, or urinal at point of use, determined in accordance with test procedures under appendices S and T of subpart B of this part.

Weatherized warm air furnace or boiler means a furnace or boiler designed for installation outdoors, approved for resistance to wind, rain, and snow, and supplied with its own venting system.

Whole-home dehumidifier means a dehumidifier that, in accordance with any manufacturer instructions available to a consumer, operates with ducting to deliver return process air to its inlet and to supply dehumidified process air from its outlet to one or more locations in the dehumidified space.

[42 FR 27898, June 1, 1977]

EDITORIAL NOTE: For FEDERAL REGISTER citations affecting § 430.2, see the List of CFR Sections Affected, which appears in the Finding Aids section of the printed volume and at *www.govinfo.gov*.

§ 430.3 Materials incorporated by reference.

(a) Certain material is incorporated by reference into this part with the approval of the Director of the Federal Register under 5 U.S.C. 552(a) and 1 CFR part 51. To enforce any edition other than that specified in this section, the U.S. Department of Energy (DOE) must publish a document in the FEDERAL REGISTER and the material must be available to the public. All approved incorporation by reference (IBR) material is available for inspection at the Department of Energy (DOE) and at the National Archives and Records Administration (NARA). Contact DOE at: The U.S. Department

of Energy, Office of Energy Efficiency and Renewable Energy, Building Technologies Office, EE–5B, 1000 Independence Avenue SW, Washington, DC 20585–0121, (202) 586–9127, *Buildings@ee.doe.gov*, *www.energy.gov/eere/buildings/appliance-and-equipment-standards-program*. For information on the availability of this material at NARA, visit *www.archives.gov/federal-register/cfr/ibr-locations.html* or email *fr.inspection@nara.gov*. The material may be obtained from the sources in the following paragraphs of this section.

(b) Air Movement and Control Association International, Inc. (AMCA), 30 West University Drive, Arlington Heights, IL 60004, (847) 394–0150, or by going to *https://www.amca.org/store/item.aspx?ItemId=81*.

(1) ANSI/AMCA 210–99, *Laboratory Methods of Testing Fans for Aerodynamic Performance Rating*, ANSI-approved December 2, 1999; IBR approved for appendices CC and CC1 to subpart B. (Co-published as ANSI/ASHRAE 51–1999.)

(2) ANSI/ASHRAE 51–07/ANSI/AMCA 210–07 (''ANSI/AMCA 210''), Laboratory Methods of Testing Fans for Certified Aerodynamic Performance Rating, AMCA approved July 28, 2006; IBR approved for appendix X1 to subpart B.

(3) ANSI/AMCA Standard 208–18, (''AMCA 208–18''), Calculation of the Fan Energy Index, ANSI approved January 24, 2018, IBR approved for appendix U to this subpart.

(4) ANSI/AMCA 210–07, ANSI/ASHRAE 51–07 (''AMCA 210–2007''), Laboratory Methods of Testing Fans for Certified Aerodynamic Performance Rating, ANSI approved August 17, 2007, Section 8—Report and Results of Test, Section 8.2—Performance graphical representation of test results, IBR approved for appendices M and M1 to subpart B, as follows:

(i) Figure 2A—Static Pressure Tap, and

(ii) Figure 12—Outlet Chamber Setup—Multiple Nozzles in Chamber.

(5) ANSI/AMCA Standard 230–15 (''AMCA 230–15''), *Laboratory Methods of Testing Air Circulating Fans for Rating and Certification*, ANSI-approved October 16, 2015; IBR approved for appendix U of subpart B.

(6) AMCA 230–15 Technical Errata 2021–05–05 (''AMCA 260–15 TE), *Technical Errata Sheet for ANSI/AMCA Standard 230–15: Density Corrections*, dated May 5, 2021; IBR approved for appendix U of subpart B.

(c) *AHRI*. Air-Conditioning, Heating, and Refrigeration Institute, 2111 Wilson Blvd, Suite 500, Arlington, VA 22201, 703–524–8800, or go to *https://www.ahrinet.org*.

(1) ANSI/AHRI 210/240–2008 with Addenda 1 and 2 (''AHRI 210/240–2008''), 2008 Standard for Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment, ANSI approved October 27, 2011 (Addendum 1 dated June 2011 and Addendum 2 dated March 2012), IBR approved for appendices M and M1 to subpart B, as follows:

(i) Section 6—Rating Requirements, Section 6.1—Standard Ratings, 6.1.3—Standard Rating Tests, 6.1.3.2—Electrical Conditions;

(ii) Section 6—Rating Requirements, Section 6.1—Standard Ratings, 6.1.3—Standard Rating Tests, 6.1.3.4—Outdoor-Coil Airflow Rate;

(iii) Section 6—Rating Requirements, Section 6.1—Standard Ratings, 6.1.3—Standard Rating Tests, 6.1.3.5—Requirements for Separated Assemblies;

(iv) Figure D1—Tunnel Air Enthalpy Test Method Arrangement;

(v) Figure D2—Loop Air Enthalpy Test Method Arrangement; and

(vi) Figure D4—Room Air Enthalpy Test Method Arrangement.

(2) AHRI Standard 1160–2009 (''AHRI 1160''), Performance Rating of Heat Pump Pool Heaters, 2009, IBR approved for appendix P to subpart B.

(3) ANSI/AHRI 1230–2010 with Addendum 2 (''AHRI 1230–2010''), 2010 Standard for Performance Rating of Variable Refrigerant Flow (VRF) Multi-Split Air-Conditioning and Heat Pump Equipment (including Addendum 1 dated March 2011), ANSI approved August 2, 2010 (Addendum 2 dated June 2014), IBR approved for appendices M and M1 to subpart B, as follows:

(i) Section 3—Definitions (except 3.8, 3.9, 3.13, 3.14, 3.15, 3.16, 3.23, 3.24, 3.26, 3.27, 3.28, 3.29, 3.30, and 3.31);

(ii) Section 5—Test Requirements, Section 5.1 (untitled), 5.1.3–5.1.4;

(iii) Section 6—Rating Requirements, Section 6.1—Standard Ratings, 6.1.5—Airflow Requirements for Systems with Capacities <65,000 Btu/h [19,000 W];

(iv) Section 6—Rating Requirements, Section 6.1—Standard Ratings, 6.1.6—Outdoor-Coil Airflow Rate (Applies to all Air-to-Air Systems);

(v) Section 6—Rating Requirements, Section 6.2—Conditions for Standard Rating Test for Air-cooled Systems < 65,000 Btu/h [19,000W] (except Table 8); and

(vi) Table 4—Refrigerant Line Length Correction Factors.

(d) *AATCC*. American Association of Textile Chemists and Colorists, P.O. Box 12215, Research Triangle Park, NC 27709, (919) 549–3526, or go to *www.aatcc.org*.

(1) AATCC Test Method 79–2010, Absorbency of Textiles, Revised 2010, IBR approved for Appendix J3 to Subpart B.

(2) AATCC Test Method 118–2007, Oil Repellency: Hydrocarbon Resistance Test, Revised 2007, IBR approved for Appendix J3 to Subpart B.

(3) AATCC Test Method 135–2010, Dimensional Changes of Fabrics after Home Laundering, Revised 2010, IBR approved for Appendix J3 to Subpart B.

(e) *ANSI*. American National Standards Institute, 25 W. 43rd Street, 4th Floor, New York, NY 10036, 212–642–4900, or go to *https://www.ansi.org*.

(1) ANSI C78.3–1991 (''ANSI C78.3''), American National Standard for Fluorescent Lamps-Instant-start and Cold-Cathode Types-Dimensional and Electrical Characteristics, approved July 15, 1991; IBR approved for § 430.32.

(2) ANSI C78.20–2003, Revision of ANSI C78.20–1995 (''ANSI C78.20''), American National Standard for electric lamps—A, G, PS, and Similar Shapes with E26 Medium Screw Bases, approved October 30, 2003; IBR approved for § 430.2.

(3) ANSI C78.21–1989, American National Standard for Electric Lamps—PAR and R Shapes, approved March 3, 1989, IBR approved for § 430.2.

(4) ANSI C78.21–2011 (R2016) (''ANSI C78.21–2016''), *American National Standard for Electric Lamps—PAR and R Shapes*, ANSI-approved August 23, 2016; IBR approved for § 430.2.

(5) ANSI C78.79–2014 (R2020) (''ANSI C78.79–2020''), *American National Standard for Electric Lamps—Nomenclature for Envelope Shapes Intended for Use with Electric Lamps*, ANSI-approved January 17, 2020; IBR approved for § 430.2.

(6) ANSI_ANSLG C78.81–2010, (''ANSI C78.81–2010''), American National Standard for Electric Lamps—Double-Capped Fluorescent Lamps— Dimensional and Electrical Characteristics, approved January 14, 2010, IBR approved for §§ 430.2 and 430.32 and appendix R to subpart B.

(7) ANSI C78.81–2016, American National Standard for Electric Lamps—Double-Capped Fluorescent Lamps—Dimensional and Electrical Characteristics, approved June 29, 2016, IBR approved for appendices Q and R to subpart B.

(8) ANSI C78.375–1997, Revision of ANSI C78.375–1991 (''ANSI C78.375''), American National Standard for Fluorescent Lamps—Guide for Electrical Measurements, first edition, approved September 25, 1997; IBR approved for appendix R to subpart B.

(9) ANSI C78.375A–2014 (R2020) (''ANSI C78.375A–2020'') *American National Standard for Electric Lamps—Fluorescent Lamps—Guide for Electrical Measures*, ANSI-approved January 17, 2020; IBR approved for appendix R to subpart B.

(10) ANSI_IEC C78.901–2005, (''ANSI C78.901–2005''), American National Standard for Electric Lamps—Single-Based Fluorescent Lamps—Dimensional and Electrical Characteristics, approved March 23, 2005; IBR approved for § 430.2 and appendix R to subpart B.

(11) ANSI C78.901–2014, American National Standard for Electric Lamps—Single-Based Fluorescent Lamps—Dimensional and Electrical Characteristics, ANSI approved July 2, 2014; IBR approved for appendix W to subpart B.

(12) ANSI/NEMA C78.901–2016 (''ANSI C78.901–2016''), American National Standard for Electric Lamps—Single-Based Fluorescent Lamps—Dimensional and Electrical Characteristics, ANSI approved August 23, 2016, IBR approved for appendices Q and R to subpart B.

(13) ANSI C79.1–1994, American National Standard for Nomenclature for Glass Bulbs—Intended for Use with Electric Lamps, approved March 24, 1994, IBR approved for § 430.2.

(14) ANSI C79.1–2002, American National Standard for Electric Lamps—Nomenclature for Glass Bulbs Intended for Use with Electric Lamps, approved September 16, 2002, IBR approved for § 430.2.

(15) ANSI__ANSLG__ C81.61–2006, Revision of ANSI C81.61–2005, (''ANSI C81.61''), American National Standard for electrical lamp bases—Specifications for Bases (Caps) for Electric Lamps, approved August 25, 2006, IBR approved for §§ 430.2; 430.32.

(16) ANSI C82.1–2004 (R2008, R2015), (''ANSI C82.1''), American National Standard for Lamp Ballasts—Line Frequency Fluorescent Lamp Ballasts, approved November 20, 2015; IBR approved for appendix Q to subpart B.

(17) ANSI C82.2–2002 (R2007, R2016), (''ANSI C82.2''), American National Standard for Lamp Ballasts—Method of Measurement of Fluorescent Lamp Ballasts, approved July 12, 2016, IBR approved for appendix Q to subpart B.

(18) ANSI C82.3–2016, (''ANSI C82.3''), American National Standard for Reference Ballasts for Fluorescent Lamps, approved April 8, 2016; IBR approved for appendices Q and R to subpart B.

(19) ANSI/NEMA C82.11–2017, (''ANSI C82.11''), American National Standard for Lamp Ballasts—High-Frequency Fluorescent Lamp Ballasts, approved January 23, 2017; IBR approved for appendix Q to subpart B.

(20) ANSI C82.13–2002 (''ANSI C82.13''), American National Standard for Lamp Ballasts—Definitions for Fluorescent Lamps and Ballasts, approved July 23, 2002; IBR approved for appendix Q to subpart B.

(21) ANSI C82.77–2002, (''ANSI C82.77'') Harmonic Emission Limits—Related Power Quality Requirements for Lighting Equipment, approved January 17, 2002; IBR approved for appendix Q to subpart B.

(22) ANSI/NEMA WD 6–2016, *Wiring Devices—Dimensional Specifications*, ANSI approved February 11, 2016, IBR approved for appendices Y and Y1 to subpart B; as follows:

(i) Figure 1–15—Plug and Receptacle; and

(ii) Figure 5–15—Plug and Receptacle.

(23) ANSI Z21.56–2006, section 2.10 (''ANSI Z21.56''), Standard for Gas-Fired Pool Heaters, approved December 13, 2005, IBR approved for appendix P to subpart B.

(24) ANSI Z21.50–2007 (CSA 2.22–2007), (''ANSI Z21.50''), Vented Gas Fireplaces, Fifth Edition, Approved February 22, 2007, IBR approved for § 430.2.

(25) [Reserved]

(26) ANSI Z21.88–2009 (CSA 2.33–2009), (''ANSI Z21.88''), Vented Gas Fireplace Heaters, Fifth Edition, Approved March 26, 2009, IBR approved for § 430.2.

NOTE 1 TO PARAGRAPH (e): The standards referenced in paragraphs (e)(4), (5), (7), (9), (12), (16), (17), (18), (19), and (21) of this section were all published by National Electrical Manufacturers Association (NEMA) and are also available from National Electrical Manufacturers Association, 1300 North 17th Street, Suite 900, Rosslyn, Virginia 22209, *https://www.nema.org/Standards/Pages/default.aspx*.

(f) *AS/NZS*. Australian/New Zealand Standard, GPO Box 476, Sydney NSW 2001, (02) 9237–6000 or (12) 0065–4646, or go to *www.standards.org.au/*Standards New Zealand, Level 10 Radio New Zealand House 144 The Terrace Wellington 6001 (Private Bag 2439 Wellington 6020), (04) 498–5990 or (04) 498–5991, or go to *www.standards.co.nz*.

(1) AS/NZS 4474.1:2007, Performance of Household Electrical Appliances—Refrigerating Appliances; Part 1: Energy Consumption and Performance, Second edition, published August 15, 2007, IBR approved for Appendix A to Subpart B.

(2) [Reserved]

(g) *ASHRAE*. American Society of Heating, Refrigerating, and Air-Conditioning Engineers, Inc., 180 Technology Parkway NW, Peachtree Corners, GA 30092; (800) 527–4723 or (404) 636–8400; *www.ashrae.org*.

(1) ANSI/ASHRAE Standard 16–2016 (''ANSI/ASHRAE 16''), Method of Testing for Rating Room Air Conditioners, Packaged Terminal Air Conditioners, and Packaged Terminal Heat Pumps for Cooling and Heating Capacity, ANSI approved November 1, 2016, IBR approved for appendix F to subpart B.

(2) ANSI/ASHRAE 23.1–2010, (''ASHRAE 23.1–2010''), Methods of Testing for Rating the Performance of Positive Displacement Refrigerant Compressors and Condensing Units

that Operate at Subcritical Temperatures of the Refrigerant, ANSI approved January 28, 2010, IBR approved for appendices M and M1 to subpart B, as follows:

(i) Section 5—Requirements;

(ii) Section 6—Instruments;

(iii) Section 7—Methods of Testing; and

(iv) Section 8—Compressor Testing.

(3) ANSI/ASHRAE Standard 37–2009 (''ASHRAE 37–2009''), *Methods of Testing for Rating Electrically Driven Unitary Air-Conditioning and Heat Pump Equipment*, ANSI-approved June 25, 2009; IBR approved for appendices CC and CC1 to subpart B.

(4) ANSI/ASHRAE Standard 37–2009, (''ANSI/ASHRAE 37–2009''), Methods of Testing for Rating Electrically Driven Unitary Air-Conditioning and Heat Pump Equipment, ANSI approved June 25, 2009, IBR approved for appendices M and M1 to subpart B, as follows:

(i) Section 5—Instruments, Section 5.1—Temperature Measuring Instruments: 5.1.1;

(ii) Section 5—Instruments, Section 5.2—Refrigerant, Liquid, and Barometric Pressure Measuring Instruments;

(iii) Section 5—Instruments, Section 5.5—Volatile Refrigerant Flow Measurement;

(iv) Section 6—Airflow and Air Differential Pressure Measurement Apparatus, Section 6.1—Enthalpy Apparatus (Excluding Figure 3): 6.1.1–6.1.2 and 6.1.4;

(v) Section 6—Airflow and Air Differential Pressure Measurement Apparatus, Section 6.2—Nozzle Airflow Measuring Apparatus (Excluding Figure 5);

(vi) Section 6—Airflow and Air Differential Pressure Measurement Apparatus, Section 6.3—Nozzles (Excluding Figure 6);

(vii) Section 6—Airflow and Air Differential Pressure Measurement Apparatus, Section 6.4—External Static Pressure Measurements;

(viii) Section 6—Airflow and Air Differential Pressure Measurement Apparatus, Section 6.5—Recommended Practices for Static Pressure Measurements;

(ix) Section 7—Methods of Testing and Calculation, Section 7.3—Indoor and Outdoor Air Enthalpy Methods (Excluding Table 1);

(x) Section 7—Methods of Testing and Calculation, Section 7.4—Compressor Calibration Method;

(xi) Section 7—Methods of Testing and Calculation, Section 7.5—Refrigerant Enthalpy Method;

(xii) Section 7—Methods of Testing and Calculation, Section 7.7—Airflow Rate Measurement, Section 7.7.2—Calculations—Nozzle Airflow Measuring Apparatus (Excluding Figure 10), 7.7.2.1–7.7.2.2;

(xiii) Section 8—Test Procedures, Section 8.1—Test Room Requirements: 8.1.2–8.1.3;

(xiv) Section 8—Test Procedures, Section 8.2—Equipment Installation;

(xv) Section 8—Test Procedures, Section 8.6—Additional Requirements for the Outdoor Air Enthalpy Method, Section 8.6.2;

(xvii) Section 8—Test Procedures, Section 8.6—Additional Requirements for the Outdoor Air Enthalpy Method, Table 2a—Test Tolerances (SI Units), and

(xviii) Section 8—Test Procedures, Section 8.6—Additional Requirements for the Outdoor Air Enthalpy Method, Table 2b—Test Tolerances (I–P Units);

(xix) Section 9—Data to be Recorded, Section 9.2—Test Tolerances; and

(xx) Section 9—Data to be Recorded, Table 3—Data to be Recorded.

(5) ANSI/ASHRAE Standard 37–2009 (RA 2019) (''ASHRAE 37–2009 (RA 2019)''), *Methods of Testing for Rating Electrically Driven Unitary Air-Conditioning and Heat Pump Equipment*, ASHRAE-approved June 21, 2019; IBR approved for appendix AA to subpart B.

(6) ANSI/ASHRAE Standard 37–2009 Errata Sheet (''ASHRAE 37–2009 Errata Sheet''), *Errata Sheet for ANSI/ASHRAE Standard 37–2009—Methods of Testing for Rating Electrically Driven Unitary Air-Conditioning and Heat Pump Equipment*, ASHRAE-approved March 27, 2019; IBR approved for appendix AA to subpart B.

(7) ASHRAE 41.1–1986 (Reaffirmed 2006) (''ASHRAE 41.1–1986''), *Standard Method for Temperature Measurement*, approved February 18, 1987; IBR approved for appendices AA, CC, and CC1 to subpart B.

(8) ANSI/ASHRAE 41.1–2013 (''ANSI/ASHRAE 41.1''), Standard Method for

Temperature Measurement, ANSI approved January 30, 2013; IBR approved for appendices F and X1 to subpart B.

(9) ANSI/ASHRAE Standard 41.1–2013, (''ANSI/ASHRAE 41.1–2013''), Standard Method for Temperature Measurement, ANSI approved January 30, 2013, IBR approved for appendix M to subpart B, as follows:

(i) Section 4—Classifications;

(ii) Section 5—Requirements, Section 5.3—Airstream Temperature Measurements;

(iii) Section 6—Instruments; and

(iv) Section 7—Temperature Test Methods (Informative).

(10) ANSI/ASHRAE Standard 41.1–2020 (''ASHRAE 41.1–2020''), *Standard Methods for Temperature Measurement,* ANSI-approved June 30, 2020; IBR approved for appendix E to subpart B.

(11) ANSI/ASHRAE Standard 41.2–1987 (RA 92), (''ASHRAE 41.2–1987 (RA 1992)''), Standard Methods for Laboratory Airflow Measurement, ANSI reaffirmed April 20, 1992, IBR approved for appendix F to subpart B.

(12) ANSI/ASHRAE Standard 41.2–1987 (RA 1992), (''ASHRAE 41.2–1987 (RA 1992)''), Standard Methods for Laboratory Airflow Measurement, ANSI reaffirmed April 20, 1992, Section 5—Section of Airflow-Measuring Equipment and Systems, IBR approved for appendix M to subpart B, as follows:

(i) Section 5.2—Test Ducts,, Section 5.2.2—Mixers, 5.2.2.1—Performance of Mixers (excluding Figures 11 and 12 and Table 1); and

(ii) Figure 14—Outlet Chamber Setup for Multiple Nozzles in Chamber.

(13) ANSI/ASHRAE Standard 41.3–2014, (''ASHRAE 41.3–2014''), Standard Methods for Pressure Measurement, ANSI approved July 3, 2014, IBR approved for appendix F to subpart B.

(14) ANSI/ASHRAE Standard 41.6–1994 (RA 2006) (''ASHRAE 41.6–1994''), *Standard Method for Measurement of Moist Air Properties,* ANSI-reaffirmed January 27, 2006; IBR approved for appendices CC and CC1 to subpart B.

(15) ANSI/ASHRAE Standard 41.6–2014, (''ASHRAE 41.6–2014''), Standard Method for Humidity Measurement, ANSI approved July 3, 2014, IBR approved for appendices E, F, and EE to subpart B.

(16) ANSI/ASHRAE Standard 41.6–2014, (''ASHRAE 41.6–2014''), Standard Method for Humidity Measurement, ANSI approved July 3, 2014, IBR approved for appendix M to subpart B, as follows:

(i) Section 4—Classifications;

(ii) Section 5—Requirements;

(iii) Section 6—Instruments and Calibration; and

(iv) Section 7—Humidity Measurement Methods.

(17) ANSI/ASHRAE 41.9–2011, (''ASHRAE 41.9–2011''), Standard Methods for Volatile-Refrigerant Mass Flow Measurements Using Calorimeters, ANSI approved February 3, 2011, IBR approved for appendix M to subpart B, as follows:

(i) Section 5—Requirements;

(ii) Section 6—Instruments;

(iii) Section 7—Secondary Refrigerant Calorimeter Method;

(iv) Section 8—Secondary Fluid Calorimeter Method;

(v) Section 9—Primary Refrigerant Calorimeter Method; and

(vi) Section 11—Lubrication Circulation Measurements.

(18) ANSI/ASHRAE Standard 41.11–2014, (''ASHRAE 41.11–2014''), Standard Methods for Power Measurement, ANSI approved July 3, 2014, IBR approved for appendix F to subpart B.

(19) ANSI/ASHRAE Standard 103–1993, (''ASHRAE 103–1993''), Methods of Testing for Annual Fuel Utilization Efficiency of Residential Central Furnaces and Boilers, (with Errata of October 24, 1996), except for sections 7.1, 7.2.2.2, 7.2.2.5, 7.2.3.1, 7.8, 8.2.1.3, 8.3.3.1, 8.4.1.1, 8.4.1.1.2, 8.4.1.2, 8.4.2.1.4, 8.4.2.1.6, 8.6.1.1, 8.7.2, 8.8.3, 9.1.2.2.1, 9.1.2.2.2, 9.5.1.1, 9.5.1.2.1, 9.5.1.2.2, 9.5.2.1, 9.7.1, 9.7.4, 9.7.6, 9.10, 11.5.11.1, 11.5.11.2 and appendices B and C, approved October 4, 1993, IBR approved for § 430.23 and appendix N to subpart B.

(20) ANSI/ASHRAE Standard 103–2017 (''ASHRAE 103–2017''), Method of Testing for Annual Fuel Utilization Efficiency of Residential Central Furnaces and Boilers, ANSI-approved July 3, 2017; IBR approved for § 430.23 and appendices O, AA, and EE to subpart B.

(21) ANSI/ASHRAE Standard 116–2010, (''ASHRAE 116–2010''), Methods of Testing for Rating Seasonal Efficiency of Unitary Air Conditioners and Heat

Pumps, ANSI approved February 24, 2010, Section 7—Methods of Test, Section 7.4—Air Enthalpy Method—Indoor Side (Primary Method), Section 7.4.3—Measurements, Section 7.4.3.4—Temperature, Section 7.4.3.4.5, IBR approved for appendices M and M1 to subpart B.

(22) ANSI/ASHRAE Standard 118.2–2022 (''ASHRAE 118.2–2022''), *Method of Testing for Rating Residential Water Heaters and Residential-Duty Commercial Water Heaters,* ANSI-approved March 1, 2022; IBR approved for appendix E to subpart B.

(23) ANSI/ASHRAE Standard 146–2011 (''ASHRAE 146''), Method of Testing and Rating Pool Heaters, ASHRAE approved February 2, 2011, IBR approved for appendix P to subpart B.

(24) 2021 ASHRAE Handbook—Fundamentals Inch-Pound Edition, Chapter 1, ''Psychrometrics'' (''2021 ASHRAE Handbook''), copyright 2021; IBR approved for appendix AA to subpart B.

(h) *ASME.* American Society of Mechanical Engineers, Three Park Avenue, New York, NY 10016–5990, 1–800 843–2763, or go to *www.asme.org.*

(1) ASME A112.18.1–2018/CSA B125.1–2018, (''ASME A112.18.1''), Plumbing supply fittings, CSA-published July 2018; IBR approved for appendix S to subpart B.

(2) ASME A112.19.2–2008, (''ASME A112.19.2–2008''), ''Ceramic plumbing fixtures,'' sections 7.1, 7.1.1, 7.1.2, 7.1.3, 7.1.4, 7.1.5, 7.4, 8.2, 8.2.1, 8.2.2, 8.2.3, 8.6, Table 5, and Table 6 approved August 2008, including Update No. 1, dated August 2009, and Update No. 2, dated March 2011, IBR approved for § 430.2 and appendix T to subpart B.

(3) ASME A112.19.2–2018/CSA B45.1–18 (''ASME A112.19.2–2018''), ''Ceramic plumbing fixtures'', July 2018 (including Errata—October 2018); IBR approved for appendix T to subpart B.

(i) *AHAM.* Association of Home Appliance Manufacturers, 1111 19th Street NW, Suite 402, Washington, DC 20036, 202–872–5955, or go to *https:////www.aham.org.*

(1) ANSI/AHAM AC–1–2020, (''AHAM AC–1–2020''), *Method for Measuring Performance of Portable Household Electric Room Air Cleaners,* ANSI-approved December 14, 2020, including AHAM Standard Interpretation dated September 19, 2022; IBR approved for appendix FF to subpart B.

(2) AHAM AC–7–2022, *Energy Test Method for Consumer Room Air Cleaners,* copyright 2022; IBR approved for § 430.2 and appendix FF to subpart B.

(3) AHAM DH–1–2022, *Energy Measurement Test Procedure for Dehumidifiers,* copyright 2022; IBR approved for appendix X1 to subpart B.

(4) AHAM DW–1–2020, Uniform Test Method for Measuring the Energy Consumption of Dishwashers, copyright 2020; IBR approved for § 430.32; appendices C1 and C2 to subpart B.

(5) AHAM DW–2–2020, Household Electric Dishwashers, copyright 2020; IBR approved for appendices C1 and C2 to subpart B.

(6) ANSI/AHAM HLD–1–2010 (''AHAM HLD–1''), Household Tumble Type Clothes Dryers, ANSI-approved June 11, 2010, IBR approved for appendices D1 and D2 to subpart B of this part.

(7) AHAM HRF–1–2019 (''HRF–1–2019''), Energy and Internal Volume of Consumer Refrigeration Products, Copyright © 2019, IBR approved for appendices A and B to subpart B of this part.

(8) ANSI/AHAM PAC–1–2015, (''ANSI/AHAM PAC–1–2015''), Portable Air Conditioners, June 19, 2015, IBR approved for appendix CC to subpart B of this part.

(9) AHAM PAC–1–2022, *Energy Measurement Test Procedure for Portable Air Conditioners,* Copyright 2022; IBR approved for appendix CC1 to subpart B of this part.

(10) AHAM RAC–1–2020 (''AHAM RAC–1''), Energy Measurement Test Procedure for Room Air Conditioners, approved 2020, IBR approved for appendix F to subpart B.

(j) *ASTM.* ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428–2959; 877–909–2786; *service@astm.org; www.astm.org.*

(1) ASTM D2156–09 (Reapproved 2013) (''ASTM D2156R13''), *Standard Test Method for Smoke Density in Flue Gases from Burning Distillate Fuels,* approved October 1, 2013; IBR approved for appendix N to subpart B.

(2) ASTM D2156–09 (Reapproved 2018) (''ASTM D2156 (R2018)''), *Standard Test Method for Smoke Density in Flue Gases*

from Burning Distillate Fuels, approved October 1, 2018; IBR approved for appendices E, O, and EE to subpart B.

(3) ASTM E97–82 (Reapproved 1987) (''ASTM E97–1987''), *Standard Test Method for Directional Reflectance Factor, 45-deg 0-deg, of Opaque Specimens by Broad-Band Filter Reflectometry*, ASTM-approved October 29, 1982; IBR approved for appendix E to subpart B.

NOTE 2 TO PARAGRAPH (J)(3): ASTM E97–1987 was withdrawn in 1991. It is reasonably available from standards resellers including GlobalSpec's Engineering 360 (*https://standards.globalspec.com/std/3801495/astm-e97-82-1987*) and IHS Markit (*https://global.ihs.com/doc_detail.cfm?document_name=ASTM%20E97&item_s_key=00020483*).

(4) ASTM E741–11 (Reapproved 2017) (''ASTM E741–11(2017)''), Standard Test Method for Determining Air Change in a Single Zone Means of a Tracer Gas Dilution Approved Sept. 1, 2017; IBR approved for appendix FF to subpart B.

(k) *CSA*. CSA Group, 178 Rexdale Blvd., Toronto, ON, Canada M9W 1R3, 1–800–463–6727 or 416–747–4044, *www.csagroup.org*.

(1) ANSI Z21.86–2016 • CSA 2.32–2016 (''ANSI Z21.86–2016''), Vented gas-fired space heating appliances, ANSI-approved December 21, 2016; IBR approved for appendix O to subpart B.

(2) CSA C374:11 (R2021), Energy performance of hot tubs and spas, published November 2011, Update No. 1—National Standard of Canada—April 2012; IBR approved for appendix GG to subpart B of this part.

(l) *CEA*. Consumer Electronics Association, Technology & Standards Department, 1919 S. Eads Street, Arlington, VA 22202, 703–907–7600, or go to *www.CE.org*.

(1) CEA Standard, CEA–770.3–D, *High Definition TV Analog Component Video Interface*, published February 2008; IBR approved for § 430.2.

(2) [Reserved]

(m) *CIE*. Commission Internationale de l'Eclairage (CIE), Central Bureau, Kegelgasse 27, A–1030, Vienna, Austria, 011 + 43 1 714 31 87 0, or go to *https://www.cie.co.at*.

(1) CIE 13.3–1995 (''CIE 13.3''), Technical Report: Method of Measuring and Specifying Colour Rendering Properties of Light Sources, 1995, ISBN 3 900 734 57 7; IBR approved for § 430.2 and appendices R and W to subpart B.

(2) CIE 15:2004 (''CIE 15''), Technical Report: Colorimetry, 3rd edition, 2004, ISBN 978 3 901906 33 6; IBR approved for appendix W to subpart B.

(3) CIE 015:2018 (''CIE 15:2018''), *Colorimetry*, 4th edition, copyright 2018; IBR approved for the appendix R to subpart B.

(n) CTA. Consumer Technology Association, 1919 S. Eads Street, Arlington, VA 22202; 703–907–7600; *www.cta.tech*.

(1) ANSI/CTA–2037–D, Determination of Television Set Power Consumption, September 2022; IBR approved for appendix H to subpart B.

(2) [Reserved]

(o) *Environmental Protection Agency (EPA)*, ENERGY STAR documents published by the Environmental Protection Agency are available online at *https://www.energystar.gov* or by contacting the Energy Star hotline at 1–888–782–7937.

(1) ENERGY STAR Testing Facility Guidance Manual: Building a Testing Facility and Performing the Solid State Test Method for ENERGY STAR Qualified Ceiling Fans, Version 1.1, approved December 9, 2002, IBR approved for appendix U to subpart B.

(2) Energy Star Program Requirements for Single Voltage External Ac-Dc and Ac-Ac Power Supplies, Eligibility Criteria (Version 2.0), effective date for EPS Manufacturers November 1, 2008, IBR approved for subpart C, § 430.32.

(p) *HDMI®*. High-Definition Multimedia Interface Licensing, LLC, 1140 East Arques Avenue, Suite 100, Sunnyvale, CA 94085, 408–616–1542, or go to *www.hdmi.org*.

(1) HDMI Specification Informational Version 1.0, *High-Definition Multimedia Interface Specification*, published September 4, 2003; IBR approved for § 430.2.

(2) [Reserved]

(q) *IEC*. International Electrotechnical Commission, 3 Rue de Varembe, Case Postale 131, 1211 Geneva 20, Switzerland; *https://webstore.iec.ch/*.

(1) IEC Standard 933–5:1992, (''IEC 60933–5 Ed. 1.0''), *Audio, video and audiovisual systems—Interconnections and matching values—Part 5: Y/C connector for video systems—Electrical matching values and description of the connector*, First Edition, 1992–12; IBR approved for

§ 430.2. (Note: IEC 933–5 is also known as IEC 60933–5.)

(2) IEC 60081:1997/AMD6, (''IEC 60081''), Double-capped fluorescent lamps—Performance specifications (Amendment 6, Edition 5.0, August 2017); IBR approved for appendix Q to subpart B.

(3) IEC 60350–2, (''IEC 60350–2''), *Household electric cooking appliances Part 2: Hobs—Methods for measuring performance*, Edition 2.1, 2021–05; IBR approved for appendix I1 to subpart B.

(4) IEC 62040–3:2021 (''IEC 62040–3 Ed. 3.0'') *Uninterruptible power systems (UPS)—Part 3: Method of specifying the performance and test requirements*, Edition 3.0, 2021–04; IBR approved for appendices Y and Y1 to subpart B.

(5) IEC 62301, *Household electrical appliances—Measurement of standby power*, first edition, June 2005; IBR approved for appendices I, I1 to subpart B.

(6) IEC 62301 (''IEC 62301''), *Household electrical appliances—Measurement of standby power*, (Edition 2.0, 2011–01); IBR approved for appendices C1, C2, D1, D2, F, G, I, I1, J, J2, N, O, P, Q, U, X1, Y, Y1, Z, BB, CC, CC1, EE, and FF to subpart B.

(7) IEC 62301, (''IEC 62301–DD''), Household electrical appliances—Measurement of standby power, (Edition 2.0, 2011–01); Section 5—Measurements, IBR approved for appendix DD to subpart B.

(8) IEC 62301, (''IEC 62301–W''), Household electrical appliances—Measurement of standby power, (Edition 2.0, 2011–01), Section 5—Measurements, IBR approved for appendix W to subpart B.

(r) *IES*. Illuminating Engineering Society (formerly Illuminating Engineering Society of North America—IESNA), 120 Wall Street, Floor 17, New York, NY 10005–4001, 212–248–5000, or go to *www.ies.org*.

(1) *The IESNA Lighting Handbook, Reference & Application*, (''The IESNA Lighting Handbook''), 9th ed., Chapter 6, ''Light Sources,'' July 2000, IBR approved for § 430.2.

(2) IES LM–9–09, (''IES LM–9''), IES Approved Method for the Electrical and Photometric Measurement of Fluorescent Lamps, approved January 31, 2009; IBR approved for § 430.2.

(3) IES LM–9–09 (''IES LM–9–09–DD''), IES Approved Method for the Electrical and Photometric Measurement of Fluorescent Lamps, approved January 31, 2009; IBR approved for appendix DD to subpart B, as follows:

(i) Section 4.0—Ambient and Physical Conditions;

(ii) Section 5.0—Electrical Conditions;

(iii) Section 6.0—Lamp Test Procedures; and

(iv) Section 7.0—Photometric Test Procedures: Section 7.5—Integrating Sphere Measurement.

(4) ANSI/IES LM–9–20 (''IES LM–9–20''), *Approved Method: Electrical and Photometric Measurements of Fluorescent Lamps*, ANSI-approved February 7, 2020; IBR approved for appendices R and V to subpart B.

(5) IESNA LM–16–1993 (''IESNA LM–16''), IESNA Practical Guide to Colorimetry of Light Sources, December 1993, IBR approved for § 430.2.

(6) IES LM–20–13, IES Approved Method for Photometry of Reflector Type Lamps, approved February 4, 2013; IBR approved for appendix DD to subpart B, as follows:

(i) Section 4.0—Ambient and Physical Conditions;

(ii) Section 5.0—Electrical and Photometric Test Conditions;

(iii) Section 6.0—Lamp Test Procedures; and

(iv) Section 8.0—Total Flux Measurements by Integrating Sphere Method.

(7) ANSI/IES LM–20–20 (''IES LM–20–20''), *Approved Method: Photometry of Reflector Type Lamps*, ANSI-approved February 7, 2020; IBR approved for appendix R to subpart B.

(8) IES LM–45–15, IES Approved Method for the Electrical and Photometric Measurement of General Service Incandescent Filament Lamps, approved August 8, 2015; IBR approved for appendix DD to subpart B as follows:

(i) Section 4.0—Ambient and Physical Conditions;

(ii) Section 5.0—Electrical Conditions;

(iii) Section 6.0—Lamp Test Procedures; and

(iv) Section 7.0—Photometric Test Procedures: Section 7.1—Total Luminous Flux Measurements with an Integrating Sphere.

(9) IES LM–45–20 (''IES LM–45–20''), *Approved Method: Electrical and Photometric Measurement of General Service*

Incandescent Filament Lamps, ANSI-approved February 7, 2020; IBR approved for appendix R to subpart B.

(10) ANSI/IES LM–49–20 (''IES LM–49–20''), *Approved Method: Life Testing of Incandescent Filament Lamps*, ANSI-approved February 7, 2020; IBR approved for appendix R to subpart B.

(11) IES LM–54–12, IES Guide to Lamp Seasoning, approved October 22, 2012; IBR approved for appendix W to subpart B, as follows:

(i) Section 4—Physical/Environmental Test Conditions;

(ii) Section 5—Electrical Test Conditions;

(iii) Section 6—Test Procedure Requirements: Section 6.1—Test Preparation; and

(iv) Section 6—Test Procedure Requirements, Section 6.2—Seasoning Test Procedures: Section 6.2.2.1—Discharge Lamps: Discharge Lamps except T5 fluorescent.

(12) ANSI/IES LM–54–20 (''IES LM–54–20''), *Approved Method: IES Guide to Lamp Seasoning*, ANSI-approved February 7, 2020; IBR approved for appendices R and V to subpart B.

(13) ANSI/IES LM–58–20 (''IES LM–58–20''), *Approved Method: Spectroradiometric Measurement Methods for Light Sources;* ANSI-approved February 7, 2020; IBR approved for appendix R to subpart B.

(14) IES LM–65–14, IES Approved Method for Life Testing of Single-Based Fluorescent Lamps, approved December 30, 2014; IBR approved for appendix W to subpart B, as follows:

(i) Section 4.0—Ambient and Physical Conditions;

(ii) Section 5.0—Electrical Conditions; and

(iii) Section 6.0—Lamp Test Procedures

(15) IES LM–66–14, (''IES LM–66''), IES Approved Method for the Electrical and Photometric Measurements of Single-Based Fluorescent Lamps, approved December 30, 2014; IBR approved for appendix W to subpart B, as follows:

(i) Section 4.0—Ambient and Physical Conditions;

(ii) Section 5.0—Power Source Characteristics; and

(iii) Section 6.0—Testing Procedures Requirements.

(16) ANSI/IES LM–75–19 (''IES LM–75–19''), Approved Method: Guide to Goniophotometer Measurements and Types, and Photometric Coordinate Systems, ANSI-approved November 22, 2019; IBR approved for appendix V to subpart B.

(17) IESNA LM–78–07, IESNA Approved Method for Total Luminous Flux Measurement of Lamps Using an Integrating Sphere Photometer, approved January 28, 2007; IBR approved for appendix W to subpart B.

(18) ANSI/IES LM–78–20 (''IES LM–78–20'') *Approved Method: Total Luminous Flux Measurement of Lamps Using an Integrating Sphere Photometer*, ANSI-approved February 7, 2020; IBR approved for appendices R and V to subpart B.

(19) IES LM–79–08, (''IES LM–79–08''), IES Approved Method for the Electrical and Photometric Measurements of Solid-State Lighting Products, approved December 31, 2007; IBR approved for appendix BB to subpart B.

(20) IES LM–79–08 (''IES LM–79–08–DD''), Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products, approved December 31, 2007; IBR approved for appendix DD to subpart B as follows:

(i) Section 1.0 Introduction: Section 1.3—Nomenclature and Definitions (except section 1.3f);

(ii) Section 2.0—Ambient Conditions;

(iii) Section 3.0—Power Supply Characteristics;

(iv) Section 5.0—Stabilization of SSL Product;

(v) Section 7.0—Electrical Settings;

(vi) Section 8.0—Electrical Instrumentation;

(vii) Section 9.0—Test Methods for Total Luminous Flux measurement: Section 9.1 Integrating sphere with a spectroradiometer (Sphere-spectroradiometer system); and Section 9.2—Integrating sphere with a photometer head (Sphere-photometer system).

(21) ANSI/IES LM–79–19 (''IES LM–79–19''), Approved Method: Optical and Electrical Measurements of Solid-State Lighting Products, ANSI-approved May 14, 2019; IBR approved for appendix V to subpart B.

(22) IES LM–84–14, (''IES LM–84''), Approved Method: Measuring Luminous Flux and Color Maintenance of

LED Lamps, Light Engines, and Luminaires, approved March 31, 2014; IBR approved for appendix BB to subpart B.

(23) ANSI/IES RP–16–10 (''ANSI/IES RP–16''), Nomenclature and Definitions for Illuminating Engineering, approved October 15, 2005; IBR approved for § 430.2.

(24) IES TM–28–14, (''IES TM–28''), Projecting Long-Term Luminous Flux Maintenance of LED Lamps and Luminaires, approved May 20, 2014; IBR approved for appendix BB to subpart B.

(s) International Safety Equipment Association, 1901 North Moore Street, Suite 808, Arlington, Virginia 22209, (703) 525–1695, *www.safetyequipment.org*.

(1) ANSI/ISEA Z358.1–2014 (''ISEA Z358.1''), American National Standard for Emergency Eyewash and Shower Equipment, ANSI-approved January 8, 2015, IBR approved for § 430.2.

(2) [Reserved]

(t) *U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy*. Resource Room of the Building Technologies Program, 950 L'Enfant Plaza SW., 6th Floor, Washington, DC 20024, 202–586–2945, (Energy Star materials are also found at *https://www.energystar.gov*.)

(1) ITU–R BT.470–6, Conventional Television Systems, published November 1998; IBR approved for § 430.2.

(2) [Reserved]

(3) International Efficiency Marking Protocol for External Power Supplies, Version 3.0, September 2013, IBR approved for § 430.32.

(u) *NSF International*. NSF International, P.O. Box 130140, 789 North Dixboro Road, Ann Arbor, MI 48113–0140, 1–800–673–6275, or go to *https://www.nsf.org*.

(1) NSF/ANSI 51–2007 (''NSF/ANSI 51''), Food equipment materials, revised and adopted April 2007, IBR approved for §§ 430.2 and 430.32.

(2) [Reserved]

(v) *Optical Society of America*. *Optical Society of America*, 2010 Massachusetts Ave., NW., Washington, DC 20036–1012, 202–223–8130, or go to *https://www.opticsinfobase.org;*

(1) ''Computation of Correlated Color Temperature and Distribution Temperature,'' A.R. Robertson, Journal of the Optical Society of America, Volume 58, Number 11, November 1968, pages 1528–1535, IBR approved for § 430.2.

(2) [Reserved]

(w) *PHTA*. Pool & Hot Tub Alliance, 2111 Eisenhower Avenue, Suite 500, Alexandria, VA 22314 (*www.phta.org*), (703) 838–0083.

(1) ANSI/APSP/ICC–14 2019, American National Standard for Portable Electric Spa Energy Efficiency, ANSI-approved November 19, 2019; IBR approved for appendix GG to subpart B of this part.

(2) [Reserved]

(x) *SMPTE*. Society of Motion Picture and Television Engineers, 3 Barker Ave., 5th Floor, White Plains, NY 10601, 914–761–1100, or go to *https://standards.smpte.org*.

(1) SMPTE 170M–2004, (''SMPTE 170M–2004''), *SMPTE Standard for Television—Composite Analog Video Signal—NTSC for Studio Applications*, approved November 30, 2004; IBR approved for § 430.2.

(2) [Reserved]

(y) *UL*. Underwriters Laboratories, Inc., 2600 NW. Lake Rd., Camas, WA 98607–8542 (*www.UL.com*)

(1) UL 729 (''UL 729–2016''), Standard for Safety for Oil-Fired Floor Furnaces, Sixth Edition, dated August 29, 2003, including revisions through November 22, 2016; IBR approved for appendix O to subpart B.

(2) UL 730 (''UL 730–2016''), Standard for Safety for Oil-Fired Wall Furnaces, Fifth Edition, dated August 29, 2003, including revisions through November 22, 2016; IBR approved for appendix O to subpart B.

(3) UL 896 (''UL 896–2016''), Standard for Safety for Oil-Burning Stoves, Fifth Edition, dated July 29, 1993; including revisions through November 22, 2016, IBR approved for appendix O to subpart B.

(4) UL 1598C (''UL 1598C–2016''), *Standard for Safety for Light-Emitting Diode (LED) Retrofit Luminaire Conversion Kits*, First edition, dated January 16, 2014 (including revisions through November 17, 2016); IBR approved for § 430.2.

[74 FR 12066, Mar. 23, 2009]

EDITORIAL NOTE: For FEDERAL REGISTER citations affecting § 430.3, see the List of CFR Sections Affected, which appears in the

Finding Aids section of the printed volume and at *www.govinfo.gov*.

§ 430.4 Sources for information and guidance.

(a) *General.* The standards listed in this paragraph are referred to in the DOE test procedures and elsewhere in this part but are not incorporated by reference. These sources are given here for information and guidance.

(b) *IESNA.* Illuminating Engineering Society of North America, 120 Wall Street, Floor 17, New York, NY 10005–4001, 212–248–5000, or go to *http://www.iesna.org*.

(1) *Illuminating Engineering Society of North America Lighting Handbook,* 8th Edition, 1993.

(2) [Reserved]

(c) *IEEE.* Institute of Electrical and Electronics Engineers, Inc., 3 Park Avenue, 17th Floor, New York, NY, 10016–5997, 212–419–7900, or go to *http://www.ieee.org*.

(1) IEEE 1515–2000, IEEE Recommended Practice for Electronic Power Subsystems: Parameter Definitions, Test Conditions, and Test Methods, March 30, 2000.

(2) IEEE 100, Authoritative Dictionary of IEEE Standards Terms, 7th Edition, January 1, 2006.

(d) *IEC.* International Electrotechnical Commission, available from the American National Standards Institute, 11 W. 42nd Street, New York, NY 10036, 212–642–4936, or go to *http://www.iec.ch*.

(1) IEC 62301, Household electrical appliances—Measurement of standby power, First Edition, June 13, 2005.

(2) IEC 60050, International Electrotechnical Vocabulary.

(e) National Voluntary Laboratory Accreditation Program, Standards Services Division, NIST, 100 Bureau Drive, Stop 2140, Gaithersburg, MD 20899–2140, 301–975–4016, or go to *http://ts.nist.gov/standards/accreditation*.

(1) National Voluntary Laboratory Accreditation Program Handbook 150–01, Energy Efficient Lighting Products, Lamps and Luminaires, August 1993.

(2) [Reserved]

[74 FR 12066, Mar. 23, 2009]

§ 430.5 Error correction procedures for energy conservation standards rules.

(a) *Scope and purpose.* The regulations in this section describe an optional procedure through which the Department of Energy may accept and consider submissions regarding possible Errors in its rules under the Energy Policy and Conservation Act, as amended (42 U.S.C. 6291–6317). This section applies to rules establishing or amending energy conservation standards under the Act, except that this section does not apply to direct final rules issued pursuant to section 325(p)(4) of the Act (42 U.S.C. 6295(p)(4)).

(b) *Definitions.*

Act means the Energy Policy and Conservation Act of 1975, as amended (42 U.S.C. 6291–6317).

Error means an aspect of the regulatory text of a rule that is inconsistent with what the Secretary intended regarding the rule at the time of posting. Examples of possible mistakes that might give rise to Errors include:

(i) A typographical mistake that causes the regulatory text to differ from how the preamble to the rule describes the rule;

(ii) A calculation mistake that causes the numerical value of an energy conservation standard to differ from what technical support documents would justify; or

(iii) A numbering mistake that causes a cross-reference to lead to the wrong text.

Rule means a rule establishing or amending an energy conservation standard under the Act.

Secretary means the Secretary of Energy or an official with delegated authority to perform a function of the Secretary of Energy under this section.

(c) *Posting of rules.* (1) It is within in the sole discretion of the Secretary to make a rule available to the public to review for Errors in the document's regulatory text.

(2) If a rule is made available for review, the Secretary ordinarily will keep the document posted for a period of 45 calendar days, but the Secretary in his or her discretion (while remaining consistent with his or her statutory obligations under EPCA and other

legal obligations when promulgating an energy conservation standard) may shorten or lengthen the time period during which the rule document is posted.

(3) Any rule document posted pursuant to paragraph (c)(1) of this section shall bear the following disclaimer: *Notice:* The text of this rule is subject to correction based on the identification of errors as defined in 10 CFR 430.5 before publication in the FEDERAL REGISTER. Readers are requested to notify the United States Department of Energy, by email at [EMAIL ADDRESS PROVIDED IN POSTED NOTICE], of any typographical or other errors, as described in such regulations, by no later than midnight on [DATE SPECIFIED IN THE POSTING OF THE DOCUMENT ON THE DEPARTMENT'S WEBSITE], in order that DOE may make any necessary corrections in the regulatory text submitted to the Office of the Federal Register for publication.

(d) *Request for error-correction review.* (1) A person identifying an Error subject to this section may request that the Secretary review a potential Error. Such a request must ordinarily be submitted within 45 calendar days of the posting of the rule pursuant to paragraph (c)(1) of this section. The Secretary in his or her discretion may shorten or lengthen the time period during which such requests may be submitted.

(2)(i) A request under this section must identify a potential Error with particularity. The request must specify the regulatory text claimed to be erroneous. The request must also provide text that the requester contends would be a correct substitute. If a requester is unable to identify a correct substitute, the requester may submit a request that states that the requester is unable to determine what text would be correct and explains why the requester is unable to do so. The request must also substantiate the claimed Error by citing evidence from the existing record of the rulemaking, demonstrating that the regulatory text of the rule is inconsistent with what the Secretary intended the text to be.

(ii) A person's disagreement with any policy choices or discretionary decisions that are contained in the rule will not constitute a valid basis for a request under this section. All policy and discretionary decisions with regard to whether to establish or amend any conservation standard and, if so, the appropriate level at which to amend or establish that standard, remain within the sole discretion of the Secretary without regard to the procedures established in this section.

(3) The evidence to substantiate a request (or evidence of the Error itself) must be in the record of the rulemaking at the time of posting the rule, which may include an accompanying preamble. The Secretary will not consider new evidence submitted in connection with an error-correction request.

(4) A request under this section must be filed in electronic format by email to the address that the disclaimer to the rule designates for error-correction requests. Should filing by email not be feasible, the requester should contact the program point of contact designated in the rule order to ascertain an appropriate alternative means of filing an error-correction request.

(5) A request that does not comply with the requirements of this section will not be considered.

(e) *Correction of rules.* The Secretary may respond to a request for correction under paragraph (d) of this section or address an Error discovered on the Secretary's own initiative by submitting to the Office of the Federal Register either a corrected rule or the rule as previously posted.

(f) *Publication in the Federal Register.* (1) If, after receiving one or more properly filed requests for correction, the Secretary decides not to undertake any corrections, the Secretary will submit the rule for publication to the Office of the Federal Register as it was posted pursuant to paragraph (c)(1) of this section.

(2) If the Secretary receives no properly filed requests after posting a rule and identifies no Errors on the Secretary's own initiative, the Secretary will submit the rule, as it was posted pursuant to paragraph (c)(1) of this section, to the Office of the Federal Register for publication. This will occur after the period prescribed pursuant to

paragraph (c)(2) of this section has elapsed.

(3) If the Secretary receives a properly filed request after posting a rule pursuant to paragraph (c)(1) of this section and determines that a correction is necessary, or discovers an Error on the Secretary's own initiative, the Secretary will, absent extenuating circumstances, submit a corrected rule for publication in the FEDERAL REGISTER within 30 days after the period prescribed by paragraph (c)(2) of this section has elapsed.

(4) Consistent with the Act, compliance with an energy conservation standard will be required upon the specified compliance date as published in the relevant rule in the FEDERAL REGISTER.

(5) Consistent with the Administrative Procedure Act, and other applicable law, the Secretary will ordinarily designate an effective date for a rule under this section that is no less than 30 days after the publication of the rule in the FEDERAL REGISTER.

(6) When the Secretary submits a rule for publication, the Secretary will make publicly available a written statement indicating how any properly filed requests for correction were handled.

(g) *Alteration of standards.* Until an energy conservation standard has been published in the FEDERAL REGISTER, the Secretary may correct such standard, consistent with the Administrative Procedure Act.

(h) *Judicial review.* For determining the prematurity, timeliness, or lateness of a petition for judicial review pursuant to section 336(b) of the Act (42 U.S.C. 6306), a rule is considered ''prescribed'' on the date when the rule is published in the FEDERAL REGISTER.

[81 FR 57757, Aug. 24, 2016, as amended at 89 FR 22924, Apr. 3, 2024

Subpart B—Test Procedures

§ 430.21 Purpose and scope.

This subpart contains test procedures required to be prescribed by DOE pursuant to section 323 of the Act.

§ 430.23 Test procedures for the measurement of energy and water consumption.

When the test procedures of this section call for rounding off of test results, and the results fall equally between two values of the nearest dollar, kilowatt-hour, or other specified nearest value, the result shall be rounded up to the nearest higher value.

(a) *Refrigerators and refrigerator-freezers.* (1) The estimated annual operating cost for models without an anti-sweat heater switch shall be the product of the following three factors, with the resulting product then being rounded to the nearest dollar per year:

(i) The representative average-use cycle of 365 cycles per year;

(ii) The average per-cycle energy consumption for the standard cycle in kilowatt-hours per cycle, determined according to appendix A of this subpart; and

(iii) The representative average unit cost of electricity in dollars per kilowatt-hour as provided by the Secretary.

(2) The estimated annual operating cost for models with an anti-sweat heater switch shall be the product of the following three factors, with the resulting product then being rounded to the nearest dollar per year:

(i) The representative average-use cycle of 365 cycles per year;

(ii) Half the sum of the average per-cycle energy consumption for the standard cycle and the average per-cycle energy consumption for a test cycle type with the anti-sweat heater switch in the position set at the factory just before shipping, each in kilowatt-hours per cycle, determined according to appendix A of this subpart; and

(iii) The representative average unit cost of electricity in dollars per kilowatt-hour as provided by the Secretary.

(3) The estimated annual operating cost for any other specified cycle type shall be the product of the following three factors, the resulting product then being rounded to the nearest dollar per year:

(i) The representative average-use cycle of 365 cycles per year;

(ii) The average per-cycle energy consumption for the specified cycle type, determined according to appendix A of this subpart; and

(iii) The representative average unit cost of electricity in dollars per kilowatt-hour as provided by the Secretary.

(4) The energy factor, expressed in cubic feet per kilowatt-hour per cycle, shall be:

(i) For models without an anti-sweat heater switch, the quotient of:

(A) The adjusted total volume in cubic feet, determined according to appendix A of this subpart, divided by—

(B) The average per-cycle energy consumption for the standard cycle in kilowatt-hours per cycle, determined according to appendix A of this subpart, the resulting quotient then being rounded to the second decimal place; and

(ii) For models having an anti-sweat heater switch, the quotient of:

(A) The adjusted total volume in cubic feet, determined according to appendix A of this subpart, divided by—

(B) Half the sum of the average per-cycle energy consumption for the standard cycle and the average per-cycle energy consumption for a test cycle type with the anti-sweat heater switch in the position set at the factory just before shipping, each in kilowatt-hours per cycle, determined according to appendix A of this subpart, the resulting quotient then being rounded to the second decimal place.

(5) The annual energy use, expressed in kilowatt-hours per year and rounded to the nearest kilowatt-hour per year, shall be determined according to appendix A of this subpart.

(6) Other useful measures of energy consumption shall be those measures of energy consumption that the Secretary determines are likely to assist consumers in making purchasing decisions which are derived from the application of appendix A of this subpart.

(7) The following principles of interpretation shall be applied to the test procedure. The intent of the energy test procedure is to simulate typical room conditions (72 °F (22.2 °C)) with door openings, by testing at 90 °F (32.2 °C) without door openings. Except for operating characteristics that are affected by ambient temperature (for example, compressor percent run time), the unit, when tested under this test procedure, shall operate in a manner equivalent to the unit's operation while in typical room conditions.

(i) The energy used by the unit shall be calculated when a calculation is provided by the test procedure. Energy consuming components that operate in typical room conditions (including as a result of door openings, or a function of humidity), and that are not excluded by this test procedure, shall operate in an equivalent manner during energy testing under this test procedure, or be accounted for by all calculations as provided for in the test procedure. Examples:

(A) Energy saving features that are designed to operate when there are no door openings for long periods of time shall not be functional during the energy test.

(B) The defrost heater shall neither function nor turn off differently during the energy test than it would when in typical room conditions. Also, the product shall not recover differently during the defrost recovery period than it would in typical room conditions.

(C) Electric heaters that would normally operate at typical room conditions with door openings shall also operate during the energy test.

(D) Energy used during adaptive defrost shall continue to be measured and adjusted per the calculation provided in this test procedure.

(ii) DOE recognizes that there may be situations that the test procedures do not completely address. In such cases, a manufacturer must obtain a waiver in accordance with the relevant provisions of 10 CFR part 430 if:

(A) A product contains energy consuming components that operate differently during the prescribed testing than they would during representative average consumer use; and

(B) Applying the prescribed test to that product would evaluate it in a manner that is unrepresentative of its true energy consumption (thereby providing materially inaccurate comparative data).

(b) *Freezers.* (1) The estimated annual operating cost for freezers without an anti-sweat heater switch shall be the

product of the following three factors, with the resulting product then being rounded to the nearest dollar per year:

(i) The representative average-use cycle of 365 cycles per year;

(ii) The average per-cycle energy consumption for the standard cycle in kilowatt-hours per cycle, determined according to appendix B of this subpart; and

(iii) The representative average unit cost of electricity in dollars per kilowatt-hour as provided by the Secretary.

(2) The estimated annual operating cost for freezers with an anti-sweat heater switch shall be the product of the following three factors, with the resulting product then being rounded to the nearest dollar per year:

(i) The representative average-use cycle of 365 cycles per year;

(ii) Half the sum of the average per-cycle energy consumption for the standard cycle and the average per-cycle energy consumption for a test cycle type with the anti-sweat heater switch in the position set at the factory just before shipping, each in kilowatt-hours per cycle, determined according to appendix B of this subpart; and

(iii) The representative average unit cost of electricity in dollars per kilowatt-hour as provided by the Secretary.

(3) The estimated annual operating cost for any other specified cycle type for freezers shall be the product of the following three factors, with the resulting product then being rounded to the nearest dollar per year:

(i) The representative average-use cycle of 365 cycles per year;

(ii) The average per-cycle energy consumption for the specified cycle type, determined according to appendix B of this subpart; and

(iii) The representative average unit cost of electricity in dollars per kilowatt-hour as provided by the Secretary.

(4) The energy factor, expressed in cubic feet per kilowatt-hour per cycle, shall be:

(i) For models without an anti-sweat heater switch, the quotient of:

(A) The adjusted total volume in cubic feet, determined according to appendix B of this subpart, divided by—

(B) The average per-cycle energy consumption for the standard cycle in kilowatt-hours per cycle, determined according to appendix B of this subpart, the resulting quotient then being rounded to the second decimal place; and

(ii) For models having an anti-sweat heater switch, the quotient of:

(A) The adjusted total volume in cubic feet, determined according to appendix B of this subpart, divided by—

(B) Half the sum of the average per-cycle energy consumption for the standard cycle and the average per-cycle energy consumption for a test cycle type with the anti-sweat heater switch in the position set at the factory just before shipping, each in kilowatt-hours per cycle, determined according to appendix B of this subpart, the resulting quotient then being rounded to the second decimal place.

(5) The annual energy use, expressed in kilowatt-hours per year and rounded to the nearest kilowatt-hour per year, shall be determined according to appendix B of this subpart.

(6) Other useful measures of energy consumption for freezers shall be those measures the Secretary determines are likely to assist consumers in making purchasing decisions and are derived from the application of appendix B of this subpart.

(7) The following principles of interpretation shall be applied to the test procedure. The intent of the energy test procedure is to simulate typical room conditions (72 °F (22.2 °C)) with door openings by testing at 90 °F (32.2 °C) without door openings. Except for operating characteristics that are affected by ambient temperature (for example, compressor percent run time), the unit, when tested under this test procedure, shall operate in a manner equivalent to the unit's operation while in typical room conditions.

(i) The energy used by the unit shall be calculated when a calculation is provided by the test procedure. Energy consuming components that operate in typical room conditions (including as a result of door openings, or a function of humidity), and that are not excluded

by this test procedure, shall operate in an equivalent manner during energy testing under this test procedure, or be accounted for by all calculations as provided for in the test procedure. Examples:

(A) Energy saving features that are designed to operate when there are no door openings for long periods of time shall not be functional during the energy test.

(B) The defrost heater shall neither function nor turn off differently during the energy test than it would when in typical room conditions. Also, the product shall not recover differently during the defrost recovery period than it would in typical room conditions.

(C) Electric heaters that would normally operate at typical room conditions with door openings shall also operate during the energy test.

(D) Energy used during adaptive defrost shall continue to be measured and adjusted per the calculation provided for in this test procedure.

(ii) DOE recognizes that there may be situations that the test procedures do not completely address. In such cases, a manufacturer must obtain a waiver in accordance with the relevant provisions of this part if:

(A) A product contains energy consuming components that operate differently during the prescribed testing than they would during representative average consumer use; and

(B) Applying the prescribed test to that product would evaluate it in a manner that is unrepresentative of its true energy consumption (thereby providing materially inaccurate comparative data).

(c) *Dishwashers.* (1) The Estimated Annual Operating Cost (EAOC) for dishwashers must be rounded to the nearest dollar per year and is defined as follows:

(i) When cold water (50 °F) is used,

$$EAOC = (D_e \times E_{TLP}) + (D_e \times N \times (M + M_{WS} + M_{DO} + M_{CO} + E_F - (E_D/2))).$$

Where,

D_e = the representative average unit cost of electrical energy, in dollars per kilowatt-hour, as provided by the Secretary,

E_{TLP} = the annual combined low-power mode energy consumption in kilowatt-hours per year and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable,

N = the representative average dishwasher use of 215 cycles per year when EAOC is determined pursuant to appendix C1 to this subpart, and 184 cycles per year when EAOC is determined pursuant to appendix C2 to this subpart,

M = the machine energy consumption per cycle, in kilowatt-hours and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable,

M_{WS} = the machine energy consumption per cycle for water softener regeneration, in kilowatt-hours and determined pursuant to section 5 of appendix C1 or appendix C2 to this subpart, as applicable,

M_{DO} = for water re-use system dishwashers, the machine energy consumption per cycle during a drain out event in kilowatt-hours and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable,

M_{CO} = for water re-use system dishwashers, the machine energy consumption per cycle during a clean out event, in kilowatt-hours and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable,

E_F = the fan-only mode energy consumption per cycle, in kilowatt-hours and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable, and

E_D = the drying energy consumption, in kilowatt-hours and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable.

(ii) When electrically heated water (120 °F or 140 °F) is used,

$$EAOC = (D_e \times E_{TLP}) + (De \times N \times (M + M_{WS} + M_{DO} + M_{CO} + E_F - (ED/2))) + (De \times N \times (W + W_{WS} + W_{DO} + W_{CO})).$$

Where,

D_e, E_{TLP}, N, M, M_{WS}, M_{DO}, M_{CO}, E_F, and E_D, are defined in paragraph (c)(1)(i) of this section,

W = the water energy consumption per cycle, in kilowatt-hours and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable,

W_{WS} = the water softener regeneration water energy consumption per cycle in kilowatt-hours and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable,

W_{DO} = The drain out event water energy consumption per cycle in kilowatt-hours and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable, and

W_{CO} = The clean out event water energy consumption per cycle in kilowatt-hours and

determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable.

(iii) When gas-heated or oil-heated water is used,

$$EAOC_g = (D_e \times E_{TLP}) + (D_e \times N \times (M + M_{WS} + M_{DO} + M_{CO} + EF - (ED/2))) + (D_g \times N \times (W_g + W_{WSg} + W_{DOg} + W_{COg})).$$

Where,

D_e, E_{TLP}, N, M, M_{WS}, M_{DO}, M_{CO}, E_F, and E_D, are defined in paragraph (c)(1)(i) of this section,

D_g = the representative average unit cost of gas or oil, as appropriate, in dollars per BTU, as provided by the Secretary,

W_g = the water energy consumption per cycle, in Btus and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable.

W_{WSg} = the water softener regeneration energy consumption per cycle in Btu per cycle and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable,

W_{DOg} = the drain out water energy consumption per cycle in kilowatt-hours and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable, and

W_{COg} = the clean out water energy consumption per cycle in kilowatt-hours and determined according to section 5 of appendix C1 or appendix C2 to this subpart, as applicable.

(2) The estimated annual energy use, EAEU, expressed in kilowatt-hours per year must be rounded to the nearest kilowatt-hour per year and is defined as follows:

$$EAEU = (M + M_{WS} + M_{DO} + M_{CO} + E_F - (E_D/2) + W + W_{WS} + W_{DO} + W_{CO}) \times N + E_{TLP}$$

Where,

M, M_{WS}, M_{DO}, M_{CO}, E_F, E_D, E_{TLP} are all defined in paragraph (c)(1)(i) of this section and W, W_{WS}, W_{DO}, W_{CO} are defined in paragraph (c)(1)(ii) of this section.

(3) The sum of the water consumption, V, the water consumption during water softener regeneration, V_{WS}, the water consumption during drain out events for dishwashers equipped with a water re-use system, V_{DO}, and the water consumption during clean out events for dishwashers equipped with a water re-use system, V_{CO}, expressed in gallons per cycle and defined pursuant to section 5 of appendix C1 or appendix C2 to this subpart, as applicable, must be rounded to one decimal place.

(4) Other useful measures of energy consumption for dishwashers are those which the Secretary determines are likely to assist consumers in making purchasing decisions and which are derived from the application of appendix C1 to this subpart or appendix C2 to this subpart, as applicable.

(d) *Clothes dryers.* (1) The estimated annual energy consumption for clothes dryers, expressed in kilowatt-hours per year, shall be the product of the annual representative average number of clothes dryer cycles as specified in appendix D1 or D2 to this subpart, as appropriate, and the per-cycle combined total energy consumption in kilowatt-hours per cycle, determined according to section 4.6 of appendix D1 or section 4.6 of appendix D2 to this subpart, as appropriate.

(2) The estimated annual operating cost for clothes dryers shall be—

(i) For an electric clothes dryer, the product of the following three factors, with the resulting product then being rounded off to the nearest dollar per year:

(A) The annual representative average number of clothes dryer cycles as specified in appendix D1 or appendix D2 to this subpart, as appropriate;

(B) The per-cycle combined total energy consumption in kilowatt-hours per cycle, determined according to section 4.6 of appendix D1 or section 4.6 of appendix D2 to this subpart, as appropriate; and

(C) The representative average unit cost of electrical energy in dollars per kilowatt-hour as provided by the Secretary; and

(ii) For a gas clothes dryer, the product of the annual representative average number of clothes dryer cycles as specified in appendix D1 or D2 to this subpart, as appropriate, times the sum of the following three factors, with the resulting product then being rounded off to the nearest dollar per year:

(A) The product of the per-cycle gas dryer electric energy consumption in kilowatt-hours per cycle, determined according to section 4.2 of appendix D1 or section 4.2 of appendix D2 to this

subpart, as appropriate, times the representative average unit cost of electrical energy in dollars per kilowatt-hour as provided by the Secretary; plus,

(B) The product of the per-cycle gas dryer gas energy consumption, in Btus per cycle, determined according to section 4.3 of appendix D1 or section 4.3 of appendix D2 to this subpart, as appropriate, times the representative average unit cost for natural gas or propane, as appropriate, in dollars per Btu as provided by the Secretary; plus,

(C) The product of the per-cycle standby mode and off mode energy consumption in kilowatt-hours per cycle, determined according to section 4.5 of appendix D1 or section 4.5 of appendix D2 to this subpart, as appropriate, times the representative average unit cost of electrical energy in dollars per kilowatt-hour as provided by the Secretary.

(3) The combined energy factor, expressed in pounds per kilowatt-hour is determined in accordance with section 4.7 of appendix D1 or section 4.7 of appendix D2 to this subpart, as appropriate, the result then being rounded off to the nearest hundredth (0.01).

(4) Other useful measures of energy consumption for clothes dryers shall be those measures of energy consumption for clothes dryers which the Secretary determines are likely to assist consumers in making purchasing decisions and which are derived from the application of appendix D1 or D2 to this subpart, as appropriate.

(e) *Water heaters.* (1) The estimated annual operating cost is calculated as:

(i) For a gas-fired or oil-fired water heater, the sum of:

(A) The product of the annual gas or oil energy consumption, determined according to section 6.3.11 or 6.4.7 of appendix E to this subpart, times the representative average unit cost of gas or oil, as appropriate, in dollars per Btu as provided by the Secretary; plus

(B) The product of the annual electric energy consumption, determined according to section 6.3.10 or 6.4.6 of appendix E to this subpart, times the representative average unit cost of electricity in dollars per kilowatt-hour as provided by the Secretary. Round the resulting sum to the nearest dollar per year.

(ii) For an electric water heater, the product of the annual energy consumption, determined according to section 6.3.10 or 6.4.6 of appendix E to this subpart, times the representative average unit cost of electricity in dollars per kilowatt-hour as provided by the Secretary. Round the resulting product to the nearest dollar per year.

(2) For an individual unit, the uniform energy factor is rounded to the nearest 0.01 and determined in accordance with section 6.3.8 or section 6.4.4 of appendix E to this subpart.

(f) *Room air conditioners.* (1) Determine cooling capacity, expressed in British thermal units per hour (Btu/h), as follows:

(i) For a single-speed room air conditioner, determine the cooling capacity in accordance with section 4.1.2 of appendix F of this subpart.

(ii) For a variable-speed room air conditioner, determine the cooling capacity in accordance with section 4.1.2 of appendix F of this subpart for test condition 1 in Table 1 of appendix F of this subpart.

(2) Determine electrical power input, expressed in watts (W) as follows:

(i) For a single-speed room air conditioner, determine the electrical power input in accordance with section 4.1.2 of appendix F of this subpart.

(ii) For a variable-speed room air conditioner, determine the electrical power input in accordance with section 4.1.2 of appendix F of this subpart, for test condition 1 in Table 1 of appendix F of this subpart.

(3) Determine the combined energy efficiency ratio (CEER), expressed in British thermal units per watt-hour (Btu/Wh) and as follows:

(i) For a single-speed room air conditioner, determine the CEER in accordance with section 5.2.2 of appendix F of this subpart.

(ii) For a variable-speed room air conditioner, determine the CEER in accordance with section 5.3.11 of appendix F of this subpart.

(4) Determine the estimated annual operating cost for a room air conditioner, expressed in dollars per year, by multiplying the following two factors and rounding as directed:

(i) For single-speed room air conditioners, the sum of AEC_{cool} and $AEC_{ia/om}$, determined in accordance with section 5.2.1 and section 5.1, respectively, of appendix F of this subpart. For variable-speed room air conditioners, the sum of AEC_{wt} and $AEC_{ia/om}$, determined in accordance with section 5.3.4 and section 5.1, respectively, of appendix F of this subpart; and

(ii) A representative average unit cost of electrical energy in dollars per kilowatt-hour as provided by the Secretary. Round the resulting product to the nearest dollar per year.

(g) *Unvented home heating equipment.* (1) The estimated annual operating cost for primary electric heaters, shall be the product of:

(i) The average annual electric energy consumption in kilowatt-hours per year, determined according to section 3.1 of appendix G of this subpart and

(ii) the representative average unit cost in dollars per kilowatt-hour as provided pursuant to section 323(b)(2) of the Act, the resulting product then being rounded off to the nearest dollar per year.

(2) The estimated regional annual operating cost for primary electric heaters, shall be the product of: (i) The regional annual electric energy consumption in kilowatt-hours per year for primary heaters determined according to section 3.2 of appendix G of this subpart and (ii) the representative average unit cost in dollars per kilowatt-hour as provided pursuant to section 323(b)(2) of the Act, the resulting product then being rounded off to the nearest dollar per year.

(3) The estimated operating cost per million Btu output shall be—

(i) For primary and supplementary electric heaters and unvented gas and oil heaters without an auxiliary electric system, the product of:

(A) One million; and

(B) The representative unit cost in dollars per Btu for natural gas, propane, or oil, as provided pursuant to section 323(b)(2) of the Act as appropriate, or the quotient of the representative unit cost in dollars per kilowatt-hour, as provided pursuant to section 323(b)(2) of the Act, divided by 3,412 Btu per kilowatt hour, the resulting product then being rounded off to the nearest 0.01 dollar per million Btu output; and

(ii) For unvented gas and oil heaters with an auxiliary electric system, the product of: (A) The quotient of one million divided by the rated output in Btu's per hour as determined in 3.4 of appendix G of this subpart; and (B) the sum of: (*1*) The product of the maximum fuel input in Btu's per hour as determined in 2.2. of this appendix times the representative unit cost in dollars per Btu for natural gas, propane, or oil, as appropriate, as provided pursuant to section 323(b)(2) of the Act, plus (*2*) the product of the maximum auxiliary electric power in kilowatts as determined in 2.1 of appendix G of this subpart times the representative unit cost in dollars per kilowatt-hour as provided pursuant to section 323(b)(2) of the Act, the resulting quantity shall be rounded off to the nearest 0.01 dollar per million Btu output.

(4) The rated output for unvented heaters is the rated output as determined according to either sections 3.3 or 3.4 of appendix G of this subpart, as appropriate, with the result being rounded to the nearest 100 Btu per hour.

(5) Other useful measures of energy consumption for unvented home heating equipment shall be those measures of energy consumption for unvented home heating equipment which the Secretary determines are likely to assist consumers in making purchasing decisions and which are derived from the application of appendix G of this subpart.

(h) *Television sets.* The power consumption of a television set, expressed in watts, including on and standby modes, shall be determined in accordance with sections 3 and 4 of appendix H of this subpart respectively. The annual energy consumption, expressed in kilowatt-hours per year, shall be determined in accordance with section 4 of appendix H of this subpart.

(i) *Cooking products.* (1) Determine the standby power for microwave ovens, excluding any microwave oven component of a combined cooking product, according to section 3.2.3 of appendix I to this subpart. Round standby power to the nearest 0.1 watt.

(2)(i) Determine the integrated annual energy consumption of a conventional electric cooking top, including any conventional cooking top component of a combined cooking product, according to section 4.3.1 of appendix I1 to this subpart. Round the result to the nearest 1 kilowatt-hour (kWh) per year.

(ii) Determine the integrated annual energy consumption of a conventional gas cooking top, including any conventional cooking top component of a combined cooking product, according to section 4.3.2 of appendix I1 to this subpart. Round the result to the nearest 1 kilo-British thermal unit (kBtu) per year.

(3) Determine the total annual gas energy consumption of a conventional gas cooking top, including any conventional cooking top component of a combined cooking product, according to section 4.1.2.2.1 of appendix I1 to this subpart. Round the result to the nearest 1 kBtu per year.

(4)(i) Determine the total annual electrical energy consumption of a conventional electric cooking top, including any conventional cooking top component of a combined cooking product, as the integrated annual energy consumption of the conventional electric cooking top, as determined in paragraph (i)(2)(i) of this section.

(ii) Determine the total annual electrical energy consumption of a conventional gas cooking top, including any conventional cooking top component of a combined cooking product, as follows, rounded to the nearest 1 kWh per year:

$$E_{TGE} = E_{AGE} + E_{TLP}$$

Where:

E_{AGE} is the conventional gas cooking top annual active mode electrical energy consumption as defined in section 4.1.2.2.2 of appendix I1 to this subpart, and E_{TLP} is the combined low-power mode energy consumption as defined in section 4.1 of appendix I1 to this subpart.

(5) Determine the estimated annual operating cost corresponding to the energy consumption of a conventional cooking top, including any conventional cooking top component of a combined cooking product, as follows, rounded to the nearest dollar per year:

$$(E_{TGE} \times C_{KWH}) + (E_{TGG} \times C_{KBTU})$$

Where:

E_{TGE} is the total annual electrical energy consumption for any electric energy usage, in kilowatt-hours (kWh) per year, as determined in accordance with paragraph (i)(4) of this section;

C_{KWH} is the representative average unit cost for electricity, in dollars per kWh, as provided pursuant to section 323(b)(2) of the Act;

E_{TGG} is the total annual gas energy consumption, in kBtu per year, as determined in accordance with paragraph (i)(3) of this section; and

C_{KBTU} is the representative average unit cost for natural gas or propane, in dollars per kBtu, as provided pursuant to section 323(b)(2) of the Act, for conventional gas cooking tops that operate with natural gas or with LP-gas, respectively.

(6) Other useful measures of energy consumption for conventional cooking tops shall be the measures of energy consumption that the Secretary determines are likely to assist consumers in making purchasing decisions and that are derived from the application of appendix I1 to this subpart.

(j) *Clothes washers.* (1) The estimated annual operating cost for automatic and semi-automatic clothes washers must be rounded off to the nearest dollar per year and is defined as follows:

(i) When using appendix J (see the note at the beginning of appendix J),

(A) When electrically heated water is used,

$$(N \times (ME_T + HE_T + E_{TLP}) \times C_{KWH})$$

Where:

N = the representative average residential clothes washer use of 234 cycles per year according to appendix J,

ME_T = the total weighted per-cycle machine electrical energy consumption, in kilowatt-hours per cycle, determined according to section 4.1.6 of appendix J,

HE_T = the total weighted per-cycle hot water energy consumption using an electrical water heater, in kilowatt-hours per cycle, determined according to section 4.1.3 of appendix J,

E_{TLP} = the per-cycle combined low-power mode energy consumption, in kilowatt-hours per cycle, determined according to section 4.6.2 of appendix J, and

C_{KWH} = the representative average unit cost, in dollars per kilowatt-hour, as provided by the Secretary.

(B) When gas-heated or oil-heated water is used,

$(N \times (((ME_T + E_{TLP}) \times C_{KWH}) + (HE_{TG} \times C_{BTU})))$

Where:

N, ME_T, E_{TLP}, and C_{KWH} are defined in paragraph (j)(1)(i)(A) of this section,

HE_{TG} = the total per-cycle hot water energy consumption using gas-heated or oil-heated water, in Btu per cycle, determined according to section 4.1.4 of appendix J, and

C_{BTU} = the representative average unit cost, in dollars per Btu for oil or gas, as appropriate, as provided by the Secretary.

(ii) When using appendix J2 (see the note at the beginning of appendix J2),

(A) When electrically heated water is used

$(N_2 \times (E_{TE2} + E_{TLP2}) \times C_{KWH})$

Where:

N_2 = the representative average residential clothes washer use of 295 cycles per year according to appendix J2,

E_{TE2} = the total per-cycle energy consumption when electrically heated water is used, in kilowatt-hours per cycle, determined according to section 4.1.7 of appendix J2,

E_{TLP2} = the per-cycle combined low-power mode energy consumption, in kilowatt-hours per cycle, determined according to section 4.4 of appendix J2, and

C_{KWH} = the representative average unit cost, in dollars per kilowatt-hour, as provided by the Secretary

(B) When gas-heated or oil-heated water is used,

$(N_2 \times (((ME_{T2} + E_{TLP2}) \times C_{KWH}) + (HE_{TG2} \times C_{BTU})))$

Where:

N_2, E_{TLP2}, and C_{KWH} are defined in paragraph (j)(1)(ii)(A) of this section,

ME_{T2} = the total weighted per-cycle machine electrical energy consumption, in kilowatt-hours per cycle, determined according to section 4.1.6 of appendix J2,

HE_{TG2} = the total per-cycle hot water energy consumption using gas-heated or oil-heated water, in Btu per cycle, determined according to section 4.1.4 of appendix J2, and

C_{BTU} = the representative average unit cost, in dollars per Btu for oil or gas, as appropriate, as provided by the Secretary.

(2)(i) The integrated modified energy factor for automatic and semi-automatic clothes washers is determined according to section 4.6 of appendix J2 (when using appendix J2). The result shall be rounded off to the nearest 0.01 cubic foot per kilowatt-hour per cycle.

(ii) The energy efficiency ratio for automatic and semi-automatic clothes washers is determined according to section 4.9 of appendix J (when using appendix J). The result shall be rounded to the nearest 0.01 pound per kilowatt-hour per cycle.

(3) The annual water consumption of a clothes washer must be determined as:

(i) When using appendix J, the product of the representative average-use of 234 cycles per year and the total weighted per-cycle water consumption in gallons per cycle determined according to section 4.2.4 of appendix J.

(ii) When using appendix J2, the product of the representative average-use of 295 cycles per year and the total weighted per-cycle water consumption for all wash cycles, in gallons per cycle, determined according to section 4.2.11 of appendix J2.

(4)(i) The integrated water factor must be determined according to section 4.2.12 of appendix J2, with the result rounded to the nearest 0.1 gallons per cycle per cubic foot.

(ii) The water efficiency ratio for automatic and semi-automatic clothes washers is determined according to section 4.7 of appendix J (when using appendix J). The result shall be rounded to the nearest 0.01 pound per gallon per cycle.

(5) Other useful measures of energy consumption for automatic or semi-automatic clothes washers shall be those measures of energy consumption that the Secretary determines are likely to assist consumers in making purchasing decisions and that are derived from the application of appendix J or appendix J2, as appropriate.

(k)–(l) [Reserved]

(m) *Central air conditioners and heat pumps.* See the note at the beginning of appendix M and M1 to determine the appropriate test method. Determine all values discussed in this section using a single appendix.

(1) Determine cooling capacity from the steady-state wet-coil test (A or A_2 Test), as described in section 3.2 of appendix M or M1 to this subpart, and rounded off to the nearest

(i) To the nearest 50 Btu/h if cooling capacity is less than 20,000 Btu/h;

(ii) To the nearest 100 Btu/h if cooling capacity is greater than or equal to 20,000 Btu/h but less than 38,000 Btu/h; and

(iii) To the nearest 250 Btu/h if cooling capacity is greater than or equal to 38,000 Btu/h and less than 65,000 Btu/h.

(2) Determine seasonal energy efficiency ratio (SEER) as described in section 4.1 of appendix M to this subpart or seasonal energy efficiency ratio 2 (SEER2) as described in section 4.1 of appendix M1 to this subpart, and round off to the nearest 0.025 Btu/W-h.

(3) Determine energy efficiency ratio (EER) as described in section 4.6 of appendix M or M1 to this subpart, and round off to the nearest 0.025 Btu/W-h. The EER from the A or A_2 test, whichever applies, when tested in accordance with appendix M1 to this subpart, is referred to as EER2.

(4) Determine heating seasonal performance factors (HSPF) as described in section 4.2 of appendix M to this subpart or heating seasonal performance factors 2 (HSPF2) as described in section 4.2 of appendix M1 to this subpart, and round off to the nearest 0.025 Btu/W-h.

(5) Determine average off mode power consumption as described in section 4.3 of appendix M or M1 to this subpart, and round off to the nearest 0.5 W.

(6) Determine all other measures of energy efficiency or consumption or other useful measures of performance using appendix M or M1 of this subpart.

(n) *Furnaces.* (1) The estimated annual operating cost for furnaces is the sum of:

(i) The product of the average annual fuel energy consumption, in Btu's per year for gas or oil furnaces or in kilowatt-hours per year for electric furnaces, determined according to section 10.2.2 or 10.3 of appendix N of this subpart, respectively, (for furnaces, excluding low pressure steam or hot water boilers and electric boilers) or section 10.2.2 or 10.3 of appendix EE of this subpart, respectively (for low pressure steam or hot water boilers and electric boilers), and the representative average unit cost in dollars per Btu for gas or oil, or dollars per kilowatt-hour for electric, as appropriate, as provided pursuant to section 323(b)(2) of the Act; plus

(ii) The product of the average annual auxiliary electric energy consumption in kilowatt-hours per year determined according to section 10.2.3 of appendix N of this subpart (for furnaces, excluding low pressure steam or hot water boilers and electric boilers) or section 10.2.3 of appendix EE of this subpart (for low pressure steam or hot water boilers and electric boilers) of this subpart, and the representative average unit cost in dollars per kilowatt-hour as provided pursuant to section 323(b)(2) of the Act.

(iii) Round the resulting sum to the nearest dollar per year.

(2) The annual fuel utilization efficiency (AFUE) for furnaces, expressed in percent, is the ratio of the annual fuel output of useful energy delivered to the heated space to the annual fuel energy input to the furnace.

(i) For gas and oil furnaces, determine AFUE according to section 10.1 of appendix N (for furnaces, excluding low pressure steam or hot water boilers and electric boilers) or section 10.1 of appendix EE (for low pressure steam or hot water boilers and electric boilers) of this subpart, as applicable.

(ii) For electric furnaces, excluding electric boilers, determine AFUE in accordance with section 11.1 of ANSI/ASHRAE 103–1993 (incorporated by reference, *see* § 430.3); for electric boilers, determine AFUE in accordance with section 11.1 of ANSI/ASHRAE 103–2017 (incorporated by reference, *see* § 430.3).

(iii) Round the AFUE to one-tenth of a percentage point.

(3) The estimated regional annual operating cost for furnaces is calculated as follows:

(i) When using appendix N of this subpart for furnaces excluding low pressure steam or hot water boilers and electric boilers (see the note at the beginning of appendix N of this subpart),

(A) For gas or oil-fueled furnaces,

$$(E_{FR} \times C_{BTU}) + (E_{AER} \times C_{KWH})$$

Where:

E_{FR} = the regional annual fuel energy consumption in Btu per year, determined according to section 10.7.1 of appendix N of this subpart;

C_{BTU} = the representative average unit cost in dollars per Btu of gas or oil, as provided pursuant to section 323(b)(2) of the Act;

E_{AER} = the regional annual auxiliary electrical energy consumption in kilowatt-hours per year, determined according to section 10.7.2 of appendix N of this subpart; and

C_{KWH} = the representative average unit cost in dollars per kilowatt-hour of electricity, as provided pursuant to section 323(b)(2) of the Act.

(B) For electric furnaces,

$(E_{ER} \times C_{KWH})$

Where:

E_{ER} = the regional annual fuel energy consumption in kilowatt-hours per year, determined according to section 10.7.3 of appendix N of this subpart; and

C_{KWH} is as defined in paragraph (n)(3)(i)(A) of this section.

(ii) When using appendix EE of this subpart for low pressure steam or hot water boilers and electric boilers (see the note at the beginning of appendix EE of this subpart),

(A) For gas or oil-fueled boilers,

$(E_{ER} \times C_{BTU}) + (E_{AER} \times C_{KWH})$

Where:

E_{FR} = the regional annual fuel energy consumption in Btu per year, determined according to section 10.5.1 of appendix EE of this subpart;

C_{BTU} and C_{KWH} are as defined in paragraph (n)(3)(i)(A) of this section; and

E_{AER} = the regional annual auxiliary electrical energy consumption in kilowatt-hours per year, determined according to section 10.5.2 of appendix EE of this subpart.

(B) For electric boilers,

$(E_{ER} \times C_{KWH})$

Where:

E_{ER} = the regional annual fuel energy consumption in kilowatt-hours per year, determined according to section 10.5.3 of appendix EE of this subpart; and

C_{KWH} is as defined in paragraph (n)(3)(i)(A) of this section.

(iii) Round the estimated regional annual operating cost to the nearest dollar per year.

(4) The energy factor for furnaces, expressed in percent, is the ratio of annual fuel output of useful energy delivered to the heated space to the total annual energy input to the furnace determined according to either section 10.6 of appendix N of this subpart (for furnaces, excluding low pressure steam or hot water boilers and electric boilers) or section 10.4 of appendix EE of this subpart (for low pressure steam or hot water boilers and electric boilers), as applicable.

(5) The average standby mode and off mode electrical power consumption for furnaces shall be determined according to section 8.10 of appendix N of this subpart (for furnaces, excluding low pressure steam or hot water boilers and electric boilers) or section 8.9 of appendix EE of this subpart (for low pressure steam or hot water boilers and electric boilers), as applicable. Round the average standby mode and off mode electrical power consumption to the nearest tenth of a watt.

(6) Other useful measures of energy consumption for furnaces shall be those measures of energy consumption which the Secretary determines are likely to assist consumers in making purchasing decisions and which are derived from the application of appendix N of this subpart (for furnaces, excluding low pressure steam or hot water boilers and electric boilers) or appendix EE of this subpart (for low pressure steam or hot water boilers and electric boilers).

(o) *Vented home heating equipment.* (1) When determining the annual fuel utilization efficiency (AFUE) of vented home heating equipment (see the note at the beginning of appendix O), expressed in percent (%), calculate AFUE in accordance with section 4.1.17 of appendix O of this subpart for vented heaters without either manual controls or thermal stack dampers; in accordance with section 4.2.6 of appendix O of this subpart for vented heaters equipped with manual controls; or in accordance with section 4.3.7 of appendix O of this subpart for vented heaters equipped with thermal stack dampers.

(2) When estimating the annual operating cost for vented home heating equipment, calculate the sum of:

(i) The product of the average annual fuel energy consumption, in Btus per year for natural gas, propane, or oil fueled vented home heating equipment, determined according to section 4.6.2 of appendix O of this subpart, and the representative average unit cost in dollars per Btu for natural gas, propane, or oil, as appropriate, as provided pursuant to section 323(b)(2) of the Act; plus

(ii) The product of the average annual auxiliary electric energy consumption in kilowatt-hours per year determined according to section 4.6.3 of appendix O of this subpart, and the representative average unit cost in dollars per kilowatt-hours as provided pursuant to section 323(b)(2) of the Act. Round the resulting sum to the nearest dollar per year.

(3) When estimating the operating cost per million Btu output for gas or oil vented home heating equipment with an auxiliary electric system, calculate the product of:

(i) The quotient of one million Btu divided by the sum of:

(A) The product of the maximum fuel input in Btus per hour as determined in sections 3.1.1 or 3.1.2 of appendix O of this subpart times the annual fuel utilization efficiency in percent as determined in sections 4.1.17, 4.2.6, or 4.3.7 of this appendix (as appropriate) divided by 100, plus

(B) The product of the maximum electric power in watts as determined in section 3.1.3 of appendix O of this subpart times the quantity 3.412; and

(ii) The sum of:

(A) the product of the maximum fuel input in Btus per hour as determined in sections 3.1.1 or 3.1.2 of this appendix times the representative unit cost in dollars per Btu for natural gas, propane, or oil, as appropriate, as provided pursuant to section 323(b)(2) of the Act; plus

(B) the product of the maximum auxiliary electric power in kilowatts as determined in section 3.1.3 of appendix O of this subpart times the representative unit cost in dollars per kilowatt-hour as provided pursuant to section 323(b)(2) of the Act. Round the resulting quantity to the nearest 0.01 dollar per million Btu output.

(p) *Pool heaters.* (1) Determine the thermal efficiency (E_t) of a pool heater expressed as a percent (%) in accordance with section 5.1 of appendix P to this subpart.

(2) Determine the integrated thermal efficiency (TE_I) of a pool heater expressed as a percent (%) in accordance with section 5.4 of appendix P to this subpart.

(3) When estimating the annual operating cost of pool heaters, calculate the sum of:

(i) The product of the average annual fossil fuel energy consumption, in Btus per year, determined according to section 5.2 of appendix P to this subpart, and the representative average unit cost in dollars per Btu for natural gas or oil, as appropriate, as provided pursuant to section 323(b)(2) of the Act; plus

(ii) The product of the average annual electrical energy consumption in kilowatt-hours per year determined according to section 5.3 of appendix P to this subpart and converted to kilowatt-hours using a conversion factor of 3412 Btus = 1 kilowatt-hour, and the representative average unit cost in dollars per kilowatt-hours as provided pursuant to section 323(b)(2) of the Act. Round the resulting sum to the nearest dollar per year.

(q) *Fluorescent lamp ballasts.* (1) Calculate ballast luminous efficiency (BLE) using appendix Q to this subpart.

(2) Calculate power factor using appendix Q to this subpart.

(r) *General service fluorescent lamps, general service incandescent lamps, and incandescent reflector lamps.* Measure initial lumen output, initial input power, initial lamp efficacy, color rendering index (CRI), correlated color temperature (CCT), and time to failure of GSFLs, IRLs, and GSILs, as applicable, in accordance with appendix R to this subpart.

(s) *Faucets.* Measure the water use for lavatory faucets, lavatory replacement aerators, kitchen faucets, and kitchen replacement aerators, in gallons or liters per minute (gpm or L/min), in accordance to section 2.1 of appendix S of this subpart. Measure the water use for metering faucets, in gallons or liters per cycle (gal/cycle or L/cycle), in accordance to section 2.1 of appendix S of this subpart.

(t) *Showerheads.* Measure the water use for showerheads, in gallons or liters per minute (gpm or L/min), in accordance to section 2.2 of appendix S of this subpart.

(u) *Water closets.* Measure the water use for water closets, expressed in gallons or liters per flush (gpf or Lpf), in

accordance with section 3(a) of appendix T to this subpart.

(v) *Urinals.* Measure the water use for urinals, expressed in gallons or liters per flush (gpf or Lpf), in accordance with section 3(b) of appendix T to this subpart.

(w) *Ceiling fans.* Measure the following attributes of a single ceiling fan in accordance with appendix U to this subpart: airflow; power consumption; ceiling fan efficiency, as applicable; ceiling fan energy index (CFEI), as applicable; standby power, as applicable; distance between the ceiling and lowest point of fan blades; blade span; blade edge thickness; and blade revolutions per minute (RPM).

(x) *Ceiling fan light kits.*

(1) For each ceiling fan light kit that requires compliance with the January 21, 2020 energy conservation standards:

(i) For a ceiling fan light kit packaged with compact fluorescent lamps, measure lamp efficacy, lumen maintenance at 1,000 hours, lumen maintenance at 40 percent of lifetime, rapid cycle stress test, and time to failure in accordance with paragraph (y) of this section for each lamp basic model.

(ii) For a ceiling fan light kit packaged with general service fluorescent lamps, measure lamp efficacy in accordance with paragraph (r) of this section for each lamp basic model.

(iii) For a ceiling fan light kit packaged with incandescent lamps, measure lamp efficacy in accordance with paragraph (r) of this section for each lamp basic model.

(iv) For a ceiling fan light kit packaged with integrated LED lamps, measure lamp efficacy in accordance with paragraph (ee) of this section for each lamp basic model.

(v) For a ceiling fan light kit packaged with other fluorescent lamps (not compact fluorescent lamps or general service fluorescent lamps), packaged with consumer-replaceable SSL (not integrated LED lamps), packaged with non-consumer-replaceable SSL, or packaged with other SSL lamps that have an ANSI standard base (not integrated LED lamps), measure efficacy in accordance with section 3 of appendix V of this subpart for each lamp basic model, consumer-replaceable SSL basic model, or non-consumer-replaceable SSL basic model.

(2) [Reserved]

(y) *Compact fluorescent lamps.* (1) Measure initial lumen output, input power, initial lamp efficacy, lumen maintenance at 1,000 hours, lumen maintenance at 40 percent of lifetime of a compact fluorescent lamp (as defined in 10 CFR 430.2), color rendering index (CRI), correlated color temperature (CCT), power factor, start time, standby mode energy consumption, and time to failure in accordance with appendix W of this subpart. Express time to failure in hours.

(2) Conduct the rapid cycle stress test in accordance with section 3.3 of appendix W of this subpart.

(z) *Dehumidifiers.* (1) Determine the capacity, expressed in pints/day, according to section 5.2 of appendix X1 to this subpart.

(2) Determine the integrated energy factor, expressed in L/kWh, according to section 5.4 of appendix X1 to this subpart.

(3) Determine the case volume, expressed in cubic feet, for whole-home dehumidifiers in accordance with section 5.7 of appendix X1 of this subpart.

(aa) *Battery Chargers.* (1) For battery chargers subject to compliance with the relevant standard at § 430.32(z) as that standard appeared in the January 1, 2022, edition of 10 CFR parts 200–499:

(i) Measure the maintenance mode power, standby power, off mode power, battery discharge energy, 24-hour energy consumption and measured duration of the charge and maintenance mode test for a battery charger other than uninterruptible power supplies in accordance with appendix Y to this subpart;

(ii) Calculate the unit energy consumption of a battery charger other than uninterruptible power supplies in accordance with appendix Y to this subpart;

(iii) Calculate the average load adjusted efficiency of an uninterruptible power supply in accordance with appendix Y to this subpart.

(2) For a battery charger subject to compliance with any amended relevant standard provided in § 430.32 that is published after September 8, 2022:

(i) Measure active mode energy, maintenance mode power, no-battery mode power, off mode power and battery discharge energy for a battery charger other than uninterruptible power supplies in accordance with appendix Y1 to this subpart.

(ii) Calculate the standby power of a battery charger other than uninterruptible power supplies in accordance with appendix Y1, to this subpart.

(iii) Calculate the average load adjusted efficiency of an uninterruptible power supply in accordance with appendix Y1 to this subpart.

(bb) *External Power Supplies.* The energy consumption of an external power supply, including active-mode efficiency expressed as a percentage and the no-load, off, and standby mode energy consumption levels expressed in watts, shall be measured in accordance with appendix Z of this subpart.

(cc) *Furnace Fans.* The energy consumption of a single unit of a furnace fan basic model expressed in watts per 1000 cubic feet per minute (cfm) to the nearest integer shall be calculated in accordance with Appendix AA of this subpart.

(dd) *Portable air conditioners.*

(1) When using appendix CC to this subpart, measure the seasonally adjusted cooling capacity (''SACC'') in British thermal units per hour (Btu/h), and the combined energy efficiency ratio, in British thermal units per watt-hour (Btu/Wh) in accordance with sections 5.2 and 5.4 of appendix CC to this subpart, respectively. When using appendix CC1 to this subpart, measure the SACC in Btu/h, and the combined energy efficiency ratio, in Btu/Wh in accordance with sections 5.2 and 5.4, respectively, of appendix CC1 to this subpart.

(2) When using appendix CC to this subpart, determine the estimated annual operating cost for portable air conditioners, in dollars per year and rounded to the nearest whole number, by multiplying a representative average unit cost of electrical energy in dollars per kilowatt-hour as provided by the Secretary by the total annual energy consumption (''AEC''), determined as follows:

(i) For dual-duct single-speed portable air conditioners, the sum of AEC_{DD_95} multiplied by 0.2, AEC_{DD_83} multiplied by 0.8, and AEC_T as measured in accordance with section 5.3 of appendix CC to this subpart.

(ii) For single-duct single-speed portable air conditioners, the sum of AEC_{SD} and AEC_T as measured in accordance with section 5.3 of appendix CC to this subpart.

(iii) For dual-duct variable-speed portable air conditioners the overall sum of

(A) The sum of $AEC_{DD_95_Full}$ and $AEC_{ia/om}$, multiplied by 0.2, and

(B) The sum of $AEC_{DD_83_Low}$ and $AEC_{ia/om}$, multiplied by 0.8, as measured in accordance with section 5.3 of appendix CC to this subpart.

(iv) For single-duct variable-speed portable air conditioners, the overall sum of

(A) The sum of AEC_{SD_Full} and $AEC_{ia/om}$, multiplied by 0.2, and

(B) The sum of AEC_{SD_Low} and $AEC_{ia/om}$, multiplied by 0.8, as measured in accordance with section 5.3 of appendix CC to this subpart.

(3) When using appendix CC1 to this subpart, determine the estimated annual operating cost for portable air conditioners, in dollars per year and rounded to the nearest whole number, by multiplying a representative average unit cost of electrical energy in dollars per kilowatt-hour as provided by the Secretary by the total AEC. The total AEC is the sum of AEC_{95}, AEC_{83}, AEC_{oc}, and AEC_{ia}, as measured in accordance with section 5.3 of appendix CC1 to this subpart.

(ee) *Integrated light-emitting diode lamp.* (1) The input power of an integrated light-emitting diode lamp must be measured in accordance with section 3 of appendix BB of this subpart.

(2) The lumen output of an integrated light-emitting diode lamp must be measured in accordance with section 3 of appendix BB of this subpart.

(3) The lamp efficacy of an integrated light-emitting diode lamp must be calculated in accordance with section 3 of appendix BB of this subpart.

(4) The correlated color temperature of an integrated light-emitting diode lamp must be measured in accordance

with section 3 of appendix BB of this subpart.

(5) The color rendering index of an integrated light-emitting diode lamp must be measured in accordance with section 3 of appendix BB of this subpart.

(6) The power factor of an integrated light-emitting diode lamp must be measured in accordance with section 3 of appendix BB of this subpart.

(7) The time to failure of an integrated light-emitting diode lamp must be measured in accordance with section 4 of appendix BB of this subpart.

(8) The standby mode power must be measured in accordance with section 5 of appendix BB of this subpart.

(ff) *Coolers and combination cooler refrigeration products.* (1) The estimated annual operating cost for models without an anti-sweat heater switch shall be the product of the following three factors, with the resulting product then being rounded to the nearest dollar per year:

(i) The representative average-use cycle of 365 cycles per year;

(ii) The average per-cycle energy consumption for the standard cycle in kilowatt-hours per cycle, determined according to appendix A of this subpart; and

(iii) The representative average unit cost of electricity in dollars per kilowatt-hour as provided by the Secretary.

(2) The estimated annual operating cost for models with an anti-sweat heater switch shall be the product of the following three factors, with the resulting product then being rounded to the nearest dollar per year:

(i) The representative average-use cycle of 365 cycles per year;

(ii) Half the sum of the average per-cycle energy consumption for the standard cycle and the average per-cycle energy consumption for a test cycle type with the anti-sweat heater switch in the position set at the factory just before shipping, each in kilowatt-hours per cycle, determined according to appendix A of this subpart; and

(iii) The representative average unit cost of electricity in dollars per kilowatt-hour as provided by the Secretary.

(3) The estimated annual operating cost for any other specified cycle type shall be the product of the following three factors, with the resulting product then being rounded to the nearest dollar per year:

(i) The representative average-use cycle of 365 cycles per year;

(ii) The average per-cycle energy consumption for the specified cycle type, determined according to appendix A of this subpart; and

(iii) The representative average unit cost of electricity in dollars per kilowatt-hour as provided by the Secretary.

(4) The energy factor, expressed in cubic feet per kilowatt-hour per cycle, shall be:

(i) For models without an anti-sweat heater switch, the quotient of:

(A) The adjusted total volume in cubic feet, determined according to appendix A of this subpart, divided by—

(B) The average per-cycle energy consumption for the standard cycle in kilowatt-hours per cycle, determined according to appendix A of this subpart, the resulting quotient then being rounded to the second decimal place; and

(ii) For models having an anti-sweat heater switch, the quotient of:

(A) The adjusted total volume in cubic feet, determined according to appendix A of this subpart, divided by—

(B) Half the sum of the average per-cycle energy consumption for the standard cycle and the average per-cycle energy consumption for a test cycle type with the anti-sweat heater switch in the position set at the factory just before shipping, each in kilowatt-hours per cycle, determined according to appendix A of this subpart, the resulting quotient then being rounded to the second decimal place.

(5) The annual energy use, expressed in kilowatt-hours per year and rounded to the nearest kilowatt-hour per year, shall be determined according to appendix A of this subpart.

(6) Other useful measures of energy consumption shall be those measures of energy consumption that the Secretary determines are likely to assist consumers in making purchasing decisions which are derived from the application of appendix A of this subpart.

(7) The following principles of interpretation shall be applied to the test procedure. The intent of the energy test procedure is to simulate operation in typical room conditions (72 °F (22.2 °C)) with door openings by testing at 90 °F (32.2 °C) ambient temperature without door openings. Except for operating characteristics that are affected by ambient temperature (for example, compressor percent run time), the unit, when tested under this test procedure, shall operate in a manner equivalent to the unit's operation while in typical room conditions.

(i) The energy used by the unit shall be calculated when a calculation is provided by the test procedure. Energy consuming components that operate in typical room conditions (including as a result of door openings, or a function of humidity), and that are not excluded by this test procedure, shall operate in an equivalent manner during energy testing under this test procedure, or be accounted for by all calculations as provided for in the test procedure. Examples:

(A) Energy saving features that are designed to operate when there are no door openings for long periods of time shall not be functional during the energy test.

(B) The defrost heater shall neither function nor turn off differently during the energy test than it would when in typical room conditions. Also, the product shall not recover differently during the defrost recovery period than it would in typical room conditions.

(C) Electric heaters that would normally operate at typical room conditions with door openings shall also operate during the energy test.

(D) Energy used during adaptive defrost shall continue to be measured and adjusted per the calculation provided for in this test procedure.

(ii) DOE recognizes that there may be situations that the test procedures do not completely address. In such cases, a manufacturer must obtain a waiver in accordance with the relevant provisions of this part if:

(A) A product contains energy consuming components that operate differently during the prescribed testing than they would during representative average consumer use; and

(B) Applying the prescribed test to that product would evaluate it in a manner that is unrepresentative of its true energy consumption (thereby providing materially inaccurate comparative data).

(8) For non-compressor models, ''compressor'' and ''compressor cycles'' as used in appendix A of this subpart shall be interpreted to mean ''refrigeration system'' and ''refrigeration system cycles,'' respectively.

(gg) *General Service Lamps.* (1) For general service incandescent lamps, use paragraph (r) of this section.

(2) For compact fluorescent lamps, use paragraph (y) of this section.

(3) For integrated LED lamps, use paragraph (ee) of this section.

(4) For other incandescent lamps, measure initial light output, input power, lamp efficacy, power factor, and standby mode power in accordance with appendix DD of this subpart.

(5) For other fluorescent lamps, measure initial light output, input power, lamp efficacy, power factor, and standby mode power in accordance with appendix DD of this subpart.

(6) For OLED and non-integrated LED lamps, measure initial light output, input power, lamp efficacy, power factor, and standby mode power in accordance with appendix DD of this subpart.

(hh) *Air cleaners.* (1) The pollen clean air delivery rate (CADR), smoke CADR, and dust CADR, expressed in cubic feet per minute (cfm), for conventional room air cleaners shall be measured in accordance with section 5 of appendix FF of this subpart.

(2) The $PM_{2.5}$ CADR, expressed in cfm, for conventional room air cleaners, shall be measured in accordance with section 5 of appendix FF of this subpart.

(3) The active mode and standby mode power consumption, expressed in watts, shall be measured in accordance with sections 5 and 6, respectively, of appendix FF of this subpart.

(4) The annual energy consumption, expressed in kilowatt-hours per year, and the integrated energy factor, expressed in CADR per watts (CADR/W), for conventional room air cleaners, shall be measured in accordance with

section 7 of appendix FF of this subpart.

(5) The estimated annual operating cost for conventional room air cleaners, expressed in dollars per year, shall be determined by multiplying the following two factors:

(i) The annual energy consumption as calculated in accordance with section 7 of appendix FF of this subpart, and

(ii) A representative average unit cost of electrical energy in dollars per kilowatt-hour as provided by the Secretary, the resulting product then being rounded off to the nearest dollar per year.

(ii) *Portable electric spas.* Measure the standby loss in watts and the fill volume in gallons of a portable electric spa in accordance with appendix GG to this subpart.

[42 FR 27898, June 1, 1977]

EDITORIAL NOTE: For FEDERAL REGISTER citations affecting § 430.23, see the List of CFR Sections Affected, which appears in the Finding Aids section of the printed volume and at *www.govinfo.gov.*

§ 430.24 [Reserved]

§ 430.25 Laboratory Accreditation Program.

The testing for general service fluorescent lamps, general service incandescent lamps (with the exception of lifetime testing), general service lamps (with the exception of applicable lifetime testing), incandescent reflector lamps, compact fluorescent lamps, and fluorescent lamp ballasts, and integrated light-emitting diode lamps must be conducted by test laboratories accredited by an Accreditation Body that is a signatory member to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA). A manufacturer's or importer's own laboratory, if accredited, may conduct the applicable testing.

[81 FR 72504, Oct. 20, 2016]

§ 430.27 Petitions for waiver and interim waiver.

(a) *General information.* This section provides a means for seeking waivers of the test procedure requirements of this subpart for basic models that meet the requirements of paragraph (a)(1) of this section. In granting a waiver or interim waiver, DOE will not change the energy use or efficiency metric that the manufacturer must use to certify compliance with the applicable energy conservation standard and to make representations about the energy use or efficiency of the covered product. The granting of a waiver or interim waiver by DOE does not exempt such basic models from any other regulatory requirement contained in this part or the certification and compliance requirements of 10 CFR part 429 and specifies an alternative method for testing the basic models addressed in the waiver.

(1) Any interested person may submit a petition to waive for a particular basic model any requirements of § 430.23 or of any appendix to this subpart, upon the grounds that the basic model contains one or more design characteristics which either prevent testing of the basic model according to the prescribed test procedures or cause the prescribed test procedures to evaluate the basic model in a manner so unrepresentative of its true energy and/or water consumption characteristics as to provide materially inaccurate comparative data.

(2) Manufacturers of basic model(s) subject to a waiver or interim waiver are responsible for complying with the other requirements of this subpart and with the requirements of 10 CFR part 429 regardless of the person that originally submitted the petition for waiver and/or interim waiver. The filing of a petition for waiver and/or interim waiver shall not constitute grounds for noncompliance with any requirements of this subpart.

(3) All correspondence regarding waivers and interim waivers must be submitted to DOE either electronically to *AS_Waiver_Requests@ee.doe.gov* (preferred method of transmittal) or by mail to U.S. Department of Energy, Building Technologies Program, Test Procedure Waiver, 1000 Independence Avenue SW., Mailstop EE–5B, Washington, DC 20585–0121.

(b) *Petition content and publication.* (1) Each petition for interim waiver and waiver must:

(i) Identify the particular basic model(s) for which a waiver is requested, each brand name under which the identified basic model(s) will be distributed in commerce, the design characteristic(s) constituting the grounds for the petition, and the specific requirements sought to be waived, and must discuss in detail the need for the requested waiver;

(ii) Identify manufacturers of all other basic models distributed in commerce in the United States and known to the petitioner to incorporate design characteristic(s) similar to those found in the basic model that is the subject of the petition;

(iii) Include any alternate test procedures known to the petitioner to evaluate the performance of the product type in a manner representative of the energy and/or water consumption characteristics of the basic model; and

(iv) Be signed by the petitioner or an authorized representative. In accordance with the provisions set forth in 10 CFR 1004.11, any request for confidential treatment of any information contained in a petition or in supporting documentation must be accompanied by a copy of the petition, application or supporting documentation from which the information claimed to be confidential has been deleted. DOE will publish in the FEDERAL REGISTER the petition and supporting documents from which confidential information, as determined by DOE, has been deleted in accordance with 10 CFR 1004.11 and will solicit comments, data and information with respect to the determination of the petition.

(2) In addition to the requirements in paragraph (b)(1) of this section, each petition for interim waiver must reference the related petition for waiver, demonstrate likely success of the petition for waiver, and address what economic hardship and/or competitive disadvantage is likely to result absent a favorable determination on the petition for interim waiver.

(c) *Notification to other manufacturers.* (1) Each petitioner for interim waiver must, upon publication of a grant of an interim waiver in the FEDERAL REGISTER, notify in writing all known manufacturers of domestically marketed basic models of the same product class (as specified in 10 CFR 430.32) and of other product classes known to the petitioner to use the technology or have the characteristic at issue in the waiver. The notice must include a statement that DOE has published the interim waiver and petition for waiver in the FEDERAL REGISTER and the date the petition for waiver was published. The notice must also include a statement that DOE will receive and consider timely written comments on the petition for waiver. Within five working days, each petitioner must file with DOE a statement certifying the names and addresses of each person to whom a notice of the petition for waiver has been sent.

(2) If a petitioner does not request an interim waiver and notification has not been provided pursuant to paragraph (c)(1) of this section, each petitioner, after filing a petition for waiver with DOE, and after the petition for waiver has been published in the FEDERAL REGISTER, must, within five working days of such publication, notify in writing all known manufacturers of domestically marketed units of the same product class (as listed in 10 CFR 430.32) and of other product classes known to the petitioner to use the technology or have the characteristic at issue in the waiver. The notice must include a statement that DOE has published the petition in the FEDERAL REGISTER and the date the petition for waiver was published. Within five working days of the publication of the petition in the FEDERAL REGISTER, each petitioner must file with DOE a statement certifying the names and addresses of each person to whom a notice of the petition for waiver has been sent.

(d) *Public comment and rebuttal.* (1) Any person submitting written comments to DOE with respect to an interim waiver must also send a copy of the comments to the petitioner by the deadline specified in the notice.

(2) Any person submitting written comments to DOE with respect to a petition for waiver must also send a copy of such comments to the petitioner.

(3) A petitioner may, within 10 working days of the close of the comment period specified in the FEDERAL REGISTER, submit a rebuttal statement to

DOE. A petitioner may rebut more than one comment in a single rebuttal statement.

(e) *Provisions specific to interim waivers.* (1) DOE will post a petition for interim waiver on its website within 5 business days of receipt of a complete petition. DOE will make best efforts to review a petition for interim waiver within 90 business days of receipt of a complete petition.

(2) A petition for interim waiver that does not meet the content requirements of paragraph (b) of this section will be considered incomplete. DOE will notify the petitioner of an incomplete petition via email.

(3) DOE will grant an interim waiver from the test procedure requirements if it appears likely that the petition for waiver will be granted and/or if DOE determines that it would be desirable for public policy reasons to grant immediate relief pending a determination on the petition for waiver. Notice of DOE's determination on the petition for interim waiver will be published in the FEDERAL REGISTER.

(f) *Provisions specific to waivers*—(1) *Disposition of application.* The petitioner shall be notified in writing as soon as practicable of the disposition of each petition for waiver. DOE shall issue a decision on the petition as soon as is practicable following receipt and review of the Petition for Waiver and other applicable documents, including, but not limited to, comments and rebuttal statements.

(2) Criteria for granting. DOE will grant a waiver from the test procedure requirements if DOE determines either that the basic model(s) for which the waiver was requested contains a design characteristic that prevents testing of the basic model according to the prescribed test procedures, or that the prescribed test procedures evaluate the basic model in a manner so unrepresentative of its true energy or water consumption characteristics as to provide materially inaccurate comparative data. Waivers may be granted subject to conditions, which may include adherence to alternate test procedures specified by DOE. DOE will consult with the Federal Trade Commission prior to granting any waiver, and will promptly publish in the FEDERAL REGISTER notice of each waiver granted or denied, and any limiting conditions of each waiver granted.

(g) *Extension to additional basic models.* A petitioner may request that DOE extend the scope of a waiver or an interim waiver to include additional basic models employing the same technology as the basic model(s) set forth in the original petition. The petition for extension must identify the particular basic model(s) for which a waiver extension is requested, each brand name under which the identified basic model(s) will be distributed in commerce, and documentation supporting the claim that the additional basic models employ the same technology as the basic model(s) set forth in the original petition. DOE will publish any such extension in the FEDERAL REGISTER.

(h) *Duration.* (1) Within one year of issuance of an interim waiver, DOE will either:

(i) Publish in the FEDERAL REGISTER a determination on the petition for waiver; or

(ii) Publish in the FEDERAL REGISTER a new or amended test procedure that addresses the issues presented in the waiver.

(2) When DOE publishes a decision and order on a petition for waiver in the FEDERAL REGISTER pursuant to paragraph (f) of this section, the interim waiver will terminate upon the data specified in the decision and order, in accordance with paragraph (i) of this section.

(3) When DOE amends the test procedure to address the issues presented in a waiver, the waiver or interim waiver will automatically terminate on the date on which use of that test procedure is required to demonstrate compliance.

(4) When DOE publishes a decision and order in the FEDERAL REGISTER to modify a waiver pursuant to paragraph (k) of this section, the existing waiver will terminate 180 days after the publication date of the decision and order.

(i) *Compliance certification and representations.* (1) If the interim waiver test procedure methodology is different than the decision and order test procedure methodology, certification reports to DOE required under 10 CFR

429.12 and any representations must be based on either of the two methodologies until 180 days after the publication date of the decision and order. Thereafter, certification reports and any representations must be based on the decision and order test procedure methodology, unless otherwise specified by DOE. Once a manufacturer uses the decision and order test procedure methodology in a certification report or any representation, all subsequent certification reports and any representations must be made using the decision and order test procedure methodology while the waiver is valid.

(2) When DOE publishes a new or amended test procedure, certification reports to DOE required under 10 CFR 429.12 and any representations must be based on the testing methodology of an applicable waiver or interim waiver, or the new or amended test procedure until the date on which use of such test procedure is required to demonstrate compliance, unless otherwise specified by DOE in the test procedure final rule. Thereafter, certification reports and any representations must be based on the test procedure final rule methodology. Once a manufacturer uses the test procedure final rule methodology in a certification report or any representation, all subsequent certification reports and any representations must be made using the test procedure final rule methodology.

(3) If DOE publishes a decision and order modifying an existing waiver, certification reports to DOE required under 10 CFR 429.12 and any representations must be based on either of the two methodologies until 180 days after the publication date of the decision and order modifying the waiver. Thereafter, certification reports and any representations must be based on the modified test procedure methodology unless otherwise specified by DOE. Once a manufacturer uses the modified test procedure methodology in a certification report or any representation, all subsequent certification reports and any representations must be made using the modified test procedure methodology while the modified waiver is valid.

(j) *Petition for waiver required of other manufactures.* Any manufacturer of a basic model employing a technology or characteristic for which a waiver was granted for another basic model and that results in the need for a waiver (as specified by DOE in a published decision and order in the FEDERAL REGISTER) must petition for and be granted a waiver for that basic model. Manufacturers may also submit a request for interim waiver pursuant to the requirements of this section.

(k) *Rescission or modification.* (1) DOE may rescind or modify a waiver or interim waiver at any time upon DOE's determination that the factual basis underlying the petition for waiver or interim waiver is incorrect, upon a determination that the results from the alternate test procedure are unrepresentative of the basic model(s)' true energy consumption characteristics, or for other appropriate reason. Waivers and interim waivers are conditioned upon the validity of statements, representations, and documents provided by the requestor; any evidence that the original grant of a waiver or interim waiver was based upon inaccurate information will weigh against continuation of the waiver. DOE's decision will specify the basis for its determination and, in the case of a modification, will also specify the change to the authorized test procedure.

(2) A person may request that DOE rescind or modify a waiver or interim waiver issued to that person if the person discovers an error in the information provided to DOE as part of its petition, determines that the waiver is no longer needed, or for other appropriate reasons. In a request for rescission, the requestor must provide a statement explaining why it is requesting rescission. In a request for modification, the requestor must explain the need for modification to the authorized test procedure and detail the modifications needed and the corresponding impact on measured energy consumption.

(3) DOE will publish a proposed rescission or modification (DOE-initiated or at the request of the original requestor) in the FEDERAL REGISTER for public comment. A requestor may, within 10 working days of the close of the comment period specified in the proposed rescission or modification published in the FEDERAL REGISTER,

submit a rebuttal statement to DOE. A requestor may rebut more than one comment in a single rebuttal statement.

(4) DOE will publish its decision in the FEDERAL REGISTER. DOE's determination will be based on relevant information contained in the record and any comments received.

(5) After the effective date of a rescission, any basic model(s) previously subject to a waiver must be tested and certified using the applicable DOE test procedure in 10 CFR part 430.

(l) *Revision of regulation.* As soon as practicable after the granting of any waiver, DOE will publish in the FEDERAL REGISTER a notice of proposed rulemaking to amend its regulations so as to eliminate any need for the continuation of such waiver. As soon thereafter as practicable, DOE will publish in the FEDERAL REGISTER a final rule.

(m) To exhaust administrative remedies, any person aggrieved by an action under this section must file an appeal with the DOE's Office of Hearings and Appeals as provided in 10 CFR part 1003, subpart C.

[79 FR 26599, May 9, 2014, as amended at 85 FR 79820, Dec. 11, 2020; 86 FR 70959, Dec. 14, 2021]

APPENDIX A TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF REFRIGERATORS, REFRIGERATOR-FREEZERS, AND MISCELLANEOUS REFRIGERATION PRODUCTS

NOTE: Prior to April 11, 2022, any representations of volume and energy use of refrigerators, refrigerator-freezers, and miscellaneous refrigeration products must be based on the results of testing pursuant to either this appendix or the procedures in appendix A as it appeared at 10 CFR part 430, subpart B, appendix A, in the 10 CFR parts 200 to 499 edition revised as of January 1, 2019. Any representations of volume and energy use must be in accordance with whichever version is selected. On or after April 11, 2022, any representations of volume and energy use must be based on the results of testing pursuant to this appendix.

For refrigerators and refrigerator-freezers, the rounding requirements specified in sections 4 and 5 of this appendix are not required for use until the compliance date of any amendment of energy conservation standards for these products published after October 12, 2021.

1. Referenced Materials

DOE incorporated by reference AHAM HRF–1–2019, *Energy and Internal Volume of Consumer Refrigeration Products* (''HRF–1–2019''), and AS/NZS 4474.1:2007, *Performance of Household Electrical Appliances—Refrigerating Appliances; Part 1: Energy Consumption and Performance, Second Edition* (''AS/NZS 4474.1:2007''), in their entirety in §430.3; however, only enumerated provisions of these documents are applicable to this appendix. If there is any conflict between HRF–1–2019 and this appendix or between AS/NZS 4474.1:2007 and this appendix, follow the language of the test procedure in this appendix, disregarding the conflicting industry standard language.

(a) AHAM HRF–1–2019, (''HRF–1–2019''), Energy and Internal Volume of Consumer Refrigeration Products:

(i) Section 3—Definitions, as specified in section 3 of this appendix;

(ii) Section 4—Method for Determining the Refrigerated Volume of Consumer Refrigeration Products, as specified in section 4.1 of this appendix;

(iii) Section 5—Method for Determining the Energy Consumption of Consumer Refrigeration Products (excluding Table 5–1 and sections 5.5.6.5, 5.8.2.1.2, 5.8.2.1.3, 5.8.2.1.4, 5.8.2.1.5, and 5.8.2.1.6), as specified in section 5 of this appendix; and

(iv) Section 6—Method for Determining the Adjusted Volume of Consumer Refrigeration Products, as specified in section 4.2 of this appendix;

(b) AS/NZS 4474.1:2007, (''AS/NZS 4474.1:2007''), Performance of Household Electrical Appliances—Refrigerating Appliances; Part 1: Energy Consumption and Performance, Second Edition:

(i) Appendix M—Method of Interpolation When Two Controls are Adjusted, as specified in sections 5.2(b) and 5.5 of this appendix.

(ii) [Reserved]

2. Scope

This appendix provides the test procedure for measuring the annual energy use in kilowatt-hours per year (kWh/yr), the total refrigerated volume in cubic feet (ft^3), and the total adjusted volume in cubic feet (ft^3) of refrigerators, refrigerator-freezers, and miscellaneous refrigeration products.

3. Definitions

Section 3, *Definitions*, of HRF–1–2019 applies to this test procedure. In case of conflicting terms between HRF–1–2019 and DOE's definitions in this appendix or in §430.2, DOE's definitions take priority.

Door-in-door means a set of doors or an outer door and inner drawer for which—

(a) Both doors (or both the door and the drawer) must be opened to provide access to the interior through a single opening;

(b) Gaskets for both doors (or both the door and the drawer) are exposed to external ambient conditions on the outside around the full perimeter of the respective openings; and

(c) The space between the two doors (or between the door and the drawer) achieves temperature levels consistent with the temperature requirements of the interior compartment to which the door-in-door provides access.

Through-the-door ice/water dispenser means a device incorporated within the cabinet, but outside the boundary of the refrigerated space, that delivers to the user on demand ice and may also deliver water from within the refrigerated space without opening an exterior door. This definition includes dispensers that are capable of dispensing ice and water or ice only.

Transparent door means an external fresh food compartment door which meets the following criteria:

(a) The area of the transparent portion of the door is at least 40 percent of the area of the door.

(b) The area of the door is at least 50 percent of the sum of the areas of all the external doors providing access to the fresh food compartments and cooler compartments.

(c) For the purposes of this evaluation, the area of a door is determined as the product of the maximum height and maximum width dimensions of the door, not considering potential extension of flaps used to provide a seal to adjacent doors.

4. Volume

Determine the refrigerated volume and adjusted volume for refrigerators, refrigerator-freezers, and miscellaneous refrigeration products in accordance with the following sections of HRF–1–2019, respectively:

4.1. Section 4, Method for Determining the Refrigerated Volume of Consumer Refrigeration Products; and

4.2. Section 6, Method for Determining the Adjusted Volume of Consumer Refrigeration Products.

5. Energy Consumption

Determine the annual energy use (''AEU'') in kilowatt-hours per year (kWh/yr), for refrigerators, refrigerator-freezers, and miscellaneous refrigeration products in accordance with section 5, *Method for Determining the Energy Consumption of Consumer Refrigeration Products,* of HRF–1–2019, except as follows.

5.1. Test Setup and Test Conditions

(a) In section 5.3.1 of HRF–1–2019, the top of the unit shall be determined by the refrigerated cabinet height, excluding any accessories or protruding components on the top of the unit.

(b) The ambient temperature and vertical ambient temperature gradient requirements specified in section 5.3.1 of HRF–1–2019 shall be maintained during both the stabilization period and the test period.

(c) The power supply requirements as specified in section 5.5.1 of HRF–1–2019 shall be maintained based on measurement intervals not to exceed one minute.

(d) The ice storage compartment temperature requirement as specified in section 5.5.6.5 in HRF–1–2019 is not required.

(e) For cases in which setup is not clearly defined by this test procedure, manufacturers must submit a petition for a waiver (See section 6 of this appendix).

(f) If the interior arrangements of the unit under test do not conform with those shown in Figures 5–1 or 5–2 of HRF–1–2019, as appropriate, the unit must be tested by relocating the temperature sensors from the locations specified in the figures to avoid interference with hardware or components within the unit, in which case the specific locations used for the temperature sensors shall be noted in the test data records maintained by the manufacturer in accordance with 10 CFR 429.71, and the certification report shall indicate that non-standard sensor locations were used. If any temperature sensor is relocated by any amount from the location prescribed in Figure 5–1 or 5–2 of HRF–1–2019 in order to maintain a minimum 1-inch air space from adjustable shelves or other components that could be relocated by the consumer, except in cases in which the Figures prescribe a temperature sensor location within 1 inch of a shelf or similar feature (*e.g.*, sensor T3 in Figure 5–1), this constitutes a relocation of temperature sensors that must be recorded in the test data and reported in the certification report as described in this paragraph.

5.2. Test Conduct

(a) Standard Approach

(i) For the purposes of comparing compartment temperatures with standardized temperatures, as described in section 5.6 of HRF–1–2019, the freezer compartment temperature shall be as specified in section 5.8.1.2.5 of HRF–1–2019, the fresh food compartment temperature shall be as specified in section 5.8.1.2.4 of HRF–1–2019, and the cooler compartment temperature shall be as specified in section 5.8.1.2.6 of HRF–1–2019.

(ii) In place of Table 5–1 in HRF–1–2019, refer to Table 1 of this section.

TABLE 1—TEMPERATURE SETTINGS: GENERAL CHART FOR ALL PRODUCTS

First test		Second test		Energy calculation based on:
Setting	Results	Setting	Results	
Mid for all Compartments.	All compartments below standard reference temperature.	Warmest for all Compartments.	All compartments below standard reference temperature.	Second Test Only.
			One or more compartments above standard reference temperature.	First and Second Test.
	One or more compartments above standard reference temperature.	Coldest for all Compartments.	All compartments below standard reference temperature.	First and Second Test.
			One or more compartments above standard reference temperature.	Model may not be certified as compliant with energy conservation standards based on testing of this unit. Confirm that unit meets product definition. If so, see section 6 of this appendix.

(b) Three-Point Interpolation Method (Optional Test for Models with Two Compartments and User-Operable Controls). As specified in section 5.6.3(6) of HRF–1–2019, and as an optional alternative to section 5.2(a) of this appendix, perform three tests such that the set of tests meets the ''minimum requirements for interpolation'' of AS/NZS 4474.1:2007 appendix M, section M3, paragraphs (a) through (c) and as illustrated in Figure M1. The target temperatures txA and txB defined in section M4(a)(i) of AS/NZ 4474.1:2007 shall be the standardized temperatures defined in section 5.6 of HRF–1–2019.

5.3. Test Cycle Energy Calculations

Section 5.8.2, *Energy Consumption*, of HRF–1–2019 applies to this test procedure, except as follows:

(a) In place of section 5.8.2.1.2 of HRF–1–2019, use the calculations provided in this section. For units with long-time automatic defrost control using the two-part test period, the test cycle energy shall be calculated as:

$$\mathrm{ET} = \left(\frac{1440 \times K \times EP1}{T1}\right) + \left[EP2 - \left(EP1 \times \frac{T2}{T1}\right)\right] \times \left[\frac{12}{CT}\right] \times K$$

Where:

ET = test cycle energy expended in kilowatt-hours per day;

1440 = conversion factor to adjust to a 24-hour average use cycle in minutes per day;

K = dimensionless correction factor of 1.0 for refrigerators and refrigerator-freezers and 0.55 for miscellaneous refrigeration products.

EP1 = energy expended in kilowatt-hours during the first part of the test;

EP2 = energy expended in kilowatt-hours during the second part of the test;

T1 and T2 = length of time in minutes of the first and second test parts, respectively;

CT = defrost timer run time or compressor run time between defrosts in hours required to go through a complete cycle, rounded to the nearest tenth of an hour;

12 = factor to adjust for a 50-percent run time of the compressor in hours per day.

(b) In place of sections 5.8.2.1.3 and 5.8.2.1.4 of HRF–1–2019, use the calculations provided in this section. For units with variable defrost control, the test cycle energy shall be calculated as set forth in section 5.3(a) of this appendix with the following addition:

CT shall be calculated equivalent to:

$$CT = \frac{CT_L \times CT_M}{F \times (CT_M - CT_L) + CT_L}$$

Where:

CT_L = the least or shortest compressor run time between defrosts used in the variable defrost control algorithm (greater than or equal to 6 but less than or equal to 12 hours), or the shortest compressor run time between defrosts observed for the test (if it is shorter than the shortest run time used in the control algorithm and is greater than 6 hours), or 6 hours (if the shortest observed run time is less than 6 hours), in hours rounded to the nearest tenth of an hour;

CT_M = the maximum compressor run time between defrosts in hours rounded to the nearest tenth of an hour (greater than CT_L but not more than 96 hours);

For variable defrost models with no values of CT_L and CT_M in the algorithm, the default values of 6 and 96 shall be used, respectively.

F = ratio of per day energy consumption in excess of the least energy and the maximum difference in per-day energy consumption and is equal to 0.20.

(c) In place of section 5.8.2.1.5 of HRF–1–2019, use the calculations provided in this section. For multiple-compressor products with automatic defrost, the two-part test method in section 5.7.2.1 of HRF–1–2019 shall be used, and the test cycle energy shall be calculated as:

$$\mathrm{ET} = \left(\frac{1440 \times K \times EP1}{T1}\right) + \sum_{i=1}^{D}\left[\left(EP2_i - \left(EP1 \times \frac{T2_i}{T1}\right)\right) \times \left(\frac{12}{CT_i}\right) \times K\right]$$

Where:

ET, 1440, 12, and K are defined in section 5.3(a) of this appendix;

EP1, and T1 are defined in section 5.3(a) of this appendix;

i = a subscript variable that can equal 1, 2, or more that identifies each individual compressor system that has automatic defrost;

D = the total number of compressor systems with automatic defrost;

$EP2_i$ = energy expended in kilowatt-hours during the second part of the test for compressor system i;

$T2_i$ = length of time in minutes of the second part of the test for compressor system i;

CT_i = compressor run time between defrosts of compressor system i, rounded to the nearest tenth of an hour, for long-time automatic defrost control equal to a fixed time in hours, and for variable defrost control equal to:

$$CT_i = \frac{CT_{L,i} \times CT_{M,i}}{F \times \left(CT_{M,i} - CT_{L,i}\right) + CT_{L,i}}$$

Where:

$CT_{L,i}$ = for compressor system i, the shortest cumulative compressor-on time between defrost heater-on events used in the variable defrost control algorithm (CT_L for the compressor system with the longest compressor run time between defrosts must be greater than or equal to 6 but less than or equal to 12 hours), in hours rounded to the nearest tenth of an hour;

$CT_{M,i}$ = for compressor system i, the maximum compressor-on time between defrost heater-on events used in the variable defrost control algorithm (greater than $CT_{L,i}$ but not more than 96 hours), in hours rounded to the nearest tenth of an hour;

For defrost cycle types with no values of CT_L and CT_M in the algorithm, the default values of 6 and 96 shall be used, respectively.

F = ratio of per day energy consumption in excess of the least energy and the maximum difference in per-day energy consumption and is equal to 0.20.

(d) In place of section 5.8.2.1.6 of HRF–1–2019, use the calculations provided in this section. For units with long-time automatic defrost control and variable defrost control with multiple defrost cycle types, the two-part test method in section 5.7.2.1 of HRF–1–2019 shall be used, and the test cycle energy shall be calculated as:

$$\mathrm{ET} = \left(\frac{1440 \times K \times EP1}{T1}\right) + \sum_{i=1}^{D}\left[\left(EP2_i - \left(EP1 \times \frac{T2_i}{T1}\right)\right) \times \left(\frac{12}{CT_i}\right) \times K\right]$$

Where:

ET, 1440, 12, and K are defined in section 5.3(a) of this appendix;

EP1, and T1 are defined in section 5.3(a) of this appendix;

i = a subscript variable that can equal 1, 2, or more that identifies the distinct defrost cycle types applicable for the product;

D = the total number of defrost cycle types;

$EP2_i$ = energy expended in kilowatt-hours during the second part of the test for defrost cycle type i;

$T2_i$ = length of time in minutes of the second part of the test for defrost cycle type i;

CT_i = defrost timer run time or compressor run time between instances of defrost cycle type i, rounded to the nearest tenth of an hour;

12 = factor to adjust for a 50-percent run time of the compressor in hours per day.

(i) For long-time automatic defrost control, CTi shall be equal to a fixed time in hours rounded to the nearest tenth of an hour. For cases in which there are more than one fixed CT value for a given defrost cycle type, an average fixed CT value shall be selected for this cycle type.

(ii) For variable defrost control, CTi shall be calculated equivalent to:

$$CT_i = \frac{CT_{L,i} \times CT_{M,i}}{F \times \left(CT_{M,i} - CT_{L,i}\right) + CT_{L,i}}$$

Where:

$CT_{L,i}$ = the least or shortest compressor run time between instances of the defrost cycle type i in hours rounded to the nearest tenth of an hour (CT_L for the defrost cycle type with the longest compressor run time between defrosts must be greater than or equal to 6 but less than or equal to 12 hours);

$CT_{M,i}$ = the maximum compressor run time between instances of defrost cycle type i in hours rounded to the nearest tenth of an hour (greater than $CT_{L,i}$ but not more than 96 hours);

For cases in which there are more than one CT_M and/or CT_L value for a given defrost cycle type, an average of the CT_M and CT_L values shall be selected for this defrost cycle type. For defrost cycle types with no values of CT_L and CT_M in the algorithm, the default values of 6 and 96 shall be used, respectively.

F = ratio of per day energy consumption in excess of the least energy and the maximum difference in per-day energy consumption and is equal to 0.20.

5.4. *Icemaker Energy Use*

(a) For refrigerators and refrigerator-freezers: To demonstrate compliance with the energy conservation standards at §430.32(a) applicable to products manufactured on or after September 15, 2014, but before the compliance date of any amended standards published after January 1, 2022, IET, expressed in kilowatt-hours per cycle, equals 0.23 for a product with one or more automatic icemakers and otherwise equals 0 (zero). To demonstrate compliance with any amended standards published after January 1, 2022, IET, expressed in kilowatt-hours per cycle, is as defined in section 5.9.2.1 of HRF–1–2019.

(b) For miscellaneous refrigeration products: To demonstrate compliance with the energy conservation standards at §430.32(aa) applicable to products manufactured on or after October 28, 2019, IET, expressed in kilowatt-hours per cycle, equals 0.23 for a product with one or more automatic icemakers and otherwise equals 0 (zero).

5.5. *Triangulation Method*

If the three-point interpolation method of section 5.2(b) of this appendix is used for setting temperature controls, the average per-

cycle energy consumption shall be defined as follows:

$E = E_X + IET$

Where:

E is defined in section 5.9.1.1 of HRF–1–2019;
IET is defined in section 5.4 of this appendix; and
E_X is defined and calculated as described in appendix M, section M4(a) of AS/NZS 4474.1:2007. The target temperatures t_{xA} and t_{xB} defined in section M4(a)(i) of AS/NZS 4474.1:2007 shall be the standardized temperatures defined in section 5.6 of HRF–1–2019.

6. Test Procedure Waivers

To the extent that the procedures contained in this appendix do not provide a means for determining the energy consumption of a basic model, a manufacturer must obtain a waiver under §430.27 to establish an acceptable test procedure for each such basic model. Such instances could, for example, include situations where the test setup for a particular basic model is not clearly defined by the provisions of this appendix. For details regarding the criteria and procedures for obtaining a waiver, please refer to §430.27.

[86 FR 56821, Oct. 12, 2021, as amended at 89 FR 3112, Jan. 17, 2024]

APPENDIX B TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF FREEZERS

NOTE: Prior to April 11, 2022, any representations of volume and energy use of freezers must be based on the results of testing pursuant to either this appendix or the procedures in appendix B as it appeared at 10 CFR part 430, subpart B, appendix B, in the 10 CFR parts 200 to 499 edition revised as of January 1, 2019. Any representations of volume and energy use must be in accordance with whichever version is selected. On or after April 11, 2022, any representations of volume and energy use must be based on the results of testing pursuant to this appendix.

For freezers, the rounding requirements specified in sections 4 and 5 of this appendix are not required for use until the compliance date of any amendment of energy conservation standards for these products published after October 12, 2021.

1. Referenced Materials

DOE incorporated by reference HRF–1–2019, *Energy and Internal Volume of Consumer Refrigeration Products* (''HRF–1–2019'') in its entirety in §430.3; however, only enumerated provisions of this document are applicable to this appendix. If there is any conflict between HRF–1–2019 and this appendix, follow the language of the test procedure in this appendix, disregarding the conflicting industry standard language.

(a) AHAM HRF–1–2019, (''HRF–1–2019''), Energy and Internal Volume of Consumer Refrigeration Products:

(i) Section 3—Definitions, as specified in section 3 of this appendix;

(ii) Section 4—Method for Determining the Refrigerated Volume of Consumer Refrigeration Products, as specified in section 4.1 of this appendix;

(iii) Section 5—Method for Determining the Energy Consumption of Consumer Refrigeration Products (excluding Table 5–1 and sections 5.5.6.5, 5.8.2.1.2, 5.8.2.1.3, 5.8.2.1.4, 5.8.2.1.5, and 5.8.2.1.6), as specified in section 5 of this appendix; and

(iv) Section 6—Method for Determining the Adjusted Volume of Consumer Refrigeration Products, as specified in section 4.2 of this appendix.

(b) Reserved.

If there is any conflict between HRF–1–2019 and this appendix, follow the language of the test procedure in this appendix, disregarding the conflicting industry standard language.

2. Scope

This appendix provides the test procedure for measuring the annual energy use in kilowatt-hours per year (kWh/yr), the total refrigerated volume in cubic feet (ft^3), and the total adjusted volume in cubic feet (ft^3) of freezers.

3. Definitions

Section 3, *Definitions*, of HRF–1–2019 applies to this test procedure. In case of conflicting terms between HRF–1–2019 and DOE's definitions in this appendix or in §430.2, DOE's definitions take priority.

Through-the-door ice/water dispenser means a device incorporated within the cabinet, but outside the boundary of the refrigerated space, that delivers to the user on demand ice and may also deliver water from within the refrigerated space without opening an exterior door. This definition includes dispensers that are capable of dispensing ice and water or ice only.

4. Volume

Determine the refrigerated volume and adjusted volume for freezers in accordance with the following sections of HRF–1–2019, respectively:

4.1. Section 4, Method for Determining the Refrigerated Volume of Consumer Refrigeration Products; and

4.2. Section 6, Method for Determining the Adjusted Volume of Consumer Refrigeration Products.

5. Energy Consumption

Determine the annual energy use (''AEU'') in kilowatt-hours per year (kWh/yr), for freezers in accordance with section 5, *Method for Determining the Energy Consumption of Consumer Refrigeration Products,* of HRF–1–2019, except as follows.

5.1. Test Setup and Test Conditions

(a) In section 5.3.1 of HRF–1–2019, the top of the unit shall be determined by the refrigerated cabinet height, excluding any accessories or protruding components on the top of the unit.

(b) The ambient temperature and vertical ambient temperature gradient requirements specified in section 5.3.1 of HRF–1–2019 shall be maintained during both the stabilization period and the test period.

(c) The power supply requirements as specified in section 5.5.1 of HRF–1–2019 shall be maintained based on measurement intervals not to exceed one minute.

(d) The ice storage compartment temperature requirement as specified in section 5.5.6.5 in HRF–1–2019 is not required.

(e) For cases in which setup is not clearly defined by this test procedure, manufacturers must submit a petition for a waiver (See section 6 of this appendix).

(f) If the interior arrangements of the unit under test do not conform with those shown in Figure 5–2 of HRF–1–2019, as appropriate, the unit must be tested by relocating the temperature sensors from the locations specified in the figures to avoid interference with hardware or components within the unit, in which case the specific locations used for the temperature sensors shall be noted in the test data records maintained by the manufacturer in accordance with 10 CFR 429.71, and the certification report shall indicate that non-standard sensor locations were used. If any temperature sensor is relocated by any amount from the location prescribed in Figure 5–2 of HRF–1- 2019 in order to maintain a minimum 1-inch air space from adjustable shelves or other components that could be relocated by the consumer, except in cases in which the Figure prescribes a temperature sensor location within 1 inch of a shelf or similar feature, this constitutes a relocation of temperature sensors that must be recorded in the test data and reported in the certification report as described in this paragraph.

5.2. Test Conduct

(a) For the purposes of comparing compartment temperatures with standardized temperatures, as described in section 5.6 of HRF–1–2019, the freezer compartment temperature shall be as specified in section 5.8.1.2.5 of HRF–1–2019.

(b) In place of Table 5–1 in HRF–1–2019, refer to Table 1 of this section.

TABLE 1—TEMPERATURE SETTINGS FOR FREEZERS

First test		Second test		Energy calculation based on:
Setting	Results	Setting	Results	
Mid	Below standard reference temperature.	Warmest	Below standard reference temperature.	Second Test Only.
			Above standard reference temperature.	First and Second Test.
	Above standard reference temperature.	Coldest	Below standard reference temperature.	First and Second Test.
			Above standard reference temperature.	Model may not be certified as compliant with energy conservation standards based on testing of this unit. Confirm that unit meets product definition. If so, see section 6 of this appendix.

5.3. Test Cycle Energy Calculations

Section 5.8.2, *Energy Consumption,* of HRF–1–2019 applies to this test procedure, except as follows:

(a) In place of section 5.8.2.1.2 of HRF–1–2019, use the calculations provided in this section. For units with long-time automatic defrost control using the two-part test period, the test cycle energy shall be calculated as:

$$\mathrm{ET} = \left(\frac{1440 \times K \times EP1}{T1}\right) + \left[EP2 - \left(EP1 \times \frac{T2}{T1}\right)\right] \times \left[\frac{12}{CT}\right] \times K$$

Where:

ET = test cycle energy expended in kilowatt-hours per day;

1440 = conversion factor to adjust to a 24-hour average use cycle in minutes per day;

K = dimensionless correction factor of 0.7 for chest freezers and 0.85 for upright freezers.

EP1 = energy expended in kilowatt-hours during the first part of the test;

EP2 = energy expended in kilowatt-hours during the second part of the test;

T1 and T2 = length of time in minutes of the first and second test parts, respectively;

CT = defrost timer run time or compressor run time between defrosts in hours required to go through a complete cycle, rounded to the nearest tenth of an hour;

12 = factor to adjust for a 50-percent run time of the compressor in hours per day.

(b) In place of sections 5.8.2.1.3 and 5.8.2.1.4 of HRF–1–2019, use the calculations provided in this section. For units with variable defrost control, the test cycle energy shall be calculated as set forth in section 5.3(a) of this appendix with the following addition:

CT shall be calculated equivalent to:

$$CT = \frac{CT_L \times CT_M}{F \times (CT_M - CT_L) + CT_L}$$

Where:

CT_L = the least or shortest compressor run time between defrosts used in the variable defrost control algorithm (greater than or equal to 6 but less than or equal to 12 hours), or the shortest compressor run time between defrosts observed for the test (if it is shorter than the shortest run time used in the control algorithm and is greater than 6 hours), or 6 hours (if the shortest observed run time is less than 6 hours), in hours rounded to the nearest tenth of an hour;

CT_M = the maximum compressor run time between defrosts in hours rounded to the nearest tenth of an hour (greater than CT_L but not more than 96 hours);

For variable defrost models with no values of CT_L and CT_M in the algorithm, the default values of 6 and 96 shall be used, respectively.

F = ratio of per day energy consumption in excess of the least energy and the maximum difference in per-day energy consumption and is equal to 0.20.

5.4. *Icemaker Energy Use*

For freezers: To demonstrate compliance with the energy conservation standards at §430.32(a) applicable to products manufactured on or after September 15, 2014, but before the compliance date of any amended standards published after January 1, 2022, IET, expressed in kilowatt-hours per cycle, equals 0.23 for a product with one or more automatic icemakers and otherwise equals 0 (zero). To demonstrate compliance with any amended standards published after January 1, 2022, IET, expressed in kilowatt-hours per cycle, is as defined in section 5.9.2.1 of HRF–1–2019.

6. Test Procedure Waivers

To the extent that the procedures contained in this appendix do not provide a means for determining the energy consumption of a basic model, a manufacturer must obtain a waiver under §430.27 to establish an acceptable test procedure for each such basic model. Such instances could, for example, include situations where the test setup for a particular basic model is not clearly defined by the provisions of this appendix. For details regarding the criteria and procedures for obtaining a waiver, please refer to §430.27.

[86 FR 56824, Oct. 12, 2021, as amended at 89 FR 3113, Jan. 17, 2024]

APPENDIX C1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF DISHWASHERS

NOTE: Manufacturers must use the results of testing under this appendix to determine compliance with the relevant standards provided at §430.32(f)(1).

Manufacturers must use the results of testing under appendix C2 to this subpart to determine compliance with the amended standards for dishwashers provided at §430.32(f)(2).

Manufacturers may use appendix C2 to certify compliance with the standards provided at §430.32(f)(2) prior to the applicable compliance date for those standards.

Any representations related to energy or water consumption of dishwashers must be made in accordance with the appropriate appendix that applies (*i.e.*, appendix C1 or appendix C2) when determining compliance with the relevant standards.

The regulation at 10 CFR 429.19(b)(3) provides instructions regarding the combination of detergent and detergent dosing, specified in section 2.5 of this appendix, used for certification.

0. Incorporation by Reference

In §430.3, DOE incorporated by reference the entire standard for AHAM DW–1–2020 and AHAM DW–2–2020; however, only enumerated provision of AHAM DW–1–2020, AHAM DW–2–2020, and IEC 62301 are applicable as follows:

0.1 AHAM DW–1–2020

(a) Sections 1.1 through 1.30 as referenced in section 1 of this appendix;

(b) Section 2.1 as referenced in sections 2 and 2.1 of this appendix;

(c) Sections 2.2 through 2.3.3, sections 2.5 through 2.7, sections 2.7.2 through 2.8, and section 2.11, as referenced in section 2 of this appendix;

(d) Section 2.4 as referenced in sections 2 and 2.2 of this appendix;

(e) Section 2.7.1 as referenced in sections 2 and 2.3 of this appendix;

(f) Section 2.9 as referenced in sections 2 and 2.4 of this appendix;

(g) Section 2.10 as referenced in sections 2 and 2.5 of this appendix;

(h) Sections 3.1 through 3.2 and sections 3.5 through 3.7 as referenced in section 3 of this appendix;

(i) Section 3.3 as referenced in sections 3 and 3.1 of this appendix;

(j) Section 3.4 as referenced in sections 3 and 3.2 of this appendix;

(k) Sections 4.1 through 4.1.2 and sections 4.1.4 through 4.2 as referenced in section 4 of this appendix;

(l) Section 4.1.4 as referenced in sections 4 and 4.1 of this appendix; and

(m) Section 5 as referenced in section 5 of this appendix.

0.2 AHAM DW–2–2020: Household Electric Dishwashers

(a) Section 3.4 as referenced in sections 2 and 2.3 of this appendix, and through reference to sections 1.5 and 1.22 of AHAM DW–1–2020 in section 1 of this appendix.

(b) Section 3.5 through reference to sections 1.5 and 1.22 of AHAM DW–1–2020 in section 1 of this appendix.

(c) Section 4.1 as referenced in section 2 of this appendix.

(d) Sections 5.3 through 5.8 as referenced in section 2 of this appendix, and through reference to sections 1.18, 1.19, and 1.20 of AHAM DW–1–2020 in section 1 of this appendix.

0.3 IEC 62301

(a) Sections 4.2, 4.3.2, and 5.2 as referenced in section 2 of this appendix; and

(b) Sections 5.1, note 1, and 5.3.2 as referenced in section 4 of this appendix.

1. Definitions

The definitions in sections 1.1 through 1.30 of AHAM DW–1–2020 apply to this test procedure, including the applicable provisions of AHAM DW–2–2020 as referenced in sections 1.5, 1.18, 1.19. 1.20, and 1.22 of AHAM DW–1–2020.

2. Testing Conditions

The testing conditions in sections 2.1 through 2.11 of AHAM DW–1–2020 apply to this test procedure, including the following provisions of:

(a) Sections 5.2, 4.3.2, and 4.2 of IEC 62301 as referenced in sections 2.1, 2.2.4, and 2.5.2 of AHAM DW–1–2020, respectively, and

(b) Sections 5.3 through 5.8 of AHAM DW–2–2020 as referenced in sections 2.6.3.1, 2.6.3.2, and 2.6.3.3 of AHAM DW–1–2020; section 3.4 of AHAM DW–2–2020, excluding the accompanying Note, as referenced in section 2.7.1 of AHAM DW–1–2020; section 5.4 of AHAM DW–2–2020 as referenced in section 2.7.4 of AHAM DW–1–2020; section 5.5 of AHAM DW–2–2020 as referenced in section 2.7.5 of AHAM DW–1–2020, and section 4.1 of AHAM DW–2–2020 as referenced in section 2.10.1 of AHAM DW–1–2020. Additionally, the following requirements are also applicable.

2.1 *Installation Requirements.*

The installation requirements described in section 2.1 of AHAM DW–1–2020 are applicable to all dishwashers, with the following additions:

2.1.1 *In-Sink Dishwashers.*

For in-sink dishwashers, the requirements pertaining to the rectangular enclosure for under-counter or under-sink dishwashers are not applicable. For such dishwashers, the rectangular enclosure must consist of a front, a back, two sides, and a bottom. The front, back, and sides of the enclosure must be brought into the closest contact with the appliance that the configuration of the dishwasher will allow. The height of the enclosure shall be as specified in the manufacturer's instructions for installation height. If no instructions are provided, the enclosure height shall be 36 inches. The dishwasher must be installed from the top and mounted to the edges of the enclosure.

2.1.2 *Dishwashers without a Direct Water Line.*

Manually fill the built-in water reservoir to the full capacity reported by the manufacturer, using water at a temperature in accordance with section 2.3 of AHAM DW–1–2020.

2.2 *Water pressure.*

The water pressure requirements described in section 2.4 of AHAM DW–1–2020 are applicable to all dishwashers except dishwashers that do not have a direct water line.

2.3 *Test load items.*

The test load items described in section 2.7.1 of AHAM DW–1–2020 apply to this test procedure, including the applicable provisions of section 3.4 of AHAM DW–2–2020, as referenced in section 2.7.1 of AHAM DW–1–2020. The following test load items may be used in the alternative.

Dishware/glassware/ flatware item	Primary source	Description	Primary No.	Alternate source	Alternate source No.
Dinner Plate	Corning Comcor®/ Corelle®.	10 inch Dinner Plate.	6003893		
Bread and Butter Plate.	Corning Comcor®/ Corelle®.	6.75 inch Bread & Butter.	6003887	Arzberg	8500217100 or 2000–00001–0217–1.
Fruit Bowl	Corning Comcor®/ Corelle®.	10 oz. Dessert Bowl	6003899	Arzberg	3820513100.
Cup	Corning Comcor®/ Corelle®.	8 oz. Ceramic Cup	6014162	Arzberg	1382–00001–4732.
Saucer	Corning Comcor®/ Corelle®.	6 inch Saucer	6010972	Arzberg	1382–00001–4731.
Serving Bowl	Corning Comcor®/ Corelle®.	1 qt. Serving Bowl	6003911		
Platter	Corning Comcor®/ Corelle®.	9.5 inch Oval Platter.	6011655		
Glass—Iced Tea	Libbey		551 HT		
Flatware—Knife	Oneida®—Accent		2619KPVF	WMF—Gastro 0800	12.0803.6047.
Flatware—Dinner Fork.	Oneida®—Accent		2619FRSF	WMF—Signum 1900.	12.1905.6040.
Flatware—Salad Fork.	Oneida®—Accent		2619FSLF	WMF—Signum 1900.	12.1964.6040.
Flatware—Teaspoon	Oneida®—Accent		2619STSF	WMF—Signum 1900.	12.1910.6040.
Flatware—Serving Fork.	Oneida®—Flight		2865FCM	WMF—Signum 1900.	12.1902.6040.
Flatware—Serving Spoon.	Oneida®—Accent		2619STBF	WMF—Signum 1900.	12.1904.6040.

2.4 *Preconditioning requirements.*

The preconditioning requirements described in section 2.9 of AHAM DW–1–2020 are applicable to all dishwashers. For dishwashers that do not have a direct water line, measurement of the prewash fill water volume, V_{pw}, if any, and measurement of the main wash fill water volume, V_{mw}, are not taken.

2.5 *Detergent.*

2.5.1 *Detergent Formulation.* Either Cascade with the Grease Fighting Power of Dawn or Cascade Complete Powder may be used.

2.5.2 *Detergent Dosage.*

2.5.2.1 *Dosage for any dishwasher other than water re-use system dishwashers.*

If Cascade with the Grease Fighting Power of Dawn detergent is used, the detergent dosing specified in section 2.5.2.1.1 of this appendix must be used.

If Cascade Complete Powder detergent is used, consult the introductory note to this appendix regarding use of the detergent dosing specified in either section 2.5.2.1.1 or section 2.5.2.1.2 of this appendix.

2.5.2.1.1 *Dosage based on fill water volumes.* Determine detergent dosage as follows:

Prewash Detergent Dosing. If the cycle setting for the test cycle includes prewash, determine the quantity of dry prewash detergent, $D_{pw,}$ in grams (g) that results in 0.25 percent concentration by mass in the prewash fill water as:

$$D_{pw} = V_{pw} \times \rho \times k \times 0.25/100$$

where,

V_{pw} = the prewash fill volume of water in gallons,

ρ = water density = 8.343 pounds (lb)/gallon for dishwashers to be tested at a nominal inlet water temperature of 50 °F (10 °C), 8.250 lb/gallon for dishwashers to be tested at a nominal inlet water temperature of 120 °F (49 °C), and 8.205 lb/gallon for dishwashers to be tested at a nominal inlet water temperature of 140 °F (60 °C), and

k = conversion factor from lb to g = 453.6 g/lb.

Main Wash Detergent Dosing. Determine the quantity of dry main wash detergent, $D_{mw,}$ in

grams (g) that results in 0.25 percent concentration by mass in the main wash fill water as:

$D_{mw} = V_{mw} \times \rho \times k \times 0.25/100$

where,

V_{mw} = the main wash fill volume of water in gallons, and

ρ and k are as defined above.

For dishwashers that do not have a direct water line, V_{mw} is equal to the manufacturer reported water capacity used in the main wash stage of the test cycle.

2.5.2.1.2 *Dosage based on number of place settings.* Determine detergent dosage as specified in sections 2.10 and 2.10.1 of AHAM DW–1–2020.

2.5.2.2 *Dosage for water re-use system dishwashers.* Determine detergent dosage as specified in section 2.10.2 of AHAM DW–1–2020.

2.5.3 *Detergent Placement.*

Prewash and main wash detergent must be placed as specified in sections 2.10 and 2.10.1 of AHAM DW–1–2020. For any dishwasher that does not have a main wash detergent compartment and the manufacturer does not recommend a location to place the main wash detergent, place the main wash detergent directly into the dishwasher chamber.

2.6 *Connected functionality.*

For dishwashers that can communicate through a network (*e.g.*, Bluetooth® or internet connection), disable all network functions that can be disabled by means provided in the manufacturer's user manual, for the duration of testing. If network functions cannot be disabled by means provided in the manufacturer's user manual, conduct the standby power test with network function in the ''as-shipped'' condition.

3. Instrumentation

For this test procedure, the test instruments are to be calibrated annually according to the specifications in sections 3.1 through 3.7 of AHAM DW–1–2020, including the applicable provisions of IEC 62301 as referenced in section 3.6 of AHAM DW–1–2020. Additionally, the following requirements are also applicable.

3.1 *Water meter.*

The water meter requirements described in section 3.3 of AHAM DW–1–2020 are applicable to all dishwashers except dishwashers that do not have a direct water line. For such dishwashers these water meter conditions do not apply and water is added manually pursuant to section 2.1.1 of this appendix.

3.2 *Water pressure gauge.*

The water pressure gauge requirements described in section 3.4 of AHAM DW–1–2020 are applicable to all dishwashers except dishwashers that do not have a direct water line. For such dishwashers these water pressure gauge conditions do not apply and water is added manually pursuant to section 2.1.1 of this appendix.

4. Test Cycle and Measurements

The test cycle and measurement specifications in sections 4.1 through 4.2 of AHAM DW–1–2020 apply to this test procedure, including section 5.1, note 1, and section 5.3.2 of IEC 62301 as referenced in section 4.2 of AHAM DW–1–2020. Additionally, the following requirements are also applicable.

4.1 *Water consumption.*

The water consumption requirements described in section 4.1.4 of AHAM DW–1–2020 are applicable to all dishwashers except dishwashers that do not have a direct water line. For such dishwashers these water consumption measurement requirements do not apply and water consumption, V, is the value reported by the manufacturer.

5. Calculation of Derived Results From Test Measurements

The calculations in section 5.1 through 5.7 of AHAM DW–1–2020 apply to this test procedure. The following additional requirements are also applicable:

(a) In sections 5.1.3, 5.1.4, 5.1.5, 5.4.3, 5.4.4, 5.4.5, and 5.7 of AHAM DW–1–2020, use N = 215 cycles/year in place of N = 184 cycles/year.

(b) In section 5.7 of AHAM DW–1–2020, use S_{LP} = 8,465 for dishwashers that are not capable of operating in fan-only mode.

(c) For dishwashers that do not have a direct water line, water consumption is equal to the volume of water use in the test cycle, as specified by the manufacturer.

(d) In sections 5.6.1.3, 5.6.1.4, 5.6.2.3, and 5.6.2.4 of AHAM DW–1–2020, use (C/e) in place of K.

[88 FR 3277, Jan. 18, 2023, as amended at 88 FR 48357, July 27, 2023; 89 FR 83617, Oct. 17, 2024]

APPENDIX C2 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF DISHWASHERS

NOTE: Manufacturers must use the results of testing under this appendix to determine compliance with the relevant standards provided at §430.32(f)(2). Manufacturers may use this appendix to certify compliance with the standards provided at §430.32(f)(2) prior to the applicable compliance date for those standards.

Any representations related to energy or water consumption of dishwashers must be made in accordance with the appropriate appendix that applies (*i.e.*, appendix C1 or appendix C2) when determining compliance with the relevant standards.

0. Incorporation by Reference

In §430.3, DOE incorporated by reference the entire standard for AHAM DW–1–2020 and AHAM DW–2–2020; however, only enumerated provision of AHAM DW–1–2020, AHAM DW–2–2020, and IEC 62301 are applicable as follows:

0.1 AHAM DW–1–2020

(a) Sections 1.1 through 1.30 as referenced in section 1 of this appendix;
(b) Section 2.1 as referenced in sections 2 and 2.1 of this appendix;
(c) Sections 2.2 through 2.3.3, sections 2.5 and 2.7, sections 2.7.2 through 2.8, and section 2.11, as referenced in section 2 of this appendix;
(d) Section 2.4 as referenced in sections 2 and 2.2 of this appendix;
(e) Section 2.6.3 as referenced in sections 2 and 2.3 of this appendix;
(f) Section 2.7.1 as referenced in sections 2 and 2.4 of this appendix;
(g) Section 2.9 as referenced in sections 2 and 2.5 of this appendix;
(h) Section 2.10 as referenced in sections 2 and 2.6 of this appendix;
(i) Sections 3.1 through 3.2 and sections 3.5 through 3.7 as referenced in section 3 of this appendix;
(j) Section 3.3 as referenced in sections 3 and 3.1 of this appendix;
(k) Section 3.4 as referenced in sections 3 and 3.2 of this appendix;
(l) Section 4.1 as referenced in sections 4 and 4.1 of this appendix;
(m) Section 4.1.4 as referenced in sections 4 and 4.1.2 of this appendix; and
(n) Section 5 as referenced in section 5 of this appendix.

0.2 AHAM DW–2–2020

(a) Section 3.4 as referenced in sections 2 and 2.4 of this appendix, and through reference to sections 1.5 and 1.22 of AHAM DW–1–2020 in section 1 of this appendix.
(b) Section 3.5 through reference to sections 1.5 and 1.22 of AHAM DW–1–2020 in section 1 of this appendix.
(c) Section 4.1 as referenced in section 2 of this appendix.
(d) Sections 5.3 through 5.8 as referenced in section 2 of this appendix, and through reference to sections 1.18, 1.19 and 1.20 of AHAM DW–1–2020 in section 1 of this appendix.
(e) Section 5.10 as referenced in sections 2 and 2.8 of this appendix;
(f) Sections 5.10.1.1 as referenced in sections 4 and 4.2 of this appendix; and
(g) Section 5.12.3.1 as referenced in sections 5 and 5.1 of this appendix.

0.3 IEC 62301

(a) Sections 4.2, 4.3.2, and 5.2 as referenced in section 2 of this appendix; and
(b) Sections 5.1, note 1, and 5.3.2 as referenced in section 4 of this appendix.

1. Definitions

The definitions in sections 1.1 through 1.30 of AHAM DW–1–2020 apply to this test procedure, including the applicable provisions of AHAM DW–2–2020 as referenced in sections 1.5, 1.18, 1.19, 1.20, and 1.22 of AHAM DW–1–2020.

2. Testing Conditions

The testing conditions in Section 2.1 through 2.11 of AHAM DW–1–2020, except sections 2.6.1 and 2.6.2, and the testing conditions in section 5.10 of AHAM DW–2–2020 apply to this test procedure, including the following provisions of:

(a) Sections 5.2, 4.3.2, and 4.2 of IEC 62301 as referenced in sections 2.1, 2.2.4, and 2.5.2 of AHAM DW–1–2020, respectively, and
(b) Sections 5.3 through 5.8 of AHAM DW–2–2020 as referenced in sections 2.6.3.1, 2.6.3.2, and 2.6.3.3 of AHAM DW–1–2020; section 3.4 of AHAM DW–2–2020, excluding the accompanying Note, as referenced in section 2.7.1 of AHAM DW–1–2020; section 5.4 of AHAM DW–2–2020 as referenced in section 2.7.4 of AHAM DW–1–2020; section 5.5 of AHAM DW–2–2020 as referenced in section 2.7.5 of AHAM DW–1–2020, and section 4.1 of AHAM DW–2–2020 as referenced in section 2.10.1 of AHAM DW–1–2020. Additionally, the following requirements are also applicable.

2.1 *Installation Requirements.*

The installation requirements described in section 2.1 of AHAM DW–1–2020 are applicable to all dishwashers, with the following additions:

2.1.1 *In-Sink Dishwashers.*

For in-sink dishwashers, the requirements pertaining to the rectangular enclosure for under-counter or under-sink dishwashers are not applicable. For such dishwashers, the rectangular enclosure must consist of a front, a back, two sides, and a bottom. The front, back, and sides of the enclosure must be brought into the closest contact with the appliance that the configuration of the dishwasher will allow. The height of the enclosure shall be as specified in the manufacturer's instructions for installation height. If no instructions are provided, the enclosure height shall be 36 inches. The dishwasher must be installed from the top and mounted to the edges of the enclosure.

2.1.2 *Dishwashers without a Direct Water Line.*

Manually fill the built-in water reservoir to the full capacity reported by the manufacturer, using water at a temperature in accordance with section 2.3 of AHAM DW–1–2020.

2.2 *Water pressure.*

The water pressure requirements described in section 2.4 of AHAM DW–1–2020 are applicable to all dishwashers except dishwashers that do not have a direct water line.

2.3 *Non-soil-sensing and soil-sensing dishwashers to be tested at a nominal inlet temperature of 50 °F, 120 °F, or 140 °F.*

The test load and soiling requirements for all non-soil-sensing and soil-sensing dishwashers shall be the same as those requirements specified in section 2.6.3 of AHAM DW–1–2020 for soil-sensing dishwashers. Additionally, both non-soil-sensing and soil-sensing compact dishwashers that have a capacity of less than four place settings shall be tested at the rated capacity of the dishwasher and the test load shall be soiled as follows at each soil load:

(a) Heavy soil load: soil two-thirds of the place settings, excluding flatware and serving pieces (rounded up to the nearest integer) or one place setting, whichever is greater;

(b) Medium soil load: soil one-quarter of the place settings, excluding flatware and serving pieces (rounded up to the nearest integer) or one place setting, whichever is smaller;

(c) Light soil load: soil one-quarter of the place settings, excluding flatware and serving pieces (rounded up to the nearest integer) or one place setting, whichever is smaller, using half the quantity of soils specified for one place setting.

2.4 *Test load items.*

The test load items described in section 2.7.1 of AHAM DW–1–2020 apply to this test procedure, including the applicable provisions of section 3.4 of AHAM DW–2–2020, as referenced in section 2.7.1 of AHAM DW–1–2020. The following test load items may be used in the alternative.

Dishware/glassware/ flatware item	Primary source	Description	Primary No.	Alternate source	Alternate source No.
Dinner Plate	Corning Comcor®/ Corelle®.	10 inch Dinner Plate.	6003893		
Bread and Butter Plate.	Corning Comcor®/ Corelle®.	6.75 inch Bread & Butter.	6003887	Arzberg	8500217100 or 2000–00001–0217–1.
Fruit Bowl	Corning Comcor®/ Corelle®.	10 oz. Dessert Bowl	6003899	Arzberg	3820513100.
Cup	Corning Comcor®/ Corelle®.	8 oz. Ceramic Cup	6014162	Arzberg	1382–00001–4732.
Saucer	Corning Comcor®/ Corelle®.	6 inch Saucer	6010972	Arzberg	1382–00001–4731.
Serving Bowl	Corning Comcor®/ Corelle®.	1 qt. Serving Bowl	6003911		
Platter	Corning Comcor®/ Corelle®.	9.5 inch Oval Platter.	6011655		
Glass—Iced Tea	Libbey		551 HT		
Flatware—Knife	Oneida®—Accent		2619KPVF	WMF—Gastro 0800	12.0803.6047.
Flatware—Dinner Fork.	Oneida®—Accent		2619FRSF	WMF—Signum 1900.	12.1905.6040.
Flatware—Salad Fork.	Oneida®—Accent		2619FSLF	WMF—Signum 1900.	12.1964.6040.
Flatware—Teaspoon	Oneida®—Accent		2619STSF	WMF—Signum 1900.	12.1910.6040.
Flatware—Serving Fork.	Oneida®—Flight		2865FCM	WMF—Signum 1900.	12.1902.6040.
Flatware—Serving Spoon.	Oneida®—Accent		2619STBF	WMF—Signum 1900.	12.1904.6040.

2.5 *Preconditioning requirements.*

The preconditioning requirements described in section 2.9 of AHAM DW–1–2020 are applicable to all dishwashers except the measurement of the prewash fill water volume, V_{pw}, if any, and measurement of the main wash fill water volume, V_{mw}, are not required.

2.6 *Detergent.*

The detergent requirements described in section 2.10 of AHAM DW–1–2020 are applicable to all dishwashers. For any dishwasher that does not have a main wash detergent compartment and the manufacturer does not recommend a location to place the main wash detergent, place the detergent directly into the dishwasher chamber.

2.7 *Connected functionality.*

For dishwashers that can communicate through a network (*e.g.*, Bluetooth® or internet connection), disable all network functions that can be disabled by means provided in the manufacturer's user manual, for the duration of testing. If network functions cannot be disabled by means provided in the manufacturer's user manual, conduct the standby power test with network function in the ''as-shipped'' condition.

2.8 *Evaluation Room Lighting Conditions.*

The lighting setup in the evaluation room where the test load is scored shall be according to the requirements specified in section 5.10 of AHAM DW–2–2020.

3. Instrumentation

For this test procedure, the test instruments are to be calibrated annually according to the specifications in section 3.1 through 3.7 of AHAM DW–1–2020, including the applicable provisions of IEC 62301 as referenced in section 3.6 of AHAM DW–1–2020. Additionally, the following requirements are also applicable.

3.1 *Water meter.*

The water meter requirements described in section 3.3 of AHAM DW–1–2020 are applicable to all dishwashers except dishwashers that do not have a direct water line. For such dishwashers these water meter conditions do not apply and water is added manually pursuant to section 2.1.1 of this appendix.

3.2 *Water pressure gauge.*

The water pressure gauge requirements described in section 3.4 of AHAM DW–1–2020 are applicable to all dishwashers except dishwashers that do not have a direct water line. For such dishwashers these water pressure gauge conditions do not apply and water is added manually pursuant to section 2.1.1 of this appendix.

4. Test Cycle and Measurements

The test cycle and measurement specifications in sections 4.1 through 4.2 of AHAM DW–1–2020 and the scoring specifications in section 5.10.1.1 of AHAM DW–2–2020 apply to this test procedure, including section 5.1, note 1, and section 5.3.2 of IEC 62301 as referenced in section 4.2 of AHAM DW–1–2020. Additionally, the following requirements are also applicable.

4.1 *Active mode cycle.*

The active mode energy consumption measurement requirements described in section 4.1 of AHAM DW–1–2020 are applicable to all dishwashers. Additionally, the following requirements are also applicable:

(a) After the completion of each test cycle (sensor heavy response, sensor medium response, and sensor light response), the test load shall be scored according to section 4.2 of this appendix and its cleaning index calculated according to section 5.1 of this appendix.

(b) A test cycle is considered valid if its cleaning index is 70 or higher; otherwise, the test cycle is invalid and the data from that test run is discarded.

(c) For soil-sensing dishwashers, if the test cycle at any soil load is invalid, clean the dishwasher filter according to manufacturer's instructions and repeat the test at that soil load on the most energy-intensive cycle (determined as provided in section 4.1.1 of this appendix) that achieves a cleaning index of 70 or higher.

(d) For non-soil-sensing dishwashers, perform testing as described in section 4.1.a through 4.1.c of this appendix, except that, if a test cycle at a given soil load meets the cleaning index threshold criteria of 70 when tested on the normal cycle, no further testing is required for test cycles at lesser soil loads.

4.1.1 *Determination of most energy-intensive cycle.*

If the most energy-intensive cycle is not known and needs to be determined via testing, ensure the filter is cleaned as specified in the manufacturer's instructions and test each available cycle type, selecting the default cycle options for that cycle type. In the absence of manufacturer recommendations on washing and drying temperature options, the highest energy consumption options must be selected. Following the completion of each test cycle, the machine electrical energy consumption and water consumption shall be measured according to sections 4.1.1 and 4.1.4 of AHAM DW–1–2020, respectively. The total cycle energy consumption, E_{MEI}, of each tested cycle type shall be calculated according to section 5.2 of this appendix. The most energy-intensive cycle is the cycle type with the highest value of E_{MEI}.

For standard dishwashers, test each cycle with a clean load of eight place settings plus six serving pieces, as specified in section 2.7 of AHAM DW–1–2020. For compact dishwashers, test each cycle with a clean load of four place settings plus six serving pieces, as specified in section 2.7 of AHAM DW–1–2020. If the capacity of the dishwasher, as stated by the manufacturer, is less than four place settings, then the test load must be the stated capacity.

4.1.2 *Water consumption.*

The water consumption requirements described in section 4.1.4 of AHAM DW–1–2020 are applicable to all dishwashers except dishwashers that do not have a direct water line. For such dishwashers these water consumption measurement requirements do not apply and water consumption, V, is the value reported by the manufacturer.

4.2 *Scoring.*

Following the termination of an active mode test, each item in the test load shall be scored on a scale from 0 to 9 according to the instructions in section 5.10.1.1 of AHAM DW–2–2020.

5. Calculation of Derived Results From Test Measurements

The calculations in sections 5.1 through 5.7 of AHAM DW–1–2020 and section 5.12.3.1 of AHAM DW–2–2020 apply to this test procedure. The following additional requirements are also applicable:

(a) For both soil-sensing and non-soil-sensing dishwashers, use the equations specified for soil-sensing dishwashers.

(b) If a non-soil-sensing dishwasher is not tested at a certain soil load as specified in section 4.1.d of this appendix, use the energy

and water consumption values of the preceding soil load when calculating the weighted average energy and water consumption values (*i.e.*, if the sensor medium response and sensor light response tests on the normal cycle are not conducted, use the values of the sensor heavy response test for all three soil loads; if only the sensor light response test is not conducted, use the values of the sensor medium response test for the sensor light response test).

(c) For dishwashers that do not have a direct water line, water consumption is equal to the volume of water use in the test cycle, as specified by the manufacturer.

(d) In sections 5.6.1.3, 5.6.1.4, 5.6.2.3, and 5.6.2.4 of AHAM DW–1–2020, use (C/e) in place of K.

5.1 *Cleaning Index.*

Determine the per-cycle cleaning index for each test cycle using the equation in section 5.12.3.1 of AHAM DW–2–2020.

5.2 *Calculation for determination of the most energy-intensive cycle type.*

The total cycle energy consumption for the determination of the most energy-intensive cycle specified in section 4.1.1 of this appendix is calculated for each tested cycle type as:

$$E_{MEI} = M + E_F - (E_D/2) + W$$

where,

M = per-cycle machine electrical energy consumption, expressed in kilowatt hours per cycle,

E_F = fan-only mode electrical energy consumption, if available on the tested cycle type, expressed in kilowatt hours per cycle,

E_D = drying energy consumed using the power-dry feature after the termination of the last rinse option of the tested cycle type, if available on the tested cycle type, expressed in kilowatt hours per cycle, and

W = water energy consumption and is defined as:

$V \times T \times K$, for dishwashers using electrically heated water, and

$V \times T \times C/e$, for dishwashers using gas-heated or oil-heated water.

Additionally,

V = water consumption in gallons per cycle,

T = nominal water heater temperature rise and is equal to 90 °F for dishwashers that operate with a nominal 140 °F inlet water temperature, and 70 °F for dishwashers that operate with a nominal 120 °F inlet water temperature,

K = specific heat of water in kilowatt-hours per gallon per degree Fahrenheit = 0.0024,

C = specific heat of water in Btu's per gallon per degree Fahrenheit = 8.2, and

e = nominal gas or oil water heater recovery efficiency = 0.75.

[88 FR 3279, Jan. 18, 2023, as amended at 89 FR 83617, Oct. 17, 2204]

APPENDIX D1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CLOTHES DRYERS

NOTE: The procedures in either this appendix or appendix D2 to this subpart must be used to determine compliance with the energy conservation standards for clothes dryers provided at § 430.32(h)(3).

Manufacturers must use a single appendix for all representations, including certifications of compliance, and may not use this appendix for certain representations and appendix D2 to this subpart for other representations. The procedures in appendix D2 to this subpart must be used to determine compliance with the energy conservation standards for clothes dryers provided at § 430.32(h)(4).

0. INCORPORATION BY REFERENCE

DOE incorporated by reference in § 430.3 the standards for AHAM HLD–1 and IEC 62301, in their entirety, however, only enumerated provisions of those documents are applicable to this appendix. In cases where there is a conflict between any industry standard(s) and this appendix, the language of the test procedure in this appendix takes precedence over the industry standard(s).

(1) AHAM HLD–1:

(i) Section 3.3.5.1 ''Standard Simulator'' as referenced in sections 2.1.2 through 2.1.3 of this appendix.

(ii) [Reserved]

(2) IEC 62301:

(i) Section 5, Paragraph 5.1, Note 1 as referenced in section 3.6.2 of this appendix.

(ii) Section 5, Paragraph 5.3.2 ''Sampling Method'' as referenced in section 3.6.3 of this appendix.

1. DEFINITIONS

1.1 ''Active mode'' means a mode in which the clothes dryer is connected to a main power source, has been activated and is performing the main function of tumbling the clothing with or without heated or unheated forced air circulation to remove moisture from the clothing, remove wrinkles or prevent wrinkling of the clothing, or both.

1.2 ''AHAM'' means the Association of Home Appliance Manufacturers.

1.3 ''AHAM HLD–1'' means the test standard published by the Association of Home Appliance Manufacturers, titled ''Household Tumble Type Clothes Dryers,'' ANSI-approved June 11, 2010, ANSI/AHAM HLD–1–2010.

1.4 ''Automatic termination control'' means a dryer control system with a sensor which monitors either the dryer load temperature or its moisture content and with a controller which automatically terminates the drying process. A mark, detent, or other visual indicator or detent which indicates a preferred automatic termination control setting must be present if the dryer is to be classified as having an ''automatic termination control.'' A mark is a visible single control setting on one or more dryer controls.

1.5 ''Bone dry'' means a condition of a load of test cloths which has been dried in a dryer at maximum temperature for a minimum of 10 minutes, removed, and weighed before cool down, and then dried again for 10-minute periods until the final weight change of the load is 1 percent or less.

1.6 ''Compact'' or ''compact size'' means a clothes dryer with a drum capacity of less than 4.4 cubic feet.

1.7 ''Cool down'' means that portion of the clothes drying cycle when the added gas or electric heat is terminated and the clothes continue to tumble and dry within the drum.

1.8 ''Cycle'' means a sequence of operation of a clothes dryer which performs a clothes drying operation, and may include variations or combinations of the functions of heating, tumbling, and drying.

1.9 ''Drum capacity'' means the volume of the drying drum in cubic feet.

1.10 ''IEC 62301'' (Second Edition) means the test standard published by the International Electrotechnical Commission (''IEC'') titled ''Household electrical appliances—Measurement of standby power,'' Publication 62301 (Edition 2.0 2011–01) (incorporated by reference; see §430.3).

1.11 ''Final moisture content'' (''FMC'') means the ratio of the weight of water contained by the dry test load (*i.e.*, after completion of the drying cycle) to the bone-dry weight of the test load, expressed as a percent.

1.12 ''Inactive mode'' means a standby mode that facilitates the activation of active mode by remote switch (including remote control), internal sensor, or timer, or that provides continuous status display.

1.13 ''Initial moisture content'' (''IMC'') means the ratio of the weight of water contained by the damp test load (*i.e.,* prior to completion of the drying cycle) to the bone-dry weight of the test load, expressed as a percent.

1.14 ''Moisture content'' means the ratio of the weight of water contained by the test load to the bone-dry weight of the test load, expressed as a percent.

1.15 ''Off mode'' means a mode in which the clothes dryer is connected to a main power source and is not providing any active or standby mode function, and where the mode may persist for an indefinite time. An indicator that only shows the user that the product is in the off position is included within the classification of an off mode.

1.16 ''Standard size'' means a clothes dryer with a drum capacity of 4.4 cubic feet or greater.

1.17 ''Standby mode'' means any product modes where the energy using product is connected to a main power source and offers one or more of the following user-oriented or protective functions which may persist for an indefinite time:

(a) To facilitate the activation of other modes (including activation or deactivation of active mode) by remote switch (including remote control), internal sensor, or timer.

(b) Continuous functions, including information or status displays (including clocks) or sensor-based functions. A timer is a continuous clock function (which may or may not be associated with a display) that provides regular scheduled tasks (e.g., switching) and that operates on a continuous basis.

1.18 ''Vented clothes dryer'' means a clothes dryer that exhausts the evaporated moisture from the cabinet.

1.19 ''Ventless clothes dryer'' means a clothes dryer that uses a closed-loop system with an internal condenser to remove the evaporated moisture from the heated air. The moist air is not discharged from the cabinet.

2. Testing Conditions

2.1 *Installation.*

2.1.1 *All clothes dryers.* For both vented clothes dryers and ventless clothes dryers, install the clothes dryer in accordance with manufacturer's instructions as shipped with the unit. If the manufacturer's instructions do not specify the installation requirements for a certain component, it shall be tested in the as-shipped condition. Where the manufacturer gives the option to use the dryer both with and without a duct, the dryer shall be tested without the exhaust simulator described in section 3.3.5.1 of AHAM HLD–1 (incorporated by reference; see §430.3). All external joints should be taped to avoid air leakage. For drying testing, disconnect all lights, such as task lights, that do not provide any information related to the drying process on the clothes dryer and that do not consume more than 10 watts during the clothes dryer test cycle. Control setting indicator lights showing the cycle progression, temperature or dryness settings, or other cycle functions that cannot be turned off during the test cycle shall not be disconnected during the active mode test cycle. For standby and off mode testing, the clothes dryer shall also be installed in accordance with section 5, paragraph 5.2 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3), disregarding the provisions regarding batteries and the determination, classification, and testing of relevant

modes. For standby and off mode testing, all lighting systems shall remain connected.

2.1.2 *Vented clothes dryers.* For vented clothes dryers, the dryer exhaust shall be restricted by adding the AHAM exhaust simulator described in section 3.3.5.1 of AHAM HLD–1.

2.1.3 *Ventless clothes dryers.* For ventless clothes dryers, the dryer shall be tested without the AHAM exhaust simulator. If the manufacturer gives the option to use a ventless clothes dryer, with or without a condensation box, the dryer shall be tested with the condensation box installed. For ventless clothes dryers, the condenser unit of the dryer must remain in place and not be taken out of the dryer for any reason between tests.

2.2 *Ambient temperature and humidity.*

2.2.1 For drying testing, maintain the room ambient air temperature at 75 ±3 °F and the room relative humidity at 50 percent ±10 percent relative humidity.

2.2.2 For standby and off mode testing, maintain room ambient air temperature conditions as specified in section 4, paragraph 4.2 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3)

2.3 *Energy supply.*

2.3.1 *Electrical supply.* Maintain the electrical supply at the clothes dryer terminal block within 1 percent of 120/240 or 120/208Y or 120 volts as applicable to the particular terminal block wiring system and within 1 percent of the nameplate frequency as specified by the manufacturer. If the dryer has a dual voltage conversion capability, conduct the test at the highest voltage specified by the manufacturer.

2.3.1.1 *Supply voltage waveform.* For the clothes dryer standby mode and off mode testing, maintain the electrical supply voltage waveform indicated in section 4, paragraph 4.3.2 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3). If the power measuring instrument used for testing is unable to measure and record the total harmonic content during the test measurement period, it is acceptable to measure and record the total harmonic content immediately before and after the test measurement period.

2.3.2 *Gas supply.*

2.3.2.1 *Natural gas supply.* Maintain the gas supply to the clothes dryer immediately ahead of all controls at a pressure of 7 to 10 inches of water column. The natural gas supplied should have a heating value of approximately 1,025 Btus per standard cubic foot. The actual heating value, H_n2, in Btus per standard cubic foot, for the natural gas to be used in the test shall be obtained either from measurements using a standard continuous flow calorimeter as described in section 2.4.6 of this appendix or by the purchase of bottled natural gas whose Btu rating is certified to be at least as accurate a rating as could be obtained from measurements with a standard continuous flow calorimeter as described in section 2.4.6 of this appendix.

2.3.2.2 *Propane gas supply.* Maintain the gas supply to the clothes dryer immediately ahead of all controls at a pressure of 11 to 13 inches of water column. The propane gas supplied should have a heating value of approximately 2,500 Btus per standard cubic foot. The actual heating value, H_p, in Btus per standard cubic foot, for the propane gas to be used in the test shall be obtained either from measurements using a standard continuous flow calorimeter as described in section 2.4.6 of this appendix or by the purchase of bottled gas whose Btu rating is certified to be at least as accurate a rating as could be obtained from measurement with a standard continuous calorimeter as described in section 2.4.6 of this appendix.

2.3.2.3 *Hourly Btu Rating.* Maintain the hourly Btu rating of the burner within ±5 percent of the rating specified by the manufacturer. If the hourly Btu rating of the burner cannot be maintained within ±5 percent of the rating specified by the manufacturer, make adjustments in the following order until an hourly Btu rating of the burner within ±5 percent of the rating specified by the manufacturer is achieved:

(1) Modify the gas inlet supply pressure within the allowable range specified in section 2.3.2.1 or 2.3.2.2 of this appendix, as applicable;

(2) If the clothes dryer is equipped with a gas pressure regulator, modify the outlet pressure of the gas pressure regulator within ±10 percent of the value recommended by the manufacturer in the installation manual, on the nameplate sticker, or wherever the manufacturer makes such a recommendation for the basic model; and

(3) Modify the orifice as necessary to achieve the required hourly Btu rating.

2.4 *Instrumentation.* Perform all test measurements using the following instruments as appropriate.

2.4.1 *Weighing scales.*

2.4.1.1 *Weighing scale for test cloth.* The scale shall have a range of 0 to a maximum of 60 pounds with a resolution of at least 0.001 pounds and a maximum error no greater than 0.1 percent of any measured value within the range of 3 to 15 pounds.

2.4.1.2 *Weighing scale for drum capacity measurements.* The scale should have a range of 0 to a maximum of 600 pounds with resolution of 0.50 pounds and a maximum error no greater than 0.5 percent of the measured value.

2.4.2 *Kilowatt-hour meter.* The kilowatt-hour meter shall have a resolution of 0.001 kilowatt-hours and a maximum error no greater than 0.5 percent of the measured value.

2.4.3 *Gas meter.* The gas meter shall have a resolution of 0.001 cubic feet and a maximum

error no greater than 0.5 percent of the measured value.

2.4.4 *Dry and wet bulb psychrometer.* The dry and wet bulb psychrometer shall have an error no greater than ±1 °F. A relative humidity meter with a maximum error tolerance expressed in °F equivalent to the requirements for the dry and wet bulb psychrometer or with a maximum error tolerance of ±2 percent relative humidity would be acceptable for measuring the ambient humidity.

2.4.5 *Temperature.* The temperature sensor shall have an error no greater than ±1 °F.

2.4.6 *Standard Continuous Flow Calorimeter.* The calorimeter shall have an operating range of 750 to 3,500 Btu per cubic feet. The maximum error of the basic calorimeter shall be no greater than 0.2 percent of the actual heating value of the gas used in the test. The indicator readout shall have a maximum error no greater than 0.5 percent of the measured value within the operating range and a resolution of 0.2 percent of the full-scale reading of the indicator instrument.

2.4.7 *Standby mode and off mode watt meter.* The watt meter used to measure standby mode and off mode power consumption shall meet the requirements specified in section 4, paragraph 4.4 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3). If the power measuring instrument used for testing is unable to measure and record the crest factor, power factor, or maximum current ratio during the test measurement period, it is acceptable to measure the crest factor, power factor, and maximum current ratio immediately before and after the test measurement period.

2.5 *Lint trap.* Clean the lint trap thoroughly before each test run.

2.6 *Test Cloths.*

2.6.1 *Energy test cloth.* The energy test cloth shall be clean and consist of the following:

(a) Pure finished bleached cloth, made with a momie or granite weave, which is a blended fabric of 50-percent cotton and 50-percent polyester and weighs within + 10 percent of 5.75 ounces per square yard after test cloth preconditioning, and has 65 ends on the warp and 57 picks on the fill. The individual warp and fill yarns are a blend of 50-percent cotton and 50-percent polyester fibers.

(b) Cloth material that is 24 inches by 36 inches and has been hemmed to 22 inches by 34 inches before washing. The maximum shrinkage after five washes shall not be more than 4 percent on the length and width.

(c) The number of test runs on the same energy test cloth shall not exceed 25 runs.

2.6.2 *Energy stuffer cloths.* The energy stuffer cloths shall be made from energy test cloth material, and shall consist of pieces of material that are 12 inches by 12 inches and have been hemmed to 10 inches by 10 inches before washing. The maximum shrinkage after five washes shall not be more than 4 percent on the length and width. The number of test runs on the same energy stuffer cloth shall not exceed 25 runs after test cloth preconditioning.

2.6.3 *Test Cloth Preconditioning.*

A new test cloth load and energy stuffer cloths shall be treated as follows:

(1) Bone dry the load to a weight change of ±1 percent, or less, as prescribed in section 1.5.

(2) Place the test cloth load in a standard clothes washer set at the maximum water fill level. Wash the load for 10 minutes in soft water (17 parts per million hardness or less), using 60.8 grams of AHAM standard test detergent Formula 3. Wash water temperature is to be controlled at 140 ° ±5 °F (60 ° ±2.7 °C). Rinse water temperature is to be controlled at 100 ° ±5 °F (37.7 ±2.7 °C).

(3) Rinse the load again at the same water temperature.

(4) Bone dry the load as prescribed in section 1.5 and weigh the load.

(5) This procedure is repeated until there is a weight change of 1 percent or less.

(6) A final cycle is to be a hot water wash with no detergent, followed by two warm water rinses.

2.7 *Test loads.*

2.7.1 *Load size.* Determine the load size for the unit under test, according to Table 1 of this section.

TABLE 1—TEST LOADS

Unit under test	Test load (bone dry weight)
Standard size clothes dryer ...	8.45 pounds ± .085 pounds.
Compact size clothes dryer ...	3.00 pounds ± .03 pounds.

Each test load must consist of energy test cloths and no more than five energy stuffer cloths.

2.7.2 *Test load preparation.* Dampen the load by agitating it in water whose temperature is 60 °F ± 5 °F and consists of 0 to 17 parts per million hardness for approximately 2 minutes in order to saturate the fabric. Then, extract water from the wet test load by spinning the load to a target moisture content between 54.0–61.0 percent of the bone-dry weight of the test load. If after extraction the moisture content is less than 54.0 percent, make a final mass adjustment, such that the moisture content is between 54.0–61.0 percent of the bone-dry weight of the test load, by adding water uniformly distributed among all of the test cloths in a very fine spray using a spray bottle.

2.7.3 *Method of loading.* Load the energy test cloths by grasping them in the center, shaking them to hang loosely, and then dropping them in the dryer at random.

2.8 *Clothes dryer preconditioning.*

2.8.1 *Vented clothes dryers.* For vented clothes dryers, before any test cycle, operate

the dryer without a test load in the non-heat mode for 15 minutes or until the discharge air temperature is varying less than 1 °F for 10 minutes—whichever is longer—in the test installation location with the ambient conditions within the specified test condition tolerances of section 2.2 of this appendix.

2.8.2 *Ventless clothes dryers.* For ventless clothes dryers, before any test cycle, the steady-state machine temperature must be equal to ambient room temperature described in 2.2.1. This may be done by leaving the machine at ambient room conditions for at least 12 hours between tests.

3. TEST PROCEDURES AND MEASUREMENTS

3.1 *Drum Capacity.* Measure the drum capacity by sealing all openings in the drum except the loading port with a plastic bag, and ensuring that all corners and depressions are filled and that there are no extrusions of the plastic bag through any openings in the interior of the drum. Support the dryer's rear drum surface on a platform scale to prevent deflection of the drum surface, and record the weight of the empty dryer. Fill the drum with water to a level determined by the intersection of the door plane and the loading port (*i.e.*, the uppermost edge of the drum that is in contact with the door seal). Record the temperature of the water and then the weight of the dryer with the added water and then determine the mass of the water in pounds. Add the appropriate volume to account for any space in the drum interior not measured by water fill (e.g., the space above the uppermost edge of the drum within a curved door) and subtract the appropriate volume to account for space that is measured by water fill but cannot be used when the door is closed (e.g., space occupied by the door when closed). The drum capacity is calculated to the nearest 0.1 cubic foot as follows:

C = w/d ±volume adjustment
C = capacity in cubic feet.
w = mass of water in pounds.
d = density of water at the measured temperature in pounds per cubic foot.

3.2 *Dryer Loading.* Load the dryer as specified in 2.7.

3.3 *Test cycle.* Operate the clothes dryer at the maximum temperature setting and, if equipped with a timer, at the maximum time setting. Any other optional cycle settings that do not affect the temperature or time settings shall be tested in the as-shipped position, except that if the clothes dryer has network capabilities, the network settings must be disabled throughout testing if such settings can be disabled by the end-user and the product's user manual provides instructions on how to do so. If the network settings cannot be disabled by the end-user, or the product's user manual does not provide instruction for disabling network settings, then the unit must be tested with the network settings in the factory default configuration for the test cycle. If the clothes dryer does not have a separate temperature setting selection on the control panel, the maximum time setting should be used for the drying test cycle. Dry the load until the moisture content of the test load is between 2.5 and 5.0 percent of the bone-dry weight of the test load, at which point the test cycle is stopped, but do not permit the dryer to advance into cool down. If required, reset the timer to increase the length of the drying cycle. After stopping the test cycle, remove and weigh the test load within 5 minutes following termination of the test cycle. The clothes dryer shall not be stopped intermittently in the middle of the test cycle for any reason. Record the data specified by section 3.4 of this appendix. If the dryer automatically stops during a cycle because the condensation box is full of water, the test is stopped, and the test run is invalid, in which case the condensation box shall be emptied and the test re-run from the beginning. For ventless clothes dryers, during the time between two cycles, the door of the dryer shall be closed except for loading and unloading.

3.4 *Data recording.* Record for each test cycle:

3.4.1 Bone-dry weight of the test load, $W_{bonedry}$, as described in section 2.7.1 of this appendix.

3.4.2 Moisture content of the wet test load before the test, IMC, as described in section 2.7.2 of this appendix.

3.4.3 Moisture content of the dry test load obtained after the test, FMC, as described in section 3.3 of this appendix.

3.4.4 Test room conditions, temperature, and percent relative humidity described in 2.2.1.

3.4.5 For electric dryers—the total kilowatt-hours of electric energy, E_t, consumed during the test described in 3.3.

3.4.6 For gas dryers:

3.4.6.1 Total kilowatt-hours of electrical energy, E_{te}, consumed during the test described in 3.3.

3.4.6.2 Cubic feet of gas per cycle, E_{tg}, consumed during the test described in 3.3.

3.4.6.3 Correct the gas heating value, GEF, as measured in 2.3.2.1 and 2.3.2.2, to standard pressure and temperature conditions in accordance with U.S. Bureau of Standards, circular C417, 1938.

3.5 *Test for automatic termination field use factor.* The field use factor for automatic termination can be claimed for those dryers which meet the requirements for automatic termination control, defined in 1.4.

3.6 *Standby mode and off mode power.* Connect the clothes dryer to a watt meter as specified in section 2.4.7 of this appendix. Establish the testing conditions set forth in section 2 of this appendix.

3.6.1 Perform standby mode and off mode testing after completion of an active mode drying cycle included as part of the test cycle; after removing the test load; without changing the control panel settings used for the active mode drying cycle; with the door closed; and without disconnecting the electrical energy supply to the clothes dryer between completion of the active mode drying cycle and the start of standby mode and off mode testing.

3.6.2 For clothes dryers that take some time to automatically enter a stable inactive mode or off mode state from a higher power state as discussed in Section 5, Paragraph 5.1, Note 1 of IEC 62301, allow sufficient time for the clothes dryer to automatically reach the default inactive/off mode state before proceeding with the test measurement.

3.6.3 Once the stable inactive/off mode state has been reached, measure and record the default inactive/off mode power, $P_{default}$, in watts, following the test procedure for the sampling method specified in Section 5, Paragraph 5.3.2 of IEC 62301.

3.6.4 For a clothes dryer with a switch (or other means) that can be optionally selected by the end user to achieve a lower-power inactive/off mode state than the default inactive/off mode state measured in section 3.6.3 of this appendix, after performing the measurement in section 3.6.3 of this appendix, activate the switch (or other means) to the position resulting in the lowest power consumption and repeat the measurement procedure described in section 3.6.3 of this appendix. Measure and record the lowest inactive/off mode power, P_{lowest}, in watts.

4. Calculation of Derived Results From Test Measurements

4.1 *Total per-cycle electric dryer energy consumption.* Calculate the total electric dryer energy consumption per cycle, E_{ce}, expressed in kilowatt-hours per cycle and defined as:

$E_{ce} = [53.5/(IMC - FMC)] \times E_t \times$ field use,

Where:

E_t = the energy recorded in section 3.4.5 of this appendix.

53.5 = an experimentally established value for the percent reduction in the moisture content of the test load during a laboratory test cycle expressed as a percent.

field use = field use factor,

= 1.18 for clothes dryers with time termination control systems only without any automatic termination control functions.

= 1.04 for clothes dryers with automatic control systems that meet the requirements of the definition for automatic termination control in section 1.4 of this appendix, including those that also have a supplementary timer control, or that may also be manually controlled.

IMC = the moisture content of the wet test load as recorded in section 3.4.2 of this appendix.

FMC = the moisture content of the dry test load as recorded in section 3.4.3 of this appendix.

4.2 *Per-cycle gas dryer electrical energy consumption.* Calculate the gas dryer electrical energy consumption per cycle, E_{ge}, expressed in kilowatt-hours per cycle and defined as:

$E_{ge} = [53.5/(IMC - FMC)] \times E_{te} \times$ field use,

Where:

E_{te} = the energy recorded in section 3.4.6.1 of this appendix.

field use, 53.5, MC_w, and MC_d as defined in section 4.1 of this appendix.

4.3 *Per-cycle gas dryer gas energy consumption.* Calculate the gas dryer gas energy consumption per cycle, E_{gg}, expressed in Btus per cycle and defined as:

$E_{gg} = [53.5/(MC_w - MC_d)] \times E_{tg} \times$ field use $\times$ GEF

Where:

E_{tg} = the energy recorded in section 3.4.6.2 of this appendix.

GEF = corrected gas heat value (Btu per cubic feet) as defined in section 3.4.6.3 of this appendix.

field use, 53.5, IMC, and FMC as defined in section 4.1 of this appendix.

4.4 *Total per-cycle gas dryer energy consumption expressed in kilowatt-hours.* Calculate the total gas dryer energy consumption per cycle, E_{cg}, expressed in kilowatt-hours per cycle and defined as:

$E_{cg} = E_{ge} + (E_{gg}/3412$ Btu/kWh)

Where:

E_{ge} as defined in 4.2

E_{gg} as defined in 4.3

4.5 *Per-cycle standby mode and off mode energy consumption.* Calculate the clothes dryer per-cycle standby mode and off mode energy consumption, E_{TSO}, expressed in kilowatt-hours per cycle and defined as:

$E_{TSO} = [(P_{default} \times S_{default}) + (P_{lowest} \times S_{lowest})] \times K/283$

Where:

$P_{default}$ = Default inactive/off mode power, in watts, as measured in section 3.6.3 of this appendix.

P_{lowest} = Lowest inactive/off mode power, in watts, as measured in section 3.6.4 of this appendix for clothes dryer with a switch (or other means) that can be optionally selected by the end user to achieve a lower-power inactive/off mode than the default inactive/off mode; otherwise, P_{lowest}=0.

$S_{default}$ = Annual hours in default inactive/off mode, defined as 8,620 if no optional lowest-power inactive/off mode is available; otherwise 4,310.

S_{lowest} = Annual hours in lowest-power inactive/off mode, defined as 0 if no optional lowest-power inactive/off mode is available; otherwise 4,310.
K = Conversion factor of watt-hours to kilowatt-hours = 0.001.
283 = Representative average number of clothes dryer cycles in a year.
8,620 = Combined annual hours for inactive and off mode.
4,310 = One-half of the combined annual hours for inactive and off mode.

4.6 *Per-cycle combined total energy consumption expressed in kilowatt-hours.* Calculate the per-cycle combined total energy consumption, E_{CC}, expressed in kilowatt-hours per cycle and defined for an electric clothes dryer as:

$E_{CC} = E_{ce} + E_{TSO}$

Where:

E_{ce} = the energy recorded in section 4.1 of this appendix, and
E_{TSO} = the energy recorded in section 4.5 of this appendix, and defined for a gas clothes dryer as:

$E_{CC} = E_{cg} + E_{TSO}$

Where:

E_{cg} = the energy recorded in section 4.4 of this appendix, and
E_{TSO} = the energy recorded in section 4.5 of this appendix.

4.7 *Combined Energy Factor in pounds per kilowatt-hour.* Calculate the combined energy factor, CEF, expressed in pounds per kilowatt-hour and defined as:

$CEF = W_{bonedry}/E_{CC}$

Where:

$W_{bonedry}$ = the bone dry test load weight 3.4.1, and
E_{CC} = the energy recorded in 4.6

[76 FR 1032, Jan. 6, 2011, as amended at 78 FR 49645, Aug. 14, 2013; 86 FR 56639, Oct. 8, 2021; 89 FR 81305, Oct. 8, 2024]

APPENDIX D2 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CLOTHES DRYERS

NOTE: The procedures in either appendix D1 to this subpart or this appendix must be used to determine compliance with the energy conservation standards for clothes dryers provided at §430.32(h)(3).

Manufacturers must use a single appendix for all representations, including certifications of compliance, and may not use appendix D1 to this subpart for certain representations and this appendix for other representations. The procedures in this appendix must be used to determine compliance with the energy conservation standards for clothes dryers provided at §430.32(h)(4). Manufacturers may use this appendix to certify compliance with the clothes dryer standards provided at §430.32(h)(4) prior to the applicable compliance date for those standards.

Per-cycle standby mode and off mode energy consumption in section 4.5 of this appendix is calculated using the value for the annual representative average number of clothes dryer cycles in a year specified in section 4.5.1(a) of this appendix until March 1, 2028. Beginning on March 1, 2028, per-cycle standby mode and off mode energy consumption in section 4.5 of this appendix is calculated using the value for the annual representative average number of clothes dryer cycles in a year specified in section 4.5.1(b) of this appendix.

0. INCORPORATION BY REFERENCE

DOE incorporated by reference in §430.3 the entire standard for AHAM HLD–1 and IEC 62301, however, only enumerated provisions of those documents are applicable to this appendix. In cases where there is a conflict between any industry standard(s) and this appendix, the language of the test procedure in this appendix takes precedence over the industry standard(s).

(1) AHAM HLD–1:

(i) Section 3.3.5.1 ''Standard Simulator'' as referenced in sections 2.1.2 through 2.1.3 of this appendix.

(ii) [Reserved]

(2) IEC 62301:

(i) Section 5, Paragraph 5.1, Note 1 as referenced in section 3.5.2 of this appendix.

(ii) Section 5, Paragraph 5.3.2 ''Sampling Method'' as referenced in section 3.5.3 of this appendix.

1. DEFINITIONS

1.1 ''Active mode'' means a mode in which the clothes dryer is connected to a main power source, has been activated and is performing the main function of tumbling the clothing with or without heated or unheated forced air circulation to remove moisture from the clothing, remove wrinkles or prevent wrinkling of the clothing, or both.

1.2 ''AHAM'' means the Association of Home Appliance Manufacturers.

1.3 ''AHAM HLD–1'' means the test standard published by the Association of Home Appliance Manufacturers, titled ''Household Tumble Type Clothes Dryers,'' ANSI-approved June 11, 2010, ANSI/AHAM HLD–1–2010.

1.4 ''Automatic termination control'' means a dryer control system with a sensor which monitors either the dryer load temperature or its moisture content and with a controller which automatically terminates the drying process. A mark, detent, or other visual indicator or detent which indicates a preferred automatic termination control setting must be present if the dryer is to be

classified as having an ''automatic termination control.'' A mark is a visible single control setting on one or more dryer controls.

1.5 ''Automatic termination control dryer'' means a clothes dryer which can be preset to carry out at least one sequence of operations to be terminated by means of a system assessing, directly or indirectly, the moisture content of the load. An automatic termination control dryer with supplementary timer or that may also be manually controlled shall be tested as an automatic termination control dryer.

1.6 ''Bone dry'' means a condition of a load of test cloths which has been dried in a dryer at maximum temperature for a minimum of 10 minutes, removed, and weighed before cool down, and then dried again for 10-minute periods until the final weight change of the load is 1 percent or less.

1.7 ''Compact'' or ''compact size'' means a clothes dryer with a drum capacity of less than 4.4 cubic feet.

1.8 ''Cool down'' means that portion of the clothes drying cycle when the added gas or electric heat is terminated and the clothes continue to tumble and dry within the drum.

1.9 ''Cycle'' means a sequence of operation of a clothes dryer which performs a clothes drying operation, and may include variations or combinations of the functions of heating, tumbling, and drying.

1.10 ''Drum capacity'' means the volume of the drying drum in cubic feet.

1.11 ''Final moisture content'' (''FMC'') means the ratio of the weight of water contained by the dry test load (*i.e.*, after completion of the drying cycle) to the bone-dry weight of the test load, expressed as a percent.

1.12 ''IEC 62301'' (Second Edition) means the test standard published by the International Electrotechnical Commission (''IEC'') titled ''Household electrical appliances—Measurement of standby power,'' Publication 62301 (Edition 2.0 2011–01) (incorporated by reference; see § 430.3).

1.13 ''Initial moisture content'' (''IMC'') means the ratio of the weight of water contained by the damp test load (*i.e.*, prior to completion of the drying cycle) to the bone-dry weight of the test load, expressed as a percent.

1.14 ''Inactive mode'' means a standby mode that facilitates the activation of active mode by remote switch (including remote control), internal sensor, or timer, or that provides continuous status display.

1.15 ''Moisture content'' means the ratio of the weight of water contained by the test load to the bone-dry weight of the test load, expressed as a percent.

1.16 ''Off mode'' means a mode in which the clothes dryer is connected to a main power source and is not providing any active or standby mode function, and where the mode may persist for an indefinite time. An indicator that only shows the user that the product is in the off position is included within the classification of an off mode.

1.17 ''Standard size'' means a clothes dryer with a drum capacity of 4.4 cubic feet or greater.

1.18 ''Standby mode'' means any product modes where the energy using product is connected to a mains power source and offers one or more of the following user-oriented or protective functions which may persist for an indefinite time:

(a) To facilitate the activation of other modes (including activation or deactivation of active mode) by remote switch (including remote control), internal sensor, or timer.

(b) Continuous functions, including information or status displays (including clocks) or sensor-based functions. A timer is a continuous clock function (which may or may not be associated with a display) that provides regular scheduled tasks (*e.g.*, switching) and that operates on a continuous basis.

1.19 ''Timer dryer'' means a clothes dryer that can be preset to carry out at least one operation to be terminated by a timer, but may also be manually controlled, and does not include any automatic termination function.

1.20 ''Vented clothes dryer'' means a clothes dryer that exhausts the evaporated moisture from the cabinet.

1.21 ''Ventless clothes dryer'' means a clothes dryer that uses a closed-loop system with an internal condenser to remove the evaporated moisture from the heated air. The moist air is not discharged from the cabinet.

2. Testing Conditions

2.1 *Installation.*

2.1.1 *All clothes dryers.* For both vented clothes dryers and ventless clothes dryers, install the clothes dryer in accordance with manufacturer's instructions as shipped with the unit. If the manufacturer's instructions do not specify the installation requirements for a certain component, it shall be tested in the as-shipped condition. Where the manufacturer gives the option to use the dryer both with and without a duct, the dryer shall be tested without the exhaust simulator described in section 3.3.5.1 of AHAM HLD–1 (incorporated by reference; see § 430.3). All external joints should be taped to avoid air leakage. For drying testing, disconnect all lights, such as task lights, that do not provide any information related to the drying process on the clothes dryer and that do not consume more than 10 watts during the clothes dryer test cycle. Control setting indicator lights showing the cycle progression, temperature or dryness settings, or other cycle functions that cannot be turned off during the test cycle shall not be disconnected during the active mode test cycle.

For standby and off mode testing, the clothes dryer shall also be installed in accordance with section 5, paragraph 5.2 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3), disregarding the provisions regarding batteries and the determination, classification, and testing of relevant modes. For standby and off mode testing, all lighting systems shall remain connected.

2.1.2 *Vented clothes dryers.* For vented clothes dryers, the dryer exhaust shall be restricted by adding the AHAM exhaust simulator described in section 3.3.5.1 of AHAM HLD–1.

2.1.3 *Ventless clothes dryers.* For ventless clothes dryers, the dryer shall be tested without the AHAM exhaust simulator. If the manufacturer gives the option to use a ventless clothes dryer, with or without a condensation box, the dryer shall be tested with the condensation box installed. For ventless clothes dryers, the condenser unit of the dryer must remain in place and not be taken out of the dryer for any reason between tests.

2.2 *Ambient temperature and humidity.*

2.2.1 For drying testing, maintain the room ambient air temperature at 75 ±3 F and the room relative humidity at 50 percent ±10 percent relative humidity.

2.2.2 For standby and off mode testing, maintain room ambient air temperature conditions as specified in section 4, paragraph 4.2 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3).

2.3 *Energy supply.*

2.3.1 *Electrical supply.* Maintain the electrical supply at the clothes dryer terminal block within 1 percent of 120/240 or 120/208Y or 120 volts as applicable to the particular terminal block wiring system and within 1 percent of the nameplate frequency as specified by the manufacturer. If the dryer has a dual voltage conversion capability, conduct the test at the highest voltage specified by the manufacturer.

2.3.1.1 *Supply voltage waveform.* For the clothes dryer standby mode and off mode testing, maintain the electrical supply voltage waveform indicated in section 4, paragraph 4.3.2 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3). If the power measuring instrument used for testing is unable to measure and record the total harmonic content during the test measurement period, it is acceptable to measure and record the total harmonic content immediately before and after the test measurement period.

2.3.2 *Gas supply.*

2.3.2.1 *Natural gas supply.* Maintain the gas supply to the clothes dryer immediately ahead of all controls at a pressure of 7 to 10 inches of water column. The natural gas supplied should have a heating value of approximately 1,025 Btus per standard cubic foot. The actual heating value, H_n2, in Btus per standard cubic foot, for the natural gas to be used in the test shall be obtained either from measurements using a standard continuous flow calorimeter as described in section 2.4.6 of this appendix or by the purchase of bottled natural gas whose Btu rating is certified to be at least as accurate a rating as could be obtained from measurements with a standard continuous flow calorimeter as described in section 2.4.6 of this appendix.

2.3.2.2 *Propane gas supply.* Maintain the gas supply to the clothes dryer immediately ahead of all controls at a pressure of 11 to 13 inches of water column. The propane gas supplied should have a heating value of approximately 2,500 Btus per standard cubic foot. The actual heating value, H_p, in Btus per standard cubic foot, for the propane gas to be used in the test shall be obtained either from measurements using a standard continuous flow calorimeter as described in section 2.4.6 of this appendix or by the purchase of bottled gas whose Btu rating is certified to be at least as accurate a rating as could be obtained from measurement with a standard continuous calorimeter as described in section 2.4.6 of this appendix.

2.3.2.3 *Hourly Btu Rating.* Maintain the hourly Btu rating of the burner within ±5 percent of the rating specified by the manufacturer. If the hourly Btu rating of the burner cannot be maintained within ±5 percent of the rating specified by the manufacturer, make adjustments in the following order until an hourly Btu rating of the burner within ±5 percent of the rating specified by the manufacturer is achieved:

(1) Modify the gas inlet supply pressure within the allowable range specified in section 2.3.2.1 or 2.3.2.2 of this appendix, as applicable;

(2) If the clothes dryer is equipped with a gas pressure regulator, modify the outlet pressure of the gas pressure regulator within ±10 percent of the value recommended by the manufacturer in the installation manual, on the nameplate sticker, or wherever the manufacturer makes such a recommendation for the basic model; and

(3) Modify the orifice as necessary to achieve the required hourly Btu rating.

2.4 *Instrumentation.* Perform all test measurements using the following instruments as appropriate.

2.4.1 *Weighing scales.*

2.4.1.1 *Weighing scale for test cloth.* The scale shall have a range of 0 to a maximum of 60 pounds with a resolution of at least 0.001 pounds and a maximum error no greater than 0.1 percent of any measured value within the range of 3 to 15 pounds.

2.4.1.2 *Weighing scale for drum capacity measurements.* The scale should have a range of 0 to a maximum of 600 pounds with resolution of 0.50 pounds and a maximum error no greater than 0.5 percent of the measured value.

2.4.2 *Kilowatt-hour meter*. The kilowatt-hour meter shall have a resolution of 0.001 kilowatt-hours and a maximum error no greater than 0.5 percent of the measured value.

2.4.3 *Gas meter*. The gas meter shall have a resolution of 0.001 cubic feet and a maximum error no greater than 0.5 percent of the measured value.

2.4.4 *Dry and wet bulb psychrometer*. The dry and wet bulb psychrometer shall have an error no greater than ±1 °F. A relative humidity meter with a maximum error tolerance expressed in °F equivalent to the requirements for the dry and wet bulb psychrometer or with a maximum error tolerance of ±2 percent relative humidity would be acceptable for measuring the ambient humidity.

2.4.5 *Temperature*. The temperature sensor shall have an error no greater than ±1 °F.

2.4.6 *Standard Continuous Flow Calorimeter*. The calorimeter shall have an operating range of 750 to 3,500 Btu per cubic foot. The maximum error of the basic calorimeter shall be no greater than 0.2 percent of the actual heating value of the gas used in the test. The indicator readout shall have a maximum error no greater than 0.5 percent of the measured value within the operating range and a resolution of 0.2 percent of the full-scale reading of the indicator instrument.

2.4.7 *Standby mode and off mode watt meter*. The watt meter used to measure standby mode and off mode power consumption shall meet the requirements specified in section 4, paragraph 4.4 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3). If the power measuring instrument used for testing is unable to measure and record the crest factor, power factor, or maximum current ratio during the test measurement period, it is acceptable to measure the crest factor, power factor, and maximum current ratio immediately before and after the test measurement period.

2.5 *Lint trap*. Clean the lint trap thoroughly before each test run.

2.6 *Test Cloths*.

2.6.1 *Energy test cloth*. The energy test cloth shall be clean and consist of the following:

(a) Pure finished bleached cloth, made with a momie or granite weave, which is a blended fabric of 50-percent cotton and 50-percent polyester and weighs within + 10 percent of 5.75 ounces per square yard after test cloth preconditioning, and has 65 ends on the warp and 57 picks on the fill. The individual warp and fill yarns are a blend of 50-percent cotton and 50-percent polyester fibers.

(b) Cloth material that is 24 inches by 36 inches and has been hemmed to 22 inches by 34 inches before washing. The maximum shrinkage after five washes shall not be more than 4 percent on the length and width.

(c) The number of test runs on the same energy test cloth shall not exceed 25 runs.

2.6.2 *Energy stuffer cloths*. The energy stuffer cloths shall be made from energy test cloth material, and shall consist of pieces of material that are 12 inches by 12 inches and have been hemmed to 10 inches by 10 inches before washing. The maximum shrinkage after five washes shall not be more than 4 percent on the length and width. The number of test runs on the same energy stuffer cloth shall not exceed 25 runs after test cloth preconditioning.

2.6.3 *Test Cloth Preconditioning*.

A new test cloth load and energy stuffer cloths shall be treated as follows:

(1) Bone dry the load to a weight change of ±1 percent, or less, as prescribed in section 1.6 of this appendix.

(2) Place the test cloth load in a standard clothes washer set at the maximum water fill level. Wash the load for 10 minutes in soft water (17 parts per million hardness or less), using 60.8 grams of AHAM standard test detergent Formula 3. Wash water temperature should be maintained at 140 °F ±5 °F (60 °C ±2.7 °C). Rinse water temperature is to be controlled at 100 °F ±5 °F (37.7 °C ±2.7 °C).

(3) Rinse the load again at the same water temperature.

(4) Bone dry the load as prescribed in section 1.6 of this appendix and weigh the load.

(5) This procedure is repeated until there is a weight change of 1 percent or less.

(6) A final cycle is to be a hot water wash with no detergent, followed by two warm water rinses.

2.7 *Test loads*.

2.7.1 *Load size*. Determine the load size for the unit under test, according to Table 1 of this section.

TABLE 1—TEST LOADS

Unit under test	Test load (bone dry weight)
Standard size clothes dryer ...	8.45 pounds ± .085 pounds.
Compact size clothes dryer ...	3.00 pounds ± .03 pounds.

Each test load must consist of energy test cloths and no more than five energy stuffer cloths.

2.7.2 *Test load preparation*. Dampen the load by agitating it in water whose temperature is 60 °F ±5 °F and consists of 0 to 17 parts per million hardness for approximately 2 minutes to saturate the fabric. Then, extract water from the wet test load by spinning the load until the moisture content of the load is between 52.5 and 57.5 percent of the bone-dry weight of the test load. Make a final mass adjustment, such that the moisture content is 57.5 percent ±0.33 percent by adding water uniformly distributed among all of the test cloths in a very fine spray using a spray bottle.

2.7.3 *Method of loading*. Load the energy test cloths by grasping them in the center,

shaking them to hang loosely, and then dropping them in the dryer at random.

2.8 *Clothes dryer preconditioning.*

2.8.1 *Vented clothes dryers.* For vented clothes dryers, before any test cycle, operate the dryer without a test load in the non-heat mode for 15 minutes or until the discharge air temperature is varying less than 1 °F for 10 minutes—whichever is longer—in the test installation location with the ambient conditions within the specified test condition tolerances of section 2.2 of this appendix.

2.8.2 *Ventless clothes dryers.* For ventless clothes dryers, before any test cycle, the steady-state machine temperature must be equal to ambient room temperature described in 2.2.1. This may be done by leaving the machine at ambient room conditions for at least 12 hours between tests.

3. TEST PROCEDURES AND MEASUREMENTS

3.1 *Drum Capacity.* Measure the drum capacity by sealing all openings in the drum except the loading port with a plastic bag, and ensuring that all corners and depressions are filled and that there are no extrusions of the plastic bag through any openings in the interior of the drum. Support the dryer's rear drum surface on a platform scale to prevent deflection of the drum surface, and record the weight of the empty dryer. Fill the drum with water to a level determined by the intersection of the door plane and the loading port (*i.e.*, the uppermost edge of the drum that is in contact with the door seal). Record the temperature of the water and then the weight of the dryer with the added water and then determine the mass of the water in pounds. Add the appropriate volume to account for any space in the drum interior not measured by water fill (e.g., the space above the uppermost edge of the drum within a curved door) and subtract the appropriate volume to account for the space that is measured by water fill but cannot be used when the door is closed (e.g., space occupied by the door when closed). The drum capacity is calculated to the nearest 0.1 cubic foot as follows:

C= w/d ±volume adjustment

C = capacity in cubic feet.

w = mass of water in pounds.

d = density of water at the measured temperature in pounds per cubic foot.

3.2 *Dryer Loading.* Load the dryer as specified in 2.7.

3.3 *Test cycle.*

3.3.1 *Timer dryers.* For timer dryers, operate the clothes dryer at the maximum temperature setting and, if equipped with a timer, at the maximum time setting. Any other optional cycle settings that do not affect the temperature or time settings shall be tested in the as-shipped position, except that if the clothes dryer has network capabilities, the network settings must be disabled throughout testing if such settings can be disabled by the end-user and the product's user manual provides instructions on how to do so. If the network settings cannot be disabled by the end-user, or the product's user manual does not provide instruction for disabling network settings, then the unit must be tested with the network settings in the factory default configuration for the test cycle. If the clothes dryer does not have a separate temperature setting selection on the control panel, the maximum time setting should be used for the drying test cycle. Dry the load until the moisture content of the test load is between 1 and 2.5 percent of the bone-dry weight of the test load, at which point the test cycle is stopped, but do not permit the dryer to advance into cool down. If required, reset the timer to increase the length of the drying cycle. After stopping the test cycle, remove and weigh the test load within 5 minutes following termination of the test cycle. The clothes dryer shall not be stopped intermittently in the middle of the test cycle for any reason. Record the data specified by section 3.4 of this appendix. If the dryer automatically stops during a cycle because the condensation box is full of water, the test is stopped, and the test run is invalid, in which case the condensation box shall be emptied and the test re-run from the beginning. For ventless clothes dryers, during the time between two cycles, the door of the dryer shall be closed except for loading and unloading.

3.3.2 *Automatic termination control dryers.* For automatic termination control dryers, a ''normal'' program shall be selected for the test cycle. For dryers that do not have a ''normal'' program, the cycle recommended by the manufacturer for drying cotton or linen clothes shall be selected. Where the drying temperature setting can be chosen independently of the program, it shall be set to the maximum. Where the dryness level setting can be chosen independently of the program, it shall be set to the ''normal'' or ''medium'' dryness level setting. If such designation is not provided, then the dryness level shall be set at the mid-point between the minimum and maximum settings. If an even number of discrete settings are provided, use the next-highest setting above the midpoint, in the direction of the maximum dryness setting or next-lowest setting below the midpoint, in the direction of the minimum dryness setting. Any other optional cycle settings that do not affect the program, temperature or dryness settings shall be tested in the as-shipped position, except that if the clothes dryer has network capabilities, the network settings must be disabled throughout testing if such settings can be disabled by the end-user and the product's user manual provides instructions on how to do so. If the network settings cannot be disabled by the end-user, or the product's user

manual does not provide instruction for disabling network settings, then the unit must be tested with the network settings in the factory default configuration for the test cycle.

Operate the clothes dryer until the completion of the programmed cycle, including the cool down period. The cycle shall be considered complete when the dryer indicates to the user that the cycle has finished (by means of a display, indicator light, audible signal, or other signal) and the heater and drum/fan motor shuts off for the final time. If the clothes dryer is equipped with a wrinkle prevention mode (*i.e.,* that continuously or intermittently tumbles the clothes dryer drum after the clothes dryer indicates to the user that the cycle has finished) that is activated by default in the as-shipped position or if manufacturers' instructions specify that the feature is recommended to be activated for normal use, the cycle shall be considered complete after the end of the wrinkle prevention mode. After the completion of the test cycle, remove and weigh the test load within 5 minutes following termination of the test cycle. Record the data specified in section 3.4 of this appendix. If the final moisture content is greater than 2 percent, the results from the test are invalid and a second run must be conducted. Conduct the second run of the test on the unit using the highest dryness level setting. If, on this second run, the dryer does not achieve a final moisture content of 2 percent or lower, the dryer has not sufficiently dried the clothes and the test results may not be used for certification of compliance with energy conservation standards. If the dryer automatically stops during a cycle because the condensation box is full of water, the test is stopped, and the test run is invalid, in which case the condensation box shall be emptied and the test re-run from the beginning. For ventless clothes dryers, during the time between two cycles, the door of the dryer shall be closed except for loading and unloading.

3.4 *Data recording.* Record for each test cycle:

3.4.1 Bone-dry weight of the test load, $W_{bonedry}$, as described in section 2.7.1 of this appendix.

3.4.2 Moisture content of the wet test load before the test, IMC, as described in section 2.7.2 of this appendix.

3.4.3 Moisture content of the dry test load obtained after the test, FMC, as described in section 3.3 of this appendix.

3.4.4 Test room conditions, temperature, and percent relative humidity described in 2.2.1.

3.4.5 For electric dryers—the total kilowatt-hours of electric energy, E_t, consumed during the test described in 3.3.

3.4.6 For gas dryers:

3.4.6.1 Total kilowatt-hours of electrical energy, E_{te}, consumed during the test described in 3.3.

3.4.6.2 Cubic feet of gas per cycle, E_{tg}, consumed during the test described in 3.3.

3.4.6.3 Correct the gas heating value, GEF, as measured in 2.3.2.1 and 2.3.2.2, to standard pressure and temperature conditions in accordance with U.S. Bureau of Standards, circular C417, 1938.

3.4.7 The cycle settings selected, in accordance with section 3.3.2 of this appendix, for the automatic termination control dryer test.

3.5 *Standby mode and off mode power.* Connect the clothes dryer to a watt meter as specified in section 2.4.7 of this appendix. Establish the testing conditions set forth in section 2 of this appendix.

3.5.1 Perform standby mode and off mode testing after completion of an active mode drying cycle included as part of the test cycle; after removing the test load; without changing the control panel settings used for the active mode drying cycle; with the door closed; and without disconnecting the electrical energy supply to the clothes dryer between completion of the active mode drying cycle and the start of standby mode and off mode testing.

3.5.2 For clothes dryers that take some time to automatically enter a stable inactive mode or off mode state from a higher power state as discussed in Section 5, Paragraph 5.1, Note 1 of IEC 62301, allow sufficient time for the clothes dryer to automatically reach the default inactive/off mode state before proceeding with the test measurement.

3.5.3 Once the stable inactive/off mode state has been reached, measure and record the default inactive/off mode power, $P_{default}$, in watts, following the test procedure for the sampling method specified in Section 5, Paragraph 5.3.2 of IEC 62301.

3.5.4 For a clothes dryer with a switch (or other means) that can be optionally selected by the end user to achieve a lower-power inactive/off mode state than the default inactive/off mode state measured in section 3.5.3 of this appendix, after performing the measurement in section 3.5.3 of this appendix, activate the switch (or other means) to the position resulting in the lowest power consumption and repeat the measurement procedure described in section 3.5.3 of this appendix. Measure and record the lowest inactive/off mode power, P_{lowest}, in watts.

4. Calculation of Derived Results From Test Measurements

4.1 *Total per-cycle electric dryer energy consumption.* Calculate the total per-cycle electric dryer energy consumption required to achieve a final moisture content of 2 percent or less, $E_{ce,}$ expressed in kilowatt-hours per cycle and defined as:

$E_{ce} = E_t$,
for automatic termination control dryers, and,
$E_{ce} = [55.5/(IMC - FMC)] \times E_t \times$ field use,
for timer dryers

Where:

55.5 = an experimentally established value for the percent reduction in the moisture content of the test load during a laboratory test cycle expressed as a percent.
E_t = the energy recorded in section 3.4.5 of this appendix.
field use = 1.18, the field use factor for clothes dryers with time termination control systems only without any automatic termination control functions.
IMC = the moisture content of the wet test load as recorded in section 3.4.2 of this appendix.
FMC = the moisture content of the dry test load as recorded in section 3.4.3 of this appendix.

4.2 *Per-cycle gas dryer electrical energy consumption*. Calculate the per-cycle gas dryer electrical energy consumption required to achieve a final moisture content of 2 percent or less, $E_{ge,}$ expressed in kilowatt-hours per cycle and defined as:

$E_{ge} = E_{te}$,
for automatic termination control dryers, and,
$E_{ge} = [55.5/(IMC - FMC)] \times E_{te} \times$ field use,
for timer dryers

Where:

E_{te} = the energy recorded in section 3.4.6.1 of this appendix.
field use, 55.5, IMC, and FMC as defined in section 4.1 of this appendix.

4.3 *Per-cycle gas dryer gas energy consumption*. Calculate the per-cycle gas dryer gas energy consumption required to achieve a final moisture content of 2 percent or less, E_{gg}, expressed in Btus per cycle and defined as:

$E_{gg} = E_{tg} \times GEF$
for automatic termination control dryers, and,
$E_{gg} = [55.5/(IMC - FMC)] \times E_{tg} \times$ field use $\times$ GEF
for timer dryers

Where:

E_{tg} = the energy recorded in section 3.4.6.2 of this appendix.
GEF = corrected gas heat value (Btu per cubic foot) as defined in section 3.4.6.3 of this appendix,
field use, 55.5, IMC, and FMC as defined in section 4.1 of this appendix.

4.4 *Total per-cycle gas dryer energy consumption expressed in kilowatt-hours*. Calculate the total per-cycle gas dryer energy consumption required to achieve a final moisture content of 2 percent or less, E_{cg}, expressed in kilowatt-hours per cycle and defined as:

$E_{cg} = E_{ge} + (E_{gg}/3412$ Btu/kWh)

Where:

E_{ge} = the energy calculated in section 4.2 of this appendix
E_{gg} = the energy calculated in section 4.3 of this appendix

4.5 *Per-cycle standby mode and off mode energy consumption*. Calculate the clothes dryer per-cycle standby mode and off mode energy consumption, E_{TSO}, expressed in kilowatt-hours per cycle and defined as:

$E_{TSO} = [(P_{default} \times S_{default}) + (P_{lowest} \times S_{lowest})] \times K/C_{annual}$

Where:

$P_{default}$ = Default inactive/off mode power, in watts, as measured in section 3.5.3 of this appendix.
P_{lowest} = Lowest inactive/off mode power, in watts, as measured in section 3.5.4 of this appendix for clothes dryer with a switch (or other means) that can be optionally selected by the end user to achieve a lower-power inactive/off mode than the default inactive/off mode; otherwise, P_{lowest} =0.
$S_{default}$ = Annual hours in default inactive/off mode, defined as 8,620 if no optional lowest-power inactive/off mode is available; otherwise 4,310.
S_{lowest} = Annual hours in lowest-power inactive/off mode, defined as 0 if no optional lowest-power inactive/off mode is available; otherwise 4,310.
K = Conversion factor of watt-hours to kilowatt-hours = 0.001.
C_{annual} = Representative average number of clothes dryer cycles in a year as specified in section 4.5.1.
8,620 = Combined annual hours for inactive and off mode.
4,310 = One-half of the combined annual hours for inactive and off mode.

4.5.1 *Representative average number of clothes dryer cycles in a year*. Per the Introductory Note:

(1) $C_{annual} = 283$
(2) $C_{annual} = 236$

4.6 *Per-cycle combined total energy consumption expressed in kilowatt-hours*. Calculate the per-cycle combined total energy consumption, E_{CC}, expressed in kilowatt-hours per cycle and defined for an electric clothes dryer as:

$E_{CC} = E_{ce} + E_{TSO}$

Where:

E_{ce} = the energy calculated in section 4.1 of this appendix, and
E_{TSO} = the energy calculated in section 4.5 of this appendix, and defined for a gas clothes dryer as:

$E_{CC} = E_{cg} + E_{TSO}$

Where:

E_{cg} = the energy calculated in section 4.4 of this appendix, and

E_{TSO} = the energy calculated in section 4.5 of this appendix.

4.7 *Combined Energy Factor in pounds per kilowatt-hour*. Calculate the combined energy factor, CEF, expressed in pounds per kilowatt-hour and defined as:

$CEF = W_{bonedry}/E_{CC}$

Where:

$W_{bonedry}$ = the bone dry test load weight recorded in section 3.4.1 of this appendix, and

E_{CC} = the energy calculated in section 4.6 of this appendix.

[78 FR 49647, Aug. 14, 2013, as amended at 86 FR 56641, Oct. 8, 2021; 89 FR 81305, Oct. 8, 2024]

APPENDIX E TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF WATER HEATERS

NOTE: Prior to December 18, 2023, representations with respect to the energy use or efficiency of consumer water heaters covered by this test method, including compliance certifications, must be based on testing conducted in accordance with either this appendix as it now appears or appendix E as it appeared at 10 CFR part 430, subpart B revised as of January 1, 2021. Prior to June 15, 2024, representations with respect to the energy use or efficiency of residential-duty commercial water heaters covered by this test method, including compliance certifications, must be based on testing conducted in accordance with either this appendix as it now appears or appendix E as it appeared at 10 CFR part 430, subpart B revised as of January 1, 2021.

On and after December 18, 2023, representations with respect to energy use or efficiency of consumer water heaters covered by this test method, including compliance certifications, must be based on testing conducted in accordance with this appendix, except as described in the paragraphs that follow. On and after June 15, 2024, representations with respect to energy use or efficiency of residential-duty commercial water heaters covered by this test method, including compliance certifications, must be based on testing conducted in accordance with this appendix, except as follows.

Prior to May 6, 2029, consumer water heaters subject to section 4.10 of this appendix may optionally apply the requirements of section 4.10 of this appendix. For residential-duty commercial water heaters subject to section 4.10 of this appendix the requirements of section 4.10 of this appendix may optionally be applied prior to the compliance date of any final rule reviewing potential amended energy conservation standards for this equipment published after June 21, 2023.

Prior to May 6, 2029, consumer water heaters subject to section 5.1.2 of this appendix (as specified at §429.17(a)(1)(ii)(E) of this chapter) may optionally apply the requirements of section 5.1.2 of this appendix in lieu of the requirements in section 5.1.1 of this appendix.

On or after May 6, 2029, representations with respect to energy use or efficiency of consumer water heaters subject to sections 4.10 and 5.1.2 of this appendix must be based on testing conducted in accordance with those provisions.

0. Incorporation by Reference.

DOE incorporated by reference in §430.3 the entire standard for: ASHRAE 41.1–2020; ASHRAE 41.6–2014; ASHRAE 118.2–2022; ASTM D2156–09 (R2018); and ASTM E97–1987. However, only enumerated provisions of ASHRAE 118.2–2022 are applicable to this appendix, as follows:

0.1 ASHRAE 118.2–2022

(a) Annex B—Gas Heating Value Correction Factor;

(b) [Reserved]

0.2 [Reserved]

1. Definitions.

1.1. *Cut-in* means the time when or water temperature at which a water heater control or thermostat acts to increase the energy or fuel input to the heating elements, compressor, or burner.

1.2. *Cut-out* means the time when or water temperature at which a water heater control or thermostat acts to reduce to a minimum the energy or fuel input to the heating elements, compressor, or burner.

1.3. *Design Power Rating* means the power rating or input rate that a water heater manufacturer assigns to a particular design of water heater and that is included on the nameplate of the water heater, expressed in kilowatts or Btu (kJ) per hour as appropriate. For modulating water heaters, the design power rating is the maximum power rating or input rate that is specified by the manufacturer on the nameplate of the water heater.

1.4. *Draw Cluster* means a collection of water draws initiated during the 24-hour simulated-use test during which no successive draws are separated by more than 2 hours.

1.5. *First-Hour Rating* means an estimate of the maximum volume of ''hot'' water that a non-flow activated water heater can supply within an hour that begins with the water heater fully heated (*i.e.*, with all thermostats satisfied).

1.6. *Flow-Activated* describes an operational scheme in which a water heater initiates and terminates heating based on sensing flow.

1.7. *Heat Trap* means a device that can be integrally connected or independently attached to the hot and/or cold water pipe connections of a water heater such that the device will develop a thermal or mechanical seal to minimize the recirculation of water due to thermal convection between the water heater tank and its connecting pipes.

1.8. *Maximum GPM (L/min) Rating* means the maximum gallons per minute (liters per minute) of hot water that can be supplied by a flow-activated water heater when tested in accordance with section 5.3.2 of this appendix.

1.9. *Modulating Water Heater* means a water heater that can automatically vary its power or input rate from the minimum to the maximum power or input rate specified on the nameplate of the water heater by the manufacturer.

1.10. *Rated Storage Volume* means the water storage capacity of a water heater, in gallons (liters), as certified by the manufacturer pursuant to 10 CFR part 429.

1.11. *Recovery Efficiency* means the ratio of energy delivered to the water to the energy content of the fuel consumed by the water heater.

1.12. *Recovery Period* means the time when the main burner of a water heater with a rated storage volume greater than or equal to 2 gallons is raising the temperature of the stored water.

1.13. *Split-system heat pump water heater* means a heat pump-type water heater in which at least the compressor, which may be installed outdoors, is separate from the storage tank.

1.14. *Standby* means the time, in hours, during which water is not being withdrawn from the water heater.

1.15. *Symbol Usage.* The following identity relationships are provided to help clarify the symbology used throughout this procedure:

C_p—specific heat of water

E_{annual}—annual energy consumption of a water heater

$E_{annual,e}$—annual electrical energy consumption of a water heater

$E_{annual,f}$—annual fossil-fuel energy consumption of a water heater

E_X—energy efficiency of a heat pump-type water heater when the 24-hour simulated use test is optionally conducted at any of the additional air temperature conditions as specified in section 2.8 of this appendix, where the subscript ''X'' corresponds to the dry-bulb temperature at which the test is conducted.

F_{hr}—first-hour rating of a non-flow activated water heater

F_{max}—maximum GPM (L/min) rating of a flow-activated water heater

i—a subscript to indicate the draw number during a test

k_V—storage tank volume scaling ratio for water heaters with a rated storage volume greater than or equal to 2 gallons

$M_{del,i}$—mass of water removed during the ith draw of the 24-hour simulated-use test

$M_{in,i}$—mass of water entering the water heater during the ith draw of the 24-hour simulated-use test

$M^*_{del,i}$—for non-flow activated water heaters, mass of water removed during the ith draw during the first-hour rating test

$M^*_{in,i}$—for non-flow activated water heaters, mass of water entering the water heater during the ith draw during the first-hour rating test

$M_{del,10m}$—for flow-activated water heaters, mass of water removed continuously during the maximum GPM (L/min) rating test

$M_{in,10m}$—for flow-activated water heaters, mass of water entering the water heater continuously during the maximum GPM (L/min) rating test

n—for non-flow activated water heaters, total number of draws during the first-hour rating test

N—total number of draws during the 24-hour simulated-use test

N_r—number of draws from the start of the 24-hour simulated-use test to the end to the first recovery period as described in section 5.4.2 of this appendix

Q—total fossil fuel and/or electric energy consumed during the entire 24-hour simulated-use test

Q_d—daily water heating energy consumption adjusted for net change in internal energy

Q_{da}—Q_d with adjustment for variation of tank to ambient air temperature difference from nominal value

Q_{dm}—overall adjusted daily water heating energy consumption including Q_{da} and Q_{HWD}

Q_e—total electrical energy used during the 24-hour simulated-use test

Q_f—total fossil fuel energy used by the water heater during the 24-hour simulated-use test

Q_{hr}—hourly standby losses of a water heater with a rated storage volume greater than or equal to 2 gallons

Q_{HW}—daily energy consumption to heat water at the measured average temperature rise across the water heater

$Q_{HW,67\ °F}$—daily energy consumption to heat quantity of water removed during test over a temperature rise of 67 °F (37.3 °C)

Q_{HWD}—adjustment to daily energy consumption, Q_{HW}, due to variation of the temperature rise across the water heater not equal to the nominal value of 67 °F (37.3 °C)

Q_r—energy consumption of water heater from the beginning of the test to the end of the first recovery period

Q_{stby}—total energy consumed during the standby time interval $\tau_{stby,1}$, as determined in section 5.4.2 of this appendix

$Q_{su,0}$—cumulative energy consumption, including all fossil fuel and electrical energy

use, of the water heater from the start of the 24-hour simulated-use test to the start of the standby period as determined in section 5.4.2 of this appendix

$Q_{su,f}$—cumulative energy consumption, including all fossil fuel and electrical energy use, of the water heater from the start of the 24-hour simulated-use test to the end of the standby period as determined in section 5.4.2 of this appendix

$\overline{T}_0$—mean tank temperature at the beginning of the 24-hour simulated-use test as determined in section 5.4.2 of this appendix

$\overline{T}_{24}$—mean tank temperature at the end of the 24-hour simulated-use test as determined in section 5.4.2 of this appendix

$\overline{T}_{a,stby}$—average ambient air temperature during all standby periods of the 24-hour simulated-use test as determined in section 5.4.2 of this appendix

$\overline{T}_{a,stby,1}$—overall average ambient temperature between the start and end of the standby period as determined in section 5.4.2 of this appendix

$\overline{T}_{t,stby,1}$— overall average mean tank temperature between the start and end of the standby period as determined in section 5.4.2 of this appendix

$\overline{T}_{del}$—for flow-activated water heaters, average outlet water temperature during the maximum GPM (L/min) rating test

$\overline{T}_{del,i}$—average outlet water temperature during the *i*th draw of the 24-hour simulated-use test

$\overline{T}_{in}$—for flow-activated water heaters, average inlet water temperature during the maximum GPM (L/min) rating test

$\overline{T}_{st}$—for water heaters which cannot have internal tank temperature directly measured, estimated average internal storage tank temperature

T_p—for water heaters which cannot have internal tank temperature directly measured, average of the inlet and the outlet water temperatures at the end of the period defined by τ_p

$\overline{T}_{in,p}$—for water heaters which cannot have internal tank temperature directly measured, average of the inlet water temperatures

$\overline{T}_{out,p}$—for water heaters which cannot have internal tank temperature directly measured, average of the outlet water temperatures

$\overline{T}_{in,i}$—average inlet water temperature during the *i*th draw of the 24-hour simulated-use test

$\overline{T}_{max,1}$—maximum measured mean tank temperature after the first recovery period of the 24-hour simulated-use test as determined in section 5.4.2 of this appendix

$\overline{T}_{su,0}$—maximum measured mean tank temperature at the beginning of the standby period as determined in section 5.4.2 of this appendix

$\overline{T}_{su,f}$—measured mean tank temperature at the end of the standby period as determined in section 5.4.2 of this appendix

$\overline{T}^*_{del,i}$—for non-flow activated water heaters, average outlet water temperature during the *i*th draw (i = 1 to n) of the first-hour rating test

$\overline{T}^*_{max,i}$—for non-flow activated water heaters, maximum outlet water temperature observed during the *i*th draw (i = 1 to n) of the first-hour rating test

$\overline{T}^*_{min,i}$—for non-flow activated water heaters, minimum outlet water temperature to terminate the *i*th draw (i = 1 to n) of the first-hour rating test

UA—standby loss coefficient of a water heater with a rated storage volume greater than or equal to 2 gallons

UEF—uniform energy factor of a water heater

V—the volume of hot water drawn during the applicable draw pattern

$V_{del,i}$—volume of water removed during the *i*th draw (i = 1 to N) of the 24-hour simulated-use test

$V_{in,i}$—volume of water entering the water heater during the *i*th draw (i = 1 to N) of the 24-hour simulated-use test

$V^*_{del,i}$—for non-flow activated water heaters, volume of water removed during the *i*th draw (i = 1 to n) of the first-hour rating test

$V^*_{in,i}$—for non-flow activated water heaters, volume of water entering the water heater during the *i*th draw (i = 1 to n) of the first-hour rating test

$V_{del,10m}$—for flow-activated water heaters, volume of water removed during the maximum GPM (L/min) rating test

$V_{in,10m}$—for flow-activated water heaters, volume of water entering the water heater during the maximum GPM (L/min) rating test

V_{st}—measured storage volume of the storage tank for water heaters with a rated storage volume greater than or equal to 2 gallons

V_{eff}—effective storage volume

$v_{out,p}$—for water heaters which cannot have internal tank temperature directly measured, average flow rate

W_f—weight of storage tank when completely filled with water for water heaters with a rated storage volume greater than or equal to 2 gallons

W_t—tare weight of storage tank when completely empty of water for water heaters with a rated storage volume greater than or equal to 2 gallons

η_r—recovery efficiency

ρ—density of water

τ_p—for water heaters which cannot have internal tank temperature directly measured, duration of the temperature measurement period, determined by the length of time taken for the outlet water temperature to be within 2 °F of the inlet

water temperature for 15 consecutive seconds (including the 15-second stabilization period)

$\tau_{stby,1}$—elapsed time between the start and end of the standby period as determined in section 5.4.2 of this appendix

$\tau_{stby,2}$—overall time of standby periods when no water is withdrawn during the 24-hour simulated-use test as determined in section 5.4.2 of this appendix

1.16. *Temperature Controller* means a device that is available to the user to adjust the temperature of the water inside a water heater that stores heated water or the outlet water temperature.

1.17. *Thermal break* means a thermally nonconductive material that can withstand a pressure of 150 psi (1.034 MPa) at a temperature greater than the maximum temperature the water heater is designed to produce and is utilized to insulate a bypass loop, if one is used in the test set-up, from the inlet piping.

1.18. *Uniform Energy Factor* means the measure of water heater overall efficiency.

1.19. *Water Heater Requiring a Storage Tank* means a water heater without a storage tank specified or supplied by the manufacturer that cannot meet the requirements of sections 2 and 5 of this appendix without the use of a storage water heater or unfired hot water storage tank.

2. Test Conditions.

2.1 *Installation Requirements.* Tests shall be performed with the water heater and instrumentation installed in accordance with section 4 of this appendix.

2.2 *Ambient Air Temperature and Relative Humidity.*

2.2.1 *Non-Heat Pump Water Heaters.* The ambient air temperature shall be maintained between 65.0 °F and 70.0 °F (18.3 °C and 21.1 °C) on a continuous basis.

2.2.2 *Heat Pump Water Heaters.* The dry-bulb temperature shall be maintained at an average of 67.5 °F ± 1 °F (19.7 °C ± 0.6 °C) after a cut-in and before the next cut-out, an average of 67.5 °F ± 2.5 °F (19.7 °C ± 1.4 °C) after a cut-out and before the next cut-in, and at 67.5 °F ± 5 °F (19.7 °C ± 2.8 °C) on a continuous basis throughout the test. The relative humidity shall be maintained within a range of 50% ± 5% throughout the test, and at an average of 50% ± 2% after a cut-in and before the next cut-out.

When testing a split-system heat pump water heater or heat pump water heater requiring a separate storage tank, the heat pump portion of the system shall be tested at the conditions within this section and the separate water heater or unfired hot water storage tank shall be tested at either the conditions within this section or the conditions specified in section 2.2.1 of this appendix.

2.3 *Supply Water Temperature.* The temperature of the water being supplied to the water heater shall be maintained at 58 °F ± 2 °F (14.4 °C ± 1.1 °C) throughout the test.

2.4 *Outlet Water Temperature.* The temperature controllers of a non-flow activated water heater shall be set so that water is delivered at a temperature of 125 °F ± 5 °F (51.7 °C ± 2.8 °C).

2.5 *Set Point Temperature.* The temperature controller of a flow-activated water heater shall be set to deliver water at a temperature of 125 °F ± 5 °F (51.7 °C ± 2.8 °C). If the flow-activated water heater is not capable of delivering water at a temperature of 125 °F ± 5 °F (51.7 °C ± 2.8 °C) when supplied with water at the supply water temperature specified in section 2.3 of this appendix, then the flow-activated water heater shall be set to deliver water at its maximum water temperature.

2.6 *Supply Water Pressure.* During the test when water is not being withdrawn, the supply pressure shall be maintained between 40 psig (275 kPa) and the maximum allowable pressure specified by the water heater manufacturer.

2.7 *Electrical and/or Fossil Fuel Supply.*

2.7.1 *Electrical.* Maintain the electrical supply voltage to within ±2% of the center of the voltage range specified on the nameplate of the water heater by the water heater and/or heat pump manufacturer, from 5 seconds after a cut-in to 5 seconds before next cut-out.

2.7.2 *Natural Gas.* Maintain the supply pressure in accordance with the supply pressure specified on the nameplate of the water heater by the manufacturer. If the supply pressure is not specified, maintain a supply pressure of 7–10 inches of water column (1.7–2.5 kPa). If the water heater is equipped with a gas appliance pressure regulator and the gas appliance pressure regulator can be adjusted, the regulator outlet pressure shall be within the greater of ±10% of the manufacturer's specified manifold pressure, found on the nameplate of the water heater, or ±0.2 inches water column (0.05 kPa). Maintain the gas supply pressure and manifold pressure only when operating at the design power rating. For all tests, use natural gas having a heating value of approximately 1,025 Btu per standard cubic foot (38,190 kJ per standard cubic meter).

2.7.3 *Propane Gas.* Maintain the supply pressure in accordance with the supply pressure specified on the nameplate of the water heater by the manufacturer. If the supply pressure is not specified, maintain a supply pressure of 11–13 inches of water column (2.7–3.2 kPa). If the water heater is equipped with a gas appliance pressure regulator and the gas appliance pressure regulator can be adjusted, the regulator outlet pressure shall be within the greater of ±10% of the manufacturer's specified manifold pressure, found on

the nameplate of the water heater, or ±0.2 inches water column (0.05 kPa). Maintain the gas supply pressure and manifold pressure only when operating at the design power rating. For all tests, use propane gas with a heating value of approximately 2,500 Btu per standard cubic foot (93,147 kJ per standard cubic meter).

2.7.4 *Fuel Oil Supply*. Maintain an uninterrupted supply of fuel oil. The fuel pump pressure shall be within ±10% of the pump pressure specified on the nameplate of the water heater or the installation and operations (I&O) manual by the manufacturer. Use fuel oil having a heating value of approximately 138,700 Btu per gallon (38,660 kJ per liter).

2.8 *Optional Test Conditions (Heat Pump-Type Water Heaters)*. The following test conditions may be used for optional representations of E_X for heat pump-type water heaters. When conducting a 24-hour simulated use test to determine E_X, the test conditions in section 2.1 and sections 2.4 through 2.7 apply. The ambient air temperature and humidity conditions in section 2.2 and the supply water temperature in section 2.3 are replaced with the air temperature, humidity, and supply water temperature conditions as shown in the following table. Testing may optionally be performed at any or all of the conditions in the table, and the sampling plan found at 10 CFR 429.17(a) may be applied for voluntary representations.

Heat pump type	Metric	Outdoor air conditions		Indoor air conditions		Supply water temperature (°F)
		Dry-bulb temperature (°F)	Relative humidity (%)	Dry-bulb temperature (°F)	Relative humidity (%)	
Split-System or Circulating ..	E_5	5.0	30	67.5	50	42.0
	E_{34}	34.0	72	.....	.....	47.0
	E_{95}	95.0	25	.....	.....	67.0
Integrated, Split-System, or Circulating.	E_{50}	N/A	N/A	50.0	58	50.0
	E_{95}	N/A	N/A	95.0	40	67.0

3. Instrumentation.

3.1 *Pressure Measurements*. Pressure-measuring instruments shall have an error no greater than the following values:

Item measured	Instrument accuracy	Instrument precision
Gas pressure	±0.1 inch of water column (±0.025 kPa)	±0.05 inch of water column (±0.012 kPa).
Atmospheric pressure	±0.1 inch of mercury column (±0.34 kPa)	±0.05 inch of mercury column (±0.17 kPa).
Water pressure	±1.0 pounds per square inch (±6.9 kPa)	±0.50 pounds per square inch (±3.45 kPa).

3.2 *Temperature Measurement*

3.2.1 *Measurement*. Temperature measurements shall be made in accordance with the Standard Method for Temperature Measurement, ASHRAE 41.1–2020, including the conditions as specified in ASHRAE 41.6–2014 as referenced in ASHRAE 41.1–2020, and excluding the steady-state temperature criteria in section 5.5 of ASHRAE 41.1–2020.

3.2.2 *Accuracy and Precision*. The accuracy and precision of the instruments, including their associated readout devices, shall be within the following limits:

Item measured	Instrument accuracy	Instrument precision
Air dry-bulb temperature	±0.2 °F (±0.1 °C)	±0.1 °F (±0.06 °C).
Air wet-bulb temperature	±0.2 °F (±0.1 °C)	±0.1 °F (±0.06 °C).
Inlet and outlet water temperatures	±0.2 °F (±0.1 °C)	±0.1 °F (±0.06 °C).
Storage tank temperatures	±0.5 °F (±0.3 °C)	±0.25 °F (±0.14 °C).

3.2.3 *Scale Division*. In no case shall the smallest scale division of the instrument or instrument system exceed 2 times the specified precision.

3.2.4 *Temperature Difference*. Temperature difference between the entering and leaving water may be measured with any of the following:

(a) A thermopile
(b) Calibrated resistance thermometers
(c) Precision thermometers
(d) Calibrated thermistors
(e) Calibrated thermocouples

(f) Quartz thermometers

3.2.5 *Thermopile Construction*. If a thermopile is used, it shall be made from calibrated thermocouple wire taken from a single spool. Extension wires to the recording device shall also be made from that same spool.

3.2.6 *Time Constant*. The time constant of the instruments used to measure the inlet and outlet water temperatures shall be no greater than 2 seconds.

3.3 *Liquid Flow Rate Measurement*. The accuracy of the liquid flow rate measurement, using the calibration if furnished, shall be equal to or less than ±1% of the measured value in mass units per unit time.

3.4 *Electrical Energy*. The electrical energy used shall be measured with an instrument and associated readout device that is accurate within ±0.5% of the reading.

3.5 *Fossil Fuels*. The quantity of fuel used by the water heater shall be measured with an instrument and associated readout device that is accurate within ±1% of the reading.

3.6 *Mass Measurements*. For mass measurements greater than or equal to 10 pounds (4.5 kg), a scale that is accurate within ±0.5% of the reading shall be used to make the measurement. For mass measurements less than 10 pounds (4.5 kg), the scale shall provide a measurement that is accurate within ±0.1 pound (0.045 kg).

3.7 *Heating Value*. The higher heating value of the natural gas, propane, or fuel oil shall be measured with an instrument and associated readout device that is accurate within ±1% of the reading. The heating values of natural gas and propane must be corrected from those measured to the standard temperature of 60.0 °F (15.6 °C) and standard pressure of 30 inches of mercury column (101.6 kPa) using the method described in Annex B of ASHRAE 118.2–2022.

3.8 *Time*. The elapsed time measurements shall be measured with an instrument that is accurate within ±0.5 seconds per hour.

3.9 *Volume*. Volume measurements shall be measured with an accuracy of ±2% of the total volume.

3.10 *Relative Humidity*. If a relative humidity (RH) transducer is used to measure the relative humidity of the surrounding air while testing heat pump water heaters, the relative humidity shall be measured with an accuracy of ±1.5% RH.

4. Installation.

4.1 *Water Heater Mounting*. A water heater designed to be freestanding shall be placed on a ¾ inch (2 cm) thick plywood platform supported by three 2x4 inch (5 cm x 10 cm) runners. If the water heater is not approved for installation on combustible flooring, suitable non-combustible material shall be placed between the water heater and the platform. Water heaters designed to be installed into a kitchen countertop space shall be placed against a simulated wall section. Wall-mounted water heaters shall be supported on a simulated wall in accordance with the manufacturer-published installation instructions. When a simulated wall is used, the construction shall be 2x4 inch (5 cm x 10 cm) studs, faced with ¾ inch (2 cm) plywood. For heat pump water heaters not delivered as a single package, the units shall be connected in accordance with the manufacturer-published installation instructions, and the overall system shall be placed on the above-described plywood platform. If installation instructions are not provided by the heat pump manufacturer, uninsulated 8 foot (2.4 m) long connecting hoses having an inside diameter of ⅝ inch (1.6 cm) shall be used to connect the storage tank and the heat pump water heater. With the exception of using the storage tank described in section 4.10 of this appendix, the same requirements shall apply for water heaters requiring a storage tank. The testing of the water heater shall occur in an area that is protected from drafts of more than 50 ft/min (0.25 m/s) from room ventilation registers, windows, or other external sources of air movement.

4.2 *Water Supply*. Connect the water heater to a water supply capable of delivering water at conditions as specified in sections 2.3 and 2.6 of this appendix.

4.3 *Water Inlet and Outlet Configuration*. For freestanding water heaters that are taller than 36 inches (91.4 cm), inlet and outlet piping connections shall be configured in a manner consistent with Figures 1 and 2 of section 7 of this appendix. Inlet and outlet piping connections for wall-mounted water heaters shall be consistent with Figure 3 of section 7 of this appendix. For freestanding water heaters that are 36 inches or less in height and not supplied as part of a counter-top enclosure (commonly referred to as an under-the-counter model), inlet and outlet piping shall be installed in a manner consistent with Figures 4, 5, or 6 of section 7 of this appendix. For water heaters that are supplied with a counter-top enclosure, inlet and outlet piping shall be made in a manner consistent with Figures 7a and 7b of section 7 of this appendix, respectively. The vertical piping noted in Figures 7a and 7b shall be located (whether inside the enclosure or along the outside in a recessed channel) in accordance with the manufacturer-published installation instructions.

All dimensions noted in Figures 1 through 7 of section 7 of this appendix must be achieved. All piping between the water heater and inlet and outlet temperature sensors, noted as T_{IN} and T_{OUT} in the figures, shall be Type ''L'' hard copper having the same diameter as the connections on the water heater. Unions may be used to facilitate installation and removal of the piping arrangements. Install a pressure gauge and diaphragm expansion tank in the supply water

piping at a location upstream of the inlet temperature sensor. Install an appropriately rated pressure and temperature relief valve on all water heaters at the port specified by the manufacturer. Discharge piping for the relief valve must be non-metallic. If heat traps, piping insulation, or pressure relief valve insulation are supplied with the water heater, they must be installed for testing. Except when using a simulated wall, provide sufficient clearance such that none of the piping contacts other surfaces in the test room.

At the discretion of the test laboratory, the mass or water delivered may be measured on either the inlet or outlet of the water heater.

For water heaters designed to be used with a mixing valve and that do not have a self-contained mixing valve, a mixing valve shall be installed according to the water heater and/or mixing valve manufacturer's installation instructions. If permitted by the water heater and mixing valve manufacturer's instructions, the mixing valve and cold water junction may be installed where the elbows are located in the outlet and inlet line, respectively. If there are no installation instructions for the mixing valve in the water heater or mixing valve manufacturer's instructions, then the mixing valve shall be installed on the outlet line and the cold water shall be supplied from the inlet line from a junction installed downstream from the location where the inlet water temperature is measured. The outlet water temperature, water flow rate, and/or mass measuring instrumentation, if installed on the outlet side of the water heater, shall be installed downstream from the mixing valve.

4.4 *Fuel and/or Electrical Power and Energy Consumption.* Install one or more instruments that measure, as appropriate, the quantity and rate of electrical energy and/or fossil fuel consumption in accordance with section 3 of this appendix.

4.5 *Internal Storage Tank Temperature Measurements.* For water heaters with rated storage volumes greater than or equal to 20 gallons, install six temperature measurement sensors inside the water heater tank with a vertical distance of at least 4 inches (100 mm) between successive sensors. For water heaters with rated storage volumes between 2 and 20 gallons, install three temperature measurement sensors inside the water heater tank. Position a temperature sensor at the vertical midpoint of each of the six equal volume nodes within a tank larger than 20 gallons or the three equal volume nodes within a tank between 2 and 20 gallons. Nodes designate the equal volumes used to evenly partition the total volume of the tank. As much as is possible, the temperature sensor should be positioned away from any heating elements, anodic protective devices, tank walls, and flue pipe walls. If the tank cannot accommodate six temperature sensors and meet the installation requirements specified in this section, install the maximum number of sensors that comply with the installation requirements. Install the temperature sensors through:

(a) The anodic device opening;

(b) The relief valve opening; or

(c) The hot water outlet.

If installed through the relief valve opening or the hot water outlet, a tee fitting or outlet piping, as applicable, must be installed as close as possible to its original location. If the relief valve temperature sensor is relocated, and it no longer extends into the top of the tank, install a substitute relief valve that has a sensing element that can reach into the tank. If the hot water outlet includes a heat trap, install the heat trap on top of the tee fitting. Cover any added fittings with thermal insulation having an R value between 4 and 8 $h \cdot ft^{2} \cdot {}^{\circ}F/Btu$ (0.7 and 1.4 $m^{2} \cdot {}^{\circ}C/W$). If temperature measurement sensors cannot be installed within the water heater, follow the alternate procedures in section 5.4.2.2 of this appendix.

4.6 *Ambient Air Temperature Measurement.* Install an ambient air temperature sensor at the vertical midpoint of the water heater and approximately 2 feet (610 mm) from the surface of the water heater. Shield the sensor against radiation.

4.7 *Inlet and Outlet Water Temperature Measurements.* Install temperature sensors in the cold-water inlet pipe and hot-water outlet pipe as shown in Figures 1, 2, 3, 4, 5, 6, 7a, and 7b of section 7 of this appendix, as applicable.

4.8 *Flow Control.* Install a valve or valves to provide flow as specified in sections 5.3 and 5.4 of this appendix.

4.9 *Flue Requirements.*

4.9.1 *Gas-Fired Water Heaters.* Establish a natural draft in the following manner. For gas-fired water heaters with a vertically discharging draft hood outlet, connect to the draft hood outlet a 5-foot (1.5-meter) vertical vent pipe extension with a diameter equal to the largest flue collar size of the draft hood. For gas-fired water heaters with a horizontally discharging draft hood outlet, connect to the draft hood outlet a 90-degree elbow with a diameter equal to the largest flue collar size of the draft hood, connect a 5-foot (1.5-meter) length of vent pipe to that elbow, and orient the vent pipe to discharge vertically upward. Install direct-vent gas-fired water heaters with venting equipment specified by the manufacturer in the I&O manual using the minimum vertical and horizontal lengths of vent pipe recommended by the manufacturer.

4.9.2 *Oil-Fired Water Heaters.* Establish a draft at the flue collar at the value specified by the manufacturer in the I&O manual. Establish the draft by using a sufficient length of vent pipe connected to the water heater

flue outlet, and directed vertically upward. For an oil-fired water heater with a horizontally discharging draft hood outlet, connect to the draft hood outlet a 90-degree elbow with a diameter equal to the largest flue collar size of the draft hood, connect to the elbow fitting a length of vent pipe sufficient to establish the draft, and orient the vent pipe to discharge vertically upward. Direct-vent oil-fired water heaters should be installed with venting equipment as specified by the manufacturer in the I&O manual, using the minimum vertical and horizontal lengths of vent pipe recommended by the manufacturer.

4.10 *Storage Tank Requirement for Water Heaters Requiring a Storage Tank (i.e., Circulating Water Heaters).* On or after May 6, 2029, when testing a gas-fired, oil-fired, or electric resistance circulating water heater (*i.e.*, any circulating water heater that does not use a heat pump), the tank to be used for testing shall be an unfired hot water storage tank having volume between 80 and 120 gallons (364–546 liters) determined using the method specified in section 5.2.1 of this appendix that meets but does not exceed the minimum energy conservation standards required according to §431.110 of this chapter. When testing a heat pump circulating water heater, the tank to be used for testing shall be an electric storage water heater that has a measured volume of 30 gallons (±5 gallons), has a First-Hour Rating less than 51 gallons resulting in classification under the low draw pattern, and has a rated UEF equal to the minimum UEF standard specified at §430.32(d), rounded to the nearest 0.01. The operational mode of the heat pump circulating water heater and storage water heater paired system shall be set in accordance with section 5.1.1 of this appendix. If the circulating water heater is supplied with a separate non-integrated circulating pump, install this pump as per the manufacturer's installation instructions and include its power consumption in energy use measurements.

4.11 *External Communication.* If the water heater can connect to an external network or controller, any external communication or connection shall be disabled for the duration of testing; however, the communication module shall remain in an ''on'' state.

5. Test Procedures.

5.1 *Operational Mode Selection.* For water heaters that allow for multiple user-selected operational modes, all procedures specified in this appendix shall be carried out with the water heater in the same operational mode (*i.e.*, only one mode).

5.1.1 *Testing at Normal Setpoint.* The operational mode shall be the default mode (or similarly named, suggested mode for normal operation) as defined by the manufacturer in the I&O manual for giving selection guidance to the consumer. For heat pump water heaters, if a default mode is not defined in the product literature, each test shall be conducted under an operational mode in which both the heat pump and any electric resistance back-up heating element(s) are activated by the unit's control scheme, and which can achieve the internal storage tank temperature specified in this test procedure; if multiple operational modes meet these criteria, the water heater shall be tested under the most energy-intensive mode. If no default mode is specified and the unit does not offer an operational mode that utilizes both the heat pump and the electric resistance back-up heating element(s), the first-hour rating test and the 24-hour simulated-use test shall be tested in heat-pump-only mode. For other types of water heaters where a default mode is not specified, test the unit in all modes and rate the unit using the results of the most energy-intensive mode.

5.1.2 *High Temperature Testing.* This paragraph applies to electric storage water heaters capable of achieving a $T_{max,1}$ above 135 °F. The following exceptions apply:

(1) Electric storage water heaters that do not have a permanent mode or setting in which the water heater is capable of heating and storing water above 135 °F (as measured by $T_{max,1}$), where permanent mode or setting means a mode of operation that is continuous and does not require any external consumer intervention to maintain for longer than 120 hours;

(2) Electric storage water heaters that meet the definition of ''heat pump-type'' water heater at §430.2;

(3) Electric storage water heaters that are only capable of heating the stored water above 135 °F in response to instructions received from a utility or third-party demand-response program.

(4) Electric storage water heaters with measured storage volumes (V_{st}) less than 20 gallons or greater than 55 gallons.

This paragraph may optionally apply to electric heat pump water heaters for voluntary representations of high-temperature operation only.

For those equipped with factory-installed or built-in mixing valves, set the unit to maintain the highest mean tank temperature possible while delivering water at 125 °F ±5 °F. For those not so equipped, install an ASSE 1017-certified mixing valve in accordance with the provisions in section 4.3 of this appendix and adjust the valve to deliver water at 125 °F ±5 °F when the water heater is operating at its highest storage tank temperature setpoint. Maintain this setting throughout the entirety of the test.

5.2 *Water Heater Preparation.*

5.2 1 *Determination of Storage Tank Volume.* For water heaters and separate storage tanks used for testing circulating water heaters, determine the storage capacity, V_{st}, of the water heater or separate storage tank

under test, in gallons (liters), by subtracting the tare weight, W_t, (measured while the tank is empty) from the gross weight of the storage tank when completely filled with water at the supply water temperature specified in section 2.3 of this appendix, W_f, (with all air eliminated and line pressure applied as described in section 2.6 of this appendix) and dividing the resulting net weight by the density of water at the measured temperature.

5.2.2 *Setting the Outlet Discharge Temperature.*

5.2.2.1 *Flow-Activated Water Heaters, including certain instantaneous water heaters and certain storage-type water heaters.* Initiate normal operation of the water heater at the design power rating. Monitor the discharge water temperature and set to the value specified in section 2.5 of this appendix in accordance with the manufacturer's I&O manual. If the water heater is not capable of providing this discharge temperature when the flow rate is 1.7 gallons ± 0.25 gallons per minute (6.4 liters ± 0.95 liters per minute), then adjust the flow rate as necessary to achieve the specified discharge water temperature. Once the proper temperature control setting is achieved, the setting must remain fixed for the duration of the maximum GPM test and the 24-hour simulated-use test.

5.2.2.2 *All Other Water Heaters.*

5.2.2.2.1 *Water Heaters with a Single Temperature Controller.*

5.2.2.2.1.1 *Water Heaters with Rated Volumes Less than 20 Gallons.* Starting with a tank at the supply water temperature as specified in section 2.3 of this appendix, initiate normal operation of the water heater. After cut-out, initiate a draw from the water heater at a flow rate of 1.0 gallon ± 0.25 gallons per minute (3.8 liters ± 0.95 liters per minute) for 2 minutes. Starting 15 seconds after commencement of the draw, record the outlet temperature at 15-second intervals until the end of the 2-minute period. Determine whether the maximum outlet temperature is within the range specified in section 2.4 of this appendix. If not, turn off the water heater, adjust the temperature controller, and then drain and refill the tank with supply water at the temperature specified in section 2.3 of this appendix. Then, once again, initiate normal operation of the water heater, and repeat the 2-minute outlet temperature test following cut-out. Repeat this sequence until the maximum outlet temperature during the 2-minute test is within the range specified in section 2.4 of this appendix. Once the proper temperature control setting is achieved, the setting must remain fixed for the duration of the first-hour rating test and the 24-hour simulated-use test.

5.2.2.2.1.2 *Water Heaters with Rated Volumes Greater than or Equal to 20 Gallons.* Starting with a tank at the supply water temperature specified in section 2.3 of this appendix, initiate normal operation of the water heater. After cut-out, initiate a draw from the water heater at a flow rate of 1.7 gallons ± 0.25 gallons per minute (6.4 liters ± 0.95 liters per minute) for 5 minutes. Starting 15 seconds after commencement of the draw, record the outlet temperature at 15-second intervals until the end of the 5-minute period. Determine whether the maximum outlet temperature is within the range specified in section 2.4 of this appendix. If not, turn off the water heater, adjust the temperature controller, and then drain and refill the tank with supply water at the temperature specified in section 2.3 of this appendix. Then, once again, initiate normal operation of the water heater, and repeat the 5-minute outlet temperature test following cut-out. Repeat this sequence until the maximum outlet temperature during the 5-minute test is within the range specified in section 2.4 of this appendix. Once the proper temperature control setting is achieved, the setting must remain fixed for the duration of the first-hour rating test and the 24-hour simulated-use test.

5.2.2.2.2 *Water Heaters with Two or More Temperature Controllers.* Verify the temperature controller set-point while removing water in accordance with the procedure set forth for the first-hour rating test in section 5.3.3 of this appendix. The following criteria must be met to ensure that all temperature controllers are set to deliver water in the range specified in section 2.4 of this appendix:

(a) At least 50 percent of the water drawn during the first draw of the first-hour rating test procedure shall be delivered at a temperature within the range specified in section 2.4 of this appendix.

(b) No water is delivered above the range specified in section 2.4 of this appendix during first-hour rating test.

(c) The delivery temperature measured 15 seconds after commencement of each draw begun prior to an elapsed time of 60 minutes from the start of the test shall be within the range specified in section 2.4 of this appendix.

If these conditions are not met, turn off the water heater, adjust the temperature controllers, and then drain and refill the tank with supply water at the temperature specified in section 2.3 of this appendix. Repeat the procedure described at the start of section 5.2.2.2.2 of this appendix until the criteria for setting the temperature controllers is met.

If the conditions stated above are met, the data obtained during the process of verifying the temperature control set-points may be used in determining the first-hour rating provided that all other conditions and methods required in sections 2 and 5.2.4 of this appendix in preparing the water heater were followed.

5.2.3 *Power Input Determination.* For all water heaters except electric types, initiate normal operation (as described in section 5.1 of this appendix) and determine the power input, P, to the main burners (including pilot light power, if any) after 15 minutes of operation. Adjust all burners to achieve an hourly Btu (kJ) rating that is within ±2% of the maximum input rate value specified by the manufacturer. For an oil-fired water heater, adjust the burner to give a CO_2 reading recommended by the manufacturer and an hourly Btu (kJ) rating that is within ±2% of the maximum input rate specified by the manufacturer. Smoke in the flue may not exceed No. 1 smoke as measured by the procedure in ASTM D2156 (R2018), including the conditions as specified in ASTM E97–1987 as referenced in ASTM D2156 (R2018). If the input rating is not within ±2%, first increase or decrease the fuel pressure within the tolerances specified in section 2.7.2, 2.7.3 or 2.7.4 (as applicable) of this appendix until it is ±2% of the maximum input rate value specified by the manufacturer. If, after adjusting the fuel pressure, the fuel input rate cannot be achieved within ±2 percent of the maximum input rate value specified by the manufacturer, for gas-fired models increase or decrease the gas supply pressure within the range specified by the manufacturer. Finally, if the measured fuel input rate is still not within ±2 percent of the maximum input rate value specified by the manufacturer, modify the gas inlet orifice, if so equipped, as necessary to achieve a fuel input rate that is within ±2 percent of the maximum input rate value specified by the manufacturer.

5.2.4 *Soak-In Period for Water Heaters with Rated Storage Volumes Greater than or Equal to 2 Gallons.* For water heaters with a rated storage volume greater than or equal to 2 gallons (7.6 liters), the water heater must sit filled with water, connected to a power source, and without any draws taking place for at least 12 hours after initially being energized so as to achieve the nominal temperature set-point within the tank and with the unit connected to a power source.

5.3 *Delivery Capacity Tests.*

5.3.1 *General.* For flow-activated water heaters, conduct the maximum GPM test, as described in section 5.3.2, Maximum GPM Rating Test for Flow-Activated Water Heaters, of this appendix. For all other water heaters, conduct the first-hour rating test as described in section 5.3.3 of this appendix.

5.3.2 *Maximum GPM Rating Test for Flow-Activated Water Heaters.* Establish normal water heater operation at the design power rating with the discharge water temperature set in accordance with section 5.2.2.1 of this appendix.

For this 10-minute test, either collect the withdrawn water for later measurement of the total mass removed or use a water meter to directly measure the water mass of volume removed. Initiate water flow through the water heater and record the inlet and outlet water temperatures beginning 15 seconds after the start of the test and at subsequent 5-second intervals throughout the duration of the test. At the end of 10 minutes, turn off the water. Determine and record the mass of water collected, M_{10m}, in pounds (kilograms), or the volume of water, V_{10m}, in gallons (liters).

5.3.3 *First-Hour Rating Test.*

5.3.3.1 *General.* During hot water draws for water heaters with rated storage volumes greater than or equal to 20 gallons, remove water at a rate of 3.0 ± 0.25 gallons per minute (11.4 ± 0.95 liters per minute). During hot water draws for water heaters with rated storage volumes below 20 gallons, remove water at a rate of 1.5 ± 0.25 gallon per minute (5.7 ± 0.95 liters per minute). Collect the water in a container that is large enough to hold the volume removed during an individual draw and is suitable for weighing at the termination of each draw to determine the total volume of water withdrawn. As an alternative to collecting the water, a water meter may be used to directly measure the water mass or volume withdrawn during each draw.

5.3.3.2 *Draw Initiation Criteria.* Begin the first-hour rating test by starting a draw on the water heater. After completion of this first draw, initiate successive draws based on the following criteria. For gas-fired and oil-fired water heaters, initiate successive draws when the temperature controller acts to reduce the supply of fuel to the main burner. For electric water heaters having a single element or multiple elements that all operate simultaneously, initiate successive draws when the temperature controller acts to reduce the electrical input supplied to the element(s). For electric water heaters having two or more elements that do not operate simultaneously, initiate successive draws when the applicable temperature controller acts to reduce the electrical input to the energized element located vertically highest in the storage tank. For heat pump water heaters that do not use supplemental, resistive heating, initiate successive draws immediately after the electrical input to the compressor is reduced by the action of the water heater's temperature controller. For heat pump water heaters that use supplemental resistive heating, initiate successive draws immediately after the electrical input to the first of either the compressor or the vertically highest resistive element is reduced by the action of the applicable water heater temperature controller. This draw initiation criterion for heat pump water heaters that use supplemental resistive heating, however, shall only apply when the water located above the thermostat at cut-out is heated to within the range specified in section 2.4 of this appendix. If this criterion

is not met, then the next draw should be initiated once the heat pump compressor cuts out.

5.3.3.3 *Test Sequence.* Establish normal water heater operation. If the water heater is not presently operating, initiate a draw. The draw may be terminated any time after cut-in occurs. After cut-out occurs (*i.e.*, all temperature controllers are satisfied), if the water heater can have its internal tank temperatures measured, record the internal storage tank temperature at each sensor described in section 4.5 of this appendix every one minute, and determine the mean tank temperature by averaging the values from these sensors.

Initiate a draw after a maximum mean tank temperature (the maximum of the mean temperatures of the individual sensors) has been observed following a cut-out. If the water heater cannot have its internal tank temperatures measured, wait 5 minutes after cut-out. Record the time when the draw is initiated and designate it as an elapsed time of zero ($\tau^* = 0$). (The superscript * is used to denote variables pertaining to the first-hour rating test). Record the outlet water temperature beginning 15 seconds after the draw is initiated and at 5-second intervals thereafter until the draw is terminated. Determine the maximum outlet temperature that occurs during this first draw and record it as $T^*_{max,1}$. For the duration of this first draw and all successive draws, in addition, monitor the inlet temperature to the water heater to ensure that the required supply water temperature test condition specified in section 2.3 of this appendix is met. Terminate the hot water draw when the outlet temperature decreases to $T^*_{max,1} - 15$ °F ($T^*_{max,1} - 8.3$ °C). (Note, if the outlet temperature does not decrease to $T^*_{max,1} - 15$ °F ($T^*_{max,1} - 8.3$ °C) during the draw, then hot water would be drawn continuously for the duration of the test. In this instance, the test would end when the temperature decreases to $T^*_{max,1} - 15$ °F ($T^*_{max,1} - 8.3$ °C) after the electrical power and/or fuel supplied to the water heater is shut off, as described in the following paragraphs.) Record this temperature as $T^*_{min,1}$. Following draw termination, determine the average outlet water temperature and the mass or volume removed during this first draw and record them as $\overline{T}^*_{del,i}$ and M^*_1 or V^*_1, respectively.

Initiate a second and, if applicable, successive draw(s) each time the applicable draw initiation criteria described in section 5.3.3.2 of this appendix are satisfied. As required for the first draw, record the outlet water temperature 15 seconds after initiating each draw and at 5-second intervals thereafter until the draw is terminated. Determine the maximum outlet temperature that occurs during each draw and record it as $T^*_{max,i}$, where the subscript i refers to the draw number. Terminate each hot water draw when the outlet temperature decreases to $T^*_{max,i} - 15$ °F ($T^*_{max,i} - 8.3$ °C). Record this temperature as $T^*_{min,i}$. Calculate and record the average outlet temperature and the mass or volume removed during each draw ($\overline{T}^*_{del,i}$ and M^*_i or V^*_i, respectively). Continue this sequence of draw and recovery until one hour after the start of the test, then shut off the electrical power and/or fuel supplied to the water heater.

If a draw is occurring at one hour from the start of the test, continue this draw until the outlet temperature decreases to $T^*_{max,n} - 15$ °F ($T^*_{max,n} - 8.3$ °C), at which time the draw shall be immediately terminated. (The subscript n shall be used to denote measurements associated with the final draw.) If a draw is not occurring one hour after the start of the test, initiate a final draw at one hour, regardless of whether the criteria described in section 5.3.3.2 of this appendix are satisfied. This draw shall proceed for a minimum of 30 seconds and shall terminate when the outlet temperature first indicates a value less than or equal to the cut-off temperature used for the previous draw ($T^*_{min,n-1}$). If an outlet temperature greater than $T^*_{min,n-1}$ is not measured within 30 seconds of initiation of the draw, zero additional credit shall be given towards first-hour rating (*i.e.*, $M^*_n = 0$ or $V^*_n = 0$) based on the final draw. After the final draw is terminated, calculate and record the average outlet temperature and the mass or volume removed during the final draw ($\overline{T}^*_{del,n}$ and M^*_n or V^*_n, respectively).

5.4 *24-Hour Simulated-Use Test.*

5.4.1 *Selection of Draw Pattern.* The water heater will be tested under a draw profile that depends upon the first-hour rating obtained following the test prescribed in section 5.3.3 of this appendix, or the maximum GPM rating obtained following the test prescribed in section 5.3.2 of this appendix, whichever is applicable. For water heaters that have been tested according to the first-hour rating procedure, one of four different patterns shall be applied based on the measured first-hour rating, as shown in Table I of this section. For water heater that have been tested according to the maximum GPM rating procedure, one of four different patterns shall be applied based on the maximum GPM, as shown in Table II of this section.

TABLE I—DRAW PATTERN TO BE USED BASED ON FIRST-HOUR RATING

First-hour rating greater than or equal to:	. . . and first-hour rating less than:	Draw pattern to be used in the 24-hour simulated-use test
0 gallons	18 gallons	Very-Small-Usage (Table III.1).

TABLE I—DRAW PATTERN TO BE USED BASED ON FIRST-HOUR RATING—Continued

First-hour rating greater than or equal to:	. . . and first-hour rating less than:	Draw pattern to be used in the 24-hour simulated-use test
18 gallons	51 gallons	Low-Usage (Table III.2).
51 gallons	75 gallons	Medium-Usage (Table III.3).
75 gallons	No upper limit	High-Usage (Table III.4).

TABLE II—DRAW PATTERN TO BE USED BASED ON MAXIMUM GPM RATING

Maximum GPM rating greater than or equal to:	and maximum GPM rating less than:	Draw pattern to be used in the 24-hour simulated-use test
0 gallons/minute	1.7 gallons/minute	Very-Small-Usage (Table III.1).
1.7 gallons/minute	2.8 gallons/minute	Low-Usage (Table III.2).
2.8 gallons/minute	4 gallons/minute	Medium-Usage (Table III.3).
4 gallons/minute	No upper limit	High-Usage (Table III.4).

The draw patterns are provided in Tables III.1 through III.4 in section 5.5 of this appendix. Use the appropriate draw pattern when conducting the test sequence provided in section 5.4.2 of this appendix for water heaters with rated storage volumes greater than or equal to 2 gallons or section 5.4.3 of this appendix for water heaters with rated storage volumes less than 2 gallons.

5.4.2 *Test Sequence for Water Heater With Rated Storage Volume Greater Than or Equal to 2 Gallons.*

If the water heater is turned off, fill the water heater with supply water at the temperature specified in section 2.3 of this appendix and maintain supply water pressure as described in section 2.6 of this appendix. Turn on the water heater and associated heat pump unit, if present. If turned on in this fashion, the soak-in period described in section 5.2.4 of this appendix shall be implemented. If the water heater has undergone a first-hour rating test prior to conduct of the 24-hour simulated-use test, allow the water heater to fully recover after completion of that test such that the main burner, heating elements, or heat pump compressor of the water heater are no longer raising the temperature of the stored water. In all cases, the water heater shall sit idle for 1 hour prior to the start of the 24-hour test; during which time no water is drawn from the unit, and there is no energy input to the main heating elements, heat pump compressor, and/or burners.

For water heaters that can have their internal storage tank temperature measured directly, perform testing in accordance with the instructions in section 5.4.2.1 of this appendix. For water heaters that cannot have their internal tank temperatures measured, perform testing in accordance with the instructions in section 5.4.2.2. of this appendix.

5.4.2.1 *Water Heaters Which Can Have Internal Storage Tank Temperature Measured Directly.*

After the 1-hour period specified in section 5.4.2 of this appendix, the 24-hour simulated-use test will begin. One minute prior to the start of the 24-hour simulated-use test, record the mean tank temperature (T_0).

At the start of the 24-hour simulated-use test, record the electrical and/or fuel measurement readings, as appropriate. Begin the 24-hour simulated-use test by withdrawing the volume specified in the appropriate table in section 5.5 of this appendix (*i.e.*, Table III.1, Table III.2, Table III.3, or Table III.4, depending on the first-hour rating or maximum GPM rating) for the first draw at the flow rate specified in the applicable table. Record the time when this first draw is initiated and assign it as the test elapsed time (τ) of zero (0). Record the average storage tank and ambient temperature every minute throughout the 24-hour simulated-use test. At the elapsed times specified in the applicable draw pattern table in section 5.5 of this appendix for a particular draw pattern, initiate additional draws pursuant to the draw pattern, removing the volume of hot water at the prescribed flow rate specified by the table. The maximum allowable deviation from the specified volume of water removed for any single draw taken at a nominal flow rate of 1.0 GPM or 1.7 GPM is ±0.1 gallons (±0.4 liters). The maximum allowable deviation from the specified volume of water removed for any single draw taken at a nominal flow rate of 3.0 GPM is ±0.25 gallons (0.9 liters). The quantity of water withdrawn during the last draw shall be increased or decreased as necessary such that the total volume of water withdrawn equals the prescribed daily amount for that draw pattern ±1.0 gallon (±3.8 liters). If this adjustment to the volume drawn during the last draw results in no draw taking place, the test is considered invalid.

All draws during the 24-hour simulated-use test shall be made at the flow rates specified in the applicable draw pattern table in section 5.5 of this appendix, within a tolerance

of ±0.25 gallons per minute (±0.9 liters per minute). Measurements of the inlet and outlet temperatures shall be made 15 seconds after the draw is initiated and at every subsequent 3-second interval throughout the duration of each draw. Calculate and record the mean of the hot water discharge temperature and the cold water inlet temperature for each draw $T_{del,i}$ and $T_{in,i}$). Determine and record the net mass or volume removed (M_i or V_i), as appropriate, after each draw.

The first recovery period is the time from the start of the 24-hour simulated-use test and continues during the temperature rise of the stored water until the first cut-out; if the cut-out occurs during a subsequent draw, the first recovery period includes the time until the draw of water from the tank stops. If, after the first cut-out occurs but during a subsequent draw, a subsequent cut-in occurs prior to the draw completion, the first recovery period includes the time until the subsequent cut-out occurs, prior to another draw. The first recovery period may continue until a cut-out occurs when water is not being removed from the water heater or a cut-out occurs during a draw and the water heater does not cut-in prior to the end of the draw.

At the end of the first recovery period, record the maximum mean tank temperature observed after cut-out ($T_{max,1}$). At the end of the first recovery period, record the total energy consumed by the water heater from the beginning of the test (Q_r), including all fossil fuel and/or electrical energy use, from the main heat source and auxiliary equipment including, but not limited to, burner(s), resistive elements(s), compressor, fan, controls, pump, *etc.*, as applicable.

The start of the portion of the test during which the standby loss coefficient is determined depends upon whether the unit has fully recovered from the first draw cluster. If a recovery is occurring at or within five minutes after the end of the final draw in the first draw cluster, as identified in the applicable draw pattern table in section 5.5 of this appendix, then the standby period starts when a maximum mean tank temperature is observed starting five minutes after the end of the recovery period that follows that draw. If a recovery does not occur at or within five minutes after the end of the final draw in the first draw cluster, as identified in the applicable draw pattern table in section 5.5 of this appendix, then the standby period starts five minutes after the end of that draw. Determine and record the total electrical energy and/or fossil fuel consumed from the beginning of the test to the start of the standby period ($Q_{su,0}$).

In preparation for determining the energy consumed during standby, record the reading given on the electrical energy (watt-hour) meter, the gas meter, and/or the scale used to determine oil consumption, as appropriate. Record the mean tank temperature at the start of the standby period ($T_{su,0}$). At 1-minute intervals, record ambient temperature, the electric and/or fuel instrument readings, and the mean tank temperature until the next draw is initiated. The end of the standby period is when the final mean tank temperature is recorded, as described. Just prior to initiation of the next draw, record the mean tank temperature ($T_{su,f}$). If the water heater is undergoing recovery when the next draw is initiated, record the mean tank temperature ($T_{su,f}$) at the minute prior to the start of the recovery. Determine the total electrical energy and/or fossil fuel energy consumption from the beginning of the test to the end of the standby period ($Q_{su,f}$). Record the time interval between the start of the standby period and the end of the standby period ($\tau_{stby,1}$).

Following the final draw of the prescribed draw pattern and subsequent recovery, allow the water heater to remain in the standby mode until exactly 24 hours have elapsed since the start of the 24-hour simulated-use test (*i.e.*, since $\tau = 0$). During the last hour of the 24-hour simulated-use test (*i.e.*, hour 23 of the 24-hour simulated-use test), power to the main burner, heating element, or compressor shall be disabled. At 24 hours, record the reading given by the gas meter, oil meter, and/or the electrical energy meter as appropriate. Determine the fossil fuel and/or electrical energy consumed during the entire 24-hour simulated-use test and designate the quantity as Q.

In the event that the recovery period continues from the end of the last draw of the first draw cluster until the subsequent draw, the standby period will start after the end of the first recovery period after the last draw of the 24-hour simulated-use test, when the temperature reaches the maximum mean tank temperature, though no sooner than five minutes after the end of this recovery period. The standby period shall last eight hours, so testing may extend beyond the 24-hour duration of the 24-hour simulated-use test. Determine and record the total electrical energy and/or fossil fuel consumed from the beginning of the 24-hour simulated-use test to the start of the 8-hour standby period ($Q_{su,0}$). In preparation for determining the energy consumed during standby, record the reading(s) given on the electrical energy (watt-hour) meter, the gas meter, and/or the scale used to determine oil consumption, as appropriate. Record the mean tank temperature at the start of the standby period ($T_{su,0}$). Record the mean tank temperature, the ambient temperature, and the electric and/or fuel instrument readings at 1-minute intervals until the end of the 8-hour period. Record the mean tank temperature at the end of the 8-hour standby period ($T_{su,f}$). If the water heater is undergoing recovery at the end of the standby period, record the mean tank temperature ($T_{su,f}$) at the minute prior

to the start of the recovery, which will mark the end of the standby period. Determine the total electrical energy and/or fossil fuel energy consumption from the beginning of the test to the end of the standby period ($Q_{su,f}$). Record the time interval between the start of the standby period and the end of the standby period as $\tau_{stby,1}$. Record the average ambient temperature from the start of the standby period to the end of the standby period ($T_{a,stby,1}$). Record the average mean tank temperature from the start of the standby period to the end of the standby period ($T_{t,stby,1}$).

If the standby period occurred at the end of the first recovery period after the last draw of the 24-hour simulated-use test, allow the water heater to remain in the standby mode until exactly 24 hours have elapsed since the start of the 24-hour simulated-use test (*i.e.*, since $\tau = 0$) or the end of the standby period, whichever is longer. At 24 hours, record the mean tank temperature (T_{24}) and the reading given by the gas meter, oil meter, and/or the electrical energy meter as appropriate. If the water heater is undergoing a recovery at 24 hours, record the reading given by the gas meter, oil meter, and/or electrical energy meter, as appropriate, and the mean tank temperature (T_{24}) at the minute prior to the start of the recovery. Determine the fossil fuel and/or electrical energy consumed during the 24 hours and designate the quantity as Q.

Record the time during which water is not being withdrawn from the water heater during the entire 24-hour period ($\tau_{stby,2}$). When the standby period occurs after the last draw of the 24-hour simulated-use test, the test may extend past hour 24. When this occurs, the measurements taken after hour 24 apply only to the calculations of the standby loss coefficient. All other measurements during the time between hour 23 and hour 24 remain the same.

5.4.2.2 *Water Heaters Which Cannot Have Internal Storage Tank Temperature Measured Directly*.

After the water heater has undergone a 1-hour idle period (as described in section 5.4.2 of this appendix), deactivate the burner, compressor, or heating element(s).

Remove water from the storage tank by performing a continuous draw at the flow rate specified for the first draw of applicable draw pattern for the 24-hour simulated use test in section 5.5 of this appendix within a tolerance of ±0.25 gallons per minute (±0.9 liters per minute). While removing the hot water, measure the inlet and outlet temperature after initiating the draw at 3-second intervals. Remove water until the outlet water temperature is within ±2 °F (±1.1 °C) of the inlet water temperature for 15 consecutive seconds. Determine the mean tank temperature using section 6.3.77 of this appendix and assign this value of $\overline{T}_{st}$ for $\overline{T}_0$, $\overline{T}_{max,1}$, and $\overline{T}_{su,0}$.

After completing the draw, reactivate the burner, compressor, or heating elements(s) and allow the unit to fully recover such that the main burner, heating elements, or heat pump compressor is no longer raising the temperature of the stored water. Let the water heater sit idle again for 1 hour prior to beginning the 24-hour test, during which time no water shall be drawn from the unit, and there shall be no energy input to the main heating elements. After the 1-hour period, the 24-hour simulated-use test will begin.

At the start of the 24-hour simulated-use test, record the electrical and/or fuel measurement readings, as appropriate. Begin the 24-hour simulated-use test by withdrawing the volume specified in the appropriate table in section 5.5 of this appendix (*i.e.*, Table III.1, Table III.2, Table III.3, or Table III.4, depending on the first-hour rating or maximum GPM rating) for the first draw at the flow rate specified in the applicable table. Record the time when this first draw is initiated and assign it as the test elapsed time (τ) of zero (0). Record the average ambient temperature every minute throughout the 24-hour simulated-use test. At the elapsed times specified in the applicable draw pattern table in section 5.5 of this appendix for a particular draw pattern, initiate additional draws pursuant to the draw pattern, removing the volume of hot water at the prescribed flow rate specified by the table. The maximum allowable deviation from the specified volume of water removed for any single draw taken at a nominal flow rate of 1.0 GPM or 1.7 GPM is ± 0.1 gallons (± 0.4 liters). The maximum allowable deviation from the specified volume of water removed for any single draw taken at a nominal flow rate of 3.0 GPM is ± 0.25 gallons (0.9 liters). The quantity of water withdrawn during the last draw shall be increased or decreased as necessary such that the total volume of water withdrawn equals the prescribed daily amount for that draw pattern ± 1.0 gallon (± 3.8 liters). If this adjustment to the volume drawn during the last draw results in no draw taking place, the test is considered invalid.

All draws during the 24-hour simulated-use test shall be made at the flow rates specified in the applicable draw pattern table in section 5.5 of this appendix, within a tolerance of ±0.25 gallons per minute (±0.9 liters per minute). Measurements of the inlet and outlet temperatures shall be made 15 seconds after the draw is initiated and at every subsequent 3-second interval throughout the duration of each draw. Calculate and record the mean of the hot water discharge temperature and the cold water inlet temperature for each draw ($T_{del,i}$ and $T_{in,i}$). Determine and record the net mass or volume removed (M_i or V_i), as appropriate, after each draw.

The first recovery period is the time from the start of the 24-hour simulated-use test

and continues until the first cut-out; if the cut-out occurs during a subsequent draw, the first recovery period includes the time until the draw of water from the tank stops. If, after the first cut-out occurs but during a subsequent draw, a subsequent cut-in occurs prior to the draw completion, the first recovery period includes the time until the subsequent cut-out occurs, prior to another draw. The first recovery period may continue until a cut-out occurs when water is not being removed from the water heater or a cut-out occurs during a draw and the water heater does not cut-in prior to the end of the draw.

At the end of the first recovery period, record the total energy consumed by the water heater from the beginning of the test (Q_r), including all fossil fuel and/or electrical energy use, from the main heat source and auxiliary equipment including, but not limited to, burner(s), resistive elements(s), compressor, fan, controls, pump, etc., as applicable.

The standby period begins at five minutes after the first time a recovery ends following last draw of the simulated-use test and shall continue for 8 hours. At the end of the 8-hour standby period, record the total amount of time elapsed since the start of the 24-hour simulated-use test (*i.e.*, since $\tau = 0$).

Determine and record the total electrical energy and/or fossil fuel consumed from the beginning of the 24-hour simulated-use test to the start of the 8-hour standby period ($Q_{su,0}$). In preparation for determining the energy consumed during standby, record the reading(s) given on the electrical energy (watt-hour) meter, the gas meter, and/or the scale used to determine oil consumption, as appropriate. Record the ambient temperature and the electric and/or fuel instrument readings at 1-minute intervals until the end of the 8-hour period. At the 8-hour mark, deactivate the water heater before drawing water from the tank. Remove water from the storage tank by performing a continuous draw atthe flow rate specified for the first draw of applicable draw pattern for the 24-hour simulated use test in section 5.5 of this appendix within a tolerance of ±0.25 gallons per minute (±0.9 liters per minute). While removing the hot water, measure the inlet and outlet temperature after initiating the draw at 3-second intervals. Remove water until the outlet water temperature is within ±2 °F (±1.1 °C) of the inlet water temperature for 15 consecutive seconds. Determine the mean tank temperature using section 6.3.77 of this appendix and assign this value of $\overline{T}_{st}$ for $\overline{T}_{su,f}$ and $\overline{T}_{24}$.

Determine the total electrical energy and/or fossil fuel energy consumption from the beginning of the test to the end of the standby period ($Q_{su,f}$). Record the time interval between the start of the standby period and the end of the standby period as $\tau_{stby,1}$. Record the average ambient temperature from the start of the standby period to the end of the standby period ($T_{a,stby,1}$). The average mean tank temperature from the start of the standby period to the end of the standby period ($T_{t,stby,1}$) shall be the average of $T_{su,0}$ and $T_{su,f}$.

5.4.3 *Test Sequence for Water Heaters With Rated Storage Volume Less Than 2 Gallons.*

Establish normal operation with the discharge water temperature at 125 °F ± 5 °F (51.7 °C ± 2.8 °C) and set the flow rate as determined in section 5.2 of this appendix. Prior to commencement of the 24-hour simulated-use test, the unit shall remain in an idle state in which controls are active but no water is drawn through the unit for a period of one hour. With no draw occurring, record the reading given by the gas meter and/or the electrical energy meter as appropriate. Begin the 24-hour simulated-use test by withdrawing the volume specified in Tables III.1 through III.4 of section 5.5 of this appendix for the first draw at the flow rate specified. Record the time when this first draw is initiated and designate it as an elapsed time, τ, of 0. At the elapsed times specified in Tables III.1 through III.4 for a particular draw pattern, initiate additional draws, removing the volume of hot water at the prescribed flow rate specified in Tables III.1 through III.4. The maximum allowable deviation from the specified volume of water removed for any single draw taken at a nominal flow rate less than or equal to 1.7 GPM (6.4 L/min) is ±0.1 gallons (±0.4 liters). The maximum allowable deviation from the specified volume of water removed for any single draw taken at a nominal flow rate of 3.0 GPM (11.4 L/min) is ±0.25 gallons (0.9 liters). The quantity of water drawn during the final draw shall be increased or decreased as necessary such that the total volume of water withdrawn equals the prescribed daily amount for that draw pattern ±1.0 gallon (±3.8 liters). If this adjustment to the volume drawn in the last draw results in no draw taking place, the test is considered invalid.

All draws during the 24-hour simulated-use test shall be made at the flow rates specified in the applicable draw pattern table in section 5.5 of this appendix within a tolerance of ±0.25 gallons per minute (±0.9 liters per minute) unless the unit being tested is flow-activated and has a rated Max GPM of less than 1 gallon per minute, in which case the tolerance shall be ±25% of the rated Max GPM. Measurements of the inlet and outlet water temperatures shall be made 15 seconds after the draw is initiated and at every 3-second interval thereafter throughout the duration of the draw. Calculate the mean of the hot water discharge temperature and the cold-water inlet temperature for each draw. Record the mass of the withdrawn water or the water meter reading, as appropriate,

after each draw. At the end of the first recovery period following the first draw, determine and record the fossil fuel and/or electrical energy consumed, Q_r. Following the final draw and subsequent recovery, allow the water heater to remain in the standby mode until exactly 24 hours have elapsed since the start of the test (*i.e.*, since $\tau = 0$). At 24 hours, record the reading given by the gas meter, oil meter, and/or the electrical energy meter, as appropriate. Determine the fossil fuel and/or electrical energy consumed during the entire 24-hour simulated-use test and designate the quantity as Q.

5.5 *Draw Patterns.*

The draw patterns to be imposed during 24-hour simulated-use tests are provided in Tables III.1 through III.4. Subject each water heater under test to one of these draw patterns based on its first-hour rating or maximum GPM rating, as discussed in section 5.4.1 of this appendix. Each draw pattern specifies the elapsed time in hours and minutes during the 24-hour test when a draw is to commence, the total volume of water in gallons (liters) that is to be removed during each draw, and the flow rate at which each draw is to be taken, in gallons (liters) per minute.

TABLE III.1—VERY-SMALL-USAGE DRAW PATTERN

Draw No.	Time during test** [hh:mm]	Volume [gallons (L)]	Flow rate*** [GPM (L/min)]
1*	0:00	2.0 (7.6)	1 (3.8)
2*	1:00	1.0 (3.8)	1 (3.8)
3*	1:05	0.5 (1.9)	1 (3.8)
4*	1:10	0.5 (1.9)	1 (3.8)
5*	1:15	0.5 (1.9)	1 (3.8)
6	8:00	1.0 (3.8)	1 (3.8)
7	8:15	2.0 (7.6)	1 (3.8)
8	9:00	1.5 (5.7)	1 (3.8)
9	9:15	1.0 (3.8)	1 (3.8)

Total Volume Drawn Per Day: 10 gallons (38 L)

*Denotes draws in first draw cluster.

**If a draw extends to the start of the subsequent draw, then the subsequent draw shall start when the required volume of the previous draw has been delivered.

***Should the water heater have a maximum GPM rating less than 1 GPM (3.8 L/min), then all draws shall be implemented at a flow rate equal to the rated maximum GPM.

TABLE III.2—LOW-USAGE DRAW PATTERN

Draw No.	Time during test [hh:mm]	Volume [gallons (L)]	Flow rate [GPM (L/min)]
1*	0:00	15.0 (56.8)	1.7 (6.4)
2*	0:30	2.0 (7.6)	1 (3.8)
3*	1:00	1.0 (3.8)	1 (3.8)
4	10:30	6.0 (22.7)	1.7 (6.4)
5	11:30	4.0 (15.1)	1.7 (6.4)
6	12:00	1.0 (3.8)	1 (3.8)
7	12:45	1.0 (3.8)	1 (3.8)
8	12:50	1.0 (3.8)	1 (3.8)
9	16:15	2.0 (7.6)	1 (3.8)
10	16:45	2.0 (7.6)	1.7 (6.4)
11	17:00	3.0 (11.4)	1.7 (6.4)

Total Volume Drawn Per Day: 38 gallons (144 L)

*Denotes draws in first draw cluster.

TABLE III.3—MEDIUM-USAGE DRAW PATTERN

Draw No.	Time during test [hh:mm]	Volume [gallons (L)]	Flow Rate [GPM (L/min)]
1*	0:00	15.0 (56.8)	1.7 (6.4)
2*	0:30	2.0 (7.6)	1 (3.8)
3*	1:40	9.0 (34.1)	1.7 (6.4)
4	10:30	9.0 (34.1)	1.7 (6.4)
5	11:30	5.0 (18.9)	1.7 (6.4)
6	12:00	1.0 (3.8)	1 (3.8)
7	12:45	1.0 (3.8)	1 (3.8)
8	12:50	1.0 (3.8)	1 (3.8)
9	16:00	1.0 (3.8)	1 (3.8)
10	16:15	2.0 (7.6)	1 (3.8)
11	16:45	2.0 (7.6)	1.7 (6.4)
12	17:00	7.0 (26.5)	1.7 (6.4)

Total Volume Drawn Per Day: 55 gallons (208 L)

*Denotes draws in first draw cluster.

TABLE III.4—HIGH-USAGE DRAW PATTERN

Draw No.	Time during test [hh:mm]	Volume [gallons (L)]	Flow rate [GPM (L/min)]
1*	0:00	27.0 (102)	3 (11.4)
2*	0:30	2.0 (7.6)	1 (3.8)
3*	0:40	1.0 (3.8)	1 (3.8)
4*	1:40	9.0 (34.1)	1.7 (6.4)
5	10:30	15.0 (56.8)	3 (11.4)
6	11:30	5.0 (18.9)	1.7 (6.4)
7	12:00	1.0 (3.8)	1 (3.8)
8	12:45	1.0 (3.8)	1 (3.8)
9	12:50	1.0 (3.8)	1 (3.8)
10	16:00	2.0 (7.6)	1 (3.8)
11	16:15	2.0 (7.6)	1 (3.8)
12	16:30	2.0 (7.6)	1.7 (6.4)
13	16:45	2.0 (7.6)	1.7 (6.4)
14	17:00	14.0 (53.0)	3 (11.4)

TABLE III.4—HIGH-USAGE DRAW PATTERN—Continued

Draw No.	Time during test [hh:mm]	Volume [gallons (L)]	Flow rate [GPM (L/min)]
Total Volume Drawn Per Day: 84 gallons (318 L)			

* Denotes draws in first draw cluster.

5.6 *Optional Tests (Heat Pump-Type Water Heaters).* Optional testing may be conducted on heat pump-type water heaters to determine E_X. If optional testing is performed, conduct the additional 24-hour simulated use test(s) at one or multiple of the test conditions specified in section 2.8 of this appendix. Prior to conducting a 24-hour simulated use test at an optional condition, confirm the air and water conditions specified in section 2.8 are met and re-set the outlet discharge temperature in accordance with section 5.2.2 of this appendix. Perform the optional 24-hour simulated use test(s) in accordance with section 5.4 of this appendix using the same draw pattern used for the determination of UEF.

6. Computations.

6.1 *First-Hour Rating Computation.* For the case in which the final draw is initiated at or prior to one hour from the start of the test, the first-hour rating, F_{hr}, shall be computed using,

$$F_{hr} = \sum_{i=1}^{n} V^*_{del,i}$$

Where:

n = the number of draws that are completed during the first-hour rating test.

$V^*_{del,i}$ = the volume of water removed during the *i*th draw of the first-hour rating test, gal (L) or, if the mass of water removed is being measured,

$$V^*_{del,i} = \frac{M^*_{del,i}}{\rho_{del,i}}$$

Where:

$M^*_{del,i}$ = the mass of water removed during the *i*th draw of the first-hour rating test, lb (kg).

$\rho_{del,i}$ = the density of water removed, evaluated at the average outlet water temperature measured during the *i*th draw of the first-hour rating test, ($\overline{T}^*_{del,i}$), lb/gal (kg/L).

or, if the volume of the water entering the water heater is being measured,

$$V^*_{del,i} = V^*_{in,i}\frac{\rho_{in,i}}{\rho_{del,i}}$$

Where:

$V^*_{in,i}$ = the volume of water entering the water heater during the *i*th draw of the first-hour rating test, gal (L).

$\rho_{in,i}$ = the density of water entering the water heater, evaluated at the average inlet water temperature measured during the *i*th draw of the first-hour rating test, ($\overline{T}^*_{in,i}$), lb/gal (kg/L).

or, if the mass of water entering the water heater is being measured,

$$V^*_{del,i} = \frac{M^*_{in,i}}{\rho_{del,i}}$$

Where:

$M^*_{in,i}$ = the mass of water entering the water heater during the *i*th draw of the first-hour rating test, lb (kg).

For the case in which a draw is not in progress at one hour from the start of the test and a final draw is imposed at the elapsed time of one hour, the first-hour rating shall be calculated using,

$$F_{hr} = V^*_{del,n}\left(\frac{\bar{T}^*_{del,n} - \bar{T}^*_{min,n-1}}{\bar{T}^*_{del,n-1} - \bar{T}^*_{min,n-1}}\right) + \sum_{i=1}^{n-1} V^*_{del,i}$$

where n and $V^*_{del,i}$ are the same quantities as defined above, and

$V^*_{del,n}$ = the volume of water removed during the *n*th (final) draw of the first-hour rating test, gal (L).

$\bar{T}^*_{del,n-1}$ = the average water outlet temperature measured during the *(n−1)*th draw of the first-hour rating test, °F (°C).

$\bar{T}^*_{del,n}$ = the average water outlet temperature measured during the *n*th (final) draw of the first-hour rating test, °F (°C).

$T^*_{min,n-1}$ = the minimum water outlet temperature measured during the *(n−1)*th draw of the first-hour rating test, °F (°C).

6.2 *Maximum GPM (L/min) Rating Computation.* Compute the maximum GPM (L/min) rating, F_{max}, as:

$$F_{max} = \frac{V_{del,10m}(\bar{T}_{del} - \bar{T}_{in})}{10(125°F - 58°F)}$$

or,

$$F_{max} = \frac{V_{del,10m}(\bar{T}_{del} - \bar{T}_{in})}{10(51.7°C - 14.4°C)}$$

Where:

$V_{del,10m}$ = the volume of water removed during the maximum GPM (L/min) rating test, gal (L).

$\bar{T}_{del}$ = the average delivery temperature, °F (°C).

$\bar{T}_{in}$ = the average inlet temperature, °F (°C).

10 = the number of minutes in the maximum GPM (L/min) rating test, min.

or, if the mass of water removed is measured,

$$V_{del,10m} = \frac{M_{del,10m}}{\rho_{del}}$$

Where:

$M_{del,10m}$ = the mass of water removed during the maximum GPM (L/min) rating test, lb (kg).

ρ_{del} = the density of water removed, evaluated at the average delivery water temperature of the maximum GPM (L/min) rating test ($\overline{T}_{del}$), lb/gal (kg/L).

or, if the volume of water entering the water heater is measured,

$$V_{del,10m} = V_{in,10m}\frac{\rho_{in}}{\rho_{del}}$$

Where:

$V_{in,10m}$ = the volume of water entering the water heater during the maximum GPM (L/min) rating test, gal (L).

ρ_{in} = the density of water entering the water heater, evaluated at the average inlet water temperature of the maximum GPM (L/min) rating test ($\overline{T}_{del}$), lb/gal (kg/L).

or, if the mass of water entering the water heater is measured,

$$V_{del,10m} = \frac{M_{in,10m}}{\rho_{del}}$$

Where:

$M_{in,10m}$ = the mass of water entering the water heater during the maximum GPM (L/min) rating test, lb (kg).

6.3 *Computations for Water Heaters with a Rated Storage Volume Greater Than or Equal to 2 Gallons and Circulating Water Heaters.*

6.3.1 *Storage Tank Capacity.* The storage tank capacity, V_{st}, is computed as follows:

$$V_{st} = \frac{\left(W_f - W_t\right)}{\rho}$$

Where:

V_{st} = the storage capacity of the water heater, or, for circulating water heaters, the storage capacity of the separate storage tank used in accordance with section 4.10, gal (L).

W_f = the weight of the storage tank when completely filled with water, lb (kg).

W_t = the (tare) weight of the storage tank when completely empty, lb (kg).

ρ = the density of water used to fill the tank measured at the temperature of the water, lb/gal (kg/L).

6.3.1.1 *Effective Storage Volume.* The effective storage tank capacity, V_{eff}, is computed as follows:

For water heaters requiring a separate storage tank, V_{eff} is the storage tank capacity of the separate storage tank as determined per section 6.3.1.

For all other water heaters:

$V_{eff} = k_V V_{st}$

Where:

V_{st} = as defined in section 6.3.1 and

k_V = a dimensionless volume scaling factor determined as follows:

If the first recovery period extends into the second draw of the 24-hour simulated use test, and

If $\overline{T}_0 > (\overline{T}_{del,1} + 5\ °F)$ and $\overline{T}_0 \geq 130\ °F$,

(if $\overline{T}_0 > (\overline{T}_{del,1} + 2.8\ °C)$ and $\overline{T}_0 \geq 54.4\ °C$),

$$k_V = \frac{\rho(\overline{T}_0)\times C_p(\overline{T}_0)\times(\overline{T}_0 - 67.5°F)}{\rho(125°F)\times C_p(125°F)\times(125°F - 67.5°F)}$$

$$(k_V = \frac{\rho(\bar{T}_0)\times C_p(\bar{T}_0)\times(\bar{T}_0 - 19.7℃)}{\rho(51.7℃)\times C_p(51.7℃)\times(51.7℃ - 19.7℃)});$$

If the first recovery period does not extend into the second draw of the 24-hour simulated use test, and

If $\overline{T}_{max,1} > (\overline{T}_{del,2} + 5\ °F)$ and $\overline{T}_{max,1} \geq 130\ °F$,

(if $\overline{T}_{max,1} > (\overline{T}_{del,2} + 2.8\ °C)$ and $\overline{T}_{max,1} \geq 54.4\ °C$),

$$k_V = \frac{\rho(\overline{T}_{max,1})\times C_p(\overline{T}_{max,1})\times(\overline{T}_{max,1} - 67.5°F)}{\rho(125°F)\times C_p(125°F)\times(125°F - 67.5°F)}$$

$$(k_V = \frac{\rho(\bar{T}_{max,1})\times C_p(\bar{T}_{max,1})\times(\bar{T}_{max,1} - 19.7℃)}{\rho(51.7℃)\times C_p(51.7℃)\times(51.7℃ - 19.7℃)});$$

Otherwise, $k_V = 1$.

Where:

$\overline{T}_0$= the mean tank temperature at the beginning of the 24-hour simulated-use test, °F(°C).

$\overline{T}_{del,1}$= the average outlet water temperature during the first draw of the 24-hour simulated-use test, °F(°C).

$\rho(\overline{T}_0)$ = the density of the stored hot water evaluated at the mean tank temperature at the beginning of the 24-hour simulated-use test ($\overline{T}_0$), lb/gal (kg/L).

$C_p(\overline{T}_0)$ = the specific heat of the stored hot water, evaluated at $\overline{T}_0$, Btu/(lb· °F) (kJ/(kg· °C)).

$\overline{T}_{max,1}$ = the maximum measured mean tank temperature after cut-out following the first draw of the 24-hour simulated-use test, °F(°C).

$\overline{T}_{del,2}$= the average outlet water temperature during the second draw of the 24-hour simulated-use test, °F(°C).

$\rho(\overline{T}_{max,1})$ = the density of the stored hot water evaluated at the maximum measured mean tank temperature after cut-out following the first draw of the 24-hour simulated-use test ($\overline{T}_{max,1}$), lb/gal (kg/L).

$C_p(\overline{T}_{max,1})$ = the specific heat of the stored hot water, evaluated at $\overline{T}_{max,1}$, Btu/(lb· °F) (kJ/(kg· °C)).

ρ(125 °F) = the density of the stored hot water at 125 °F, lb/gal (kg/L).

C_p(125 °F) = the specific heat of the stored hot water at 125 °F, Btu/(lb· °F) (kJ/(kg· °C)).

125 °F (51.7 °C) = the nominal maximum mean tank temperature for a storage tank that does not utilize a mixing valve to achieve a 125 °F delivery temperature.

67.5 °F (19.7 °C) = the nominal average ambient air temperature.

6.3.2 *Mass of Water Removed.* Determine the mass of water removed during each draw of the 24-hour simulated-use test ($M_{del,i}$) as:

If the mass of water removed is measured, use the measured value, or, if the volume of water removed is being measured,

$$M_{del,i} = V_{del,i} * P_{del,i}$$

Where:

$V_{del,i}$ = volume of water removed during the *i*th draw of the 24-hour simulated-use test, gal (L).

$\rho_{del,i}$ = density of the water removed, evaluated at the average outlet water temperature measured during the *i*th draw of the 24-hour simulated-use test, ($\overline{T}_{del,i}$), lb/gal (kg/L).

or, if the volume of water entering the water heater is measured,

$$M_{del,i} = V_{in,i} * \rho_{in,i}$$

Where:

$V_{in,i}$ = volume of water entering the water heater during draw *i*th draw of the 24-hour simulated-use test, gal (L).

$\rho_{in,i}$ = density of the water entering the water heater, evaluated at the average inlet water temperature measured during the *i*th draw of the 24-hour simulated-use test, ($\overline{T}_{in,i}$), lb/gal (kg/L).

or, if the mass of water entering the water heater is measured,

$$M_{del,i} = M_{in,i}$$

Where:

$M_{in,i}$ = mass of water entering the water heater during draw *i*th draw of the 24-hour simulated-use test, lb (kg).

6.3.3 *Recovery Efficiency.* The recovery efficiency for gas, oil, and heat pump water heaters with a rated storage volume greater than or equal to 2 gallons, η_r, is computed as:

$$\eta_r = \frac{V_{st}\,\rho_1\,C_{p1}\left(\bar{T}_{max,1} - \bar{T}_0\right)}{Q_r} + \sum_{i=1}^{N_r} \frac{M_{del,i}\,C_{pi}\left(\bar{T}_{del,i} - \bar{T}_{in,i}\right)}{Q_r}$$

Where:

V_{st} = as defined in section 6.3.1 of this appendix.

ρ_1 = density of stored hot water evaluated at $(\overline{T}_{max,1} + \overline{T}_0)/2$, lb/gal (kg/L).

C_{p1} = specific heat of the stored hot water, evaluated at $(\overline{T}_{max,1} + \overline{T}_0)/2$, Btu/(lb· °F) (kJ/(kg· °C).

$\overline{T}_{max,1}$ = maximum mean tank temperature recorded after the first recovery period as defined in section 5.4.2 of this appendix, °F (°C).

$\overline{T}_0$ = mean tank temperature recorded at the beginning of the 24-hour simulated-use test as determined in section 5.4.2 of this appendix, °F (°C).

Q_r = the total energy used by the water heater during the first recovery period as defined in section 5.4.2 of this appendix, including auxiliary energy such as pilot lights, pumps, fans, *etc.*, Btu (kJ). (Electrical auxiliary energy shall be converted to thermal energy using the following conversion: 1 kWh = 3412 Btu).

N_r = number of draws from the start of the 24-hour simulated-use test to the end to the first recovery period as described in section 5.4.2.

$M_{del,i}$ = mass of water removed as calculated in section 6.3.2 of this appendix during the *i*th draw of the first recovery period as described in section 5.4.2, lb (kg).

C_{pi} = specific heat of the withdrawn water during the *i*th draw of the first recovery period as described in section 5.4.2, evaluated at $(\overline{T}_{del,i} + \overline{T}_{in,i})/2$, Btu/(lb· °F) (kJ/(kg· °C)).

$\overline{T}_{del,i}$ = average water outlet temperature measured during the *i*th draw of the first recovery period as described in section 5.4.2, °F (°C).

$\overline{T}_{in,i}$ = average water inlet temperature measured during the *i*th draw of the first recovery period as described in section 5.4.2, °F (°C).

The recovery efficiency for electric water heaters with immersed heating elements, not including heat pump water heaters with immersed heating elements, is assumed to be 98 percent.

6.3.4 *Hourly Standby Losses.* The energy consumed as part of the standby loss test of the 24-hour simulated-use test, $Q_{stby,}$ is computed as:

$$Q_{stby} = Q_{su,f} - Q_{su,o}$$

Where:

$Q_{su,0}$ = cumulative energy consumption, including all fossil fuel and electrical energy use, of the water heater from the start of the 24-hour simulated-use test to the start of the standby period as determined in section 5.4.2 of this appendix, Btu (kJ).

$Q_{su,f}$ = cumulative energy consumption, including all fossil fuel and electrical energy use, of the water heater from the start of the 24-hour simulated-use test to the end of the standby period as determined in section 5.4.2 of this appendix, Btu (kJ).

The hourly standby energy losses are computed as:

$$Q_{hr} = \frac{Q_{stby} - \dfrac{V_{st}\,\rho\,C_p\left(\bar{T}_{su,f} - \bar{T}_{su.0}\right)}{\eta_r}}{\tau_{stby,1}}$$

Where:

Q_{hr} = the hourly standby energy losses of the water heater, Btu/h (kJ/h).

V_{st} = as defined in section 6.3.1 of this appendix.

ρ = density of the stored hot water, evaluated at $(\overline{T}_{su,f} + \overline{T}_{su,0})/2$, lb/gal (kg/L).

C_p = specific heat of the stored water, evaluated at $(\overline{T}_{su,f} + \overline{T}_{su,0})/2$, Btu/(lb· °F), (kJ/(kg·K)).

$\overline{T}_{su,f}$ = the mean tank temperature measured at the end of the standby period as determined in section 5.4.2 of this appendix, °F (°C).

$\overline{T}_{su,0}$ = the maximum mean tank temperature measured at the beginning of the standby period as determined in section 5.4.2 of this appendix, °F (°C).

η_r = as defined in section 6.3.3 of this appendix.

$\tau_{stby,1}$ = elapsed time between the start and end of the standby period as determined in section 5.4.2 of this appendix, h.

The standby heat loss coefficient for the tank is computed as:

$$UA = \frac{Q_{hr}}{\overline{T}_{t,stby,1} - \overline{T}_{a,stby,1}}$$

Where:

UA = standby heat loss coefficient of the storage tank, Btu/(h· °F), (kJ/(h· °C).

$\overline{T}_{t,stby,1}$ = overall average mean tank temperature between the start and end of the standby period as determined in section 5.4.2 of this appendix, °F (°C).

$\overline{T}_{a,stby,1}$ = overall average ambient temperature between the start and end of the standby period as determined in section 5.4.2 of this appendix, °F (°C).

6.3.5 *Daily Water Heating Energy Consumption*. The total energy used by the water heater during the 24-hour simulated-use test (Q) is as measured in section 5.4.2 of this appendix, or,

$Q = Q_f + Q_e$ = total energy used by the water heater during the 24-hour simulated-use test, including auxiliary energy such as pilot lights, pumps, fans, etc., Btu (kJ).

Q_f = total fossil fuel energy used by the water heater during the 24-hour simulated-use test, Btu (kJ).

Q_e = total electrical energy used during the 24-hour simulated-use test, Btu (kJ). (Electrical energy shall be converted to thermal energy using the following conversion: 1kWh = 3412 Btu.)

The daily water heating energy consumption, Q_d, is computed as:

$$Q_d = Q - \frac{V_{st}\,\rho\,C_p\,(\overline{T}_{24} - \overline{T}_0)}{\eta_r}$$

Where:

V_{st} = as defined in section 6.3.1 of this appendix.

ρ = density of the stored hot water, evaluated at $(\overline{T}_{24} + \overline{T}_0)/2$, lb/gal (kg/L).

C_p = specific heat of the stored water, evaluated at $(\overline{T}_{24} + \overline{T}_0)/2$, Btu/(lb· °F), (kJ/(kg·K)).

$\overline{T}_{24}$ = mean tank temperature at the end of the 24-hour simulated-use test as determined in section 5.4.2 of this appendix, °F (°C).

$\overline{T}_0$ = mean tank temperature recorded at the beginning of the 24-hour simulated-use test as determined in section 5.4.2 of this appendix, °F (°C).

η_r = as defined in section 6.3.3 of this appendix.

6.3.6 *Adjusted Daily Water Heating Energy Consumption*. The adjusted daily water heating energy consumption, $Q_{da,}$ takes into account that the ambient temperature may differ from the nominal value of 67.5 °F (19.7 °C) due to the allowable variation in surrounding ambient temperature of 65 °F (18.3 °C) to 70 °C (21.1 °C). The adjusted daily water heating energy consumption is computed as:

$Q_{da} = Q_d - (67.5\ °C - \overline{T}_{a,stby,2})\ UA\ \tau_{stby,2}$

or,

$Q_{da} = Q_d - (19.7\ °C - \overline{T}_{a,stby,2})\ UA\ \tau_{stby,2}$

Where:

Q_{da} = the adjusted daily water heating energy consumption, Btu (kJ).

Q_d = as defined in section 6.3.4 of this appendix.

$\overline{T}_{a,stby,2}$ = the average ambient temperature during the total standby portion, $\tau_{stby,2}$, of the 24-hour simulated-use test, °F (°C).

UA = as defined in section 6.3.4 of this appendix.

$\tau_{stby,2}$ = the number of hours during the 24-hour simulated-use test when water is not being withdrawn from the water heater.

A modification is also needed to take into account that the temperature difference between the outlet water temperature and supply water temperature may not be equivalent to the nominal value of 67 °F (125 °F–58 °F) or 37.3 °C (51.7 °C–14.4 °C). The following equations adjust the experimental data to a nominal 67 °F (37.3 °C) temperature rise.

The energy used to heat water, Btu/day (kJ/day), may be computed as:

$$Q_{HW} = \sum_{i=1}^{N} \frac{M_{del,i}\, C_{pi}\left(\bar{T}_{del,i} - \bar{T}_{in,i}\right)}{\eta_r}$$

Where:

N = total number of draws in the 24-hour simulated-use test.

$M_{del,i}$ = the mass of water removed during the *i*th draw (i = 1 to N) as calculated in section 6.3.2 of this appendix, lb (kg).

C_{pi} = the specific heat of the water withdrawn during the *i*th draw of the 24-hour simulated-use test, evaluated at ($\overline{T}_{del,i}$ + $\overline{T}_{in,i}$)/2, Btu/(lb· °F) (kJ/(kg· °C)).

$\overline{T}_{del,i}$ = the average water outlet temperature measured during the *i*th draw (i = 1 to N), °F (°C).

$\overline{T}_{in,i}$ = the average water inlet temperature measured during the *i*th draw (i = 1 to N), °F (°C).

η_r = as defined in section 6.3.3 of this appendix.

The energy required to heat the same quantity of water over a 67 °F (37.3 °C) temperature rise, Btu/day (kJ/day), is:

$$Q_{HW,67°F} = \sum_{i=1}^{N} \frac{M_{del,i}\, C_{pi}(125°F - 58°F)}{\eta_r}$$

or,

$$Q_{HW,37.3°C} = \sum_{i=1}^{N} \frac{M_{del,i}\, C_{pi}(51.7°C - 14.4°C)}{\eta_r}$$

The difference between these two values is:

$Q_{HWD} = Q_{HW,67.\ °F} - Q_{HW}$

or,

$Q_{HWD} = Q_{HW,37.3\ °C} - Q_{HW}$

This difference (Q_{HWD}) must be added to the adjusted daily water heating energy consumption value. Thus, the daily energy consumption value, which takes into account that the ambient temperature may not be 67.5 °F (19.7 °C) and that the temperature rise across the storage tank may not be 67 °F (37.3 °C) is:

$Q_{dm} = Q_{da} - Q_{HWD}$

6.3.7 *Estimated Mean Tank Temperature for Water Heaters with Rated Storage Volumes Greater Than or Equal to 2 Gallons.* If testing is conducted in accordance with section 5.4.2.2 of this appendix, calculate the mean tank temperature immediately prior to the internal tank temperature determination draw using the following equation:

$$\bar{T}_{st} = T_p - \frac{v_{out,p}}{V_{st}} \times \tau_p(\bar{T}_{in,p} - \bar{T}_{out,p})$$

Where:

$\overline{T}_{st}$ = the estimated average internal storage tank temperature, °F (°C).

T_p = the average of the inlet and the outlet water temperatures at the end of the period defined by τ_p, °F (°C).

$v_{out,p}$ = the average flow rate during the period, gal/min (L/min).

V_{st} = the rated storage volume of the water heater, gal (L).

τ_p = the number of minutes in the duration of the period, determined by the length of

time taken for the outlet water temperature to be within 2 °F of the inlet water temperature for 15 consecutive seconds and including the 15-second stabilization period.

$\overline{T}_{in,p}$ = the average of the inlet water temperatures during the period, °F (°C).

$\overline{T}_{out,p}$ = the average of the outlet water temperatures during the period, °F (°C).

6.3.8 *Uniform Energy Factor*. The uniform energy factor, UEF, is computed as:

$$UEF = \sum_{i=1}^{N} \frac{M_{del,i}\, C_{pi}\, (125°F - 58°F)}{Q_{dm}}$$

or,

$$UEF = \sum_{i=1}^{N} \frac{M_{del,i}\, C_{pi}\, (51.7°C - 14.4°C)}{Q_{dm}}$$

Where:

N = total number of draws in the 24-hour simulated-use test.

Q_{dm} = the modified daily water heating energy consumption as computed in accordance with section 6.3.6 of this appendix, Btu (kJ).

$M_{del,i}$ = the mass of water removed during the *i*th draw (i = 1 to N) as calculated in section 6.3.2 of this appendix, lb (kg).

C_{pi} = the specific heat of the water withdrawn during the *i*th draw of the 24-hour simulated-use test, evaluated at (125 °F + 58 °F)/2 = 91.5 °F ((51.7 °C + 14.4 °C)/2 = 33 °C), Btu/(lb· °F) (kJ/(kg· °C)).

6.3.9 *Annual Energy Consumption*. The annual energy consumption for water heaters with rated storage volumes greater than or equal to 2 gallons is computed as:

$$E_{annual} = 365 * \frac{(V)(\rho)(C_p)(67)}{UEF}$$

Where:

UEF = the uniform energy factor as computed in accordance with section 6.3.88 of this appendix.

365 = the number of days in a year.

V = the volume of hot water drawn during the applicable draw pattern, gallons.

= 10 for the very-small-usage draw pattern.

= 38 for the low-usage draw pattern.

= 55 for the medium-usage draw pattern.

= 84 for high-usage draw pattern.

ρ = 8.24 lb/gallon, the density of water at 125 °F.

C_p = 1.00 Btu/(lb °F), the specific heat of water at 91.5 °F.

67 = the nominal temperature difference between inlet and outlet water

6.3.10 *Annual Electrical Energy Consumption*. The annual electrical energy consumption in kilowatt-hours for water heaters with rated storage volumes greater than or equal to 2 gallons, $E_{annual,e,}$ is computed as:

$$E_{annual,e} = \frac{E_{annual}}{3412} * \left(\frac{Q_e}{Q}\right)$$

Where:

E_{annual} = the annual energy consumption as determined in accordance with section 6.3.99 of this appendix, Btu (kJ).

Q_e = the daily electrical energy consumption as defined in section 6.3.5 of this appendix, Btu (kJ).

Q = total energy used by the water heater during the 24-hour simulated-use test in accordance with section 6.3.5 of this appendix, Btu (kJ).

3412 = conversion factor from Btu to kWh.

6.3.11 *Annual Fossil Fuel Energy Consumption.* The annual fossil fuel energy consumption for water heaters with rated storage volumes greater than or equal to 2 gallons, $E_{annual,f,}$ is computed as:

$E_{annual,f} = E_{annual} - (E_{annual,e} * 3412)$

Where:

E_{annual} = the annual energy consumption as determined in accordance with section 6.3.9 of this appendix, Btu (kJ).

$E_{annual,e}$ = the annual electrical energy consumption as determined in accordance with section 6.3.10 of this appendix, kWh.

3412 = conversion factor from kWh to Btu.

6.4 *Computations for Water Heaters with a Rated Storage Volume Less Than 2 Gallons.*

6.4.1 *Mass of Water Removed*

Calculate the mass of water removed using the calculations in section 6.3.2 of this appendix.

6.4.2 *Recovery Efficiency.* The recovery efficiency, $\eta_{r,}$ is computed as:

$$\eta_r = \frac{M_1 \, C_{p1} \left(\overline{T}_{del,1} - \overline{T}_{in,1}\right)}{Q_r}$$

Where:

M_1 = mass of water removed during the first draw of the 24-hour simulated-use test, lb (kg).

C_{p1} = specific heat of the withdrawn water during the first draw of the 24-hour simulated-use test, evaluated at ($\overline{T}_{del,1}$ + $\overline{T}_{in,1}$)/2, Btu/(lb· °F) (kJ/(kg· °C)).

$\overline{T}_{del,1}$ = average water outlet temperature measured during the first draw of the 24-hour simulated-use test, °F (°C).

$\overline{T}_{in,1}$ = average water inlet temperature measured during the first draw of the 24-hour simulated-use test, °F (°C).

Q_r = the total energy used by the water heater during the first recovery period as defined in section 5.4.3 of this appendix, including auxiliary energy such as pilot lights, pumps, fans, etc., Btu (kJ). (Electrical auxiliary energy shall be converted to thermal energy using the following conversion: 1 kWh = 3412 Btu.)

6.4.3 *Daily Water Heating Energy Consumption.* The daily water heating energy consumption, $Q_{d,}$ is computed as:

$Q_d = Q$

Where:

$Q = Q_f + Q_e$ = the energy used by the water heater during the 24-hour simulated-use test.

Q_f = total fossil fuel energy used by the water heater during the 24-hour simulated-use test, Btu (kJ).

Q_e = total electrical energy used during the 24-hour simulated-use test, Btu (kJ). (Electrical auxiliary energy shall be converted to thermal energy using the following conversion: 1 kWh = 3412 Btu.)

A modification is needed to take into account that the temperature difference between the outlet water temperature and supply water temperature may not be equivalent to the nominal value of 67 °F (125 °F − 58 °F) or 37.3 °C (51.7 °C − 14.4 °C). The following equations adjust the experimental data to a nominal 67 °F (37.3 °C) temperature rise.

The energy used to heat water may be computed as:

$$Q_{HW} = \sum_{i=1}^{N} \frac{M_{del,i} \, C_{pi} \left(\overline{T}_{del,i} - \overline{T}_{in,i}\right)}{\eta_r}$$

Where:

N = total number of draws in the 24-hour simulated-use test.

$M_{del,i}$ = the mass of water removed during the *i*th draw (i = 1 to N) as calculated in section 6.4.1 of this appendix, lb (kg).

C_{pi} = the specific heat of the water withdrawn during the *i*th draw of the 24-hour simulated-use test, evaluated at ($\overline{T}_{del,i}$ + $\overline{T}_{in,i}$)/2, Btu/(lb· °F) (kJ/(kg· °C)).

$\overline{T}_{del,i}$ = the average water outlet temperature measured during the *i*th draw (i = 1 to N), °F (°C).

$\overline{T}_{in,i}$ = the average water inlet temperature measured during the *i*th draw (i = 1 to N), °F (°C).

η_r = as defined in section 6.4.2 of this appendix.

The energy required to heat the same quantity of water over a 67 °F (37.3 °C) temperature rise is:

$$Q_{HW,67°F} = \sum_{i=1}^{N} \frac{M_{del,i}\, C_{pi}(125°F - 58°F)}{\eta_r}$$

or,

$$Q_{HW,37.3°C} = \sum_{i=1}^{N} \frac{M_{del,i}\, C_{pi}(51.7°C - 14.4°C)}{\eta_r}$$

Where:

N = total number of draws in the 24-hour simulated-use test.

$M_{del,i}$ = the mass of water removed during the *i*th draw (i = 1 to N) as calculated in section 6.4.1 of this appendix, lb (kg).

C_{pi} = the specific heat of the water withdrawn during the *i*th draw of the 24-hour simulated-use test, evaluated at ($\overline{T}_{del,i}$ + $\overline{T}_{in,i}$)/2, Btu/(lb· °F) (kJ/(kg· °C)).

η_r = as defined in section 6.4.2 of this appendix.

The difference between these two values is:

$Q_{HWD} = Q_{HW,67\ °F} - Q_{HW}$

or,

$Q_{HWD} = Q_{HW,37.3\ °C} - Q_{HW}$

This difference (Q_{HWD}) must be added to the daily water heating energy consumption value. Thus, the daily energy consumption value, which takes into account that the temperature rise across the water heater may not be 67 °F (37.3 °C), is:

$Q_{dm} = Q_{da} + Q_{HWD}$

6.4.4 *Uniform Energy Factor*. The uniform energy factor, UEF, is computed as:

$$UEF = \sum_{i=1}^{N} \frac{M_{del,i}\, C_{pi}\, (125°F - 58°F)}{Q_{dm}}$$

or,

$$UEF = \sum_{i=1}^{N} \frac{M_{del,i}\, C_{pi}\, (51.7°C - 14.4°C)}{Q_{dm}}$$

Where:

N = total number of draws in the 24-hour simulated-use test.

Q_{dm} = the modified daily water heating energy consumption as computed in accordance with section 6.4.3 of this appendix, Btu (kJ).

$M_{del,i}$ = the mass of water removed during the *i*th draw (i = 1 to N) as calculated in section 6.4.1 of this appendix, lb (kg).

C_{pi} = the specific heat of the water withdrawn during the *i*th draw of the 24-hour simulated-use test, evaluated at (125 °F + 58 °F)/2 = 91.5 °F ((51.7 °C + 14.4 °C)/2 = 33.1 °C), Btu/(lb· °F) (kJ/(kg· °C)).

6.4.5 *Annual Energy Consumption*. The annual energy consumption for water heaters with rated storage volumes less than 2 gallons, $E_{annual,}$ is computed as:

$$E_{annual} = 365 * \frac{(V)(\rho)(C_p)(67)}{UEF}$$

Where:

UEF = the uniform energy factor as computed in accordance with section 6.4.4 of this appendix.

365 = the number of days in a year.

V = the volume of hot water drawn during the applicable draw pattern, gallons.

= 10 for the very-small-usage draw pattern.

= 38 for the low-usage draw pattern.

= 55 for the medium-usage draw pattern.

= 84 for high-usage draw pattern.

ρ = 8.24 lb/gallon, the density of water at 125 °F.

C_p = 1.00 Btu/(lb °F), the specific heat of water at 91.5 °F.

67 = the nominal temperature difference between inlet and outlet water.

6.4.6 *Annual Electrical Energy Consumption.* The annual electrical energy consumption in kilowatt-hours for water heaters with rated storage volumes less than 2 gallons, $E_{annual,e,}$ is computed as:

$$E_{annual,e} = \frac{E_{annual}}{3412} * \left(\frac{Q_e}{Q}\right)$$

Where:

Q_e = the daily electrical energy consumption as defined in section 6.4.3 of this appendix, Btu (kJ).

E_{annual} = the annual energy consumption as determined in accordance with section 6.4.5 of this appendix, Btu (kJ).

Q = total energy used by the water heater during the 24-hour simulated-use test in accordance with section 6.4.3 of this appendix, Btu (kJ).

Q_{dm} = the modified daily water heating energy consumption as computed in accordance with section 6.4.3 of this appendix, Btu (kJ).

3412 = conversion factor from Btu to kWh.

6.4.7 *Annual Fossil Fuel Energy Consumption.* The annual fossil fuel energy consumption for water heaters with rated storage volumes less than 2 gallons, $E_{annual,f,}$ is computed as:

Where:

E_{annual} = the annual energy consumption as defined in section 6.4.5 of this appendix, Btu (kJ).

$E_{annual,e}$ = the annual electrical energy consumption as defined in section 6.4.6 of this appendix, kWh.

3412 = conversion factor from kWh to Btu.

6.5 *Energy Efficiency at Optional Test Conditions.* If testing is conducted at optional test conditions in accordance with section 5.6 of this appendix, calculate the energy efficiency at the test condition, $E_{X,}$ using the formulas in sections 6.3 or 6.4 of this appendix (as applicable), except substituting the applicable ambient temperature and supply water temperature used for testing (as specified in section 2.8 of this appendix) for the nominal ambient temperature and supply water temperature conditions used in the equations for determining UEF (*i.e.,* 67.5 °F and 58 °F).

7. Test Set-Up Diagrams




Figure 1.




Figure 2.




Figure 3.




Figure 4.




Figure 5.




Figure 6.




Figure 7a.




Figure 7b.

[88 FR 40473, June 21, 2023, as amended at 89 FR 37943, May 6, 2204]

APPENDIX F TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF ROOM AIR CONDITIONERS

NOTE: On or after September 27, 2021, any representations made with respect to the energy use or efficiency of room air conditioners must be made in accordance with the results of testing pursuant to this appendix.

Prior to September 27, 2021, manufacturers must either test room air conditioners in accordance with this appendix, or the previous version of this appendix as it appeared in the Code of Federal Regulations on January 1, 2020. DOE notes that, because representations made on or after September 27, 2021 must be made in accordance with this appendix, manufacturers may wish to begin using this test procedure immediately.

0. Incorporation by Reference

DOE incorporated by reference the entire standard for AHAM RAC–1, ANSI/ASHRAE 16, ANSI/ASHRAE 41.1, ASHRAE 41.2–1987 (RA 1992), ASHRAE 41.3–2014, ASHRAE 41.6–2014, ASHRAE 41.11–2014 and IEC 62301 in §430.3. However, only enumerated provisions of AHAM RAC–1 and ANSI/ASHRAE 16 apply to this appendix, as follows:

(1) ANSI/AHAM RAC–1:

(i) Section 4—Testing Conditions, Section 4.1—General

(ii) Section 5—Standard Measurement Test, Section 5.2—Standard Test Conditions: 5.2.1.1

(iii) Section 6—Tests and Measurements, Section 6.1—Cooling capacity

(iv) Section 6— Tests and Measurements, Section 6.2—Electrical Input

(2) ANSI/ASHRAE 16:

(i) Section 3—Definitions

(ii) Section 5—Instruments

(iii) Section 6—Apparatus, Section 6.1—Calorimeters, Sections 6.1.1–6.1.1., 6.1.1.3a, 6.1.1.4–6.1.4, including Table 1

(iv) Section 7—Methods of Testing, Section 7.1—Standard Test Methods, Section 7.1a, 7.1.1a

(v) Section 8—Test Procedures, Section 8.1—General

(vi) Section 8—Test Procedures, Section 8.2—Test Room Requirements

(viii) Section 8—Test Procedures, Section 8.3—Air Conditioner Break-In

(ix) Section 8—Test Procedures, Section 8.4—Air Conditioner Installation

(x) Section 8 —Test Procedures, Section 8.5—Cooling Capacity Test

(xi) Section 9—Data To Be Recorded, Section 9.1

(xii) Section 10—Measurement Uncertainty

(xiii) Normative Appendix A Cooling Capacity Calculations—Calorimeter Test Indoor and Calorimeter Test Outdoor

If there is any conflict between any industry standard(s) and this appendix, follow the language of the test procedure in this appendix, disregarding the conflicting industry standard language.

Scope

This appendix contains the test requirements to measure the energy performance of a room air conditioner.

2. Definitions

2.1 ''Active mode'' means a mode in which the room air conditioner is connected to a mains power source, has been activated and is performing any of the following functions: Cooling or heating the conditioned space, or circulating air through activation of its fan or blower, with or without energizing active air-cleaning components or devices such as ultra-violet (UV) radiation, electrostatic filters, ozone generators, or other air-cleaning devices.

2.2 ''ANSI/AHAM RAC–1'' means the test standard published jointly by the American National Standards Institute and the Association of Home Appliance Manufacturers, titled ''Energy Measurement Test Procedure for Room Air Conditioners,'' Standard RAC–1–2020 (incorporated by reference; see §430.3).

2.3 ''ANSI/ASHRAE 16'' means the test standard published jointly by the American National Standards Institute and the American Society of Heating, Refrigerating, and Air-Conditioning Engineers titled ''Method of Testing for Rating Room Air Conditioners and Packaged Terminal Air Conditioners,'' Standard 16–2016 (incorporated by reference; see §430.3).

2.4 ''ANSI/ASHRAE 41.1'' means the test standard published jointly by the American National Standards Institute and the American Society of Heating, Refrigerating, and Air-Conditioning Engineers titled ''Standard Method for Temperature Measurement,'' Standard 41.1–2013 (incorporated by reference; see §430.3).

2.5 ''ASHRAE 41.2–1987 (RA 1992)'' means the test standard published jointly by the American National Standards Institute and the American Society of Heating, Refrigerating, and Air-Conditioning Engineers titled ''Standard Methods for Laboratory Airflow Measurement,'' Standard 41.2–1987 (RA 1992) (incorporated by reference; see §430.3).

2.6 ''ASHRAE 41.3–2014'' means the test standard published jointly by the American National Standards Institute and the American Society of Heating, Refrigerating, and Air-Conditioning Engineers titled ''Standard Methods for Pressure Measurement,'' Standard 41.3–2014 (incorporated by reference; see §430.3).

2.7 ''ASHRAE 41.6–2014'' means the test standard published jointly by the American National Standards Institute and the American Society of Heating, Refrigerating, and Air-Conditioning Engineers titled ''Standard Method for Humidity Measurement,'' Standard 41.6–2014 (incorporated by reference; see §430.3).

2.8 ''ASHRAE 41.11–2014'' means the test standard published jointly by the American National Standards Institute and the American Society of Heating, Refrigerating, and Air-Conditioning Engineers titled ''Standard Methods for Power Measurement,'' Standard 41.11–2014 (incorporated by reference; see §430.3).

2.9 ''Combined energy efficiency ratio'' means the energy efficiency of a room air conditioner in British thermal units per watt-hour (Btu/Wh) and determined in section 5.2.2 of this appendix for single-speed room air conditioners and section 5.3.12 of this appendix for variable-speed room air conditioners.

2.10 ''Cooling capacity'' means the amount of cooling, in British thermal units per hour (Btu/h), provided to a conditioned space, measured under the specified conditions and determined in section 4.1 of this appendix.

2.11 ''Cooling mode'' means an active mode in which a room air conditioner has activated the main cooling function according to the thermostat or temperature sensor signal or switch (including remote control).

2.12 ''Full compressor speed (full)'' means the compressor speed at which the unit operates at full load test conditions, when using user settings with a unit thermostat setpoint of 75 °F to achieve maximum cooling capacity, according to the instructions in ANSI/ASHRAE Standard 16–2016.

2.13 ''IEC 62301'' means the test standard published by the International Electrotechnical Commission, titled ''Household electrical appliances—Measurement of standby power,'' Publication 62301 (Edition 2.0 2011–01), (incorporated by reference; see §430.3).

2.14 ''Inactive mode'' means a standby mode that facilitates the activation of active mode by remote switch (including remote control) or internal sensor or which provides continuous status display.

2.15 ''Intermediate compressor speed (intermediate)'' means the compressor speed higher than the low compressor speed at which the measured capacity is higher than the capacity at low compressor speed by one third of the difference between $Capacity_4$, the measured cooling capacity at test condition 4 in Table 1 of this appendix, and $Capacity_1$, the measured cooling capacity with the full compressor speed at test condition 1 in Table 1 of this appendix, with a tolerance of plus 5 percent (designs with non-discrete speed stages) or the next highest inverter frequency step (designs with discrete speed steps), achieved by following the instructions certified by the manufacturer.

2.16 ''Low compressor speed (low)'' means the compressor speed at which the unit operates at low load test conditions, achieved by following the instructions certified by the manufacturer, such that $Capacity_4$, the measured cooling capacity at test condition 4 in Table 1 of this appendix, is no less than 47 percent and no greater than 57 percent of $Capacity_1$, the measured cooling capacity with the full compressor speed at test condition 1 in Table 1 of this appendix.

2.17 ''Off mode'' means a mode in which a room air conditioner is connected to a mains power source and is not providing any active or standby mode function and where the mode may persist for an indefinite time, including an indicator that only shows the user that the product is in the off position.

2.18 ''Single-speed room air conditioner'' means a type of room air conditioner that cannot automatically adjust the compressor speed based on detected conditions.

2.19 ''Standby mode'' means any product mode where the unit is connected to a mains power source and offers one or more of the following user-oriented or protective functions which may persist for an indefinite time:

(a) To facilitate the activation of other modes (including activation or deactivation of active mode) by remote switch (including remote control), internal sensor, or timer. A timer is a continuous clock function (which may or may not be associated with a display) that provides regular scheduled tasks (*e.g.*, switching) and that operates on a continuous basis.

(b) Continuous functions, including information or status displays (including clocks) or sensor-based functions.

2.20 ''Theoretical comparable single-speed room air conditioner'' means a theoretical single-speed room air conditioner with the same cooling capacity and electrical power input as the variable-speed room air conditioner under test, with no cycling losses considered, at test condition 1 in Table 1 of this appendix.

2.21 ''Variable-speed compressor'' means a compressor that can vary its rotational speed in non-discrete stages or discrete steps from low to full.

2.22 ''Variable-speed room air conditioner'' means a type of room air conditioner that can automatically adjust compressor speed based on detected conditions.

3. Test Methods and General Instructions

3.1 *Cooling mode.* The test method for testing room air conditioners in cooling mode (''cooling mode test'') consists of applying the methods and conditions in AHAM RAC–1 Section 4, Paragraph 4.1 and for single-speed room air conditioners, Section 5, Paragraph 5.2.1.1, and for variable-speed room air conditioners, Section 5, Paragraph 5.2.1.2, except in accordance with ANSI/ASHRAE 16, including the references to ANSI/ASHRAE 41.1, ANSI/ASHRAE 41.2–1987 (RA 1992), ANSI/ASHRAE 41.3–2014, ANSI/ASHRAE 41.6–2014, and ANSI/ASHRAE 41.11–2014, all referenced therein, as defined in sections 2.3 through 2.8 of this appendix. Use the cooling capacity simultaneous indoor calorimeter and outdoor calorimeter test method in Section 7.1.a and Sections 8.1 through 8.5 of ANSI/ASHRAE 16, except as otherwise specified in this appendix. If a unit can operate on multiple operating voltages as distributed in commerce by the manufacturer, test it and rate the corresponding basic models at all nameplate operating voltages. For a variable-speed room air conditioner, test the unit following the cooling mode test a total of four times: One test at each of the test conditions listed in Table 1 of this appendix, consistent with section 4.1 of this appendix.

3.1.1 *Through-the-wall installation.* Install a non-louvered room air conditioner inside a compatible wall sleeve with the provided or manufacturer-required rear grille, and with only the included trim frame and other manufacturer-provided installation materials, per manufacturer instructions provided to consumers.

3.1.2 *Power measurement accuracy.* All instruments used for measuring electrical inputs to the test unit, reconditioning equipment, and any other equipment that operates within the calorimeter walls must be accurate to ±0.5 percent of the quantity measured.

3.1.3 *Electrical supply.* For cooling mode testing, test at each nameplate operating voltage, and maintain the input standard voltage within ±1 percent. Test at the rated frequency, maintained within ±1 percent.

3.1.4 *Control settings.* If the room air conditioner has network capabilities, all network features must be disabled throughout testing.

3.1.5 *Measurement resolution.* Record measurements at the resolution of the test instrumentation.

3.1.6 *Temperature tolerances.* Maintain each of the measured chamber dry-bulb and wet-bulb temperatures within a range of 1.0 °F.

3.2 *Standby and off modes.*

3.2.1 Install the room air conditioner in accordance with Section 5, Paragraph 5.2 of IEC 62301 and maintain the indoor test conditions (and outdoor test conditions where applicable) as required by Section 4, Paragraph 4.2 of IEC 62301. If testing is not conducted in a facility used for testing cooling mode performance, the test facility must comply with Section 4, Paragraph 4.2 of IEC 62301.

3.2.2 *Electrical supply.* For standby mode and off mode testing, maintain the electrical supply voltage and frequency according to the requirements in Section 4, Paragraph 4.3.1 of IEC 62301.

3.2.3 *Supply voltage waveform.* For the standby mode and off mode testing, maintain

the electrical supply voltage waveform indicated in Section 4, Paragraph 4.3.2 of IEC 62301.

3.2.4 *Wattmeter*. The wattmeter used to measure standby mode and off mode power consumption must meet the resolution and accuracy requirements in Section 4, Paragraph 4.4 of IEC 62301.

3.2.5 *Air ventilation damper*. If the unit is equipped with an outdoor air ventilation damper, close this damper during standby mode and off mode testing.

4. Test Conditions and Measurements

4.1 *Cooling mode.*

4.1.1 *Temperature conditions.* Establish the test conditions described in Sections 4 and 5 of AHAM RAC–1 and in accordance with ANSI/ASHRAE 16, including the references to ANSI/ASHRAE 41.1 and ANSI/ASHRAE 41.6–2014, for cooling mode testing, with the following exceptions for variable-speed room air conditioners: Conduct the set of four cooling mode tests with the test conditions presented in Table 1 of this appendix. For test condition 1 and test condition 2, achieve the full compressor speed with user settings, as defined in section 2.12 of this appendix. For test condition 3 and test condition 4, set the required compressor speed in accordance with instructions the manufacturer provided to DOE.

TABLE 1—INDOOR AND OUTDOOR INLET AIR TEST CONDITIONS—VARIABLE-SPEED ROOM AIR CONDITIONERS

Test condition	Evaporator inlet (indoor) air, °F		Condenser inlet (outdoor) air, °F		Compressor speed
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
Test Condition 1	80	67	95	75	Full.
Test Condition 2	80	67	92	72.5	Full.
Test Condition 3	80	67	87	69	Intermediate.
Test Condition 4	80	67	82	65	Low.

4.1.2 *Cooling capacity and power measurements.* For single-speed units, measure the cooling mode cooling capacity (expressed in Btu/h), Capacity, and electrical power input (expressed in watts), $P_{cool,}$ in accordance with Section 6, Paragraphs 6.1 and 6.2 of AHAM RAC–1, respectively, and in accordance with ANSI/ASHRAE 16, including the references to ANSI/ASHRAE 41.2–1987 (RA 1992) and ANSI/ASHRAE 41.11–2014. For variable-speed room air conditioners, measure the condition-specific cooling capacity (expressed in Btu/h), $Capacity_{tc}$, and electrical power input (expressed in watts), P_{tc}, for each of the four cooling mode rating test conditions (tc), as required in Section 6, Paragraphs 6.1 and 6.2, respectively, of AHAM RAC–1, respectively, and in accordance with ANSI/ASHRAE 16, including the references to ANSI/ASHRAE 41.2–1987 (RA 1992) and ANSI/ASHRAE 41.11–2014.

4.2 *Standby and off modes.* Establish the testing conditions set forth in section 3.2 of this appendix, ensuring the unit does not enter any active mode during the test. For a unit that drops from a higher power state to a lower power state as discussed in Section 5, Paragraph 5.1, Note 1 of IEC 62301, allow sufficient time for the room air conditioner to reach the lower power state before proceeding with the test measurement. Use the sampling method test procedure specified in Section 5, Paragraph 5.3.2 of IEC 62301 for testing all standby and off modes, with the following modifications: Allow the product to stabilize for 5 to 10 minutes and use an energy use measurement period of 5 minutes.

4.2.1 If the unit has an inactive mode, as defined in section 2.14 of this appendix, measure and record the average inactive mode power, Pia, in watts.

4.2.2 If the unit has an off mode, as defined in section 2.17 of this appendix, measure and record the average off mode power, P_{om}, in watts.

5. Calculations

5.1 *Annual energy consumption in inactive mode and off mode.* Calculate the annual energy consumption in inactive mode and off mode, $AEC_{ia/om,}$ expressed in kilowatt-hours per year (kWh/year).

$$AEC_{ia/om} = (P_{ia} \times t_{ia} + P_{om} \times t_{om})$$

Where:

$AEC_{ia/om}$ = annual energy consumption in inactive mode and off mode, in kWh/year.

P_{ia} = average power in inactive mode, in watts, determined in section 4.2 of this appendix.

P_{om} = average power in off mode, in watts, determined in section 4.2 of this appendix.

t_{ia} = annual operating hours in inactive mode and multiplied by a 0.001 kWh/Wh conversion factor from watt-hours to kilowatt-hours. This value is 5.115 kWh/W if the unit has inactive mode and no off mode,

2.5575 kWh/W if the unit has both inactive and off mode, and 0 kWh/W if the unit does not have inactive mode.

t_{om} = annual operating hours in off mode and multiplied by a 0.001 kWh/Wh conversion factor from watt-hours to kilowatt-hours. This value is 5.115 kWh/W if the unit has off mode and no inactive mode, 2.5575 kWh/W if the unit has both inactive and off mode, and 0 kWh/W if the unit does not have off mode.

5.2 *Combined energy efficiency ratio for single-speed room air conditioners.* Calculate the combined energy efficiency ratio for single-speed room air conditioners as follows:

5.2.1 *Single-speed room air conditioner annual energy consumption in cooling mode.* Calculate the annual energy consumption in cooling mode for a single-speed room air conditioner, $AEC_{cool,}$ expressed in kWh/year.

$$AEC_{cool} = 0.75 \times P_{cool}$$

Where:

AEC_{cool} = single-speed room air conditioner annual energy consumption in cooling mode, in kWh/year.

P_{cool} = single-speed room air conditioner average power in cooling mode, in watts, determined in section 4.1.2 of this appendix.

0.75 is 750 annual operating hours in cooling mode multiplied by a 0.001 kWh/Wh conversion factor from watt-hours to kilowatt-hours.

5.2.2 *Single-speed room air conditioner combined energy efficiency ratio.* Calculate the combined energy efficiency ratio, CEER, expressed in Btu/Wh, as follows:

$$CEER = \left[\frac{Capacity}{\left(\frac{AEC_{cool} + AEC_{ia/om}}{0.75}\right)}\right]$$

Where:

CEER = combined energy efficiency ratio, in Btu/Wh.

Capacity = single-speed room air conditioner cooling capacity, in Btu/h, determined in section 4.1.2 of this appendix.

AEC_{cool} = single-speed room air conditioner annual energy consumption in cooling mode, in kWh/year, calculated in section 5.2.1 of this appendix.

$AEC_{ia/om}$ = annual energy consumption in inactive mode and off mode, in kWh/year, determined in section 5.1 of this appendix.

0.75 as defined in section 5.2.1 of this appendix.

5.3 *Combined energy efficiency ratio for variable-speed room air conditioners.* Calculate the combined energy efficiency ratio for variable-speed room air conditioners as follows:

5.3.1 *Weighted electrical power input.* Calculate the weighted electrical power input in cooling mode, $P_{wt,}$ expressed in watts, as follows:

$$P_{wt} = \Sigma_{tc}\ P_{tc} \times W_{tc}$$

Where:

P_{wt} = weighted electrical power input, in watts, in cooling mode.

P_{tc} = electrical power input, in watts, in cooling mode for each test condition in Table 1 of this appendix.

W_{tc} = weighting factors for each cooling mode test condition: 0.08 for test condition 1, 0.20 for test condition 2, 0.33 for test condition 3, and 0.39 for test condition 4. tc represents the cooling mode test condition: ''1'' for test condition 1 (95 °F condenser inlet dry-bulb temperature), ''2'' for test condition 2 (92 °F), ''3'' for test condition 3 (87 °F), and ''4'' for test condition 4 (82 °F).

5.3.2 *Theoretical comparable single-speed room air conditioner.* Calculate the cooling capacity, expressed in Btu/h, and the electrical power input, expressed in watts, for a theoretical comparable single-speed room air conditioner at all cooling mode test conditions.

$$Capacity_{ss__tc} = Capacity_1 \times (1 + (M_c \times (95 - T_{tc})))$$

$$P_{ss__tc} = P_1 \times (1 - (M_p \times (95 - T_{tc})))$$

Where:

$Capacity_{ss__tc}$ = theoretical comparable single-speed room air conditioner cooling capacity, in Btu/h, calculated for each of the cooling mode test conditions in Table 1 of this appendix.

$Capacity_1$ = variable-speed room air conditioner unit's cooling capacity, in Btu/h, determined in section 4.1.2 of this appendix for test condition 1 in Table 1 of this appendix.

$P_{ss__tc}$ = theoretical comparable single-speed room air conditioner electrical power input, in watts, calculated for each of the

cooling mode test conditions in Table 1 of this appendix.

P_1 = variable-speed room air conditioner unit's electrical power input, in watts, determined in section 4.1.2 of this appendix for test condition 1 in Table 1 of this appendix.

M_c = adjustment factor to determine the increased capacity at lower outdoor test conditions, 0.0099 per °F.

M_p = adjustment factor to determine the reduced electrical power input at lower outdoor test conditions, 0.0076 per °F.

95 is the condenser inlet dry-bulb temperature for test condition 1 in Table 1 of this appendix, 95 °F.

T_{tc} = condenser inlet dry-bulb temperature for each of the test conditions in Table 1 of this appendix (in °F).

tc as explained in section 5.3.1 of this appendix.

5.3.3 *Variable-speed room air conditioner unit's annual energy consumption for cooling mode at each cooling mode test condition.* Calculate the annual energy consumption for cooling mode under each test condition, AEC_{tc}, expressed in kilowatt-hours per year (kWh/year), as follows:

$$AEC_{tc} = 0.75 \times P_{tc}$$

Where:

AEC_{tc} = variable-speed room air conditioner unit's annual energy consumption, in kWh/year, in cooling mode for each test condition in Table 1 of this appendix.

P_{tc} = as defined in section 5.3.1 of this appendix.

0.75 as defined in section 5.2.1 of this appendix.

tc as explained in section 5.3.1 of this appendix.

5.3.4 *Variable-speed room air conditioner weighted annual energy consumption.* Calculate the weighted annual energy consumption in cooling mode for a variable-speed room air conditioner, AEC_{wt}, expressed in kWh/year.

$$AEC_{wt} = \Sigma_{tc}\ AEC_{tc} \times W_{tc}$$

Where:

AEC_{wt} = weighted annual energy consumption in cooling mode for a variable-speed room air conditioner, expressed in kWh/year.

AEC_{tc} = variable-speed room air conditioner unit's annual energy consumption, in kWh/year, in cooling mode for each test condition in Table 1 of this appendix, determined in section 5.3.3 of this appendix.

W_{tc} = weighting factors for each cooling mode test condition: 0.08 for test condition 1, 0.20 for test condition 2, 0.33 for test condition 3, and 0.39 for test condition 4.

tc as explained in section 5.3.1 of this appendix.

5.3.5 *Theoretical comparable single-speed room air conditioner annual energy consumption in cooling mode at each cooling mode test condition.* Calculate the annual energy consumption in cooling mode for a theoretical comparable single-speed room air conditioner for cooling mode under each test condition, $AEC_{ss__tc}$, expressed in kWh/year.

$$AEC_{ss__tc} = 0.75 \times P_{ss__tc}$$

Where:

$AEC_{ss__tc}$ = theoretical comparable single-speed room air conditioner annual energy consumption, in kWh/year, in cooling mode for each test condition in Table 1 of this appendix.

$P_{ss__tc}$ = theoretical comparable single-speed room air conditioner electrical power input, in watts, in cooling mode for each test condition in Table 1 of this appendix, determined in section 5.3.2 of this appendix.

0.75 as defined in section 5.2.1 of this appendix.

tc as explained in section 5.3.1 of this appendix.

5.3.6 *Variable-speed room air conditioner combined energy efficiency ratio at each cooling mode test condition.* Calculate the variable-speed room air conditioner unit's combined energy efficiency ratio, $CEER_{tc}$, for each test condition, expressed in Btu/Wh.

$$CEER_{tc} = \frac{Capacity_{tc}}{\left(\frac{AEC_{tc} + AEC_{ia/om}}{0.75}\right)}$$

Where:

$CEER_{tc}$ = variable-speed room air conditioner unit's combined energy efficiency ratio, in Btu/Wh, for each test condition in Table 1 of this appendix.

$Capacity_{tc}$ = variable-speed room air conditioner unit's cooling capacity, in Btu/h, for each test condition in Table 1 of this appendix, determined in section 4.1.2 of this appendix.

AEC_{tc} = variable-speed room air conditioner unit's annual energy consumption, in kWh/year, in cooling mode for each test condition in Table 1 of this appendix, determined in section 5.3.3 of this appendix.

$AEC_{ia/om}$ = annual energy consumption in inactive mode and off mode, in kWh/year, determined in section 5.1 of this appendix.

0.75 as defined in section 5.2.1 of this appendix.

tc as explained in section 5.3.1 of this appendix.

5.3.7 *Theoretical comparable single-speed room air conditioner combined energy efficiency ratio.* Calculate the combined energy efficiency ratio for a theoretical comparable single-speed room air conditioner, $CEER_{ss__tc}$, for each test condition, expressed in Btu/Wh.

$$CEER_{ss_tc} = \frac{Capacity_{ss_tc}}{\left(\frac{AEC_{ss_tc} + AEC_{ia/om}}{0.75}\right)}$$

Where:

$CEER_{ss__tc}$ = theoretical comparable single-speed room air conditioner combined energy efficiency ratio, in Btu/Wh, for each test condition in Table 1 of this appendix.

$Capacity_{ss__tc}$ = theoretical comparable single-speed room air conditioner cooling capacity, in Btu/h, for each test condition in Table 1 of this appendix, determined in section 5.3.2 of this appendix.

$AEC_{ss__tc}$ = theoretical comparable single-speed room air conditioner annual energy consumption, in kWh/year, in cooling mode for each test condition in Table 1 of this appendix, determined in section 5.3.5 of this appendix.

$AEC_{ia/om}$ = annual energy consumption in inactive mode and off mode, in kWh/year, determined in section 5.1 of this appendix.

0.75 as defined in section 5.2.1 of this appendix.

tc as explained in section 5.3.1 of this appendix.

5.3.8 *Theoretical comparable single-speed room air conditioner adjusted combined energy efficiency ratio.* Calculate the adjusted combined energy efficiency ratio, for a theoretical comparable single-speed room air conditioner, $CEER_{ss__tc__adj}$, with cycling losses considered, for each test condition, expressed in Btu/Wh.

$$CEER_{ss__tc__adj} = CEER_{ss__tc} \times CLF_{tc}$$

Where:

$CEER_{ss__tc__adj}$ = theoretical comparable single-speed room air conditioner adjusted combined energy efficiency ratio, in Btu/Wh, for each test condition in Table 1 of this appendix.

$CEER_{ss__tc}$ = theoretical comparable single-speed room air conditioner combined energy efficiency ratio, in Btu/Wh, for each test condition in Table 1 of this appendix, determined in section 5.3.7 of this appendix.

CLF_{tc} = cycling loss factor for each test condition; 1 for test condition 1, 0.956 for test condition 2, 0.883 for test condition 3, and 0.810 for test condition 4.

tc as explained in section 5.3.1 of this appendix.

5.3.9 *Weighted combined energy efficiency ratio.* Calculate the weighted combined energy efficiency ratio for the variable-speed room air conditioner unit, $CEER_{wt}$, and theoretical comparable single-speed room air conditioner, $CEER_{ss__wt}$, expressed in Btu/Wh.

$$CEER_{wt} = \Sigma_{tc}\ CEER_{tc} \times W_{tc}$$

$$CEER_{ss__wt} = \Sigma_{tc}\ CEER_{ss__tc__adj} \times W_{tc}$$

Where:

$CEER_{wt}$ = variable-speed room air conditioner unit's weighted combined energy efficiency ratio, in Btu/Wh.

$CEER_{ss__wt}$ = theoretical comparable single-speed room air conditioner weighted combined energy efficiency ratio, in Btu/Wh.

$CEER_{tc}$ = variable-speed room air conditioner unit's combined energy efficiency ratio, in Btu/Wh, at each test condition in Table 1 of this appendix, determined in section 5.3.6 of this appendix.

$CEER_{ss__tc__adj}$ = theoretical comparable single-speed room air conditioner adjusted combined energy efficiency ratio, in Btu/Wh, at each test condition in Table 1 of this appendix, determined in section 5.3.8 of this appendix.

W_{tc} as defined in section 5.3.4 of this appendix.

tc as explained in section 5.3.1 of this appendix.

5.3.10 *Variable-speed room air conditioner performance adjustment factor.* Calculate the variable-speed room air conditioner unit's performance adjustment factor, $F_{p.}$

$$F_p = \frac{\left(CEER_{wt} - CEER_{ss_wt}\right)}{CEER_{ss_wt}}$$

Where:

F_p = variable-speed room air conditioner unit's performance adjustment factor.

$CEER_{wt}$ = variable-speed room air conditioner unit's weighted combined energy efficiency ratio, in Btu/Wh, determined in section 5.3.9 of this appendix.

$CEER_{ss_wt}$ = theoretical comparable single-speed room air conditioner weighted combined energy efficiency ratio, in Btu/Wh, determined in section 5.3.9 of this appendix.

5.3.11 *Variable-speed room air conditioner combined energy efficiency ratio*. Calculate the combined energy efficiency ratio, CEER, expressed in Btu/Wh, for variable-speed air conditioners.

$$CEER = CEER_1 \times (1 + F_p)$$

Where:

CEER = combined energy efficiency ratio, in Btu/Wh.

$CEER_1$ = variable-speed room air conditioner combined energy efficiency ratio for test condition 1 in Table 1 of this appendix, in Btu/Wh, determined in section 5.3.6 of this appendix.

F_p = variable-speed room air conditioner performance adjustment factor, determined in section 5.3.10 of this appendix.

[86 FR 16476, Mar. 29, 2021, as amended at 86 FR 24484, May 7, 2021; 88 FR 59791, Aug. 30, 2023]

Appendix G to Subpart B of Part 430—Uniform Test Method for Measuring the Energy Consumption of Unvented Home Heating Equipment

1. Testing conditions.

1.1 *Installation*.

1.1.1 *Electric heater*. Install heater according to manufacturer's instructions. Heaters shall be connected to an electrical supply circuit of nameplate voltage with a wattmeter installed in the circuit. The wattmeter shall have a maximum error not greater than one percent.

1.1.2 *Unvented gas heater*. Install heater according to manufacturer's instructions. Heaters shall be connected to a gas supply line with a gas displacement meter installed between the supply line and the heater according to manufacturer's specifications. The gas displacement meter shall have a maximum error not greater than one percent. Gas heaters with electrical auxiliaries shall be connected to an electrical supply circuit of nameplate voltage with a wattmeter installed in the circuit. The wattmeter shall have a maximum error not greater than one percent.

1.1.3 *Unvented oil heater*. Install heater according to manufacturer's instructions. Oil heaters with electric auxiliaries shall be connected to an electrical supply circuit of nameplate voltage with a wattmeter installed in the circuit. The wattmeter shall have a maximum error not greater than one percent.

1.2 *Temperature regulating controls*. All temperature regulating controls shall be shorted out of the circuit or adjusted so that they will not operate during the test period.

1.3 *Fan controls*. All fan controls shall be set at the highest fan speed setting.

1.4 *Energy supply*.

1.4.1 *Electrical supply*. Supply power to the heater within one percent of the nameplate voltage.

1.4.2 *Natural gas supply*. For an unvented gas heater utilizing natural gas, maintain the gas supply to the heater with a normal inlet test pressure immediately ahead of all controls at 7 to 10 inches of water column. The regulator outlet pressure at normal supply test pressure shall be approximately that recommended by the manufacturer. The natural gas supplied should have a higher heating value within ±5 percent of 1,025 Btu's per standard cubic foot. Determine the higher heating value, in Btu's per standard cubic foot, for the natural gas to be used in the test, with an error no greater than one percent. Alternatively, the test can be conducted using ''bottled'' natural gas of a higher heating value within ±5 percent of 1,025 Btu's per standard cubic foot as long as the actual higher heating value of the bottled natural gas has been determined with an error no greater than one percent as certified by the supplier.

1.4.3 *Propane gas supply*. For an unvented gas heater utilizing propane, maintain the gas supply to the heater with a normal inlet test pressure immediately ahead of all controls at 11 to 13 inches of water column. The regulator outlet pressure at normal supply test pressure shall be that recommended by the manufacturer. The propane supplied should have a higher heating value of within±5 percent of 2,500 Btu's per standard cubic foot. Determine the higher heating value in Btu's per standard foot, for the propane to be used in the test, with an error no greater than one percent. Alternatively, the test can be conducted using ''bottled'' propane of a

higher heating value within ±5 percent of 2,500 Btu's per standard cubic foot as long as the actual higher heating value of the bottled propane has been determined with an error no greater than one percent as certified by the supplier.

1.4.4 *Oil supply.* For an unvented oil heater utilizing kerosene, determine the higher heating value in Btu's per gallon with an error no greater than one percent. Alternatively, the test can be conducted using a tested fuel of a higher heating value within ±5 percent of 137,400 Btu's per gallon as long as the actual higher heating value of the tested fuel has been determined with an error no greater than one percent as certified by the supplier.

1.5 *Energy flow instrumentation.* Install one or more energy flow instruments which measure, as appropriate and with an error no greater than one percent, the quantity of electrical energy, natural gas, propane gas, or oil supplied to the heater.

2. Testing and measurements.

2.1 *Electric power measurement.* Establish the test conditions set forth in section 1 of this appendix. Allow an electric heater to warm up for at least five minutes before recording the maximum electric power measurement from the wattmeter. Record the maximum electric power (P_E) expressed in kilowatts.

Allow the auxiliary electrical system of a forced air unvented gas, propane, or oil heater to operate for at least five minutes before recording the maximum auxiliary electric power measurement from the wattmeter. Record the maximum auxiliary electric power (P_A) expressed in kilowatts.

2.2 *Natural gas, propane, and oil measurement.* Establish the test conditions as set forth in section 1 of this appendix. A natural gas, propane, or oil heater shall be operated for one hour. Using either the nameplate rating or the energy flow instrumentation set forth in section 1.5 of this appendix and the fuel supply rating set forth in sections 1.4.2, 1.4.3, or 1.4.4 of this appendix, as appropriate, determine the maximum fuel input (P_F) of the heater under test in Btu's per hour. The energy flow instrumentation shall measure the maximum fuel input with an error no greater than one percent.

2.3 *Pilot light measurement.* Except as provided in section 2.3.1 of this appendix, measure the energy input rate to the pilot light (Q_p), with an error no greater than 3 percent, for unvented heaters so equipped.

2.3.1 The measurement of Q_p is not required for unvented heaters where the pilot light is designed to be turned off by the user when the heater is not in use (*i.e.*, for units where turning the control to the OFF position will shut off the gas supply to the burner(s) and the pilot light). This provision applies only if an instruction to turn off the unit is provided on the heater near the gas control value (*e.g.*, by label) by the manufacturer.

2.4 *Electrical standby mode power measurement.* Except as provided in section 2.4.1 of this appendix, for all electric heaters and unvented heaters with electrical auxiliaries, measure the standby power ($P_{W,SB}$) in accordance with the procedures in IEC 62301 Second Edition (incorporated by reference; see §430.3), with all electrical auxiliaries not activated. Voltage shall be as specified in section 1.4.1 *Electrical supply* of this appendix. The recorded standby power ($P_{W,SB}$) shall be rounded to the second decimal place, and for loads greater than or equal to 10W, at least three significant figures shall be reported.

2.4.1 The measurement of $P_{W,SB}$ is not required for heaters designed to be turned off by the user when the heater is not in use (*i.e.*, for units where turning the control to the OFF position will shut off the electrical supply to the heater). This provision applies only if an instruction to turn off the unit is provided on the heater (*e.g.*, by label) by the manufacturer.

3. Calculations.

3.1 *Annual energy consumption for primary electric heaters.* For primary electric heaters, calculate the annual energy consumption (E_E) expressed in kilowatt-hours per year and defined as:

$E_E = 2080(0.77)DHR$

where:

2080 = national average annual heating load hours
0.77 = adjustment factor
DHR = design heating requirement and is equal to $P_E/1.2$ in kilowatts.
P_E = as defined in 2.1 of this appendix
1.2 = typical oversizing factor for primary electric heaters

3.2 *Annual energy consumption for primary electric heaters by geographic region of the United States.* For primary electric heaters, calculate the annual energy consumption by geographic region of the United States (E_R) expressed in kilowatt-hours per year and defined as:

$E_R = HLH(0.77)\ (DHR)$

where:

HLH = heating load hours for a specific region determined from Figure 1 of this appendix in hours
0.77 = as defined in 3.1 of this appendix
DHR = as defined in 3.1 of this appendix

3.3 *Rated output for electric heaters.* Calculate the rated output (Q_{out}) for electric heaters, expressed in Btu's per hour, and defined as:

$Q_{out} = P_E\ (3{,}412\ Btu/kWh)$

where:

P_E = as defined in 2.1 of this appendix

3.4 *Rated output for unvented heaters using either natural gas, propane, or oil.* For unvented heaters using either natural gas, propane, or oil equipped without auxiliary electrical systems, the rated output (Q_{out}), expressed in Btu's per hour, is equal to P_F, as determined in section 2.2 of this appendix.

For unvented heaters using either natural gas, propane, or oil equipped with auxiliary electrical systems, calculate the rated output (Q_{out}), expressed in Btu's per hour, and defined as:

$Q_{out} = P_F + P_A$ (3,412 Btu/kWh)


where:

P_F = as defined in 2.2 of this appendix in Btu/hr

P_A = as defined in 2.1 of this appendix in Btu/hr

FIGURE I

Heating Load Hours (HLH) for the United States and Territories



This map is reasonably accurate for most parts of the United States but is necessarily highly generalized and consequently not too accurate in mountainous regions, particularly in the Rockies

Alaska — 3500 HLH
Hawaii and Territories — 0 HLH

(Energy Policy and Conservation Act, Pub. L. 94–163, as amended by Pub. L. 94–385; Federal Energy Administration Act of 1974, Pub. L. 93–275, as amended by Pub. L. 94–385; Department of Energy Organization Act, Pub. L. 95–91; E.O. 11790, 39 FR 23185)

[43 FR 20132, May 10, 1978. Redesignated and amended at 44 FR 37938, June 29, 1979; 49 FR 12157, Mar. 28, 1984; 77 FR 74571, Dec. 17, 2012]

APPENDIX H TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE POWER CONSUMPTION OF TELEVISION SETS

NOTE: On or after April 14, 2023 and prior to September 11, 2023, any representations made with respect to the energy use or energy efficiency of a television must be based upon results generated under this appendix as it appeared in 10 CFR part 430 edition revised as of January 1, 2023, or this appendix. Beginning September 11, 2023 any representations made with respect to the energy use or efficiency of a television must be based upon results generated under this appendix. Given that beginning September 11, 2023, representations with respect to the energy use or efficiency of televisions must be made in accordance with tests conducted pursuant to this appendix, manufacturers may wish to begin using this test procedure as soon as possible.

0. Incorporation by Reference

DOE incorporated by reference in §430.3, ANSI/CTA–2037–D in its entirety. However, only enumerated provisions of ANSI/CTA–2037–D are applicable to this appendix, as follows:

0.1 ANSI/CTA–2037–D

(a) Section 5 as referenced in section 2 of this appendix;
(b) Sections 6 and 8 through 11 as referenced in section 3 of this appendix;
(c) Section 7 as referenced in sections 3 and 4 of this appendix; and
(d) Annex A as referenced in section 4 of this appendix.

0.2 [Reserved]

1. Scope

This appendix covers the test requirements used to measure the energy and power consumption of television sets that have a diagonal screen size of at least fifteen inches; and are powered by mains power (including TVs with auxiliary batteries but not TVs with main batteries).

2. Definitions and Symbols

2.1. *Definitions*. The following terms are defined according to section 5.1 of ANSI/CTA–2037–D.

(a) Annual energy consumption
(b) Automatic brightness control
(c) Brightest selectable picture setting
(d) Default preset picture setting
(e) Dynamic Luminance
(f) Energy-Efficient-Ethernet
(g) Filmmaker Mode
(h) Forced menu
(i) Gloss Unit (GU)
(j) HDR10
(k) High Dynamic Range
(l) Home configuration
(m) Hybrid Log Gamma (HLG)
(n) Illuminance
(o) International System of Units
(p) Luminance
(q) Main battery
(r) Motion-Based Dynamic Dimming
(s) Neutral density filter
(t) Off Mode
(u) On Mode
(v) Perceptual Quantization Video
(w) Preset picture setting
(x) Quick start
(y) Retail Configuration
(z) Snoot
(aa) Software
(ab) Wake-By-Remote-Control-App
(ac) Wake-By-Smart-Speaker
(ad) Wake-On-Cast

2.2. *Symbol usage*. The symbols and abbreviations in section 5.2 of ANSI/CTA–2037–D apply to this test procedure.

3. Test Conduct

Determine the dynamic luminance and on mode and standby mode power consumption of TVs by following the procedure specified in sections 6 through 11 of ANSI/CTA–2037–D.

4. Calculation of Measured Values

Calculate the on mode power consumption, dynamic luminance, standby mode power consumption, and annual energy consumption as specified in Annex A of ANSI/CTA–2037–D. The following additional requirements are also applicable.

4.1. Round on mode power value as specified in Annex A of ANSI/CTA–2037–D.

4.2. Round dynamic luminance to the nearest tenth.

4.3. Round standby mode power as specified in section 7.1.2 of ANSI/CTA–2037–D.

4.4. Round annual energy consumption as specified in Annex A of ANSI/CTA–2037–D.

[88 FR 16109, Mar. 15, 2023]

APPENDIX I TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF MICROWAVE OVENS

NOTE: After September 26, 2022, representations made with respect to the energy use of microwave ovens must fairly disclose the results of testing pursuant to this appendix.

On or after April 29, 2022 and prior to September 26, 2022 representations, including compliance certifications, made with respect to the energy use of microwave ovens must fairly disclose the results of testing pursuant to either this appendix or appendix I as it appeared at 10 CFR part 430, subpart B, in the 10 CFR parts 200 to 499 edition revised as of January 1, 2020. Representations made with

respect to the energy use of microwave ovens within that range of time must fairly disclose the results of testing under the selected version. Given that after September 26, 2022 representations with respect to the energy use of microwave ovens must be made in accordance with tests conducted pursuant to this appendix, manufacturers may wish to begin using this test procedure as soon as possible.

1. Definitions

The following definitions apply to the test procedures in this appendix, including the test procedures incorporated by reference:

1.1 *Active mode* means a mode in which the product is connected to a mains power source, has been activated, and is performing the main function of producing heat by means of a gas flame, electric resistance heating, electric inductive heating, or microwave energy.

1.2 *Built-in* means the product is enclosed in surrounding cabinetry, walls, or other similar structures on at least three sides, and can be supported by surrounding cabinetry or the floor.

1.3 *Combined cooking product* means a household cooking appliance that combines a cooking product with other appliance functionality, which may or may not include another cooking product. Combined cooking products include the following products: Conventional range, microwave/conventional cooking top, microwave/conventional oven, and microwave/conventional range.

1.4 *Drop-in* means the product is supported by horizontal surface cabinetry.

1.5 *IEC 62301 (First Edition)* means the test standard published by the International Electrotechnical Commission, titled ''Household electrical appliances—Measurement of standby power,'' Publication 62301 (First Edition 2005–06) (incorporated by reference; see §430.3).

1.6 *IEC 62301 (Second Edition)* means the test standard published by the International Electrotechnical Commission, titled ''Household electrical appliances—Measurement of standby power,'' Publication 62301 (Edition 2.0 2011–01) (incorporated by reference; see §430.3).

1.7 *Normal non-operating temperature* means a temperature of all areas of an appliance to be tested that is within 5 °F (2.8 °C) of the temperature that the identical areas of the same basic model of the appliance would attain if it remained in the test room for 24 hours while not operating with all oven doors closed.

1.8 *Off mode* means any mode in which a cooking product is connected to a mains power source and is not providing any active mode or standby function, and where the mode may persist for an indefinite time. An indicator that only shows the user that the product is in the off position is included within the classification of an off mode.

1.9 *Standby mode* means any mode in which a cooking product is connected to a mains power source and offers one or more of the following user-oriented or protective functions which may persist for an indefinite time:

(1) Facilitation of the activation of other modes (including activation or deactivation of active mode) by remote switch (including remote control), internal sensor, or timer;

(2) Provision of continuous functions, including information or status displays (including clocks) or sensor-based functions. A timer is a continuous clock function (which may or may not be associated with a display) that allows for regularly scheduled tasks and that operates on a continuous basis.

2. Test Conditions

2.1 *Installation.* Install a drop-in or built-in cooking product in a test enclosure in accordance with manufacturer's instructions. If the manufacturer's instructions specify that the cooking product may be used in multiple installation conditions, install the appliance according to the built-in configuration. Completely assemble the product with all handles, knobs, guards, and similar components mounted in place. Position any electric resistance heaters and baffles in accordance with the manufacturer's instructions.

2.1.1 *Microwave ovens, excluding any microwave oven component of a combined cooking product.* Install the microwave oven in accordance with the manufacturer's instructions and connect to an electrical supply circuit with voltage as specified in section 2.2.1 of this appendix. Install the microwave oven in accordance with Section 5, Paragraph 5.2 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3), disregarding the provisions regarding batteries and the determination, classification, and testing of relevant modes. If the microwave oven can communicate through a network (*e.g.*, Bluetooth® or internet connection), disable the network function, if it is possible to disable it by means provided in the manufacturer's user manual, for the duration of testing. If the network function cannot be disabled, or means for disabling the function are not provided in the manufacturer's user manual, test the microwave oven with the network function in the factory default setting or in the as-shipped condition as instructed in Section 5, paragraph 5.2 of IEC 62301 (Second Edition). Configure the unit such that the clock display remains on during testing, regardless of manufacturer's instructions or default setting or supplied setting, unless the clock display powers down automatically with no option for the consumer to override

this function. Install a watt meter in the circuit that meets the requirements of section 2.8.1.2 of this appendix.

2.2 *Energy supply*.

2.2.1 *Electrical supply*.

2.2.1.1 *Voltage*. For microwave oven testing, maintain the electrical supply to the unit at 240/120 volts ±1 percent. Maintain the electrical supply frequency for all products at 60 hertz ±1 percent.

2.3 *Air circulation*. Maintain air circulation in the room sufficient to secure a reasonably uniform temperature distribution, but do not cause a direct draft on the unit under test.

2.4 *Ambient room test conditions*.

2.4.1 *Standby mode and off mode ambient temperature*. For standby mode and off mode testing, maintain room ambient air temperature conditions as specified in Section 4, Paragraph 4.2 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3).

2.5 *Normal non-operating temperature*. All areas of the appliance to be tested must attain the normal non-operating temperature, as defined in section 1.7 of this appendix, before any testing begins. Measure the applicable normal non-operating temperature using the equipment specified in sections 2.6.2.1 of this appendix.

2.6 *Instrumentation*. Perform all test measurements using the following instruments, as appropriate:

2.6.1 *Electrical Measurements*.

2.6.1.1 *Standby mode and off mode watt meter*. The watt meter used to measure standby mode and off mode power must meet the requirements specified in Section 4, Paragraph 4.4 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3). For microwave oven standby mode and off mode testing, if the power measuring instrument used for testing is unable to measure and record the crest factor, power factor, or maximum current ratio during the test measurement period, measure the crest factor, power factor, and maximum current ratio immediately before and after the test measurement period to determine whether these characteristics meet the requirements specified in Section 4, Paragraph 4.4 of IEC 62301 (Second Edition).

2.6.2 *Temperature measurement equipment*.

2.6.2.1 *Room temperature indicating system*. For the test of microwave ovens, the room temperature indicating system must have an error no greater than ±1 °F (±0.6 °C) over the range 65° to 90 °F (18 °C to 32 °C).

3. Test Methods and Measurements

3.1. *Test methods*.

3.1.1 *Microwave oven*.

3.1.1.1 *Microwave oven test standby mode and off mode power except for any microwave oven component of a combined cooking product*. Establish the testing conditions set forth in section 2, Test Conditions, of this appendix. For microwave ovens that drop from a higher power state to a lower power state as discussed in Section 5, Paragraph 5.1, Note 1 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3), allow sufficient time for the microwave oven to reach the lower power state before proceeding with the test measurement. Follow the test procedure as specified in Section 5, Paragraph 5.3.2 of IEC 62301 (Second Edition). For units in which power varies as a function of displayed time in standby mode, set the clock time to 3:23 and use the average power approach described in Section 5, Paragraph 5.3.2(a) of IEC 62301 (First Edition), but with a single test period of 10 minutes +0/−2 sec after an additional stabilization period until the clock time reaches 3:33. If a microwave oven is capable of operation in either standby mode or off mode, as defined in sections 1.9 and 1.8 of this appendix, respectively, or both, test the microwave oven in each mode in which it can operate.

3.2 *Test measurements*.

3.2.1 *Microwave oven standby mode and off mode power except for any microwave oven component of a combined cooking product*. Make measurements as specified in Section 5, Paragraph 5.3 of IEC 62301 (Second Edition) (incorporated by reference; see §430.3). If the microwave oven is capable of operating in standby mode, as defined in section 1.9 of this appendix, measure the average standby mode power of the microwave oven, PSB, in watts as specified in section 3.1.1.1 of this appendix. If the microwave oven is capable of operating in off mode, as defined in section 1.8 of this appendix, measure the average off mode power of the microwave oven, POM, as specified in section 3.1.1.1.

3.3 *Recorded values*.

3.3.1 For microwave ovens except for any microwave oven component of a combined cooking product, record the average standby mode power, PSB, for the microwave oven standby mode, as determined in section 3.2.1 of this appendix for a microwave oven capable of operating in standby mode. Record the average off mode power, POM, for the microwave oven off mode power test, as determined in section 3.2.1 of this appendix for a microwave oven capable of operating in off mode.

[85 FR 50766, Aug. 18, 2020, as amended at 87 FR 18271, Mar. 30, 2022; 87 FR 51538, Aug. 22, 2022]

APPENDIX I1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CONVENTIONAL COOKING PRODUCTS

NOTE: Any representation related to energy consumption of conventional cooking tops, including the conventional cooking top component of combined cooking products,

made after February 20, 2023 must be based upon results generated under this test procedure. Upon the compliance date(s) of any energy conservation standard(s) for conventional cooking tops, including the conventional cooking top component of combined cooking products, use of the applicable provisions of this test procedure to demonstrate compliance with the energy conservation standard is required.

0. Incorporation by Reference

DOE incorporated by reference in §430.3, the entire test standard for IEC 60350–2; IEC 62301 (First Edition); and IEC 62301 (Second Edition). However, only enumerated provisions of those standards are applicable to this appendix, as follows. If there is a conflict, the language of the test procedure in this appendix takes precedence over the referenced test standards.

0.1 IEC 60350–2

(a) Section 5.1 as referenced in section 2.4.1 of this appendix;
(b) Section 5.3 as referenced in sections 2.7.1.1, 2.7.3.1, 2.7.3.3, 2.7.3.4, 2.7.4, and 2.7.5 of this appendix;
(c) Section 5.5 as referenced in section 2.5.1 of this appendix;
(d) Section 5.6.1 as referenced in section 2.6.1 of this appendix;
(e) Section 5.6.1.5 as referenced in section 3.1.1.2 of this appendix;
(f) Section 6.3 as referenced in section 3.1.1.1.1 of this appendix;
(g) Section 6.3.1 as referenced in section 3.1.1.1.1 of this appendix;
(h) Section 6.3.2 as referenced in section 3.1.1.1.1 of this appendix;
(i) Section 7.5.1 as referenced in section 2.6.2 of this appendix;
(j) Section 7.5.2 as referenced in section 3.1.4.4 of this appendix;
(k) Section 7.5.2.1 as referenced in sections 1 and 3.1.4.2 of this appendix;
(l) Section 7.5.2.2 as referenced in section 3.1.4.4 of this appendix;
(m) Section 7.5.4.1 as referenced in sections 1 and 3.1.4.5 of this appendix;
(n) Annex A as referenced in section 3.1.1.2 of this appendix;
(o) Annex B as referenced in sections 2.6.1 and 2.8.3 of this appendix; and
(p) Annex C as referenced in section 3.1.4.1 of this appendix.

0.2 IEC 62301 (First Edition)

(a) Paragraph 5.3 as referenced in section 3.2 of this appendix; and
(b) Paragraph 5.3.2 as referenced in section 3.2 of this appendix.

0.3 IEC 62301 (Second Edition)

(a) Paragraph 4.2 as referenced in section 2.4.2 of this appendix;
(b) Paragraph 4.3.2 as referenced in section 2.2.1.1.2 of this appendix;
(c) Paragraph 4.4 as referenced in section 2.7.1.2 of this appendix;
(d) Paragraph 5.1 as referenced in section 3.2 of this appendix; and
(e) Paragraph 5.3.2 as referenced in section 3.2 of this appendix.

1. Definitions

The following definitions apply to the test procedures in this appendix, including the test procedures incorporated by reference:

Active mode means a mode in which the product is connected to a mains power source, has been activated, and is performing the main function of producing heat by means of a gas flame, electric resistance heating, or electric inductive heating.

Built-in means the product is enclosed in surrounding cabinetry, walls, or other similar structures on at least three sides, and can be supported by surrounding cabinetry or the floor.

Combined cooking product means a household cooking appliance that combines a cooking product with other appliance functionality, which may or may not include another cooking product. Combined cooking products include the following products: conventional range, microwave/conventional cooking top, microwave/conventional oven, and microwave/conventional range.

Combined low-power mode means the aggregate of available modes other than active mode, but including the delay start mode portion of active mode.

Cooking area means an area on a conventional cooking top surface heated by an inducted magnetic field where cookware is placed for heating, where more than one cookware item can be used simultaneously and controlled separately from other cookware placed on the cooking area, and that may or may not include limitative markings.

Cooking top control means a part of the conventional cooking top used to adjust the power and the temperature of the cooking zone or cooking area for one cookware item.

Cooking zone means a part of a conventional cooking top surface that is either a single electric resistance heating element, multiple concentric sizes of electric resistance heating elements, an inductive heating element, or a gas surface unit that is defined by limitative markings on the surface of the cooking top and can be controlled independently of any other cooking area or cooking zone.

Cycle finished mode means a standby mode in which a conventional cooking top provides continuous status display following operation in active mode.

Drop-in means the product is supported by horizontal surface cabinetry.

Freestanding means the product is supported by the floor and is not specified in the manufacturer's instructions as able to be installed such that it is enclosed by surrounding cabinetry, walls, or other similar structures.

Inactive mode means a standby mode that facilitates the activation of active mode by remote switch (including remote control), internal sensor, or timer, or that provides continuous status display.

Infinite power settings means a cooking zone control without discrete power settings, which allows for selection of any power setting up to the maximum power setting.

Maximum-below-threshold power setting means the power setting on a conventional cooking top that is the highest power setting that results in smoothened water temperature data that do not meet the evaluation criteria specified in Section 7.5.4.1 of IEC 60350–2.

Maximum power setting means the maximum possible power setting if only one cookware item is used on the cooking zone or cooking area of a conventional cooking top, including any optional power boosting features. For conventional electric cooking tops with multi-ring cooking zones or cooking areas, the maximum power setting is the maximum power corresponding to the concentric heating element with the largest diameter, which may correspond to a power setting which may include one or more of the smaller concentric heating elements. For conventional gas cooking tops with multi-ring cooking zones, the maximum power setting is the maximum heat input rate when the maximum number of rings of the cooking zone are ignited.

Minimum-above-threshold power setting means the power setting on a conventional cooking top that is the lowest power setting that results in smoothened water temperature data that meet the evaluation criteria specified in Section 7.5.4.1 of IEC 60350–2. This power setting is also referred to as the simmering setting.

Multi-ring cooking zone means a cooking zone on a conventional cooking top with multiple concentric sizes of electric resistance heating elements or gas burner rings.

Off mode means any mode in which a product is connected to a mains power source and is not providing any active mode or standby function, and where the mode may persist for an indefinite time. An indicator that only shows the user that the product is in the off position is included within the classification of an off mode.

Power setting means a setting on a cooking zone control that offers a gas flame, electric resistance heating, or electric inductive heating.

Simmering period means, for each cooking zone, the 20-minute period during the simmering test starting at time t_{90}.

Smoothened water temperature means the 40-second moving-average temperature as calculated in Section 7.5.4.1 of IEC 60350–2, rounded to the nearest 0.1 degree Celsius.

Specialty cooking zone means a warming plate, grill, griddle, or any cooking zone that is designed for use only with non-circular cookware, such as a bridge zone. Specialty cooking zones are not tested under this appendix.

Stable temperature means a temperature that does not vary by more than 1 °C over a 5-minute period.

Standard cubic foot of gas means the quantity of gas that occupies 1 cubic foot when saturated with water vapor at a temperature of 60 °F and a pressure of 14.73 pounds per square inch (30 inches of mercury or 101.6 kPa).

Standby mode means any mode in which a product is connected to a mains power source and offers one or more of the following user-oriented or protective functions which may persist for an indefinite time:

(1) Facilitation of the activation of other modes (including activation or deactivation of active mode) by remote switch (including remote control), internal sensor, or timer;

(2) Provision of continuous functions, including information or status displays (including clocks) or sensor-based functions. A timer is a continuous clock function (which may or may not be associated with a display) that allows for regularly scheduled tasks and that operates on a continuous basis.

Target turndown temperature (Tc_{target}) means the temperature as calculated according to Section 7.5.2.1 of IEC 60350–2 and section 3.1.4.2 of this appendix, for each cooking zone.

Thermocouple means a device consisting of two dissimilar metals which are joined together and, with their associated wires, are used to measure temperature by means of electromotive force.

Time t_{90} means the first instant during the simmering test for each cooking zone at which the smoothened water temperature is greater than or equal to 90 °C.

Turndown temperature (T_c) means, for each cooking zone, the measured water temperature at the time at which the tester begins adjusting the cooking top controls to change the power setting.

2. Test Conditions and Instrumentation

2.1 *Installation.* Install the conventional cooking top or combined cooking product in accordance with the manufacturer's instructions. If the manufacturer's instructions specify that the product may be used in multiple installation conditions, install the product according to the built-in configuration. Completely assemble the product with

all handles, knobs, guards, and similar components mounted in place. Position any electric resistance heaters, gas burners, and baffles in accordance with the manufacturer's instructions. If the product can communicate through a network (*e.g.,* Bluetooth® or internet connection), disable the network function, if it is possible to disable it by means provided in the manufacturer's user manual, for the duration of testing. If the network function cannot be disabled, or if means for disabling the function are not provided in the manufacturer's user manual, the product shall be tested in the factory default setting or in the as-shipped condition.

2.1.1 *Freestanding combined cooking product.* Install a freestanding combined cooking product with the back directly against, or as near as possible to, a vertical wall which extends at least 1 foot above the product and 1 foot beyond both sides of the product, and with no side walls.

2.1.2 *Drop-in or built-in combined cooking product.* Install a drop-in or built-in combined cooking product in a test enclosure in accordance with manufacturer's instructions.

2.1.3 *Conventional cooking top.* Install a conventional cooking top with the back directly against, or as near as possible to, a vertical wall which extends at least 1 foot above the product and 1 foot beyond both sides of the product.

2.2 *Energy supply.*

2.2.1 *Electrical supply.*

2.2.1.1 *Supply voltage.*

2.2.1.1.1 *Active mode supply voltage.* During active mode testing, maintain the electrical supply to the product at either 240 volts ±1 percent or 120 volts ±1 percent, according to the manufacturer's instructions, except for products which do not allow for a mains electrical supply. The actual voltage shall be maintained and recorded throughout the test. Instantaneous voltage fluctuations caused by the turning on or off of electrical components shall not be considered.

2.2.1.1.2 *Standby mode and off mode supply voltage.* During standby mode and off mode testing, maintain the electrical supply to the product at either 240 volts ±1 percent, or 120 volts ±1 percent, according to the manufacturer's instructions. Maintain the electrical supply voltage waveform specified in Section 4, Paragraph 4.3.2 of IEC 62301 (Second Edition), disregarding the provisions regarding batteries and the determination, classification, and testing of relevant modes. If the power measuring instrument used for testing is unable to measure and record the total harmonic content during the test measurement period, total harmonic content may be measured and recorded immediately before and after the test measurement period.

2.2.1.2 *Supply frequency.* Maintain the electrical supply frequency for all tests at 60 hertz ±1 percent.

2.2.2 *Gas supply.*

2.2.2.1 *Natural gas.* Maintain the natural gas pressure immediately ahead of all controls of the unit under test at 7 to 10 inches of water column, except as specified in section 3.1.3 of this appendix. The natural gas supplied should have a higher heating value (dry-basis) of approximately 1,025 Btu per standard cubic foot. Obtain the higher heating value on a dry basis of gas, H_n, in Btu per standard cubic foot, for the natural gas to be used in the test either from measurements made by the manufacturer conducting the test using equipment that meets the requirements described in section 2.7.2.2 of this appendix or by the use of bottled natural gas whose gross heating value is certified to be at least as accurate a value that meets the requirements in section 2.7.2.2 of this appendix.

2.2.2.2 *Propane.* Maintain the propane pressure immediately ahead of all controls of the unit under test at 11 to 13 inches of water column, except as specified in section 3.1.3 of this appendix. The propane supplied should have a higher heating value (dry-basis) of approximately 2,500 Btu per standard cubic foot. Obtain the higher heating value on a dry basis of gas, H_p, in Btu per standard cubic foot, for the propane to be used in the test either from measurements made by the manufacturer conducting the test using equipment that meets the requirements described in section 2.7.2.2 of this appendix, or by the use of bottled propane whose gross heating value is certified to be at least as accurate a value that meets the requirements described in section 2.7.2.2 of this appendix.

2.3 *Air circulation.* Maintain air circulation in the room sufficient to secure a reasonably uniform temperature distribution, but do not cause a direct draft on the unit under test.

2.4 *Ambient room test conditions.*

2.4.1 *Active mode ambient conditions.* During active mode testing, maintain the ambient room air pressure specified in Section 5.1 of IEC 60350–2, and maintain the ambient room air temperature at 25 ± 5 °C with a target temperature of 25 °C.

2.4.2 *Standby mode and off mode ambient conditions.* During standby mode and off mode testing, maintain the ambient room air temperature conditions specified in Section 4, Paragraph 4.2 of IEC 62301 (Second Edition).

2.5 *Product temperature.*

2.5.1 *Product temperature stability.* Prior to any testing, the product must achieve a stable temperature meeting the ambient room air temperature specified in section 2.4 of this appendix. For all conventional cooking tops, forced cooling may be used to assist in reducing the temperature of the product between tests, as specified in Section 5.5 of IEC

60350–2. Forced cooling must not be used during the period of time used to assess temperature stability.

2.5.2 *Product temperature measurement.* Measure the product temperature in degrees Celsius using the equipment specified in section 2.7.3.3 of this appendix at the following locations.

2.5.2.1 Measure the product temperature at the center of the cooking zone under test for any gas burner adjustment in section 3.1.3 of this appendix and per-cooking zone energy consumption test in section 3.1.4 of this appendix, except that the product temperature measurement is not required for any potential simmering setting pre-selection test in section 3.1.4.3 of this appendix. For a conventional gas cooking top, measure the product temperature inside the burner body of the cooking zone under test, after temporarily removing any burner cap on that cooking zone.

2.5.2.2 Measure the temperature at the center of each cooking zone for the standby mode and off mode power test in section 3.2 of this appendix. For a conventional gas cooking top, measure the temperature inside the burner body of each cooking zone, after temporarily removing any burner cap on that cooking zone. Calculate the product temperature as the average of the temperatures at the center of each cooking zone.

2.6 *Test loads.*

2.6.1 *Test vessels.* The test vessel for active mode testing of each cooking zone must meet the specifications in Section 5.6.1 and Annex B of IEC 60350–2.

2.6.2 *Water load.* The water used to fill the test vessels for active mode testing must meet the specifications in Section 7.5.1 of IEC 60350–2. The water temperature at the start of each test, except for the gas burner adjustment in section 3.1.3 of this appendix and the potential simmering setting pre-selection test in section 3.1.4.3 of this appendix, must have an initial temperature equal to 25 ± 0.5 °C.

2.7 *Instrumentation.* Perform all test measurements using the following instruments, as appropriate:

2.7.1 *Electrical measurements.*

2.7.1.1 *Active mode watt-hour meter.* The watt-hour meter for measuring the active mode electrical energy consumption must have a resolution as specified in Table 1 of Section 5.3 of IEC 60350–2. Measurements shall be made as specified in Table 2 of Section 5.3 of IEC 60350–2.

2.7.1.2 *Standby mode and off mode watt meter.* The watt meter used to measure standby mode and off mode power must meet the specifications in Section 4, Paragraph 4.4 of IEC 62301 (Second Edition). If the power measuring instrument used for testing is unable to measure and record the crest factor, power factor, or maximum current ratio during the test measurement period, measure the crest factor, power factor, and maximum current ratio immediately before and after the test measurement period to determine whether these characteristics meet the specifications in Section 4, Paragraph 4.4 of IEC 62301 (Second Edition).

2.7.2 *Gas measurements.*

2.7.2.1 *Gas meter.* The gas meter used for measuring gas consumption must have a resolution of 0.01 cubic foot or less and a maximum error no greater than 1 percent of the measured valued for any demand greater than 2.2 cubic feet per hour.

2.7.2.2 *Standard continuous flow calorimeter.* The maximum error of the basic calorimeter must be no greater than 0.2 percent of the actual heating value of the gas used in the test. The indicator readout must have a maximum error no greater than 0.5 percent of the measured value within the operating range and a resolution of 0.2 percent of the full-scale reading of the indicator instrument.

2.7.2.3 *Gas line temperature.* The incoming gas temperature must be measured at the gas meter. The instrument for measuring the gas line temperature shall have a maximum error no greater than ±2 °F over the operating range.

2.7.2.4 *Gas line pressure.* The incoming gas pressure must be measured at the gas meter. The instrument for measuring the gas line pressure must have a maximum error no greater than 0.1 inches of water column.

2.7.3 *Temperature measurements.*

2.7.3.1 *Active mode ambient room temperature.* The room temperature indicating system must meet the specifications in Table 1 of Section 5.3 of IEC 60350–2. Measurements shall be made as specified in Table 2 of Section 5.3 of IEC 60350–2.

2.7.3.2 *Standby mode and off mode ambient room temperature.* The room temperature indicating system must have an error no greater than ±1 °F (±0.6 °C) over the range 65° to 90 °F (18 °C to 32 °C).

2.7.3.3 *Product temperature.* The temperature indicating system must have an error no greater than ±1 °F (±0.6 °C) over the range 65° to 90 °F (18 °C to 32 °C). Measurements shall be made as specified in Table 2 of Section 5.3 of IEC 60350–2.

2.7.3.4 *Water temperature.* Measure the test vessel water temperature with a thermocouple that meets the specifications in Table 1 of Section 5.3 of IEC 60350–2. Measurements shall be made as specified in Table 2 of Section 5.3 of IEC 60350–2.

2.7.4 *Room air pressure.* The room air pressure indicating system must meet the specifications in Table 1 of Section 5.3 of IEC 60350–2.

2.7.5 *Water mass.* The scale used to measure the mass of the water load must meet the specifications in Table 1 of Section 5.3 of IEC 60350–2.

2.8 *Power settings.*

2.8.1 On a multi-ring cooking zone on a conventional gas cooking top, all power settings are considered, whether they ignite all rings of orifices or not.

2.8.2 On a multi-ring cooking zone on a conventional electric cooking top, only power settings corresponding to the concentric heating element with the largest diameter are considered, which may correspond to operation with one or more of the smaller concentric heating elements energized.

2.8.3 On a cooking zone with infinite power settings where the available range of rotation from maximum to minimum is more than 150 rotational degrees, evaluate power settings that are spaced by 10 rotational degrees. On a cooking zone with infinite power settings where the available range of rotation from maximum to minimum is less than or equal to 150 rotational degrees, evaluate power settings that are spaced by 5 rotational degrees, starting with the first position that meets the definition of a power setting, irrespective of how the knob is labeled. Polar coordinate paper, as provided in Annex B of IEC 60350–2 may be used to mark power settings.

3. Test Methods and Measurements


3.1 *Active mode.* Perform the following test methods for conventional cooking tops and the conventional cooking top component of a combined cooking product.

3.1.1 *Test vessel and water load selection.*

3.1.1.1 *Conventional electric cooking tops.*

3.1.1.1.1 For cooking zones, measure the size of each cooking zone as specified in Section 6.3.2 of IEC 60350–2, not including any specialty cooking zones as defined in section 1 of this appendix. For circular cooking zones on smooth cooking tops, the cooking zone size is determined using the outer diameter of the printed marking, as specified in Section 6.3 of IEC 60350–2. For open coil cooking zones, the cooking zone size is determined using the widest diameter of the coil, see Figure 3.1.1.1. For non-circular cooking zones, the cooking zone size is determined by the measurement of the shorter side or minor axis. For cooking areas, determine the number of cooking zones as specified in Section 6.3.1 of IEC 60350–2.

Figure 3.1.1.1 Evaluation of the Size of a Coil Cooking Zone



3.1.1.1.2 Determine the test vessel diameter in millimeters (mm) and water load mass in grams (g) for each measured cooking zone. For cooking zones, test vessel selection is based on cooking zone size as specified in Table 3 in Section 5.6.1.5 of IEC 60350–2. For cooking areas, test vessel selection is based on the number of cooking zones as specified in Annex A of IEC 60350–2. If a selected test vessel (including its lid) cannot be centered on the cooking zone due to interference with a structural component of the cooking top, the test vessel with the largest diameter that can be centered on the cooking zone shall be used. The allowable tolerance on the water load weight is ±0.5 g.

3.1.1.2 *Conventional gas cooking tops.*

3.1.1.2.1 Record the nominal heat input rate for each cooking zone, not including any specialty cooking zones as defined in section 1 of this appendix.

3.1.1.2.2 Determine the test vessel diameter in mm and water load mass in g for each measured cooking zone according to Table 3.1 of this appendix. If a selected test vessel cannot be centered on the cooking zone due to interference with a structural component of the cooking top, the test vessel with the largest diameter that can be centered on the cooking zone shall be used. The allowable tolerance on the water load weight is ±0.5 g.

TABLE 3.1—TEST VESSEL SELECTION FOR CONVENTIONAL GAS COOKING TOPS

Nominal gas burner input rate (Btu/h)		Test vessel diameter (mm)	Water load mass (g)
Minimum (>)	Maximum (≤)		
	5,600	210	2,050
5,600	8,050	240	2,700
8,050	14,300	270	3,420
14,300	.....	300	4,240

3.1.2 *Unit Preparation.* Before the first measurement is taken, all cooking zones must be operated simultaneously for at least 10 minutes at maximum power. This step shall be conducted once per product.

3.1.3 *Gas burner adjustment.* Prior to active mode testing of each tested burner of a conventional gas cooking top, the burner heat input rate must be adjusted, if necessary, to within 2 percent of the nominal heat input rate of the burner as specified by the manufacturer. Prior to ignition and any adjustment of the burner heat input rate, the conventional cooking top must achieve the product temperature specified in section 2.5 of this appendix. Ignite and operate the gas burner under test with the test vessel and water mass specified in section 3.1.1 of this appendix. Measure the heat input rate of the gas burner under test starting 5 minutes after ignition. If the measured input rate of the gas burner under test is within 2 percent of the nominal heat input rate of the burner as specified by the manufacturer, no adjustment of the heat input rate shall be made.

3.1.3.1 *Conventional gas cooking tops with an adjustable internal pressure regulator.* If the measured heat input rate of the burner under test is not within 2 percent of the nominal heat input rate of the burner as specified by the manufacturer, adjust the product's internal pressure regulator such that the heat input rate of the burner under test is within 2 percent of the nominal heat input rate of the burner as specified by the manufacturer. Adjust the burner with sufficient air flow to prevent a yellow flame or a flame with yellow tips. Complete section 3.1.4 of this appendix while maintaining the same gas pressure regulator adjustment.

3.1.3.2 *Conventional gas cooking tops with a non-adjustable internal pressure regulator or without an internal pressure regulator.* If the measured heat input rate of the burner under test is not within 2 percent of the nominal heat input rate of the burner as specified by the manufacturer, remove the product's internal pressure regulator, or block it in the open position, and initially maintain the gas pressure ahead of all controls of the unit under test approximately equal to the manufacturer's recommended manifold pressure. Adjust the gas supply pressure such that the heat input rate of the burner under test is within 2 percent of the nominal heat input rate of the burner as specified by the manufacturer. Adjust the burner with sufficient air flow to prevent a yellow flame or a flame with yellow tips. Complete section 3.1.4 of this appendix while maintaining the same gas pressure regulator adjustment.

3.1.4 *Per-cooking zone energy consumption test.* Establish the test conditions set forth in section 2 of this appendix. Turn off the gas flow to the conventional oven(s), if so equipped. The product temperature must meet the specifications in section 2.5 of this appendix.

3.1.4.1 *Test vessel placement.* Position the test vessel with water load for the cooking zone under test, selected and prepared as specified in section 3.1.1 of this appendix, in the center of the cooking zone, and as specified in Annex C to IEC 60350–2.

3.1.4.2 *Overshoot test.* Use the test methods set forth in Section 7.5.2.1 of IEC 60350–2 to determine the target turndown temperature for each cooking zone, Tc_{target}, in degrees Celsius, as follows.

$Tc_{target} = 93\ °C - (T_{max} - T_{70})$

Where:

T_{max} is highest recorded temperature value, in degrees Celsius; and

T_{70} is the average recorded temperature between the time 10 seconds before the power is turned off and the time 10 seconds after the power is turned off.

If T_{70} is within the tolerance of 70 ± 0.5 °C, the target turndown temperature is the highest of 80 °C and the calculated Tc_{target}, rounded to the nearest integer. If T_{70} is outside of the tolerance, the overshoot test is considered invalid and must be repeated after allowing the product to return to ambient conditions.

3.1.4.3 *Potential simmering setting pre-selection test.* The potential simmering setting for each cooking zone may be determined using the potential simmering setting pre-selecting test. If a potential simmering setting is already known, it may be used instead of completing sections 3.1.4.3.1 through 3.1.4.3.4 of this appendix.

3.1.4.3.1 Use the test vessel with water load for the cooking zone under test, selected, prepared, and positioned as specified in sections 3.1.1 and 3.1.4.1 of this appendix. The temperature of the conventional cooking top is not required to meet the specification for the product temperature in section 2.5 of this appendix for the potential simmering setting pre-selection test. Operate the cooking zone under test with the lowest available power setting. Measure the energy consumption for 10 minutes ±2 seconds.

3.1.4.3.2 Calculate the power density of the power setting, j, on a conventional electric cooking top, Qe_j, in watts per square centimeter, as:

$$Qe_j = \frac{6 \times E_j}{a}$$

Where:

a = the surface area of the test vessel bottom, in square centimeters; and

E_j = the electrical energy consumption during the 10-minute test, in Wh.

3.1.4.3.3 Calculate the power density of the power setting, j, on a conventional gas cooking top, Qg_j, in Btu/h per square centimeter, as:

$$Qg_j = \frac{6 \times \left(V_j \times CF \times H + Ee_j \times K_e\right)}{a}$$

Where:

a = the surface area of the test vessel bottom, in square centimeters;

V_j = the volume of gas consumed during the 10-minute test, in cubic feet;

CF = the gas correction factor to standard temperature and pressure, as calculated in section 4.1.1.2.1 of this appendix;

H = either H_n or H_p, the heating value of the gas used in the test as specified in sections 2.2.2.1 and 2.2.2.2 of this appendix, in Btu per standard cubic foot of gas;

Ee_j = the electrical energy consumption of the conventional gas cooking top during the 10-minute test, in Wh; and

K_e = 3.412 Btu/Wh, conversion factor of watt-hours to Btu.

3.1.4.3.4 Repeat the measurement for each successively higher power setting until Qe_j exceeds 0.8 W/cm² for conventional electric cooking tops or Qg_j exceeds 4.0 Btu/h·cm² for conventional gas cooking tops.

For conventional cooking tops with rotating knobs for selecting the power setting, the selection knob shall be turned to the maximum power setting in between each test, to avoid hysteresis. The selection knob shall be turned in the direction from higher power to lower power to select the power setting for the test. If the appropriate power setting is passed, the selection knob shall be turned to the maximum power setting again before repeating the power setting selection.

Of the last two power settings tested, the potential simmering setting is the power setting that produces a power density closest to 0.8 W/cm² for conventional electric cooking tops or 4.0 Btu/h·cm² for conventional gas cooking tops. The closest power density may be higher or lower than the applicable threshold value.


3.1.4.4 *Simmering test.* The product temperature must meet the specifications in section 2.5 of this appendix at the start of each simmering test. For each cooking zone, conduct the test method specified in Section 7.5.2 of IEC 60350–2, using the potential simmering setting identified in section 3.1.4.3 of this appendix for the initial simmering setting used in Section 7.5.2.2 of IEC 60350–2.

For conventional cooking tops with rotating knobs for selecting the power setting, the selection knob shall be turned in the direction from higher power to lower power to

select the potential simmering setting for the test, to avoid hysteresis. If the appropriate setting is passed, the test is considered invalid and must be repeated after allowing the product to return to ambient conditions.

3.1.4.5 *Evaluation of the simmering test.* Evaluate the test conducted under section 3.1.4.4 of this appendix as set forth in Section 7.5.4.1 of IEC 60350–2 according to Figure 3.1.4.5 of this appendix. If the measured turndown temperature, Tc, is not within –0.5 °C and +1 °C of the target turndown temperature, Tc_{target}, the test is considered invalid and must be repeated after allowing the product to return to ambient conditions.

Figure 3.1.4.5 Evaluation of the Simmering Test



3.2 *Standby mode and off mode power.* Establish the standby mode and off mode testing conditions set forth in section 2 of this appendix. For products that take some time to enter a stable state from a higher power state as discussed in Section 5, Paragraph 5.1, Note 1 of IEC 62301 (Second Edition), allow sufficient time for the product to reach the lower power state before proceeding with the test measurement. Follow the test procedure as specified in Section 5, Paragraph 5.3.2 of IEC 62301 (Second Edition) for testing in each possible mode as described in sections 3.2.1 and 3.2.2 of this appendix. For units in which power varies as a function of displayed time in standby mode, set the clock time to 3:23 at the end of an initial stabilization period, as specified in Section 5, Paragraph 5.3 of IEC 62301 (First Edition). After an additional 10-minute stabilization period, measure the power use for a single test period of 10 minutes +0/−2 seconds that starts when the clock time first reads 3:33. Use the average power approach described in Section 5, Paragraph 5.3.2(a) of IEC 62301 (First Edition).

3.2.1 If the product has an inactive mode, as defined in section 1 of this appendix, measure the average inactive mode power, P_{IA}, in watts.

3.2.2 If the product has an off mode, as defined in section 1 of this appendix, measure the average off mode power, P_{OM}, in watts.

3.3 *Recorded values.*

3.3.1 *Active mode.*

3.3.1.1 For a conventional gas cooking top tested with natural gas, record the natural gas higher heating value in Btu per standard cubic foot, H_n, as determined in section 2.2.2.1 of this appendix for the natural gas supply, for each test. For a conventional gas cooking top tested with propane, record the propane higher heating value in Btu per standard cubic foot, H_p, as determined in section 2.2.2.2 of this appendix for the propane supply, for each test.

3.3.1.2 Record the test room temperature in degrees Celsius and relative air pressure in hectopascals (hPa) during each test.

3.3.1.3 *Per-cooking zone energy consumption test.*

3.3.1.3.1 Record the product temperature in degrees Celsius, T_P, prior to the start of each overshoot test or simmering test, as determined in section 2.5 of this appendix.

3.3.1.3.2 *Overshoot test.* For each cooking zone, record the initial temperature of the water in degrees Celsius, $T_{i\geq}$ the average water temperature between the time 10 seconds before the power is turned off and the time 10 seconds after the power is turned off in degrees Celsius, T_{70}; the highest recorded water temperature in degrees Celsius, T_{max}; and the target turndown temperature in degrees Celsius, Tc_{target}.

3.3.1.3.3 *Simmering test.* For each cooking zone, record the temperature of the water throughout the test, in degrees Celsius, and the values in sections 3.3.1.3.3.1 through 3.3.1.3.3.7 of this appendix for the Energy Test Cycle, if an Energy Test Cycle is measured in section 3.1.4.5 of this appendix, otherwise for both the maximum-below-threshold power setting and the minimum-above-threshold power setting. Because t_{90} may not be known until completion of the simmering test, water temperature, any electrical energy consumption, and any gas volumetric consumption measurements may be recorded for several minutes after the end of the simmering period to ensure that the full simmering period is recorded.

3.3.1.3.3.1 The power setting under test.

3.3.1.3.3.2 The initial temperature of the water, in degrees Celsius, T_i.

3.3.1.3.3.3 The time at which the tester begins adjusting the cooking top control to change the power setting, to the nearest second, t_c and the turndown temperature, in degrees Celsius, Tc.

3.3.1.3.3.4 The time at which the simmering period starts, to the nearest second, t_{90}.

3.3.1.3.3.5 The time at which the simmering period ends, to the nearest second, t_S and the smoothened water temperature at the end of the simmering period, in degrees Celsius, T_S.

3.3.1.3.3.6 For a conventional electric cooking top, the electrical energy consumption from the start of the test to t_S, E, in watt-hours.

3.3.1.3.3.7 For a conventional gas cooking top, the volume of gas consumed from the start of the test to t_S, V, in cubic feet of gas; and any electrical energy consumption of the cooking top from the start of the test to t_S, E_e, in watt-hours.

3.3.2 *Standby mode and off mode.* Make measurements as specified in section 3.2 of this appendix. If the product is capable of operating in inactive mode, as defined in section 1 of this appendix, record the average inactive mode power, P_{IA}, in watts as specified in section 3.2.1 of this appendix. If the product is capable of operating in off mode, as defined in section 1 of this appendix, record the average off mode power, P_{OM}, in watts as specified in section 3.2.2 of this appendix.

4. Calculation of Derived Results From Test Measurements

4.1. Active mode energy consumption of conventional cooking tops and any conventional cooking top component of a combined cooking product.

4.1.1 Per-cycle active mode energy consumption of a conventional cooking top and any conventional cooking top component of a combined cooking product.

4.1.1.1 Conventional electric cooking top per-cycle active mode energy consumption.

4.1.1.1.1 Conventional electric cooking top per-cooking zone normalized active mode energy consumption. For each cooking zone, calculate the per-cooking zone normalized active mode energy consumption of a conventional electric cooking top, E, in watt-hours, using the following equation:

$E = E_{ETC}$

for cooking zones where an Energy Test Cycle was measured in section 3.1.4.5 of this appendix, and

$$E = E_{MAT} - \frac{E_{MAT} - E_{MBT}}{T_{S,MAT} - T_{S,MBT}} \times (T_{S,MAT} - 90)$$

for cooking zones where a minimum-above-threshold cycle and a maximum-below-threshold cycle were measured in section 3.1.4.5 of this appendix.

Where:

E_{ETC} = the electrical energy consumption of the Energy Test Cycle from the start of the test to the end of the test for the cooking zone, as determined in section 3.1.4.5 of this appendix, in watt-hours;

E_{MAT} = the electrical energy consumption of the minimum-above-threshold power setting from the start of the test to the end of the test for the cooking zone, as determined in section 3.1.4.5 of this appendix, in watt-hours;

E_{MBT} = the electrical energy consumption of the maximum-below-threshold power setting from the start of the test to the end of the test for the cooking zone, as determined in section 3.1.4.5 of this appendix, in watt-hours;

$T_{S,MAT}$ = the smoothened water temperature at the end of the minimum-above-threshold power setting test for the cooking zone, in degrees Celsius; and

$T_{S,MBT}$ = the smoothened water temperature at the end of the maximum-below-threshold power setting test for the cooking zone, in degrees Celsius.

4.1.1.1.2 Calculate the per-cycle active mode total energy consumption of a conventional electric cooking top, E_{CET}, in watt-hours, using the following equation:

$$E_{CET} = \frac{2853g}{n} \times \sum_{z=1}^{n} \frac{E_z}{m_z}$$

Where:

n = the total number of cooking zones tested on the conventional cooking top;

E_z = the normalized energy consumption representative of the Energy Test Cycle for each cooking zone, as calculated in section 4.1.1.1.1 of this appendix, in watt-hours;

m_z is the mass of water used for each cooking zone, in grams; and

2853 = the representative water load mass, in grams.

4.1.1.2 Conventional gas cooking top per-cycle active mode energy consumption.

4.1.1.2.1 Gas correction factor to standard temperature and pressure. Calculate the gas correction factor to standard temperature and pressure, which converts between standard cubic feet and measured cubic feet of gas for a given set of test conditions:

$$CF = \frac{(P_{gas} \times 0.0361) + P_{atm}}{P_{base}} \times \frac{T_{base}}{(T_{gas} + T_k)}$$

Where:

P_{gas} = the measured line gas gauge pressure, in inches of water column;

0.0361= the conversion factor from inches of water column to pounds per square inch;

P_{atm} = the measured atmospheric pressure, in pounds per square inch;

P_{base} = 14.73 pounds per square inch, the standard sea level air pressure;

T_{base} = 519.67 degrees Rankine (or 288.7 Kelvin);

T_{gas} = the measured line gas temperature, in degrees Fahrenheit (or degrees Celsius); and

T_k = the adder converting from degrees Fahrenheit to degrees Rankine, 459.7 (or from degrees Celsius to Kelvin, 273.16).

4.1.1.2.2 Conventional gas cooking top per-cooking zone normalized active mode gas energy consumption. For each cooking zone, calculate the per-cooking zone normalized active mode gas energy consumption of a conventional gas cooking top, E_g, in Btu, using the following equation:

$E_g = E_{gt,ETC}$

for cooking zones where an Energy Test Cycle was measured in section 3.1.4.5 of this appendix, and

$$E_g = E_{gt,MAT} - \frac{E_{gt,MAT} - E_{gt,MBT}}{T_{S,MAT} - T_{S,MBT}} \times (T_{S,MAT} - 90)$$

for cooking zones where a minimum-above-threshold cycle and a maximum-below-threshold cycle were measured in section 3.1.4.5 of this appendix.

Where:

$E_{gt,ETC}$ = the as-tested gas energy consumption of the Energy Test Cycle for the cooking zone, in Btu, calculated as the product of: V, the gas consumption of the Energy Test Cycle, as determined in section 3.1.4.5 of this appendix, in cubic feet; CF, the gas correction factor to standard temperature and pressure for the test, as calculated in section 4.1.1.2.1 of this appendix; and H, either H_n or H_p, the heating value of the gas used in the test as specified in sections 2.2.2.1 and 2.2.2.2 of this appendix, expressed in Btu per standard cubic foot of gas;

$E_{gt,MAT}$ = the as-tested gas energy consumption of the minimum-above-threshold power setting for the cooking zone, in Btu, calculated as the product of: V, the gas consumption of the minimum-above-threshold power setting, as determined in section 3.1.4.5 of this appendix, in cubic feet; CF, the gas correction factor to standard temperature and pressure for the test, as calculated in section 4.1.1.2.1 of this appendix; and H, either H_n or H_p, the heating value of the gas used in the test as specified in sections 2.2.2.1 and 2.2.2.2 of this appendix, expressed in Btu per standard cubic foot of gas;

$E_{gt,MBT}$ = the as-tested gas energy consumption of the maximum-below-threshold power setting for the cooking zone, in Btu, calculated as the product of: V, the gas consumption of the maximum-below-threshold power setting, as determined in section 3.1.4.5 of this appendix, in cubic feet; CF, the gas correction factor to standard temperature and pressure for the test, as calculated in section 4.1.1.2.1 of this appendix; and H, either H_n or H_p, the heating value of the gas used in the test as specified in sections 2.2.2.1 and 2.2.2.2 of this appendix, expressed in Btu per standard cubic foot of gas;

$T_{S,MAT}$ = the smoothened water temperature at the end of the minimum-above-threshold power setting test for the cooking zone, in degrees Celsius; and

$T_{S,MBT}$ = the smoothened water temperature at the end of the maximum-below-threshold power setting test for the cooking zone, in degrees Celsius.

4.1.1.2.3 Conventional gas cooking top per-cooking zone active mode normalized electrical energy consumption. For each cooking zone, calculate the per-cooking zone normalized active mode electrical energy consumption of a conventional gas cooking top, E_e, in watt-hours, using the following equation:

$E_e = E_{e,ETC}$

for cooking zones where an Energy Test Cycle was measured in section 3.1.4.5 of this appendix, and

$$E_e = E_{e,MAT} - \frac{E_{e,MAT} - E_{e,MBT}}{T_{S,MAT} - T_{S,MBT}} \times (T_{S,MAT} - 90)$$

for cooking zones where a minimum-above-threshold cycle and a maximum-below-threshold cycle were measured in section 3.1.4.5 of this appendix.

Where:

$E_{e,ETC}$ = the electrical energy consumption of the Energy Test Cycle from the start of the test to the end of the test for the cooking zone, as determined in section 3.1.4.5 of this appendix, in watt-hours;

$E_{e,MAT}$ = the electrical energy consumption of the minimum-above-threshold power setting from the start of the test to the end of the test for the cooking zone, as determined in section 3.1.4.5 of this appendix, in watt-hours;

$E_{e,MBT}$ = the electrical energy consumption of the maximum-below-threshold power setting from the start of the test to the end of the test for the cooking zone, as determined in section 3.1.4.5 of this appendix, in watt-hours;

$T_{S,MAT}$ = the smoothened water temperature at the end of the minimum-above-threshold power setting test for the cooking zone, in degrees Celsius; and

$T_{S,MBT}$ = the smoothened water temperature at the end of the maximum-below-threshold power setting test for the cooking zone, in degrees Celsius.

4.1.1.2.4 Conventional gas cooking top per-cycle active mode gas energy consumption. Calculate the per-cycle active mode gas energy consumption of a conventional gas cooking top, E_{CGG}, in Btu, using the following equation:

$$E_{CGG} = \frac{2853g}{n} \times \sum_{z=1}^{n} \frac{E_{gz}}{m_z}$$

Where:

n, m_z, and 2853 are defined in section 4.1.1.1.2 of this appendix; and

E_{gz} = the normalized gas energy consumption representative of the Energy Test Cycle for each cooking zone, as calculated in section 4.1.1.2.2 of this appendix, in Btu.

4.1.1.2.5 Conventional gas cooking top per-cycle active mode electrical energy consumption. Calculate the per-cycle active mode electrical energy consumption of a conventional gas cooking top, E_{CGE}, in watt-hours, using the following equation:

$$E_{CGE} = \frac{2853g}{n} \times \sum_{z=1}^{n} \frac{E_{ez}}{m_z}$$

Where:

n, m_z, and 2853 are defined in section 4.1.1.1.2 of this appendix; and

E_{ez} = the normalized electrical energy consumption representative of the Energy Test Cycle for each cooking zone, as calculated in section 4.1.1.2.3 of this appendix, in watt-hours.

4.1.1.2.6 Conventional gas cooking top per-cycle active-mode total energy consumption. Calculate the per-cycle active mode total energy consumption of a conventional gas cooking top, E_{CGT}, in Btu, using the following equation:

$E_{CGT} = E_{CGG} + (E_{CGE} \times K_e)$

Where:

E_{CGG} = the per-cycle active mode gas energy consumption of a conventional gas cooking top as determined in section 4.1.1.2.4 of this appendix, in Btu;

E_{CGE} = the per-cycle active mode electrical energy consumption of a conventional gas cooking top as determined in section 4.1.1.2.5 of this appendix, in watt-hours; and

K_e = 3.412 Btu/Wh, conversion factor of watt-hours to Btu.

4.1.2 Annual active mode energy consumption of a conventional cooking top and any conventional cooking top component of a combined cooking product.

4.1.2.1 Conventional electric cooking top annual active mode energy consumption. Calculate the annual active mode total energy consumption of a conventional electric cooking top, E_{AET}, in kilowatt-hours per year, using the following equation:

$E_{AET} = E_{CET} \times K \times N_C$

Where:

E_{CET} = the conventional electric cooking top per-cycle active mode total energy consumption, as determined in section 4.1.1.1.2 of this appendix, in watt-hours;

K = 0.001 kWh/Wh conversion factor for watt-hours to kilowatt-hours; and

N_C = 418 cooking cycles per year, the average number of cooking cycles per year normalized for duration of a cooking event estimated for conventional cooking tops.

4.1.2.2 Conventional gas cooking top annual active mode energy consumption.

4.1.2.2.1 Conventional gas cooking top annual active mode gas energy consumption. Calculate the annual active mode gas energy consumption of a conventional gas cooking top, E_{AGG}, in kBtu per year, using the following equation:

$E_{AGG} = E_{CGG} \times K \times N_C$

Where:

K and N_C are defined in section 4.1.2.1 of this appendix; and

E_{CGG} = the conventional gas cooking top per-cycle active mode gas energy consumption, as determined in section 4.1.1.2.4 of this appendix, in Btu.

4.1.2.2.2 Conventional gas cooking top annual active mode electrical energy consumption. Calculate the annual active mode electrical energy consumption of a conventional gas cooking top, E_{AGE}, in kilowatt-hours per year, using the following equation:

$E_{AGE} = E_{CGE} \times K \times N_C$

Where:

K and N_C are defined in section 4.1.2.1 of this appendix; and

E_{CGE} = the conventional gas cooking top per-cycle active mode electrical energy consumption, as determined in section 4.1.1.2.5 of this appendix, in watt-hours.

4.1.2.2.3 Conventional gas cooking top annual active mode total energy consumption. Calculate the annual active mode total energy consumption of a conventional gas cooking top, E_{AGT}, in kBtu per year, using the following equation:

$E_{AGT} = E_{AGG} + (E_{AGE} \times K_e)$

Where:

E_{AGG} = the conventional gas cooking top annual active mode gas energy consumption as determined in section 4.1.2.2.1 of this appendix, in kBtu per year;

E_{AGE} = the conventional gas cooking top annual active mode electrical energy consumption as determined in section 4.1.2.2.2 of this appendix, in kilowatt-hours per year; and

K_e is defined in section 4.1.1.2.6 of this appendix.

4.2 Annual combined low-power mode energy consumption of a conventional cooking top and any conventional cooking top component of a combined cooking product.

4.2.1 Conventional cooking top annual combined low-power mode energy consumption. Calculate the annual combined low-power mode energy consumption for a conventional cooking top, E_{TLP}, in kilowatt-hours per year, using the following equation:

$$E_{TLP} = [(P_{IA} \times F_{IA}) + (P_{OM} \times F_{OM})] \times K \times S_T$$

Where:

P_{IA} = inactive mode power, in watts, as measured in section 3.2.1 of this appendix;

P_{OM} = off mode power, in watts, as measured in section 3.2.2 of this appendix;

F_{IA} and F_{OM} are the portion of annual hours spent in inactive mode and off mode hours respectively, as defined in Table 4.2.1 of this appendix;

K = 0.001 kWh/Wh conversion factor for watt-hours to kilowatt-hours; and

S_T = 8,544, total number of inactive mode and off mode hours per year for a conventional cooking top.

TABLE 4.2.1—ANNUAL HOUR MULTIPLIERS

Types of low-power mode(s) available	F_{IA}	F_{OM}
Both inactive and off mode	0.5	0.5
Inactive mode only	1	0
Off mode only	0	1

4.2.2 Conventional cooking top component of a combined cooking product annual combined low-power mode energy consumption. Calculate the annual combined low-power mode energy consumption for the conventional cooking top component of a combined cooking product, E_{TLP}, in kilowatt-hours per year, using the following equation:

$$E_{TLP} = [(P_{IA} \times F_{IA}) + (P_{OM} \times F_{OM})] \times K \times S_{TOT} \times H_C$$

Where:

P_{IA}, P_{OM}, F_{IA}, F_{OM}, and K are defined in section 4.2.1 of this appendix;

S_{TOT} = the total number of inactive mode and off mode hours per year for a combined cooking product, as defined in Table 4.2.2 of this appendix; and

H_C = the percentage of hours per year assigned to the conventional cooking top component of a combined cooking product, as defined in Table 4.2.2 of this appendix.

TABLE 4.2.2—COMBINED COOKING PRODUCT USAGE FACTORS

Type of combined cooking product	S_{TOT}	H_C
Cooking top and conventional oven (conventional range)	8,392	60
Cooking top and microwave oven	8,481	77
Cooking top, conventional oven, and microwave oven	8,329	51

4.3 Integrated annual energy consumption of a conventional cooking top and any conventional cooking top component of a combined cooking product.

4.3.1 Conventional electric cooking top integrated annual energy consumption. Calculate the integrated annual energy consumption, IAEC, of a conventional electric cooking top, in kilowatt-hours per year, using the following equation:

$$IAEC = E_{AET} + E_{TLP}$$

Where:

E_{AET} = the conventional electric cooking top annual active mode energy consumption, as determined in section 4.1.2.1 of this appendix; and

E_{TLP} = the annual combined low-power mode energy consumption of a conventional cooking top or any conventional cooking top component of a combined cooking product, as determined in section 4.2 of this appendix.

4.3.2 Conventional gas cooking top integrated annual energy consumption. Calculate the integrated annual energy consumption, IAEC, of a conventional gas cooking top, in kBtu per year, defined as:

$$IAEC = E_{AGT} + (E_{TLP} \times K_e)$$

Where:

E_{AGT} = the conventional gas cooking top annual active mode total energy consumption, as determined in section 4.1.2.2.3 of this appendix;

E_{TLP} = the annual combined low-power mode energy consumption of a conventional cooking top or any conventional cooking top component of a combined cooking product, as determined in section 4.2 of this appendix; and

K_e is defined in section 4.1.1.2.6 of this appendix.

[87 FR 51538, Aug. 22, 2022, as amended at 88 FR 7847, Feb. 7, 2023]

APPENDIX J TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF AUTOMATIC AND SEMI-AUTOMATIC CLOTHES WASHERS

NOTE 1 TO APPENDIX J TO SUBPART B OF PART 430: Manufacturers must use the results of testing under appendix J2 to this subpart to determine compliance with the residential clothes washer standards provided at §430.32(g)(1) and the commercial clothes washer standards provided at §431.156(b).

Manufacturers must use the results of testing under this appendix to determine compliance with the residential clothes washer standards provided at §430.32(g)(2) and for any amended commercial clothes washer standards provided at §431.156 that are published after January 1, 2022.

Any representations related to energy or water consumption of residential or commercial clothes washers must be made in accordance with the appropriate appendix that applies (*i.e.*, this appendix or appendix J2 to this subpart) when determining compliance with the relevant standard. Manufacturers may also use this appendix to certify compliance with the residential clothes washer standards provided at §430.32(g)(2) or any amended standards for commercial clothes washers prior to the applicable compliance date for those standards.

0. Incorporation by Reference

DOE incorporated by reference in §430.3, the entire test standard for IEC 62301. However, only enumerated provisions of this standard are applicable to this appendix, as follows. In cases in which there is a conflict, the language of the test procedure in this appendix takes precedence over the referenced test standard.

0.1 IEC 62301:

(a) Section 4.2 as referenced in section 2.4 of this appendix;

(b) Section 4.3.2 as referenced in section 2.1.2 of this appendix;

(c) Section 4.4 as referenced in section 2.5.3 of this appendix;

(d) Section 5.1 as referenced in section 3.5.2 of this appendix;

(e) Section 5.2 as referenced in section 2.10.2 of this appendix; and

(f) Section 5.3.2 as referenced in section 3.5.3 of this appendix.

0.2 [Reserved]

1. Definitions

Active mode means a mode in which the clothes washer is connected to a mains power source, has been activated, and is performing one or more of the main functions of washing, soaking, tumbling, agitating, rinsing, and/or removing water from the clothing, or is involved in functions necessary for these main functions, such as admitting water into the washer or pumping water out of the washer. Active mode also includes delay start and cycle finished modes.

Active-mode energy efficiency ratio means the quotient of the weighted-average load size divided by the total clothes washer energy consumption per cycle, with such energy consumption expressed as the sum of the machine electrical energy consumption, the hot water energy consumption, and the energy required for removal of the remaining moisture in the wash load.

Active washing mode means a mode in which the clothes washer is performing any of the operations included in a complete cycle intended for washing a clothing load, including the main functions of washing, soaking, tumbling, agitating, rinsing, and/or removing water from the clothing.

Bone-dry means a condition of a load of test cloth that has been dried in a dryer at maximum temperature for a minimum of 10 minutes, removed and weighed before cool down, and then dried again for 10 minute periods until the final weight change of the load is 1 percent or less.

Clothes container means the compartment within the clothes washer that holds the clothes during the operation of the machine.

Cold rinse means the coldest rinse temperature available on the machine, as indicated to the user on the clothes washer control panel.

Combined low-power mode means the aggregate of available modes other than active washing mode, including inactive mode, off mode, delay start mode, and cycle finished mode.

Cycle finished mode means an active mode that provides continuous status display, intermittent tumbling, or air circulation following operation in active washing mode.

Delay start mode means an active mode in which activation of active washing mode is facilitated by a timer.

Energy efficiency ratio means the quotient of the weighted-average load size divided by the total clothes washer energy consumption per cycle, with such energy consumption expressed as the sum of:

(a) The machine electrical energy consumption;

(b) The hot water energy consumption;

(c) The energy required for removal of the remaining moisture in the wash load; and

(d) The combined low-power mode energy consumption.

Energy test cycle means the complete set of wash/rinse temperature selections required for testing, as determined according to section 2.12 of this appendix.

Fixed water fill control system means a clothes washer water fill control system that automatically terminates the fill when the water reaches a pre-defined level that is not based on the size or weight of the clothes

load placed in the clothes container, without allowing or requiring the user to determine or select the water fill level.

Inactive mode means a standby mode that facilitates the activation of active mode by remote switch (including remote control), internal sensor, or timer, or that provides continuous status display.

Load usage factor means the percentage of the total number of wash loads that a user would wash a particular size (weight) load.

Lot means a quantity of cloth that has been manufactured with the same batches of cotton and polyester during one continuous process.

Manual water fill control system means a clothes washer water fill control system that requires the user to determine or select the water fill level.

Non-user-adjustable adaptive water fill control system means a clothes washer water fill control system that is capable of automatically adjusting the water fill level based on the size or weight of the clothes load placed in the clothes container.

Normal cycle means the cycle recommended by the manufacturer (considering manufacturer instructions, control panel labeling, and other markings on the clothes washer) for normal, regular, or typical use for washing up to a full load of normally soiled cotton clothing. For machines where multiple cycle settings are recommended by the manufacturer for normal, regular, or typical use for washing up to a full load of normally soiled cotton clothing, then the Normal cycle is the cycle selection that results in the lowest EER or AEER value.

Off mode means a mode in which the clothes washer is connected to a mains power source and is not providing any active or standby mode function, and where the mode may persist for an indefinite time.

Standby mode means any mode in which the clothes washer is connected to a mains power source and offers one or more of the following user oriented or protective functions that may persist for an indefinite time:

(a) Facilitating the activation of other modes (including activation or deactivation of active mode) by remote switch (including remote control), internal sensor, or timer;

(b) Continuous functions, including information or status displays (including clocks) or sensor-based functions.

A timer is a continuous clock function (which may or may not be associated with a display) that provides regular scheduled tasks (*e.g.,* switching) and that operates on a continuous basis.

Temperature use factor means, for a particular wash/rinse temperature setting, the percentage of the total number of wash loads that an average user would wash with that setting.

User-adjustable adaptive water fill control system means a clothes washer fill control system that allows the user to adjust the amount of water that the machine provides, which is based on the size or weight of the clothes load placed in the clothes container.

Wash time means the wash portion of active washing mode, which begins when the cycle is initiated and includes the agitation or tumble time, which may be periodic or continuous during the wash portion of active washing mode.

Water efficiency ratio means the quotient of the weighted-average load size divided by the total weighted per-cycle water consumption for all wash cycles in gallons.

2. Testing Conditions and Instrumentation

2.1 *Electrical energy supply.*

2.1.1 *Supply voltage and frequency.* Maintain the electrical supply at the clothes washer terminal block within 2 percent of 120, 120/240, or 120/208Y volts as applicable to the particular terminal block wiring system and within 2 percent of the nameplate frequency as specified by the manufacturer. If the clothes washer has a dual voltage conversion capability, conduct test at the highest voltage specified by the manufacturer.

2.1.2 *Supply voltage waveform.* For the combined low-power mode testing, maintain the electrical supply voltage waveform indicated in Section 4, Paragraph 4.3.2 of IEC 62301. If the power measuring instrument used for testing is unable to measure and record the total harmonic content during the test measurement period, total harmonic content may be measured and recorded immediately before and after the test measurement period.

2.2 *Supply water.* Maintain the temperature of the hot water supply at the water inlets between 120 °F (48.9 °C) and 125 °F (51.7 °C), targeting the midpoint of the range. Maintain the temperature of the cold water supply at the water inlets between 55 °F (12.8 °C) and 60 °F (15.6 °C), targeting the midpoint of the range.

2.3 *Water pressure.* Maintain the static water pressure at the hot and cold water inlet connection of the clothes washer at 35 pounds per square inch gauge (psig) ± 2.5 psig (241.3 kPa ± 17.2 kPa) when the water is flowing.

2.4 *Test room temperature.* For all clothes washers, maintain the test room ambient air temperature at 75 ± 5 °F (23.9 ± 2.8 °C) for active mode testing and combined low-power mode testing. Do not use the test room ambient air temperature conditions specified in Section 4, Paragraph 4.2 of IEC 62301 for combined low-power mode testing.

2.5 *Instrumentation.* Perform all test measurements using the following instruments, as appropriate:

2.5.1 *Weighing scales.*

2.5.1.1 *Weighing scale for test cloth.* The scale used for weighing test cloth must have a resolution of no larger than 0.2 oz (5.7 g)

and a maximum error no greater than 0.3 percent of the measured value.

2.5.1.2 *Weighing scale for clothes container capacity measurement.* The scale used for performing the clothes container capacity measurement must have a resolution no larger than 0.50 lbs (0.23 kg) and a maximum error no greater than 0.5 percent of the measured value.

2.5.2 *Watt-hour meter.* The watt-hour meter used to measure electrical energy consumption must have a resolution no larger than 1 Wh (3.6 kJ) and a maximum error no greater than 2 percent of the measured value for any demand greater than 50 Wh (180.0 kJ).

2.5.3 *Watt meter.* The watt meter used to measure combined low-power mode power consumption must comply with the requirements specified in Section 4, Paragraph 4.4 of IEC 62301. If the power measuring instrument used for testing is unable to measure and record the crest factor, power factor, or maximum current ratio during the test measurement period, the crest factor, power factor, and maximum current ratio may be measured and recorded immediately before and after the test measurement period.

2.5.4 *Water and air temperature measuring devices.* The temperature devices used to measure water and air temperature must have an error no greater than ±1 °F (±0.6 °C) over the range being measured.

2.5.4.1 Non-reversible temperature indicator labels, adhered to the inside of the clothes container, may be used to confirm that an extra-hot wash temperature greater than or equal to 140 °F has been achieved during the wash cycle, under the following conditions. The label must remain waterproof, intact, and adhered to the wash drum throughout an entire wash cycle; provide consistent maximum temperature readings; and provide repeatable temperature indications sufficient to demonstrate that a wash temperature of greater than or equal to 140 °F has been achieved. The label must have been verified to consistently indicate temperature measurements with an accuracy of ±1 °F. If using a temperature indicator label to test a front-loading clothes washer, adhere the label along the interior surface of the clothes container drum, midway between the front and the back of the drum, adjacent to one of the baffles. If using a temperature indicator label to test a top-loading clothes washer, adhere the label along the interior surface of the clothes container drum, on the vertical portion of the sidewall, as close to the bottom of the container as possible.

2.5.4.2 Submersible temperature loggers placed inside the wash drum may be used to confirm that an extra-hot wash temperature greater than or equal to 140 °F has been achieved during the wash cycle, under the following conditions. The submersible temperature logger must have a time resolution of at least 1 data point every 5 seconds and a temperature measurement accuracy of ±1 °F. Due to the potential for a waterproof capsule to provide a thermal insulating effect, failure to measure a temperature of 140 °F does not necessarily indicate the lack of an extra-hot wash temperature. However, such a result would not be conclusive due to the lack of verification of the water temperature requirement, in which case an alternative method must be used to confirm that an extra-hot wash temperature greater than or equal to 140 °F has been achieved during the wash cycle.

2.5.5 *Water meter.* A water meter must be installed in both the hot and cold water lines to measure water flow and/or water consumption. The water meters must have a resolution no larger than 0.1 gallons (0.4 liters) and a maximum error no greater than 2 percent for the water flow rates being measured. If the volume of hot water for any individual cycle within the energy test cycle is less than 0.1 gallons (0.4 liters), the hot water meter must have a resolution no larger than 0.01 gallons (0.04 liters).

2.5.6 *Water pressure gauge.* A water pressure gauge must be installed in both the hot and cold water lines to measure water pressure. The water pressure gauges must have a resolution of 1 pound per square inch gauge (psig) (6.9 kPa) and a maximum error no greater than 5 percent of any measured value.

2.6 *Bone-dryer.* The dryer used for drying the cloth to bone-dry must heat the test cloth load above 210 °F (99 °C).

2.7 *Test cloths.* The test cloth material and dimensions must conform to the specifications in appendix J3 to this subpart. The energy test cloth and the energy stuffer cloths must be clean and must not be used for more than 60 test runs (after preconditioning as specified in section 5 of appendix J3 to this subpart). All energy test cloth must be permanently marked identifying the lot number of the material. Mixed lots of material must not be used for testing a clothes washer. The moisture absorption and retention must be evaluated for each new lot of test cloth using the standard extractor Remaining Moisture Content (RMC) procedure specified in appendix J3 to this subpart.

2.8 *Test Loads.*

2.8.1 *Test load sizes.* Create small and large test loads as defined in Table 5.1 of this appendix based on the clothes container capacity as measured in section 3.1 of this appendix. Record the bone-dry weight for each test load.


2.8.2 *Test load composition.* Test loads must consist primarily of energy test cloths and no more than five energy stuffer cloths per load to achieve the proper weight.

2.9 *Preparation and loading of test loads.* Use the following procedures to prepare and load each test load for testing in section 3 of this appendix.

2.9.1 Test loads for energy and water consumption measurements must be bone-dry prior to the first cycle of the test, and dried to a maximum of 104 percent of bone-dry weight for subsequent testing.

2.9.2 Prepare the energy test cloths for loading by grasping them in the center, lifting, and shaking them to hang loosely, as illustrated in Figure 2.9.2 of this appendix.


Figure 2.9.2—Grasping Energy Test Cloths in the Center, Lifting, and Shaking to Hang Loosely



For all clothes washers, follow any manufacturer loading instructions provided to the user regarding the placement of clothing within the clothes container. In the absence of any manufacturer instructions regarding the placement of clothing within the clothes container, the following loading instructions apply.

2.9.2.1 To load the energy test cloths in a top-loading clothes washer, arrange the cloths circumferentially around the axis of rotation of the clothes container, using alternating lengthwise orientations for adjacent pieces of cloth. Complete each cloth layer across its horizontal plane within the clothes container before adding a new layer. Figure 2.9.2.1 of this appendix illustrates the correct loading technique for a vertical-axis clothes washer.

Figure 2.9.2.1—Loading Energy Test Cloths into a Top-Loading Clothes Washer



2.9.2.2 To load the energy test cloths in a front-loading clothes washer, grasp each test cloth in the center as indicted in section 2.9.2 of this appendix, and then place each cloth into the clothes container prior to activating the clothes washer.

2.10 *Clothes washer installation.* Install the clothes washer in accordance with manufacturer's instructions.

2.10.1 *Water inlet connections.* If the clothes washer has 2 water inlets, connect the inlets to the hot water and cold water supplies, in accordance with the manufacturer's instructions. If the clothes washer has only 1 water inlet, connect the inlet to the cold water supply, in accordance with the manufacturer's instructions. Use the water inlet hoses provided with the clothes washer; otherwise use commercially available water inlet hoses, not to exceed 72 inches in length, in accordance with manufacturer's instructions.

2.10.2 *Low-power mode testing.* For combined low-power mode testing, install the clothes washer in accordance with Section 5, Paragraph 5.2 of IEC 62301, disregarding the provisions regarding batteries and the determination, classification, and testing of relevant modes.

2.11 *Clothes washer pre-conditioning.* If the clothes washer has not been filled with water in the preceding 96 hours, or if it has not been in the test room at the specified ambient conditions for 8 hours, pre-condition it by running it through a cold rinse cycle and then draining it to ensure that the hose, pump, and sump are filled with water.

2.12 *Determining the energy test cycle.*

2.12.1 *Automatic clothes washers.* To determine the energy test cycle, evaluate the wash/rinse temperature selection flowcharts in the order in which they are presented in this section. Use the large load size to evaluate each flowchart. The determination of the energy test cycle must take into consideration all cycle settings available to the end user, including any cycle selections or cycle modifications provided by the manufacturer via software or firmware updates to the product, for the basic model under test. The energy test cycle does not include any cycle that is recommended by the manufacturer exclusively for cleaning, deodorizing, or sanitizing the clothes washer.

Figure 2.12.1.1—Determination of Cold Wash/Cold Rinse




Figure 2.12.1.2—Determination of Hot Wash/Cold Rinse




Figure 2.12.1.3—Determination of Warm Wash/Cold Rinse




Figure 2.12.1.4—Determination of Warm Wash/Warm Rinse





Figure 2.12.1.5—Determination of Extra-Hot Wash/Cold Rinse



2.12.2. *Semi-automatic clothes washers.* The energy test cycle for semi-automatic clothes washers includes only the Cold Wash/Cold Rinse (''Cold'') test cycle. Energy and water use for all other wash/rinse temperature combinations are calculated numerically in section 3.4.2 of this appendix.

3. Test Measurements

3.1 *Clothes container capacity.* Measure the entire volume that a clothes load could occupy within the clothes container during active mode washer operation according to the following procedures:

3.1.1 Place the clothes washer in such a position that the uppermost edge of the clothes container opening is leveled horizontally, so that the container will hold the


maximum amount of water. For front-loading clothes washers, the door seal and shipping bolts or other forms of bracing hardware to support the wash drum during shipping must remain in place during the capacity measurement. If the design of a front-loading clothes washer does not include shipping bolts or other forms of bracing hardware to support the wash drum during shipping, a laboratory may support the wash drum by other means, including temporary bracing or support beams. Any temporary bracing or support beams must keep the wash drum in a fixed position, relative to the geometry of the door and door seal components, that is representative of the position of the wash drum during normal operation. The method used must avoid damage to the unit that would affect the results of the energy and water testing. For a front-loading clothes washer that does not include shipping bolts or other forms of bracing hardware to support the wash drum during shipping, the laboratory must fully document the alternative method used to support the wash drum during capacity measurement, include such documentation in the final test report, and pursuant to §429.71 of this chapter, the manufacturer must retain such documentation as part its test records.

3.1.2 Line the inside of the clothes container with a 2 mil thickness (0.051 mm) plastic bag. All clothes washer components that occupy space within the clothes container and that are recommended for use during a wash cycle must be in place and must be lined with a 2 mil thickness (0.051 mm) plastic bag to prevent water from entering any void space.

3.1.3 Record the total weight of the machine before adding water.


3.1.4 Fill the clothes container manually with either 60 °F ± 5 °F (15.6 °C ± 2.8 °C) or 100 °F ± 10 °F (37.8 °C ± 5.5 °C) water, with the door open. For a top-loading vertical-axis clothes washer, fill the clothes container to the uppermost edge of the rotating portion, including any balance ring. Figure 3.1.4.1 of this appendix illustrates the maximum fill level for top-loading clothes washers.

Figure 3.1.4.1—Maximum Fill Level for the Clothes Container Capacity Measurement of Top-Loading Vertical-Axis Clothes Washers



For a front-loading horizontal-axis clothes washer, fill the clothes container to the highest point of contact between the door and the door gasket. If any portion of the door or gasket would occupy the measured volume space when the door is closed, exclude from the measurement the volume that the door or gasket portion would occupy. For a front-loading horizontal-axis clothes washer with a concave door shape, include any additional volume above the plane defined by the highest point of contact between the door and the door gasket, if that area can be occupied by clothing during washer operation. For a top-loading horizontal-axis clothes washer, include any additional volume above the plane of the door hinge that clothing could occupy during washer operation. Figure 3.1.4.2 of this appendix illustrates the maximum fill volumes for all horizontal-axis clothes washer types.

Figure 3.1.4.2—Maximum Fill Level for the Clothes Container Capacity Measurement of Horizontal-Axis Clothes Washers



For all clothes washers, exclude any volume that cannot be occupied by the clothing load during operation.

3.1.5 Measure and record the weight of water, W, in pounds.

3.1.6 Calculate the clothes container capacity as follows:

$C = W/d$

Where:

C = Capacity in cubic feet (liters).
W = Mass of water in pounds (kilograms).
d = Density of water (62.0 lbs/ft^3 for 100 °F (993 kg/m^3 for 37.8 °C) or 62.3 lbs/ft^3 for 60 °F (998 kg/m^3 for 15.6 °C)).

3.1.7 Calculate the clothes container capacity, C, to the nearest 0.01 cubic foot for the purpose of determining test load sizes per Table 5.1 of this appendix and for all subsequent calculations that include the clothes container capacity.

3.2 *Cycle settings.*

3.2.1 *Wash/rinse temperature selection.* For automatic clothes washers, set the wash/rinse temperature selection control to obtain the desired wash/rinse temperature selection within the energy test cycle.

3.2.2 *Wash time setting.*

3.2.2.1 If the cycle under test offers a range of wash time settings, the wash time setting shall be the higher of either the minimum or 70 percent of the maximum wash time available for the wash cycle under test, regardless of the labeling of suggested dial locations. If 70 percent of the maximum wash time is not available on a dial with a discrete number of wash time settings, choose the next-highest setting greater than 70 percent.

3.2.2.2 If the clothes washer is equipped with an electromechanical dial or timer controlling wash time that rotates in both directions, reset the dial to the minimum wash time and then turn it in the direction of increasing wash time to reach the appropriate setting. If the appropriate setting is passed, return the dial to the minimum wash time and then turn in the direction of increasing wash time until the appropriate setting is reached.

3.2.3 *Water fill level settings.* The water fill level settings depend on the clothes washer's water fill control system, as determined in Table 3.2.3.

TABLE 3.2.3—CLOTHES WASHER WATER FILL CONTROL SETTINGS

	Settings are user-adjustable	Settings are not user-adjustable
Water fill level unaffected by the size or weight of the clothing load.	Manual water fill	Fixed water fill.
Water fill level is determined automatically by the clothes washer based on the size and weight of the clothing load.	User-adjustable adaptive water fill.	Non-user-adjustable adaptive water fill.

3.2.3.1 *Clothes washers with a manual water fill control system.* For the large test load size, set the water fill level selector to the maximum water fill level setting available for the wash cycle under test. If the water fill level selector has two settings available for the wash cycle under test, for the small test load size, select the minimum water fill level setting available for the wash cycle under test.

If the water fill level selector has more than two settings available for the wash cycle under test, for the small test load size, select the second-lowest water fill level setting.

3.2.3.2 *Clothes washers with a fixed water fill control system.* The water level is automatically determined by the water fill control system.

3.2.3.3 *Clothes washers with a user-adjustable adaptive water fill control system.* For the

large test load size, set the water fill selector to the setting that uses the most water. For the small test load size, set the water fill selector to the setting that uses the least water.

3.2.3.4 *Clothes washers with a non-user-adjustable adaptive water fill control system.* The water level is automatically determined by the water fill control system.

3.2.3.5 *Clothes washers with multiple water fill control systems.* If a clothes washer allows user selection among multiple water fill control systems, test all water fill control systems and, for each one, calculate the energy consumption (HE_T, ME_T, DE_T, and E_{TLP}) and water consumption (Q_T) values as set forth in section 4 of this appendix. Then, calculate the average of the tested values (one from each water fill control system) for each variable (HE_T, ME_T, DE_T, E_{TLP}, and Q_T) and use the average value for each variable in the final calculations in section 4 of this appendix.

3.2.4 *Manufacturer default settings.* For clothes washers with electronic control systems, use the manufacturer default settings for any cycle selections, except for (1) the temperature selection, (2) the wash water fill levels, or (3) network settings. If the clothes washer has network capabilities, the network settings must be disabled throughout testing if such settings can be disabled by the end-user and the product's user manual provides instructions on how to do so. For all other cycle selections, the manufacturer default settings must be used for wash conditions such as agitation/tumble operation, soil level, spin speed, wash times, rinse times, optional rinse settings, water heating time for water heating clothes washers, and all other wash parameters or optional features applicable to that wash cycle. Any optional wash cycle feature or setting (other than wash/rinse temperature, water fill level selection, or network settings on clothes washers with network capabilities) that is activated by default on the wash cycle under test must be included for testing unless the manufacturer instructions recommend not selecting this option, or recommend selecting a different option, for washing normally soiled cotton clothing. For clothes washers with control panels containing mechanical switches or dials, any optional settings, except for the temperature selection or the wash water fill levels, must be in the position recommended by the manufacturer for washing normally soiled cotton clothing. If the manufacturer instructions do not recommend a particular switch or dial position to be used for washing normally soiled cotton clothing, the setting switch or dial must remain in its as-shipped position.

3.2.5 For each wash cycle tested, include the entire active washing mode and exclude any delay start or cycle finished modes.

3.2.6 *Anomalous Test Cycles.* If during a wash cycle the clothes washer: (a) Signals to the user by means of a visual or audio alert that an out-of-balance condition has been detected; or (b) terminates prematurely and thus does not include the agitation/tumble operation, spin speed(s), wash times, and rinse times applicable to the wash cycle under test, discard the test data and repeat the wash cycle. Document in the test report the rejection of data from any wash cycle during testing and the reason for the rejection.

3.3 *Test cycles for automatic clothes washers.* Perform testing on each wash/rinse temperature selection available in the energy test cycle as defined in section 2.12.1 of this appendix. Test each load size as defined in section 2.8 of this appendix with its associated water fill level defined in section 3.2.3 of this appendix. Assign the bone-dry weight according to the value measured in section 2.8 of this appendix. Place the test load in the clothes washer and initiate the cycle under test. Measure the values for hot water consumption, cold water consumption, electrical energy consumption, and cycle time for the complete cycle. Record the weight of the test load immediately after completion of the cycle. Table 3.3 of this appendix provides the symbol definitions for each measured value.

TABLE 3.3—SYMBOL DEFINITIONS OF MEASURED VALUES FOR AUTOMATIC CLOTHES WASHER TEST CYCLES

Wash/rinse temperature selection	Load size	Bone-dry weight	Hot water	Cold water	Electrical energy	Cycle time	Cycle complete weight
Extra-Hot/Cold	Large	WIx_L	Hx_L	Cx_L	Ex_L	Tx_L	WCx_L
	Small	WIx_S	Hx_S	Cx_S	Ex_S	Tx_S	WCx_S
Hot/Cold	Large	WIh_L	Hh_L	Ch_L	Eh_L	Th_L	WCh_L
	Small	WIh_S	Hh_S	Ch_S	Eh_S	Th_S	WCh_S
Warm/Cold *	Large	WIw_L	Hw_L	Cw_L	Ew_L	Tw_L	WCw_L
	Small	WIw_S	Hw_S	Cw_S	Ew_S	Tw_S	WCw_S
Warm/Warm *	Large	$WIww_L$	Hww_L	Cww_L	Eww_L	Tww_L	$WCww_L$
	Small	$WIww_S$	Hww_S	Cww_S	Eww_S	Tww_S	$WCww_S$
Cold/Cold	Large	WIc_L	Hc_L	Cc_L	Ec_L	Tc_L	WCc_L

TABLE 3.3—SYMBOL DEFINITIONS OF MEASURED VALUES FOR AUTOMATIC CLOTHES WASHER TEST CYCLES—Continued

Wash/rinse temperature selection	Load size	Bone-dry weight	Hot water	Cold water	Electrical energy	Cycle time	Cycle complete weight
	Small	WIc_S	Hc_S	Cc_S	Ec_S	Tc_S	WCc_S

*If two cycles are tested to represent the Warm/Cold selection or the Warm/Warm selection, calculate the average of the two tested cycles and use that value for all further calculations.

3.4 *Test cycles for semi-automatic clothes washers.*

3.4.1 *Test Measurements.* Perform testing on each wash/rinse temperature selection available in the energy test cycle as defined in section 2.12.2 of this appendix. Test each load size as defined in section 2.8 of this appendix with the associated water fill level defined in section 3.2.3 of this appendix. Assign the bone-dry weight according to the value measured in section 2.8 of this appendix. Place the test load in the clothes washer and initiate the cycle under test. Measure the values for cold water consumption, electrical energy consumption, and cycle time for the complete cycle. Record the weight of the test load immediately after completion of the cycle. Table 3.4.1 of this appendix provides symbol definitions for each measured value for the Cold temperature selection.

TABLE 3.4.1—SYMBOL DEFINITIONS OF MEASURED VALUES FOR SEMI-AUTOMATIC CLOTHES WASHER TEST CYCLES

Temperature selection	Load size	Bone-dry weight	Hot water	Cold water	Electrical energy	Cycle time	Cycle complete weight
Cold	Large	WIc_L	not measured.	Cc_L	Ec_L	Tc_L	WCc_L
	Small	WIc_S	not measured.	Cc_S	Ec_S	Tc_S	WCc_S

3.4.2 *Calculation of Hot and Warm measured values.* In lieu of testing, the measured values for the Hot and Warm cycles are calculated based on the measured values for the Cold cycle, as defined in section 3.4.1 of this appendix. Table 3.4.2 of this appendix provides the symbol definitions and calculations for each value for the Hot and Warm temperature selections.

TABLE 3.4.2—SYMBOL DEFINITIONS AND CALCULATION OF MEASURED VALUES FOR SEMI-AUTOMATIC CLOTHES WASHER TEST CYCLES

Temperature selection	Load Size	Bone-Dry weight	Hot water	Cold water	Electrical energy	Cycle time	Cycle complete weight
Hot	Large	$WIh_L = WIc_L$.	$Hh_L = Cc_L$		$Eh_L = Ec_L$	$Th_L = Tc_L$	$WCh_L = WCc_L$
	Small	$WIh_S = WIc_S$.	$Hh_S = Cc_S$		$Eh_S = Ec_S$	$Th_S = Tc_S$	$WCh_S = WCc_S$
Warm	Large	$WIw_L = WIc_L$.	$Hw_L = Cc_L \div 2$.	$Cw_L = Cc_L \div 2$.	$Ew_L = Ec_L$	$Tw_L = Tc_L$	$WCw_L = WCc_L$
	Small	$WIw_S = WIc_S$.	$Hw_S = Cc_S \div 2$.	$Cw_S = Cc_S \div 2$.	$Ew_S = Ec_S$	$Tw_S = Tc_S$	$WCw_S = WCc_S$

3.5 *Combined low-power mode power.* Connect the clothes washer to a watt meter as specified in section 2.5.3 of this appendix. Establish the testing conditions set forth in sections 2.1, 2.4, and 2.10.2 of this appendix.

3.5.1 Perform combined low-power mode testing after completion of an active mode wash cycle included as part of the energy test cycle; after removing the test load; without changing the control panel settings used for the active mode wash cycle; with the door closed; and without disconnecting the electrical energy supply to the clothes washer between completion of the active mode wash cycle and the start of combined low-power mode testing.

3.5.2 For a clothes washer that takes some time to automatically enter a stable inactive mode or off mode state from a higher

power state as discussed in Section 5, Paragraph 5.1, note 1 of IEC 62301, allow sufficient time for the clothes washer to automatically reach the default inactive/off mode state before proceeding with the test measurement.

3.5.3 Once the stable inactive/off mode state has been reached, measure and record the default inactive/off mode power, $P_{default}$, in watts, following the test procedure for the sampling method specified in Section 5, Paragraph 5.3.2 of IEC 62301.

3.5.4 For a clothes washer with a switch, dial, or button that can be optionally selected by the end user to achieve a lower-power inactive/off mode state than the default inactive/off mode state measured in section 3.5.3 of this appendix, after performing the measurement in section 3.5.3 of this appendix, activate the switch, dial, or button to the position resulting in the lowest power consumption and repeat the measurement procedure described in section 3.5.3 of this appendix. Measure and record the lowest-power inactive/off mode power, P_{lowest}, in Watts.

3.6 *Energy consumption for the purpose of determining the cycle selection(s) to be included in the energy test cycle.* This section is implemented only in cases where the energy test cycle flowcharts in section 2.12.1 of this appendix require the determination of the wash/rinse temperature selection with the highest energy consumption.

3.6.1 For the wash/rinse temperature selection being considered under this section, establish the testing conditions set forth in section 2 of this appendix. Select the applicable cycle selection and wash/rinse temperature selection. For all wash/rinse temperature selections, select the cycle settings as described in section 3.2 of this appendix.

3.6.2 Measure each wash cycle's electrical energy consumption (E_L) and hot water consumption (H_L). Calculate the total energy consumption for each cycle selection (E_{TL}), as follows:

$$E_{TL} = E_L + (H_L \times T \times K)$$

Where:

E_L is the electrical energy consumption, expressed in kilowatt-hours per cycle.

H_L is the hot water consumption, expressed in gallons per cycle.

T = nominal temperature rise = 65 °F (36.1 °C).

K = Water specific heat in kilowatt-hours per gallon per degree F = 0.00240 kWh/gal − °F (0.00114 kWh/L − °C).

4. Calculation of Derived Results From Test Measurements

4.1 *Hot water and machine electrical energy consumption of clothes washers.*

4.1.1 *Per-cycle temperature-weighted hot water consumption for all load sizes tested.* Calculate the per-cycle temperature-weighted hot water consumption for the large test load size, Vh_L, and the small test load size, Vh_S, expressed in gallons per cycle (or liters per cycle) and defined as:

(a) $Vh_L = [Hx_L \times TUF_X] + [Hh_L \times TUF_h] + [Hw_L \times TUF_w] + [Hww_L \times TUF_{ww}] + [Hc_L \times TUF_c]$

(b) $Vh_S = [Hx_S \times TUF_X] + [Hh_S \times TUF_h] + [Hw_S \times TUF_w] + [Hww_S \times TUF_{ww}] + [Hc_S \times TUF_c]$

Where:

Hx_L, Hh_L, Hw_L, Hww_L, Hc_L, Hx_S, Hh_S, Hw_S, Hww_S, and Hc_S are the hot water consumption values, in gallons per-cycle (or liters per cycle) as measured in section 3.3 of this appendix for automatic clothes washers or section 3.4 of this appendix for semi-automatic clothes washers.

TUF_X, TUF_h, TUF_w, TUF_{ww}, and TUF_c are temperature use factors for Extra-Hot Wash/Cold Rinse, Hot Wash/Cold Rinse, Warm Wash/Cold Rinse, Warm Wash/Warm Rinse, and Cold Wash/Cold Rinse temperature selections, respectively, as defined in Table 4.1.1 of this appendix.

TABLE 4.1.1—TEMPERATURE USE FACTORS

Wash/rinse temperature selections available in the energy test cycle	Clothes washers with cold rinse only					Clothes washers with both cold and warm rinse		
	C/C	H/C C/C	H/C W/C C/C *	XH/C H/C C/C	XH/C H/C W/C C/C	H/C W/C W/W C/C	XH/C H/C W/W C/C	XH/C H/C W/C W/W C/C
TUFx (Extra-Hot/Cold)	.....	.....	.....	0.14	0.05	.....	0.14	0.05
TUFh (Hot/Cold)	.....	0.63	0.14	**0.49	0.09	0.14	**0.22	0.09
TUFw (Warm/Cold)	.....	.....	0.49	.....	0.49	0.22	.....	0.22
TUFww (Warm/Warm)	.....	.....	.....	.....	.....	0.27	0.27	0.27
TUFc (Cold/Cold)	1.00	0.37	0.37	0.37	0.37	0.37	0.37	0.37

*This column applies to all semi-automatic clothes washers.

** On clothes washers with only two wash temperature selections <140 °F, the higher of the two wash temperatures is classified as a Hot Wash/Cold Rinse, in accordance with the wash/rinse temperature definitions within the energy test cycle.

4.1.2 *Total per-cycle hot water energy consumption for all load sizes tested.* Calculate the total per-cycle hot water energy consumption for the large test load size, HE_L, and the small test load size, HE_S, expressed in kilowatt-hours per cycle and defined as:

(a) $HE_L = [Vh_L \times T \times K]$ = Total energy when the large test load is tested.

(b) $HE_S = [Vh_S \times T \times K]$ = Total energy when the small test load is tested.

Where:

Vh_L and Vh_S are defined in section 4.1.1 of this appendix.

T = Temperature rise = 65 °F (36.1 °C).

K = Water specific heat in kilowatt-hours per gallon per degree F = 0.00240 kWh/gal − °F (0.00114 kWh/L − °C).

4.1.3 *Total weighted per-cycle hot water energy consumption.* Calculate the total weighted per-cycle hot water energy consumption, HE_T, expressed in kilowatt-hours per cycle and defined as:

$HE_T = [HE_L \times LUF_L] + [HE_S \times LUF_S]$

Where:

HE_L and HE_S are defined in section 4.1.2 of this appendix.

LUF_L = Load usage factor for the large test load = 0.5.

LUF_S = Load usage factor for the small test load = 0.5.

4.1.4 *Total per-cycle hot water energy consumption using gas-heated or oil-heated water, for product labeling requirements.* Calculate for the energy test cycle the per-cycle hot water consumption, HE_{TG}, using gas-heated or oil-heated water, expressed in Btu per cycle (or megajoules per cycle) and defined as:

$HE_{TG} = HE_T \times 1/e \times 3412$ Btu/kWh or $HE_{TG} = HE_T \times 1/e \times 3.6$ MJ/kWh.

Where:

e = Nominal gas or oil water heater efficiency = 0.75.

HE_T = As defined in section 4.1.3 of this appendix.

4.1.5 *Per-cycle machine electrical energy consumption for all load sizes tested.* Calculate the total per-cycle machine electrical energy consumption for the large test load size, ME_L, and the small test load size, ME_S, expressed in kilowatt-hours per cycle and defined as:

(a) $ME_L = [Ex_L \times TUF_X] + [Eh_L \times TUF_h] + [Ew_L \times TUF_w] + [Eww_L \times TUF_{ww}] + [Ec_L \times TUF_c]$

(b) $ME_S = [Ex_S \times TUF_X] + [Eh_S \times TUF_h] + [Ew_S \times TUF_w] + [Eww_S \times TUF_{ww}] + [Ec_S \times TUF_c]$

Where:

Ex_L, Eh_L, Ew_L, Eww_L, Ec_L, Ex_S, Eh_S, Ew_S, Eww_S, and Ec_S are the electrical energy consumption values, in kilowatt-hours per cycle as measured in section 3.3 of this appendix for automatic clothes washers or section 3.4 of this appendix for semi-automatic clothes washers.

TUF_X, TUF_h, TUF_w, TUF_{ww}, and TUF_c are defined in Table 4.1.1 of this appendix.

4.1.6 *Total weighted per-cycle machine electrical energy consumption.* Calculate the total weighted per-cycle machine electrical energy consumption, ME_T, expressed in kilowatt-hours per cycle and defined as:

$ME_T = [ME_L \times LUF_L] + [ME_S \times LUF_S]$

Where:

ME_L and ME_S are defined in section 4.1.5 of this appendix.

LUF_L and LUF_S are defined in section 4.1.3 of this appendix.

4.2 *Water consumption of clothes washers.*

4.2.1 *Per cycle total water consumption for each large load size tested.* Calculate the per-cycle total water consumption of the large test load for the Extra-Hot Wash/Cold Rinse cycle, Qx_L, Hot Wash/Cold Rinse cycle, Qh_L, Warm Wash/Cold Rinse cycle, Qw_L, Warm Wash/Warm Rinse cycle, Qww_L, and Cold Wash/Cold Rinse cycle, Qc_L, defined as:

(a) $Qx_L = Hx_L + Cx_L$

(b) $Qh_L = Hh_L + Ch_L$

(c) $Qw_L = Hw_L + Cw_L$

(d) $Qww_L = Hww_L + Cww_L$

(e) $Qc_L = Hc_L + Cc_L$

Where:

Hx_L, Hh_L, Hw_L, Hww_L, Hc_L, Cx_L, Ch_L, Cw_L, Cww_L, and Cc_L are defined in section 3.3 of this appendix for automatic clothes washers or section 3.4 of this appendix for semi-automatic clothes washers.

4.2.2 *Per cycle total water consumption for each small load size tested.* Calculate the per-cycle total water consumption of the small test load for the Extra-Hot Wash/Cold Rinse cycle, Qx_S, Hot Wash/Cold Rinse cycle, Qh_S, Warm Wash/Cold Rinse cycle, Qw_S, Warm Wash/Warm Rinse cycle, Qww_S, and Cold Wash/Cold Rinse cycle, Qc_S, defined as:

(a) $Qx_S = Hx_S + Cx_S$

(b) $Qh_S = Hh_S + Ch_S$

(c) $Qw_S = Hw_S + Cw_S$

(d) $Qww_S = Hww_S + Cww_S$

(e) $Qc_S = Hc_S + Cc_S$

Where:

Hx_S, Hh_S, Hw_S, Hww_S, Hc_S, Cx_S, Ch_S, Cw_S, Cww_S, and Cc_S are defined in section 3.3 of this appendix for automatic clothes washers or section 3.4 of this appendix for semi-automatic clothes washers.

4.2.3 *Per-cycle total water consumption for all load sizes tested.* Calculate the total per-

cycle water consumption for the large test load size, Q_L, and the small test load size, Q_S, expressed in gallons per cycle (or liters per cycle) and defined as:

(a) $Q_L = [Qx_L \times TUFx] + [Qh_L \times TUFh] + [Qw_L \times TUFw] + [Qww_L \times TUFww] + [Qc_L \times TUFc]$

(b) $Q_S = [Qx_S \times TUFx] + [Qh_S \times TUFh] + [Qw_S \times TUFw] + [Qww_S \times TUFww] + [Qc_S \times TUFc]$

Where:

Qx_L, Qh_L, Qw_L, Qww_L, and Qc_L are defined in section 4.2.1 of this appendix.

Qx_S, Qh_S, Qw_S, Qww_S, and Qc_S are defined in section 4.2.2 of this appendix.

TUFx, TUFh, TUFw, TUFww, and TUFc are defined in Table 4.1.1 of this appendix.

4.2.4 *Total weighted per-cycle water consumption*. Calculate the total per-cycle water consumption, Q_T, expressed in gallons per cycle (or liters per cycle) and defined as:

$Q_T = [Q_L \times LUF_L] + [Q_S \times LUF_S]$

Where:

Q_L and Q_S are defined in section 4.2.3 of this appendix.

LUF_L and LUF_S are defined in section 4.1.3 of this appendix.

4.3 *Remaining moisture content (RMC).*

4.3.1 *Per cycle remaining moisture content for each large load size tested*. Calculate the per-cycle remaining moisture content of the large test load for the Extra-Hot Wash/Cold Rinse cycle, $RMCx_L$, Hot Wash/Cold Rinse cycle, $RMCh_L$, Warm Wash/Cold Rinse cycle, $RMCw_L$, Warm Wash/Warm Rinse cycle, $RMCww_L$, and Cold Wash/Cold Rinse cycle, $RMCc_L$, defined as:

(a) $RMCx_L = (WCx_L - WIx_L)/WIx_L$

(b) $RMCh_L = (WCh_L - WIh_L)/WIh_L$

(c) $RMCw_L = (WCw_L - WIw_L)/WIw_L$

(d) $RMCww_L = (WCww_L - WIww_L)/WIww_L$

(e) $RMCc_L = (WCc_L - WIc_L)/WIc_L$

Where:

WCx_L, WCh_L, WCw_L, $WCww_L$, WCc_L, WIx_L, WIh_L, WIw_L, $WIww_L$, and WIc_L are the bone-dry weights and cycle completion weights as measured in section 3.3 of this appendix for automatic clothes washers or section 3.4 of this appendix for semi-automatic clothes washers.

4.3.2 *Per cycle remaining moisture content for each small load size tested*. Calculate the per-cycle remaining moisture content of the small test load for the Extra-Hot Wash/Cold Rinse cycle, $RMCx_S$, Hot Wash/Cold Rinse cycle, $RMCh_S$, Warm Wash/Cold Rinse cycle, $RMCw_S$, Warm Wash/Warm Rinse cycle, $RMCww_S$, and Cold Wash/Cold Rinse cycle, $RMCc_S$, defined as:

(a) $RMCx_S = (WCx_S—WIx_S)/WIx_S$

(b) $RMCh_S = (WCh_S—WIh_S)/WIh_S$

(c) $RMCw_S = (WCw_S—WIw_S)/WIw_S$

(d) $RMCww_S = (WCww_S—WIww_S)/WIww_S$

(e) $RMCc_S = (WCc_S—WIc_S)/WIc_S$

Where:

WCx_S, WCh_S, WCw_S, $WCww_S$, WCc_S, WIx_S, WIh_S, WIw_S, $WIww_S$, and WIc_S are the bone-dry weights and cycle completion weights as measured in section 3.3 of this appendix for automatic clothes washers or section 3.4 of this appendix for semi-automatic clothes washers.

4.3.3 *Per-cycle remaining moisture content for all load sizes tested*. Calculate the per-cycle temperature-weighted remaining moisture content for the large test load size, RMC_L, and the small test load size, RMC_S, defined as:

(a) $RMC_L = [RMCx_L \times TUF_X] + [RMCh_L \times TUF_h] + [RMCw_L \times TUF_w] + [RMCww_L \times TUF_{ww}] + [RMCc_L \times TUF_c]$

(b) $RMC_S = [RMCx_S \times TUF_X] + [RMCh_S \times TUF_h] + [RMCw_S \times TUF_w] + [RMCww_S \times TUF_{ww}] + [RMCc_S \times TUF_c]$

Where:

$RMCx_L$, $RMCh_L$, $RMCw_L$, $RMCww_L$, and $RMCc_L$ are defined in section 4.3.1 of this appendix.

$RMCx_S$, $RMCh_S$, $RMCw_S$, $RMCww_S$, and $RMCc_S$ are defined in section 4.3.2 of this appendix.

TUF_X, TUF_h, TUF_w, TUF_{ww}, and TUF_c are defined in Table 4.1.1 of this appendix.

4.3.4 *Weighted per-cycle remaining moisture content*. Calculate the weighted per-cycle remaining moisture content, RMC_T, defined as:

$RMC_T = [RMC_L \times LUF_L] + [RMC_S \times LUF_S]$

Where:

RMC_L and RMC_S are defined in section 4.3.3 of this appendix.

LUF_L and LUF_S are defined in section 4.1.3 of this appendix.

4.3.5 Apply the RMC correction curve as described in section 9 of appendix J3 to this subpart to calculate the corrected remaining moisture content, RMC_{corr}, expressed as a percentage as follows:

$RMC_{corr} = (A \times RMC_T + B) \times 100\%$

Where:

A and B are the coefficients of the RMC correction curve as defined in section 8.7 of appendix J3 to this subpart.

RMC_T = As defined in section 4.3.4 of this appendix.

4.4 *Per-cycle energy consumption for removal of moisture from test load*. Calculate the per-cycle energy required to remove the remaining moisture of the test load, DE_T, expressed in kilowatt-hours per cycle and defined as:

$DE_T = [(LUF_L \times \text{Large test load weight}) + (LUF_S \times \text{Small test load weight})] \times (RMC_{corr} - 2\%) \times (DEF) \times (DUF)$

Where:

LUF_L and LUF_S are defined in section 4.1.3 of this appendix.

Large and small test load weights are defined in Table 5.1 of this appendix.

RMC_{corr} = As defined in section 4.3.5 of this appendix.

DEF = Nominal energy required for a clothes dryer to remove moisture from clothes = 0.5 kWh/lb (1.1 kWh/kg).

DUF = Dryer usage factor, percentage of washer loads dried in a clothes dryer = 0.91.

4.5 *Cycle time.*

4.5.1 *Per-cycle temperature-weighted cycle time for all load sizes tested.* Calculate the per-cycle temperature-weighted cycle time for the large test load size, T_L, and the small test load size, T_S, expressed in minutes, and defined as:

(a) $T_L = [Tx_L \times TUF_X] + [Th_L \times TUF_h] + [Tw_L \times TUF_w] + [Tww_L \times TUF_{ww}] + [Tc_L \times TUF_c]$

(b) $T_S = [Tx_S \times TUF_X] + [Th_S \times TUF_h] + [Tw_S \times TUF_w] + [Tww_S \times TUF_{ww}] + [Tc_S \times TUF_c]$

Where:

Tx_L, Th_L, Tw_L, Tww_L, Tc_L, Tx_S, Th_S, Tw_S, Tww_S, and Tc_S are the cycle time values, in minutes as measured in section 3.3 of this appendix for automatic clothes washers or section 3.4 of this appendix for semi-automatic clothes washers.

TUF_X, TUF_h, TUF_w, TUF_{ww}, and TUF_c are temperature use factors for Extra-Hot Wash/Cold Rinse, Hot Wash/Cold Rinse, Warm Wash/Cold Rinse, Warm Wash/Warm Rinse, and Cold Wash/Cold Rinse temperature selections, respectively, as defined in Table 4.1.1 of this appendix.

4.5.2 *Total weighted per-cycle cycle time.* Calculate the total weighted per-cycle cycle time, T_T, expressed in minutes, rounded to the nearest minute, and defined as:

$T_T = [T_L \times LUF_L] + [T_S \times LUF_S]$

Where:

T_L and T_S are defined in section 4.5.1 of this appendix.

LUF_L and LUF_S are defined in section 4.1.3 of this appendix.

4.6 Combined low-power mode energy consumption.

4.6.1 *Annual hours in default inactive/off mode.* Calculate the annual hours spent in default inactive/off mode, $S_{default}$, expressed in hours and defined as:

$S_{default} = [8{,}760 - (234 \times T_T/60)]/N$

Where:

T_T = As defined in section 4.5.2 of this appendix, in minutes.

N = Number of inactive/off modes, defined as 1 if no optional lowest-power inactive/off mode is available; otherwise 2.

8,760 = Total number of hours in a year.

234 = Representative average number of clothes washer cycles in a year.

60 = Conversion from minutes to hours.

4.6.2 *Per-cycle combined low-power mode energy consumption.* Calculate the per-cycle combined low-power mode energy consumption, E_{TLP}, expressed in kilowatt-hours per cycle and defined as:

$E_{TLP} = [(P_{default} \times S_{default}) + (P_{lowest} \times S_{lowest})] \times K_p/234$

Where:

$P_{default}$ = Default inactive/off mode power, in watts, as measured in section 3.5.3 of this appendix.

P_{lowest} = Lowest-power inactive/off mode power, in watts, as measured in section 3.5.4 of this appendix for clothes washers with a switch, dial, or button that can be optionally selected by the end user to achieve a lower-power inactive/off mode than the default inactive/off mode; otherwise, $P_{lowest} = 0$.

$S_{default}$ = Annual hours in default inactive/off mode, as calculated in section 4.6.1 of this appendix.

S_{lowest} = Annual hours in lowest-power inactive/off mode, defined as 0 if no optional lowest-power inactive/off mode is available; otherwise equal to $S_{default}$, as calculated in section 4.6.1 of this appendix.

K_p = Conversion factor of watt-hours to kilowatt-hours = 0.001.

234 = Representative average number of clothes washer cycles in a year.

4.7 *Water efficiency ratio.* Calculate the water efficiency ratio, WER, expressed in pounds per gallon per cycle (or kilograms per liter per cycle), as:

$WER = [(LUF_L \times \text{Large test load weight}) + (LUF_S \times \text{Small test load weight})]/Q_T$

Where:

LUF_L and LUF_S are defined in section 4.1.3 of this appendix.

Large and small test load weights are defined in Table 5.1 of this appendix.

Q_T = As defined in section 4.2.4 of this appendix.

4.8 *Active-mode energy efficiency ratio.* Calculate the active-mode energy efficiency ratio, AEER, expressed in pounds per kilowatt-hour per cycle (or kilograms per kilowatt-hour per cycle) and defined as:

$AEER = [(LUF_L \times \text{Large test load weight}) + (LUF_S \times \text{Small test load weight})]/(ME_T + HE_T + DE_T)$

Where:

LUF_L and LUF_S are defined in section 4.1.3 of this appendix.

Large and small test load weights are defined in Table 5.1 of this appendix.

ME_T = As defined in section 4.1.6 of this appendix.

HE_T = As defined in section 4.1.3 of this appendix.

DE_T = As defined in section 4.4 of this appendix.

4.9 *Energy efficiency ratio.* Calculate the energy efficiency ratio, EER, expressed in

pounds per kilowatt-hour per cycle (or kilograms per kilowatt-hour per cycle) and defined as:

$EER = [(LUF_L \times \text{Large test load weight}) + (LUF_S \times \text{Small test load weight})]/(ME_T + HE_T + DE_T + E_{TLP})$

Where:

LUF_L and LUF_S are defined in section 4.1.3 of this appendix.

Large and small test load weights are defined in Table 5.1 of this appendix.

ME_T = As defined in section 4.1.6 of this appendix.

HE_T = As defined in section 4.1.3 of this appendix.

DE_T = As defined in section 4.4 of this appendix.

E_{TLP} = As defined in section 4.6.2 of this appendix.

5. Test Loads

TABLE 5.1—TEST LOAD SIZES

Container volume		Small load		Large load	
cu. ft.	liter	lb	kg	lb	kg
≥ <	≥ <				
0.00–0.80	0.00–22.7	3.00	1.36	3.00	1.36
0.80–0.90	22.7–25.5	3.10	1.41	3.35	1.52
0.90–1.00	25.5–28.3	3.20	1.45	3.70	1.68
1.00–1.10	28.3–31.1	3.30	1.50	4.00	1.81
1.10–1.20	31.1–34.0	3.40	1.54	4.30	1.95
1.20–1.30	34.0–36.8	3.45	1.56	4.60	2.09
1.30–1.40	36.8–39.6	3.55	1.61	4.95	2.25
1.40–1.50	39.6–42.5	3.65	1.66	5.25	2.38
1.50–1.60	42.5–45.3	3.75	1.70	5.55	2.52
1.60–1.70	45.3–48.1	3.80	1.72	5.85	2.65
1.70–1.80	48.1–51.0	3.90	1.77	6.20	2.81
1.80–1.90	51.0–53.8	4.00	1.81	6.50	2.95
1.90–2.00	53.8–56.6	4.10	1.86	6.80	3.08
2.00–2.10	56.6–59.5	4.20	1.91	7.10	3.22
2.10–2.20	59.5–62.3	4.30	1.95	7.45	3.38
2.20–2.30	62.3–65.1	4.35	1.97	7.75	3.52
2.30–2.40	65.1–68.0	4.45	2.02	8.05	3.65
2.40–2.50	68.0–70.8	4.55	2.06	8.35	3.79
2.50–2.60	70.8–73.6	4.65	2.11	8.70	3.95
2.60–2.70	73.6–76.5	4.70	2.13	9.00	4.08
2.70–2.80	76.5–79.3	4.80	2.18	9.30	4.22
2.80–2.90	79.3–82.1	4.90	2.22	9.60	4.35
2.90–3.00	82.1–85.0	5.00	2.27	9.90	4.49
3.00–3.10	85.0–87.8	5.10	2.31	10.25	4.65
3.10–3.20	87.8–90.6	5.20	2.36	10.55	4.79
3.20–3.30	90.6–93.4	5.25	2.38	10.85	4.92
3.30–3.40	93.4–96.3	5.35	2.43	11.15	5.06
3.40–3.50	96.3–99.1	5.45	2.47	11.50	5.22
3.50–3.60	99.1–101.9	5.55	2.52	11.80	5.35
3.60–3.70	101.9–104.8	5.65	2.56	12.10	5.49
3.70–3.80	104.8–107.6	5.70	2.59	12.40	5.62
3.80–3.90	107.6–110.4	5.80	2.63	12.75	5.78
3.90–4.00	110.4–113.3	5.90	2.68	13.05	5.92
4.00–4.10	113.3–116.1	6.00	2.72	13.35	6.06
4.10–4.20	116.1–118.9	6.10	2.77	13.65	6.19
4.20–4.30	118.9–121.8	6.15	2.79	14.00	6.35
4.30–4.40	121.8–124.6	6.25	2.83	14.30	6.49
4.40–4.50	124.6–127.4	6.35	2.88	14.60	6.62
4.50–4.60	127.4–130.3	6.45	2.93	14.90	6.76
4.60–4.70	130.3–133.1	6.55	2.97	15.25	6.92
4.70–4.80	133.1–135.9	6.60	2.99	15.55	7.05
4.80–4.90	135.9–138.8	6.70	3.04	15.85	7.19
4.90–5.00	138.8–141.6	6.80	3.08	16.15	7.33
5.00–5.10	141.6–144.4	6.90	3.13	16.50	7.48
5.10–5.20	144.4–147.2	7.00	3.18	16.80	7.62
5.20–5.30	147.2–150.1	7.05	3.20	17.10	7.76
5.30–5.40	150.1–152.9	7.15	3.24	17.40	7.89
5.40–5.50	152.9–155.7	7.25	3.29	17.70	8.03
5.50–5.60	155.7–158.6	7.35	3.33	18.05	8.19
5.60–5.70	158.6–161.4	7.45	3.38	18.35	8.32
5.70–5.80	161.4–164.2	7.50	3.40	18.65	8.46
5.80–5.90	164.2–167.1	7.60	3.45	18.95	8.60
5.90–6.00	167.1–169.9	7.70	3.49	19.30	8.75
6.00–6.10	169.9–172.7	7.80	3.54	19.60	8.89
6.10–6.20	172.7–175.6	7.90	3.58	19.90	9.03

TABLE 5.1—TEST LOAD SIZES—Continued

Container volume		Small load		Large load	
cu. ft.	liter	lb	kg	lb	kg
≥ <	≥ <				
6.20–6.30	175.6–178.4	7.95	3.61	20.20	9.16
6.30–6.40	178.4–181.2	8.05	3.65	20.55	9.32
6.40–6.50	181.2–184.1	8.15	3.70	20.85	9.46
6.50–6.60	184.1–186.9	8.25	3.74	21.15	9.59
6.60–6.70	186.9–189.7	8.30	3.76	21.45	9.73
6.70–6.80	189.7–192.6	8.40	3.81	21.80	9.89
6.80–6.90	192.6–195.4	8.50	3.86	22.10	10.02
6.90–7.00	195.4–198.2	8.60	3.90	22.40	10.16
7.00–7.10	198.2–201.0	8.70	3.95	22.70	10.30
7.10–7.20	201.0–203.9	8.80	3.99	23.05	10.46
7.20–7.30	203.9–206.7	8.85	4.01	23.35	10.59
7.30–7.40	206.7–209.5	8.95	4.06	23.65	10.73
7.40–7.50	209.5–212.4	9.05	4.11	23.95	10.86
7.50–7.60	212.4–215.2	9.15	4.15	24.30	11.02
7.60–7.70	215.2–218.0	9.25	4.20	24.60	11.16
7.70–7.80	218.0–220.9	9.30	4.22	24.90	11.29
7.80–7.90	220.9–223.7	9.40	4.26	25.20	11.43
7.90–8.00	223.7–226.5	9.50	4.31	25.50	11.57

Notes: (1) All test load weights are bone-dry weights.
(2) Allowable tolerance on the test load weights is ±0.10 lbs (0.05 kg).

[87 FR 33381, June 1, 2022, as amended at 87 FR 78820, Dec. 23, 2022; 89 FR 84076, Oct. 21, 2024]

APPENDIX J1 TO SUBPART B OF PART 430 [RESERVED]

APPENDIX J2 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF AUTOMATIC AND SEMI-AUTOMATIC CLOTHES WASHERS

NOTE 1 TO APPENDIX J2 TO SUBPART B OF PART 430: Manufacturers must use the results of testing under this appendix to determine compliance with the residential clothes washer standards provided at §430.32(g)(1) and the commercial clothes washer standards provided at §431.156(b).

Manufacturers must use the results of testing under Appendix J to this subpart to determine compliance with the residential clothes washer standards provided at §430.32(g)(2) and for any amended commercial clothes washer standards provided at §431.156 that are published after January 1, 2022.

Any representations related to energy or water consumption of residential or commercial clothes washers must be made in accordance with the appropriate appendix that applies (*i.e.*, appendix J to this subpart or this appendix) when determining compliance with the relevant standard.

0. INCORPORATION BY REFERENCE

DOE incorporated by reference in §430.3, the entire test standard for IEC 62301. However, only enumerated provisions of this standard are applicable to this appendix, as follows. In cases in which there is a conflict, the language of the test procedure in this appendix takes precedence over the referenced test standard.

0.1 IEC 62301:

(a) Section 4.2 as referenced in section 2.4 of this appendix;

(b) Section 4.3.2 as referenced in section 2.1.2 of this appendix;

(c) Section 4.4 as referenced in section 2.5.3 of this appendix;

(d) Section 5.1 as referenced in section 3.9.2 of this appendix;

(e) Section 5.2 as referenced in section 2.10 of this appendix; and

(f) Section 5.3.2 as referenced in section 3.9.3 of this appendix.

0.2 [Reserved]

1. DEFINITIONS

Active mode means a mode in which the clothes washer is connected to a mains power source, has been activated, and is performing one or more of the main functions of washing, soaking, tumbling, agitating, rinsing, and/or removing water from the clothing, or is involved in functions necessary for these main functions, such as admitting water into the washer or pumping water out of the washer. Active mode also includes delay start and cycle finished modes.

Active washing mode means a mode in which the clothes washer is performing any of the operations included in a complete cycle intended for washing a clothing load, including the main functions of washing, soaking, tumbling, agitating, rinsing, and/or removing water from the clothing.

Adaptive water fill control system means a clothes washer automatic water fill control system that is capable of automatically adjusting the water fill level based on the size or weight of the clothes load placed in the clothes container.

Automatic water fill control system means a clothes washer water fill control system that does not allow or require the user to determine or select the water fill level, and includes adaptive water fill control systems and fixed water fill control systems.

Bone-dry means a condition of a load of test cloth that has been dried in a dryer at maximum temperature for a minimum of 10 minutes, removed and weighed before cool down, and then dried again for 10 minute periods until the final weight change of the load is 1 percent or less.

Clothes container means the compartment within the clothes washer that holds the clothes during the operation of the machine.

Cold rinse means the coldest rinse temperature available on the machine, as indicated to the user on the clothes washer control panel.

Combined low-power mode means the aggregate of available modes other than active washing mode, including inactive mode, off mode, delay start mode, and cycle finished mode.

Cycle finished mode means an active mode that provides continuous status display, intermittent tumbling, or air circulation following operation in active washing mode.

Delay start mode means an active mode in which activation of active washing mode is facilitated by a timer.

Energy test cycle means the complete set of wash/rinse temperature selections required for testing, as determined according to section 2.12 of this appendix.

Fixed water fill control system means a clothes washer automatic water fill control system that automatically terminates the fill when the water reaches a pre-defined level that is not based on the size or weight of the clothes load placed in the clothes container, without allowing or requiring the user to determine or select the water fill level.

Inactive mode means a standby mode that facilitates the activation of active mode by remote switch (including remote control), internal sensor, or timer, or that provides continuous status display.

Integrated modified energy factor means the quotient of the cubic foot (or liter) capacity of the clothes container divided by the total clothes washer energy consumption per cycle, with such energy consumption expressed as the sum of:

(a) The machine electrical energy consumption;

(b) The hot water energy consumption;

(c) The energy required for removal of the remaining moisture in the wash load; and

(d) The combined low-power mode energy consumption.

Integrated water factor means the quotient of the total weighted per-cycle water consumption for all wash cycles in gallons divided by the cubic foot (or liter) capacity of the clothes washer.

Load usage factor means the percentage of the total number of wash loads that a user would wash a particular size (weight) load.

Lot means a quantity of cloth that has been manufactured with the same batches of cotton and polyester during one continuous process.

Manual water fill control system means a clothes washer water fill control system that requires the user to determine or select the water fill level.

Modified energy factor means the quotient of the cubic foot (or liter) capacity of the clothes container divided by the total clothes washer energy consumption per cycle, with such energy consumption expressed as the sum of the machine electrical energy consumption, the hot water energy consumption, and the energy required for removal of the remaining moisture in the wash load.

Non-water-heating clothes washer means a clothes washer that does not have an internal water heating device to generate hot water.

Normal cycle means the cycle recommended by the manufacturer (considering manufacturer instructions, control panel labeling, and other markings on the clothes washer) for normal, regular, or typical use for washing up to a full load of normally soiled cotton clothing. For machines where multiple cycle settings are recommended by the manufacturer for normal, regular, or typical use for washing up to a full load of normally soiled cotton clothing, then the Normal cycle is the cycle selection that results in the lowest IMEF or MEF_{J2} value.

Off mode means a mode in which the clothes washer is connected to a mains power source and is not providing any active or standby mode function, and where the mode may persist for an indefinite time.

Standby mode means any mode in which the clothes washer is connected to a mains power source and offers one or more of the following user oriented or protective functions that may persist for an indefinite time:

(a) Facilitating the activation of other modes (including activation or deactivation of active mode) by remote switch (including remote control), internal sensor, or timer;

(b) Continuous functions, including information or status displays (including clocks) or sensor-based functions.

(c) A timer is a continuous clock function (which may or may not be associated with a display) that provides regular scheduled tasks (*e.g.*, switching) and that operates on a continuous basis.

Temperature use factor means, for a particular wash/rinse temperature setting, the percentage of the total number of wash loads that an average user would wash with that setting.

User-adjustable adaptive water fill control system means a clothes washer fill control system that allows the user to adjust the amount of water that the machine provides, which is based on the size or weight of the clothes load placed in the clothes container.

Wash time means the wash portion of active washing mode, which begins when the cycle is initiated and includes the agitation or tumble time, which may be periodic or continuous during the wash portion of active washing mode.

Water factor means the quotient of the total weighted per-cycle water consumption for cold wash divided by the cubic foot (or liter) capacity of the clothes washer.

Water-heating clothes washer means a clothes washer where some or all of the hot water for clothes washing is generated by a water heating device internal to the clothes washer.

2. TESTING CONDITIONS AND INSTRUMENTATION

2.1 *Electrical energy supply.*

2.1.1 *Supply voltage and frequency.* Maintain the electrical supply at the clothes washer terminal block within 2 percent of 120, 120/240, or 120/208Y volts as applicable to the particular terminal block wiring system and within 2 percent of the nameplate frequency as specified by the manufacturer. If the clothes washer has a dual voltage conversion capability, conduct test at the highest voltage specified by the manufacturer.

2.1.2 *Supply voltage waveform.* For the combined low-power mode testing, maintain the electrical supply voltage waveform indicated in Section 4, Paragraph 4.3.2 of IEC 62301. If the power measuring instrument used for testing is unable to measure and record the total harmonic content during the test measurement period, total harmonic content may be measured and recorded immediately before and after the test measurement period.

2.2 *Supply water.* Maintain the temperature of the hot water supply at the water inlets between 130 °F (54.4 °C) and 135 °F (57.2 °C), targeting the midpoint of the range. Maintain the temperature of the cold water supply at the water inlets between 55 °F (12.8 °C) and 60 °F (15.6 °C), targeting the midpoint of the range.

2.3 *Water pressure.* Maintain the static water pressure at the hot and cold water inlet connection of the clothes washer at 35 pounds per square inch gauge (psig) ± 2.5 psig (241.3 kPa ± 17.2 kPa) when the water is flowing.

2.4 *Test room temperature.* For all clothes washers, maintain the test room ambient air temperature at 75 ± 5 °F (23.9 ± 2.8 °C) for active mode testing and combined low-power mode testing. Do not use the test room ambient air temperature conditions specified in Section 4, Paragraph 4.2 of IEC 62301 for combined low-power mode testing.

2.5 *Instrumentation.* Perform all test measurements using the following instruments, as appropriate:

2.5.1 *Weighing scales.*

2.5.1.1 *Weighing scale for test cloth.* The scale used for weighing test cloth must have a resolution of no larger than 0.2 oz (5.7 g) and a maximum error no greater than 0.3 percent of the measured value.

2.5.1.2 *Weighing scale for clothes container capacity measurement.* The scale used for performing the clothes container capacity measurement must have a resolution no larger than 0.50 lbs (0.23 kg) and a maximum error no greater than 0.5 percent of the measured value.

2.5.2 *Watt-hour meter.* The watt-hour meter used to measure electrical energy consumption must have a resolution no larger than 1 Wh (3.6 kJ) and a maximum error no greater than 2 percent of the measured value for any demand greater than 50 Wh (180.0 kJ).

2.5.3 *Watt meter.* The watt meter used to measure combined low-power mode power consumption must comply with the requirements specified in Section 4, Paragraph 4.4 of IEC 62301 (incorporated by reference, see §430.3). If the power measuring instrument used for testing is unable to measure and record the crest factor, power factor, or maximum current ratio during the test measurement period, the crest factor, power factor, and maximum current ratio may be measured and recorded immediately before and after the test measurement period.

2.5.4 *Water and air temperature measuring devices.* The temperature devices used to measure water and air temperature must have an error no greater than ±1 °F (±0.6 °C) over the range being measured.

2.5.4.1 Non-reversible temperature indicator labels, adhered to the inside of the clothes container, may be used to confirm that an extra-hot wash temperature greater than 135 °F has been achieved during the wash cycle, under the following conditions. The label must remain waterproof, intact, and adhered to the wash drum throughout an entire wash cycle; provide consistent maximum temperature readings; and provide repeatable temperature indications sufficient to demonstrate that a wash temperature of greater than 135 °F has been achieved. The label must have been verified to consistently indicate temperature measurements with an accuracy of ±1 °F if the label provides a temperature indicator at 135 °F. If the label does not provide a temperature indicator at 135 °F, the label must have been verified to consistently indicate temperature measurements with an accuracy of ±1 °F if the next-highest temperature indicator is greater

than 135 °F and less than 140 °F, or ±3 °F if the next-highest temperature indicator is 140 °F or greater. If the label does not provide a temperature indicator at 135 °F, failure to activate the next-highest temperature indicator does not necessarily indicate the lack of an extra-hot wash temperature. However, such a result would not be conclusive due to the lack of verification of the water temperature requirement, in which case an alternative method must be used to confirm that an extra-hot wash temperature greater than 135 °F has been achieved during the wash cycle. If using a temperature indicator label to test a front-loading clothes washer, adhere the label along the interior surface of the clothes container drum, midway between the front and the back of the drum, adjacent to one of the baffles. If using a temperature indicator label to test a top-loading clothes washer, adhere the label along the interior surface of the clothes container drum, on the vertical portion of the sidewall, as close to the bottom of the container as possible.

2.5.4.2 Submersible temperature loggers placed inside the wash drum may be used to confirm that an extra-hot wash temperature greater than 135 °F has been achieved during the wash cycle, under the following conditions. The submersible temperature logger must have a time resolution of at least 1 data point every 5 seconds and a temperature measurement accuracy of ±1 °F. Due to the potential for a waterproof capsule to provide a thermal insulating effect, failure to measure a temperature of 135 °F does not necessarily indicate the lack of an extra-hot wash temperature. However, such a result would not be conclusive due to the lack of verification of the water temperature requirement, in which case an alternative method must be used to confirm that an extra-hot wash temperature greater than 135 °F has been achieved during the wash cycle.

2.5.5 *Water meter.* A water meter must be installed in both the hot and cold water lines to measure water flow and/or water consumption. The water meters must have a resolution no larger than 0.1 gallons (0.4 liters) and a maximum error no greater than 2 percent for the water flow rates being measured. If the volume of hot water for any individual cycle within the energy test cycle is less than 0.1 gallons (0.4 liters), the hot water meter must have a resolution no larger than 0.01 gallons (0.04 liters).

2.5.6 *Water pressure gauge.* A water pressure gauge must be installed in both the hot and cold water lines to measure water pressure. The water pressure gauges must have a resolution of 1 pound per square inch gauge (psig) (6.9 kPa) and a maximum error no greater than 5 percent of any measured value.

2.6 *Bone dryer temperature.* The dryer used for bone drying must heat the test cloth load above 210 °F (99 °C).

2.7 *Test cloths.* The test cloth material and dimensions must conform to the specifications in appendix J3 to this subpart. The energy test cloth and the energy stuffer cloths must be clean and must not be used for more than 60 test runs (after preconditioning as specified in section 5 of appendix J3 to this subpart). All energy test cloth must be permanently marked identifying the lot number of the material. Mixed lots of material must not be used for testing a clothes washer. The moisture absorption and retention must be evaluated for each new lot of test cloth using the standard extractor Remaining Moisture Content (RMC) procedure specified in appendix J3 to this subpart.

2.8 *Test load sizes.* Use Table 5.1 of this appendix to determine the maximum, minimum, and, when required, average test load sizes based on the clothes container capacity as measured in section 3.1 of this appendix. Test loads must consist of energy test cloths and no more than five energy stuffer cloths per load to achieve the proper weight.

Use the test load sizes and corresponding water fill settings defined in Table 2.8 of this appendix when measuring water and energy consumption. Use only the maximum test load size when measuring RMC.

TABLE 2.8—REQUIRED TEST LOAD SIZES AND WATER FILL SETTINGS


Water fill control system type	Test load size	Water fill setting
Manual water fill control system	Max	Max.
	Min	Min.
Automatic water fill control system	Max	As determined by the clothes washer.
	Avg	
	Min	

2.9 *Use of test loads.*

2.9.1 Test loads for energy and water consumption measurements must be bone dry prior to the first cycle of the test, and dried to a maximum of 104 percent of bone dry weight for subsequent testing.

2.9.2 Prepare the energy test cloths for loading by grasping them in the center, lifting, and shaking them to hang loosely, as illustrated in Figure 2.9.2 of this appendix.


Figure 2.9.2—Grasping Energy Test Cloths in the Center, Lifting, and Shaking to Hang Loosely



For all clothes washers, follow any manufacturer loading instructions provided to the user regarding the placement of clothing within the clothes container. In the absence of any manufacturer instructions regarding the placement of clothing within the clothes container, the following loading instructions apply.

2.9.2.1 To load the energy test cloths in a top-loading clothes washer, arrange the cloths circumferentially around the axis of rotation of the clothes container, using alternating lengthwise orientations for adjacent pieces of cloth. Complete each cloth layer across its horizontal plane within the clothes container before adding a new layer. Figure 2.9.2.1 of this appendix illustrates the correct loading technique for a vertical-axis clothes washer.

Figure 2.9.2.1—Loading Energy Test Cloths into a Top-Loading Clothes Washer



2.9.2.2 To load the energy test cloths in a front-loading clothes washer, grasp each test cloth in the center as indicted in section 2.9.2 of this appendix, and then place each cloth into the clothes container prior to activating the clothes washer.

2.10 *Clothes washer installation.* Install the clothes washer in accordance with manufacturer's instructions. For combined low-power mode testing, install the clothes washer in accordance with Section 5, Paragraph 5.2 of IEC 62301 (incorporated by reference; see § 430.3), disregarding the provisions regarding batteries and the determination, classification, and testing of relevant modes.

2.11 *Clothes washer pre-conditioning.*

2.11.1 *Non-water-heating clothes washer.* If the clothes washer has not been filled with water in the preceding 96 hours, pre-condition it by running it through a cold rinse cycle and then draining it to ensure that the hose, pump, and sump are filled with water.

2.11.2 *Water-heating clothes washer.* If the clothes washer has not been filled with water in the preceding 96 hours, or if it has not been in the test room at the specified ambient conditions for 8 hours, pre-condition it by running it through a cold rinse cycle and then draining it to ensure that the hose, pump, and sump are filled with water.

2.12 *Determining the energy test cycle.* To determine the energy test cycle, evaluate the wash/rinse temperature selection flowcharts in the order in which they are presented in this section. Except for Cold Wash/Cold Rinse, use the maximum load size to evaluate each flowchart. The determination of the energy test cycle must take into consideration all cycle settings available to the end user, including any cycle selections or cycle modifications provided by the manufacturer via software or firmware updates to the product, for the basic model under test. The energy test cycle does not include any cycle that is recommended by the manufacturer exclusively for cleaning, deodorizing, or sanitizing the clothes washer.

Figure 2.12.1—Determination of Cold Wash/Cold Rinse




Figure 2.12.2—Determination of Hot Wash/Cold Rinse




Figure 2.12.3—Determination of Warm Wash/Cold Rinse




Figure 2.12.4—Determination of Warm Wash/Warm Rinse





Figure 2.12.5—Determination of Extra-Hot Wash/Cold Rinse



3. TEST MEASUREMENTS

3.1 *Clothes container capacity*. Measure the entire volume that a clothes load could occupy within the clothes container during active mode washer operation according to the following procedures:

3.1.1 Place the clothes washer in such a position that the uppermost edge of the clothes container opening is leveled horizontally, so that the container will hold the maximum amount of water. For front-loading clothes washers, the door seal and shipping bolts or other forms of bracing hardware to support the wash drum during shipping must remain in place during the capacity measurement.

If the design of a front-loading clothes washer does not include shipping bolts or other forms of bracing hardware to support

the wash drum during shipping, a laboratory may support the wash drum by other means, including temporary bracing or support beams. Any temporary bracing or support beams must keep the wash drum in a fixed position, relative to the geometry of the door and door seal components, that is representative of the position of the wash drum during normal operation. The method used must avoid damage to the unit that would affect the results of the energy and water testing.


For a front-loading clothes washer that does not include shipping bolts or other forms of bracing hardware to support the wash drum during shipping, the laboratory must fully document the alternative method used to support the wash drum during capacity measurement, include such documentation in the final test report, and pursuant to §429.71 of this chapter, the manufacturer must retain such documentation as part its test records.

3.1.2 Line the inside of the clothes container with a 2 mil thickness (0.051 mm) plastic bag. All clothes washer components that occupy space within the clothes container and that are recommended for use during a wash cycle must be in place and must be lined with a 2 mil thickness (0.051 mm) plastic bag to prevent water from entering any void space.

3.1.3 Record the total weight of the machine before adding water.

3.1.4 Fill the clothes container manually with either 60 °F ± 5 °F (15.6 °C ± 2.8 °C) or 100 °F ± 10 °F (37.8 °C ± 5.5 °C) water, with the door open. For a top-loading vertical-axis clothes washer, fill the clothes container to the uppermost edge of the rotating portion, including any balance ring. Figure 3.1.4.1 of this appendix illustrates the maximum fill level for top-loading clothes washers.


Figure 3.1.4.1—Maximum Fill Level for the Clothes Container Capacity Measurement of Top-Loading Vertical-Axis Clothes Washers



For a front-loading horizontal-axis clothes washer, fill the clothes container to the highest point of contact between the door and the door gasket. If any portion of the door or gasket would occupy the measured volume space when the door is closed, exclude from the measurement the volume that the door or gasket portion would occupy. For a front-loading horizontal-axis clothes washer with a concave door shape, include any additional volume above the plane defined by the highest point of contact between the door and the door gasket, if that area can be occupied by clothing during washer operation. For a top-loading horizontal-axis clothes washer, include any additional volume above the plane of the door hinge that clothing could occupy during washer operation. Figure 3.1.4.2 of this appendix illustrates the maximum fill volumes for all horizontal-axis clothes washer types.

Figure 3.1.4.2—Maximum Fill Volumes for the Clothes Container Capacity

Measurement of Horizontal-Axis Clothes Washers



For all clothes washers, exclude any volume that cannot be occupied by the clothing load during operation.

3.1.5 Measure and record the weight of water, W, in pounds.

3.1.6 Calculate the clothes container capacity as follows:

$C = W/d$

where:

C = Capacity in cubic feet (liters).
W = Mass of water in pounds (kilograms).
d = Density of water (62.0 lbs/ft^3 for 100 °F (993 kg/m^3 for 37.8 °C) or 62.3 lbs/ft^3 for 60 °F (998 kg/m^3 for 15.6 °C)).

3.1.7 Calculate the clothes container capacity, C, to the nearest 0.01 cubic foot for the purpose of determining test load sizes per Table 5.1 of this appendix and for all subsequent calculations that include the clothes container capacity.

3.2 *Procedure for measuring water and energy consumption values on all automatic and semi-automatic washers.*

3.2.1 Perform all energy consumption tests under the energy test cycle.

3.2.2 Perform the test sections listed in Table 3.2.2 in accordance with the wash/rinse temperature selections available in the energy test cycle.

TABLE 3.2.2—TEST SECTION REFERENCE

Wash/rinse temperature selections available in the energy test cycle	Corresponding test section reference
Extra-Hot/Cold	3.3
Hot/Cold	3.4
Warm/Cold	3.5
Warm/Warm	3.6
Cold/Cold	3.7
Test Sections Applicable to all Clothes Washers	
Remaining Moisture Content	3.8
Combined Low-Power Mode Power	3.9

3.2.3 *Hot and cold water faucets.*

3.2.3.1 For automatic clothes washers, open both the hot and cold water faucets.

3.2.3.2 For semi-automatic washers:

(1) For hot inlet water temperature, open the hot water faucet completely and close the cold water faucet;

(2) For warm inlet water temperature, open both hot and cold water faucets completely;

(3) For cold inlet water temperature, close the hot water faucet and open the cold water faucet completely.

3.2.4 *Wash/rinse temperature selection.* Set the wash/rinse temperature selection control to obtain the desired wash/rinse temperature selection within the energy test cycle.

3.2.5 *Wash time setting.*

3.2.5.1 If the cycle under test offers a range of wash time settings, the wash time setting shall be the higher of either the minimum or 70 percent of the maximum wash time available for the wash cycle under test, regardless of the labeling of suggested dial locations. If 70 percent of the maximum wash time is not available on a dial with a discrete number of wash time settings, choose the next-highest setting greater than 70 percent.

3.2.5.2 If the clothes washer is equipped with an electromechanical dial or timer controlling wash time that rotates in both directions, reset the dial to the minimum wash time and then turn it in the direction of increasing wash time to reach the appropriate setting. If the appropriate setting is passed, return the dial to the minimum wash time and then turn in the direction of increasing wash time until the appropriate setting is reached.

3.2.6 *Water fill levels.*

3.2.6.1 *Clothes washers with manual water fill control system.* Set the water fill selector to the maximum water level available for the wash cycle under test for the maximum test load size and the minimum water level available for the wash cycle under test for the minimum test load size.

3.2.6.2 *Clothes washers with automatic water fill control system.*

3.2.6.2.1 *Not user adjustable.* The maximum, minimum, and average water levels as described in the following sections refer to the amount of water fill that is automatically selected by the control system when the respective test loads are used.

3.2.6.2.2 *User-adjustable adaptive.* Conduct four tests on clothes washers with user-adjustable adaptive water fill controls. Conduct the first test using the maximum test load and with the adaptive water fill control system set in the setting that uses the most water. Conduct the second test using the minimum test load and with the adaptive water fill control system set in the setting that uses the least water. Conduct the third test using the average test load and with the adaptive water fill control system set in the setting that uses the most water. Conduct the fourth test using the average test load and with the adaptive water fill control system set in the setting that uses the least water. Average the results of the third and fourth tests to obtain the energy and water consumption values for the average test load size.

3.2.6.3 *Clothes washers with automatic water fill control system and alternate manual water fill control system.* If a clothes washer with an automatic water fill control system allows user selection of manual controls as an alternative, test both manual and automatic modes and, for each mode, calculate the energy consumption (HE_T, ME_T, and D_E) and water consumption (Q_T) values as set forth in section 4 of this appendix. Then, calculate the average of the two values (one from each mode, automatic and manual) for each variable (HE_T, ME_T, D_E, and Q_T) and use the average value for each variable in the final calculations in section 4 of this appendix.

3.2.7 *Manufacturer default settings.* For clothes washers with electronic control systems, use the manufacturer default settings for any cycle selections, except for (1) the temperature selection, (2) the wash water fill levels, (3) if necessary, the spin speeds on wash cycles used to determine remaining moisture content, or (4) network settings. If the clothes washer has network capabilities, the network settings must be disabled throughout testing if such settings can be disabled by the end-user and the product's user manual provides instructions on how to do so. For all other cycle selections, the manufacturer default settings must be used for wash conditions such as agitation/tumble operation, soil level, spin speed on wash cycles used to determine energy and water consumption, wash times, rinse times, optional rinse settings, water heating time for water heating clothes washers, and all other wash parameters or optional features applicable to that wash cycle. Any optional wash cycle feature or setting (other than wash/rinse temperature, water fill level selection, spin speed on wash cycles used to determine remaining moisture content, or network settings on clothes washers with network capabilities) that is activated by default on the wash cycle under test must be included for testing unless the manufacturer instructions recommend not selecting this option, or recommend selecting a different option, for washing normally soiled cotton clothing. For clothes washers with control panels containing mechanical switches or dials, any optional settings, except for (1) the temperature selection, (2) the wash water fill levels, or (3) if necessary, the spin speeds on wash cycles used to determine remaining moisture content, must be in the position recommended by the manufacturer for washing normally soiled cotton clothing. If the manufacturer instructions do not recommend a particular switch or dial position to be used for washing normally soiled cotton clothing, the setting switch or dial must remain in its as-shipped position.

3.2.8 For each wash cycle tested, include the entire active washing mode and exclude any delay start or cycle finished modes.

3.2.9 *Anomalous Test Cycles.* If during a wash cycle the clothes washer: (a) Signals to the user by means of a visual or audio alert that an out-of-balance condition has been detected; or (b) terminates prematurely and thus does not include the agitation/tumble operation, spin speed(s), wash times, and rinse times applicable to the wash cycle under test, discard the test data and repeat the wash cycle. Document in the test report the rejection of data from any wash cycle during testing and the reason for the rejection.

3.3 *Extra-Hot Wash/Cold Rinse.* Measure the water and electrical energy consumption for each water fill level and test load size as specified in sections 3.3.1 through 3.3.3 of this appendix for the Extra-Hot Wash/Cold Rinse as defined within the energy test cycle.

3.3.1 *Maximum test load and water fill.* Measure the values for hot water consumption (Hm_X), cold water consumption (Cm_X), and electrical energy consumption (Em_X) for an Extra-Hot Wash/Cold Rinse cycle, with the controls set for the maximum water fill level. Use the maximum test load size as specified in Table 5.1 of this appendix.

3.3.2 *Minimum test load and water fill.* Measure the values for hot water consumption (Hm_n), cold water consumption (Cm_n), and electrical energy consumption (Em_n) for an Extra-Hot Wash/Cold Rinse cycle, with the controls set for the minimum water fill level. Use the minimum test load size as specified in Table 5.1 of this appendix.

3.3.3 *Average test load and water fill.* For a clothes washer with an automatic water fill control system, measure the values for hot

water consumption (Hm_a), cold water consumption (Cm_a), and electrical energy consumption (Em_a) for an Extra-Hot Wash/Cold Rinse cycle. Use the average test load size as specified in Table 5.1 of this appendix.

3.4 *Hot Wash/Cold Rinse.* Measure the water and electrical energy consumption for each water fill level and test load size as specified in sections 3.4.1 through 3.4.3 of this appendix for the Hot Wash/Cold Rinse temperature selection, as defined within the energy test cycle.

3.4.1 *Maximum test load and water fill.* Measure the values for hot water consumption (Hh_X), cold water consumption (Ch_X), and electrical energy consumption (Eh_X) for a Hot Wash/Cold Rinse cycle, with the controls set for the maximum water fill level. Use the maximum test load size as specified in Table 5.1 of this appendix.

3.4.2 *Minimum test load and water fill.* Measure the values for hot water consumption (Hh_n), cold water consumption (Ch_n), and electrical energy consumption (Eh_n) for a Hot Wash/Cold Rinse cycle, with the controls set for the minimum water fill level. Use the minimum test load size as specified in Table 5.1 of this appendix.

3.4.3 *Average test load and water fill.* For a clothes washer with an automatic water fill control system, measure the values for hot water consumption (Hh_a), cold water consumption (Ch_a), and electrical energy consumption (Eh_a) for a Hot Wash/Cold Rinse cycle. Use the average test load size as specified in Table 5.1 of this appendix.

3.5 *Warm Wash/Cold Rinse.* Measure the water and electrical energy consumption for each water fill level and test load size as specified in sections 3.5.1 through 3.5.3 of this appendix for the applicable Warm Wash/Cold Rinse temperature selection(s), as defined within the energy test cycle.

For a clothes washer with fewer than four discrete Warm Wash/Cold Rinse temperature selections, test all Warm Wash/Cold Rinse selections. For a clothes washer that offers four or more Warm Wash/Cold Rinse selections, test at all discrete selections, or test at the 25 percent, 50 percent, and 75 percent positions of the temperature selection device between the hottest hot (≤135 °F (57.2 °C)) wash and the coldest cold wash. If a selection is not available at the 25, 50 or 75 percent position, in place of each such unavailable selection, use the next warmer setting. For each reportable value to be used for the Warm Wash/Cold Rinse temperature selection, calculate the average of all Warm Wash/Cold Rinse temperature selections tested pursuant to this section.

3.5.1 *Maximum test load and water fill.* Measure the values for hot water consumption (Hw_X), cold water consumption (Cw_X), and electrical energy consumption (Ew_X) for the Warm Wash/Cold Rinse cycle, with the controls set for the maximum water fill level. Use the maximum test load size as specified in Table 5.1 of this appendix.

3.5.2 *Minimum test load and water fill.* Measure the values for hot water consumption (Hw_n), cold water consumption (Cw_n), and electrical energy consumption (Ew_n) for the Warm Wash/Cold Rinse cycle, with the controls set for the minimum water fill level. Use the minimum test load size as specified in Table 5.1 of this appendix.

3.5.3 *Average test load and water fill.* For a clothes washer with an automatic water fill control system, measure the values for hot water consumption (Hw_a), cold water consumption (Cw_a), and electrical energy consumption (Ew_a) for a Warm Wash/Cold Rinse cycle. Use the average test load size as specified in Table 5.1 of this appendix.

3.6 *Warm Wash/Warm Rinse.* Measure the water and electrical energy consumption for each water fill level and/or test load size as specified in sections 3.6.1 through 3.6.3 of this appendix for the applicable Warm Wash/Warm Rinse temperature selection(s), as defined within the energy test cycle. For a clothes washer with fewer than four discrete Warm Wash/Warm Rinse temperature selections, test all Warm Wash/Warm Rinse selections. For a clothes washer that offers four or more Warm Wash/Warm Rinse selections, test at all discrete selections, or test at 25 percent, 50 percent, and 75 percent positions of the temperature selection device between the hottest hot (≤ 135 °F (57.2 °C)) wash and the coldest cold wash. If a selection is not available at the 25, 50 or 75 percent position, in place of each such unavailable selection use the next warmer setting. For each reportable value to be used for the Warm Wash/Warm Rinse temperature selection, calculate the average of all Warm Wash/Warm Rinse temperature selections tested pursuant to this section.

3.6.1 *Maximum test load and water fill.* Measure the values for hot water consumption (Hww_X), cold water consumption (Cww_X), and electrical energy consumption (Eww_X) for the Warm Wash/Warm Rinse cycle, with the controls set for the maximum water fill level. Use the maximum test load size as specified in Table 5.1 of this appendix.

3.6.2 *Minimum test load and water fill.* Measure the values for hot water consumption (Hww_n), cold water consumption (Cww_n), and electrical energy consumption (Eww_n) for the Warm Wash/Warm Rinse cycle, with the controls set for the minimum water fill level. Use the minimum test load size as specified in Table 5.1 of this appendix.

3.6.3 *Average test load and water fill.* For a clothes washer with an automatic water fill control system, measure the values for hot water consumption (Hww_a), cold water consumption (Cww_a), and electrical energy consumption (Eww_a) for the Warm Wash/Warm Rinse cycle. Use the average test load size as specified in Table 5.1 of this appendix.

3.7 *Cold Wash/Cold Rinse.* Measure the water and electrical energy consumption for each water fill level and test load size as specified in sections 3.7.1 through 3.7.3 of this appendix for the applicable Cold Wash/Cold Rinse temperature selection, as defined within the energy test cycle.

3.7.1 *Maximum test load and water fill.* Measure the values for hot water consumption (Hc_X), cold water consumption (Cc_X), and electrical energy consumption (Ec_X) for a Cold Wash/Cold Rinse cycle, with the controls set for the maximum water fill level. Use the maximum test load size as specified in Table 5.1 of this appendix.

3.7.2 *Minimum test load and water fill.* Measure the values for hot water consumption (Hc_n), cold water consumption (Cc_n), and electrical energy consumption (Ec_n) for a Cold Wash/Cold Rinse cycle, with the controls set for the minimum water fill level. Use the minimum test load size as specified in Table 5.1 of this appendix.

3.7.3 *Average test load and water fill.* For a clothes washer with an automatic water fill control system, measure the values for hot water consumption (Hc_a), cold water consumption (Cc_a), and electrical energy consumption (Ec_a) for a Cold Wash/Cold Rinse cycle. Use the average test load size as specified in Table 5.1 of this appendix.

3.8 *Remaining moisture content (RMC).*

3.8.1 The wash temperature must be the same as the rinse temperature for all testing. Use the maximum test load as defined in Table 5.1 of this appendix for testing.

3.8.2 *Clothes washers with cold rinse only.*

3.8.2.1 Record the actual ''bone dry'' weight of the test load (WI_X), then place the test load in the clothes washer.

3.8.2.2 Set the water level controls to maximum fill.

3.8.2.3 Run the Cold Wash/Cold Rinse cycle.

3.8.2.4 Record the weight of the test load immediately after completion of the wash cycle (WC_X).

3.8.2.5 Calculate the remaining moisture content of the maximum test load, RMC_X, defined as:

$$RMC_X = (WC_X - WI_X)/WI_X$$

3.8.2.6 Apply the RMC correction curve described in section 9 of appendix J3 to this subpart to calculate the corrected remaining moisture content, RMC_{corr}, expressed as a percentage as follows:

$$RMC_{corr} = (A \times RMC_X + B) \times 100\%$$

where:

A and B are the coefficients of the RMC correction curve as defined in section 8.7 of appendix J3 to this subpart.

RMC_X = As defined in section 3.8.2.5 of this appendix.

3.8.2.7 Use RMC_{corr} as the final corrected RMC in section 4.3 of this appendix.

3.8.3 *Clothes washers with both cold and warm rinse options.*

3.8.3.1 Complete sections 3.8.2.1 through 3.8.2.4 of this appendix for a Cold Wash/Cold Rinse cycle. Calculate the remaining moisture content of the maximum test load for Cold Wash/Cold Rinse, RMC_{COLD}, defined as:

$$RMC_{COLD} = (WC_X - WI_X)/WI_X$$

3.8.3.2 Apply the RMC correction curve described in section 9 of appendix J3 to this subpart to calculate the corrected remaining moisture content for Cold Wash/Cold Rinse, $RMC_{COLD,corr}$, expressed as a percentage, as follows:

$$RMC_{COLD,corr} = (A \times RMC_{COLD} + B) \times 100\%$$

where:

A and B are the coefficients of the RMC correction curve as defined in section 8.7 of appendix J3 to this subpart.

RMC_{COLD} = As defined in section 3.8.3.1 of this appendix.

3.8.3.3 Complete sections 3.8.2.1 through 3.8.2.4 of this appendix using a Warm Wash/Warm Rinse cycle instead. Calculate the remaining moisture content of the maximum test load for Warm Wash/Warm Rinse, RMC_{WARM}, defined as:

$$RMC_{WARM} = (WC_X - WI_X)/WI_X$$

3.8.3.4 Apply the RMC correction curve described in section 9 of appendix J3 to this subpart to calculate the corrected remaining moisture content for Warm Wash/Warm Rinse, $RMC_{WARM,corr}$, expressed as a percentage, as follows:

$$RMC_{WARM,corr} = (A \times RMC_{WARM} + B) \times 100\%$$

where:

A and B are the coefficients of the RMC correction curve as defined in section 8.7 of appendix J3 to this subpart.

RMC_{WARM} = As defined in section 3.8.3.3 of this appendix.

3.8.3.5 Calculate the corrected remaining moisture content of the maximum test load, RMC_{corr}, expressed as a percentage as follows:

$$RMC_{corr} = RMC_{COLD,corr} \times (1 - TUF_{ww}) + RMC_{WARM,corr} \times (TUF_{ww})$$

where:

$RMC_{COLD,corr}$ = As defined in section 3.8.3.2 of this Appendix.

$RMC_{WARM,corr}$ = As defined in section 3.8.3.4 of this Appendix.

TUF_{ww} is the temperature use factor for Warm Wash/Warm Rinse as defined in Table 4.1.1 of this appendix.

3.8.3.6 Use RMC_{corr} as calculated in section 3.8.3.5 as the final corrected RMC used in section 4.3 of this appendix.

3.8.4 *Clothes washers that have options such as multiple selections of spin speeds or spin times that result in different RMC values, and that are available within the energy test cycle.*

3.8.4.1 Complete sections 3.8.2 or 3.8.3 of this appendix, as applicable, using the maximum and minimum extremes of the available spin options, excluding any ''no spin'' (zero spin speed) settings. Combine the calculated values $RMC_{corr,max\ extraction}$ and $RMC_{corr,min\ extraction}$ at the maximum and minimum settings, respectively, as follows:

$RMC_{corr} = 0.75 \times RMC_{corr,max\ extraction} + 0.25 \times RMC_{corr,min\ extraction}$

where:

$RMC_{corr,\ max\ extraction}$ is the corrected remaining moisture content using the maximum spin setting, calculated according to section 3.8.2 or 3.8.3 of this appendix, as applicable.

$RMC_{corr,\ min\ extraction}$ is the corrected remaining moisture content using the minimum spin setting, calculated according to section 3.8.2 or 3.8.3 of this appendix, as applicable.

3.8.4.2 Use RMC_{corr} as calculated in section 3.8.4.1 as the final corrected RMC used in section 4.3 of this appendix.

3.8.5 The procedure for calculating the corrected RMC as described in section 3.8.2, 3.8.3, or 3.8.4 of this appendix may be replicated twice in its entirety, for a total of three independent corrected RMC measurements. If three replications of the RMC measurement are performed, use the average of the three corrected RMC measurements as the final corrected RMC in section 4.3 of this appendix.

3.9 *Combined low-power mode power.* Connect the clothes washer to a watt meter as specified in section 2.5.3 of this appendix. Establish the testing conditions set forth in sections 2.1, 2.4, and 2.10 of this appendix.

3.9.1 Perform combined low-power mode testing after completion of an active mode wash cycle included as part of the energy test cycle; after removing the test load; without changing the control panel settings used for the active mode wash cycle; with the door closed; and without disconnecting the electrical energy supply to the clothes washer between completion of the active mode wash cycle and the start of combined low-power mode testing.

3.9.2 For a clothes washer that takes some time to automatically enter a stable inactive mode or off mode state from a higher power state as discussed in Section 5, Paragraph 5.1, note 1 of IEC 62301 (incorporated by reference; see §430.3), allow sufficient time for the clothes washer to automatically reach the default inactive/off mode state before proceeding with the test measurement.

3.9.3 Once the stable inactive/off mode state has been reached, measure and record the default inactive/off mode power, $P_{default}$, in watts, following the test procedure for the sampling method specified in Section 5, Paragraph 5.3.2 of IEC 62301.

3.9.4 For a clothes washer with a switch, dial, or button that can be optionally selected by the end user to achieve a lower-power inactive/off mode state than the default inactive/off mode state measured in section 3.9.3 of this appendix, after performing the measurement in section 3.9.3, activate the switch, dial, or button to the position resulting in the lowest power consumption and repeat the measurement procedure described in section 3.9.3. Measure and record the lowest-power inactive/off mode power, P_{lowest}, in Watts.

3.10 *Energy consumption for the purpose of determining the cycle selection(s) to be included in the energy test cycle.* This section is implemented only in cases where the energy test cycle flowcharts in section 2.12 require the determination of the wash/rinse temperature selection with the highest energy consumption.

3.10.1 For the wash/rinse temperature selection being considered under this section, establish the testing conditions set forth in section 2 of this appendix. Select the applicable cycle selection and wash/rinse temperature selection. For all wash/rinse temperature selections, the manufacturer default settings shall be used as described in section 3.2.7 of this appendix.

3.10.2 Use the clothes washer's maximum test load size, determined from Table 5.1 of this appendix, for testing under this section.

3.10.3 For clothes washers with a manual fill control system, user-adjustable automatic water fill control system, or automatic water fill control system with alternate manual water fill control system, use the water fill selector setting resulting in the maximum water level available for each cycle selection for testing under this section.

3.10.4 Each wash cycle tested under this section shall include the entire active washing mode and exclude any delay start or cycle finished modes.

3.10.5 Measure each wash cycle's electrical energy consumption (E_X) and hot water consumption (H_X). Calculate the total energy consumption for each cycle selection (E_{TX}), as follows:

$E_{TX} = E_X + (H_X \times T \times K)$

where:

E_X is the electrical energy consumption, expressed in kilowatt-hours per cycle.

H_X is the hot water consumption, expressed in gallons per cycle.

T = nominal temperature rise = 75 °F (41.7 °C).

K = Water specific heat in kilowatt-hours per gallon per degree F = 0.00240 kWh/gal - °F (0.00114 kWh/L- °C).

4. Calculation of Derived Results From Test Measurements

4.1 *Hot water and machine electrical energy consumption of clothes washers.*

4.1.1 *Per-cycle temperature-weighted hot water consumption for all maximum, average, and minimum water fill levels tested.* Calculate the per-cycle temperature-weighted hot water consumption for the maximum water fill level, Vh_X, the average water fill level, Vh_a, and the minimum water fill level, Vh_n, expressed in gallons per cycle (or liters per cycle) and defined as:

(a) $Vh_X = [Hm_X \times TUF_m] + [Hh_X \times TUF_h] + [Hw_X \times TUF_w] + [Hww_X \times TUF_{ww}] + [Hc_X \times TUF_c]$

(b) $Vh_a = [Hm_a \times TUF_m] + [Hh_a \times TUF_h] + [Hw_a \times TUF_w] + [Hww_a \times TUF_{ww}] + [Hc_a \times TUF_c]$

(c) $Vh_n = [Hm_n \times TUF_m] + [Hh_n \times TUF_h] + [Hw_n \times TUF_w] + [Hww_n \times TUF_{ww}] + [Hc_n \times TUF_c]$

where:

Hm_X, Hm_a, and Hm_n, are reported hot water consumption values, in gallons per-cycle (or liters per cycle), at maximum, average, and minimum water fill levels, respectively, for the Extra-Hot Wash/Cold Rinse cycle, as measured in sections 3.3.1 through 3.3.3 of this appendix.

Hh_X, Hh_a, and Hh_n, are reported hot water consumption values, in gallons per-cycle (or liters per cycle), at maximum, average, and minimum water fill levels, respectively, for the Hot Wash/Cold Rinse cycle, as measured in sections 3.4.1 through 3.4.3 of this appendix.

Hw_X, Hw_a, and Hw_n, are reported hot water consumption values, in gallons per-cycle (or liters per cycle), at maximum, average, and minimum water fill levels, respectively, for the Warm Wash/Cold Rinse cycle, as measured in sections 3.5.1 through 3.5.3 of this appendix.

Hww_X, Hww_a, and Hww_n, are reported hot water consumption values, in gallons per-cycle (or liters per cycle), at maximum, average, and minimum water fill levels, respectively, for the Warm Wash/Warm Rinse cycle, as measured in sections 3.6.1 through 3.6.3 of this appendix.

Hc_X, Hc_a, and Hc_n, are reported hot water consumption values, in gallons per-cycle (or liters per cycle), at maximum, average, and minimum water fill levels, respectively, for the Cold Wash/Cold Rinse cycle, as measured in sections 3.7.1 through 3.7.3 of this appendix.

TUF_m, TUF_h, TUF_w, TUF_{ww}, and TUF_c are temperature use factors for Extra-Hot Wash/Cold Rinse, Hot Wash/Cold Rinse, Warm Wash/Cold Rinse, Warm Wash/Warm Rinse, and Cold Wash/Cold Rinse temperature selections, respectively, as defined in Table 4.1.1 of this appendix.

TABLE 4.1.1—TEMPERATURE USE FACTORS

Wash/Rinse Temperature Selections Available in the Energy Test Cycle	Clothes washers with cold rinse only					Clothes washers with both cold and warm rinse		
	C/C	H/C C/C	H/C W/C C/C	XH/C H/C C/C	XH/C H/C W/C C/C	H/C W/C W/W C/C	XH/C H/C W/W C/C	XH/C H/C W/C W/W C/C
TUF_m (Extra-Hot/Cold)	.....	.....	.....	0.14	0.05	.....	0.14	0.05
TUF_h (Hot/Cold)	.....	0.63	0.14	*0.49	0.09	0.14	*0.22	0.09
TUF_w (Warm/Cold)	.....	.....	0.49	.....	0.49	0.22	.....	0.22
TUF_{ww} (Warm/Warm)	.....	.....	.....	.....	.....	0.27	0.27	0.27
TUF_c (Cold/Cold)	1.00	0.37	0.37	0.37	0.37	0.37	0.37	0.37

*On clothes washers with only two wash temperature selections ≤135 °F, the higher of the two wash temperatures is classified as a Hot Wash/Cold Rinse, in accordance with the wash/rinse temperature definitions within the energy test cycle.

4.1.2 *Total per-cycle hot water energy consumption for all maximum, average, and minimum water fill levels tested.* Calculate the total per-cycle hot water energy consumption for the maximum water fill level, HE_{max}, the average water fill level, HE_{avg}, and the minimum water fill level, HE_{min}, expressed in kilowatt-hours per cycle and defined as:

(a) $HE_{max} = [Vh_X \times T \times K]$ = Total energy when a maximum load is tested.

(b) $HE_{avg} = [Vh_a \times T \times K]$ = Total energy when an average load is tested.

(c) $HE_{min} = [Vh_n \times T \times K]$ = Total energy when a minimum load is tested.

where:

Vh_X, Vh_a, and Vh_n are defined in section 4.1.1 of this appendix.

T = Temperature rise = 75 °F (41.7 °C).

K = Water specific heat in kilowatt-hours per gallon per degree F = 0.00240 kWh/gal- °F (0.00114 kWh/L- °C).

4.1.3 *Total weighted per-cycle hot water energy consumption.* Calculate the total weighted per-cycle hot water energy consumption, HE_T, expressed in kilowatt-hours per cycle and defined as:

$HE_T = [HE_{max} \times F_{max}] + [HE_{avg} \times F_{avg}] + HE_{min} \times F_{min}]$

where:

HE_{max}, HE_{avg}, and HE_{min} are defined in section 4.1.2 of this appendix.

F_{max}, F_{avg}, and F_{min} are the load usage factors for the maximum, average, and minimum test loads based on the size and type of

the control system on the washer being tested, as defined in Table 4.1.3 of this appendix.

TABLE 4.1.3—LOAD USAGE FACTORS

Load usage factor	Water fill control system	
	Manual	Automatic
F_{max} =	0.72	0.12
F_{avg} =	.....	0.74
F_{min} =	0.28	0.14

4.1.4 *Total per-cycle hot water energy consumption using gas-heated or oil-heated water, for product labeling requirements.* Calculate for the energy test cycle the per-cycle hot water consumption, HE_{TG}, using gas-heated or oil-heated water, expressed in Btu per cycle (or megajoules per cycle) and defined as:

$HE_{TG} = HE_T \times 1/e \times 3412$ Btu/kWh or $HE_{TG} = HE_T \times 1/e \times 3.6$ MJ/kWh

where:

e = Nominal gas or oil water heater efficiency = 0.75.

HE_T = As defined in section 4.1.3 of this Appendix.

4.1.5 *Per-cycle machine electrical energy consumption for all maximum, average, and minimum test load sizes.* Calculate the total per-cycle machine electrical energy consumption for the maximum water fill level, ME_{max}, the average water fill level, ME_{avg}, and the minimum water fill level, ME_{min}, expressed in kilowatt-hours per cycle and defined as:

(a) $ME_{max} = [Em_X \times TUF_m] + [Eh_X \times TUF_h] + [Ew_X \times TUF_w] + [Eww_X \times TUF_{ww}] + [Ec_X \times TUF_c]$

(b) $ME_{avg} = [Em_a \times TUF_m] + [Eh_a \times TUF_h] + [Ew_a \times TUF_w] + [Eww_a \times TUF_{ww}] + [Ec_a \times TUF_c]$

(c) $ME_{min} = [Em_n \times TUF_m] + [Eh_n \times TUF_h] + [Ew_n \times TUF_w] + [Eww_n \times TUF_{ww}] + [Ec_n \times TUF_c]$

where:

Em_X, Em_a, and Em_n, are reported electrical energy consumption values, in kilowatt-hours per cycle, at maximum, average, and minimum test loads, respectively, for the Extra-Hot Wash/Cold Rinse cycle, as measured in sections 3.3.1 through 3.3.3 of this appendix.

Eh_X, Eh_a, and Eh_n, are reported electrical energy consumption values, in kilowatt-hours per cycle, at maximum, average, and minimum test loads, respectively, for the Hot Wash/Cold Rinse cycle, as measured in sections 3.4.1 through 3.4.3 of this appendix.

Ew_X, Ew_a, and Ew_n, are reported electrical energy consumption values, in kilowatt-hours per cycle, at maximum, average, and minimum test loads, respectively, for the Warm Wash/Cold Rinse cycle, as measured in sections 3.5.1 through 3.5.3 of this appendix.

Eww_X, Eww_a, and Eww_n, are reported electrical energy consumption values, in kilowatt-hours per cycle, at maximum, average, and minimum test loads, respectively, for the Warm Wash/Warm Rinse cycle, as measured in sections 3.6.1 through 3.6.3 of this appendix.

Ec_X, Ec_a, and Ec_n, are reported electrical energy consumption values, in kilowatt-hours per cycle, at maximum, average, and minimum test loads, respectively, for the Cold Wash/Cold Rinse cycle, as measured in sections 3.7.1 through 3.7.3 of this appendix.

TUF_m, TUF_h, TUF_w, TUF_{ww}, and TUF_c are defined in Table 4.1.1 of this appendix.

4.1.6 *Total weighted per-cycle machine electrical energy consumption.* Calculate the total weighted per-cycle machine electrical energy consumption, ME_T, expressed in kilowatt-hours per cycle and defined as:

$ME_T = [ME_{max} \times F_{max}] + [ME_{avg} \times F_{avg}] + [ME_{min} \times F_{min}]$

where:

ME_{max}, ME_{avg}, and ME_{min} are defined in section 4.1.5 of this appendix.

F_{max}, F_{avg}, and F_{min} are defined in Table 4.1.3 of this appendix.

4.1.7 *Total per-cycle energy consumption when electrically heated water is used.* Calculate the total per-cycle energy consumption, E_{TE}, using electrically heated water, expressed in kilowatt-hours per cycle and defined as:

$E_{TE} = H_{ET} + M_{ET}$

where:

M_{ET} = As defined in section 4.1.6 of this appendix.

H_{ET} = As defined in section 4.1.3 of this appendix.

4.2 Water consumption of clothes washers.

4.2.1 *Per-cycle water consumption for Extra-Hot Wash/Cold Rinse.* Calculate the maximum, average, and minimum total water consumption, expressed in gallons per cycle (or liters per cycle), for the Extra-Hot Wash/Cold Rinse cycle and defined as:

$Qm_{max} = [Hm_X + Cm_X]$
$Qm_{avg} = [Hm_a + Cm_a]$
$Qm_{min} = [Hm_n + Cm_n]$

where:

Hm_X, Cm_X, Hm_a, Cm_a, Hm_n, and Cm_n are defined in section 3.3 of this appendix.

4.2.2 *Per-cycle water consumption for Hot Wash/Cold Rinse.* Calculate the maximum, average, and minimum total water consumption, expressed in gallons per cycle (or liters per cycle), for the Hot Wash/Cold Rinse cycle and defined as:

$Qh_{max} = [Hh_X + Ch_X]$
$Qh_{avg} = [Hh_a + Ch_a]$
$Qh_{min} = [Hh_n + Ch_n]$

where:

Hh_X, Ch_X, Hh_a, Ch_a, Hh_n, and Ch_n are defined in section 3.4 of this appendix.

4.2.3 *Per-cycle water consumption for Warm Wash/Cold Rinse.* Calculate the maximum, average, and minimum total water consumption, expressed in gallons per cycle (or liters per cycle), for the Warm Wash/Cold Rinse cycle and defined as:

$Qw_{max} = [Hw_X + Cw_X]$
$Qw_{avg} = [Hw_a + Cw_a]$
$Qw_{min} = [Hw_n + Cw_n]$

where:

Hw_X, Cw_X, Hw_a, Cw_a, Hw_n, and Cw_n are defined in section 3.5 of this appendix.

4.2.4 *Per-cycle water consumption for Warm Wash/Warm Rinse.* Calculate the maximum, average, and minimum total water consumption, expressed in gallons per cycle (or liters per cycle), for the Warm Wash/Warm Rinse cycle and defined as:

$Qww_{max} = [Hww_X + Cww_X]$
$Qww_{avg} = [Hww_a + Cww_a]$
$Qww_{min} = [Hww_n + Cww_n]$

where:

Hww_X, Cww_X, Hww_a, Cww_a, Hww_n, and Cww_n are defined in section 3.6 of this appendix.

4.2.5 *Per-cycle water consumption for Cold Wash/Cold Rinse.* Calculate the maximum, average, and minimum total water consumption, expressed in gallons per cycle (or liters per cycle), for the Cold Wash/Cold Rinse cycle and defined as:

$Qc_{max} = [Hc_X + Cc_X]$
$Qc_{avg} = [Hc_a + Cc_a]$
$Qc_{min} = [Hc_n + Cc_n]$

where:

Hc_X, Cc_X, Hc_a, Cc_a, Hc_n, and Cc_n are defined in section 3.7 of this appendix.

4.2.6 *Total weighted per-cycle water consumption for Extra-Hot Wash/Cold Rinse.* Calculate the total weighted per-cycle water consumption for the Extra-Hot Wash/Cold Rinse cycle, Qm_T, expressed in gallons per cycle (or liters per cycle) and defined as:

$Qm_T = [Qm_{max} \times F_{max}] + [Qm_{avg} \times F_{avg}] + [Qm_{min} \times F_{min}]$

where:

Qm_{max}, Qm_{avg}, Qm_{min} are defined in section 4.2.1 of this appendix.

F_{max}, F_{avg}, F_{min} are defined in Table 4.1.3 of this appendix.

4.2.7 *Total weighted per-cycle water consumption for Hot Wash/Cold Rinse.* Calculate the total weighted per-cycle water consumption for the Hot Wash/Cold Rinse cycle, Qh_T, expressed in gallons per cycle (or liters per cycle) and defined as:

$Qh_T = [Qh_{max} \times F_{max}] + [Qh_{avg} \times F_{avg}] + [Qh_{min} \times F_{min}]$

where:

Qh_{max}, Qh_{avg}, Qh_{min} are defined in section 4.2.2 of this appendix.

F_{max}, F_{avg}, F_{min} are defined in Table 4.1.3 of this appendix.

4.2.8 *Total weighted per-cycle water consumption for Warm Wash/Cold Rinse.* Calculate the total weighted per-cycle water consumption for the Warm Wash/Cold Rinse cycle, Qw_T, expressed in gallons per cycle (or liters per cycle) and defined as:

$Qw_T = [Qw_{max} \times F_{max}] + [Qw_{avg} \times F_{avg}] + [Qw_{min} \times F_{min}]$

where:

Qw_{max}, Qw_{avg}, Qw_{min} are defined in section 4.2.3 of this appendix.

F_{max}, F_{avg}, F_{min} are defined in Table 4.1.3 of this appendix.

4.2.9 *Total weighted per-cycle water consumption for Warm Wash/Warm Rinse.* Calculate the total weighted per-cycle water consumption for the Warm Wash/Warm Rinse cycle, Qww_T, expressed in gallons per cycle (or liters per cycle) and defined as:

$Qww_T = [Qww_{max} \times F_{max}] + [Qww_{avg} \times F_{avg}] + [Qww_{min} \times F_{min}]$

where:

Qww_{max}, Qww_{avg}, Qww_{min} are defined in section 4.2.4 of this appendix.

F_{max}, F_{avg}, F_{min} are defined in Table 4.1.3 of this appendix.

4.2.10 *Total weighted per-cycle water consumption for Cold Wash/Cold Rinse.* Calculate the total weighted per-cycle water consumption for the Cold Wash/Cold Rinse cycle, Qc_T, expressed in gallons per cycle (or liters per cycle) and defined as:

$Qc_T = [Qc_{max} \times F_{max}] + [Qc_{avg} \times F_{avg}] + [Qc_{min} \times F_{min}]$

where:

Qc_{max}, Qc_{avg}, Qc_{min} are defined in section 4.2.5 of this appendix.

F_{max}, F_{avg}, F_{min} are defined in Table 4.1.3 of this appendix.

4.2.11 *Total weighted per-cycle water consumption for all wash cycles.* Calculate the total weighted per-cycle water consumption for all wash cycles, Q_T, expressed in gallons per cycle (or liters per cycle) and defined as:

$Q_T = [Qm_T \times TUF_m] + [Qh_T \times TUF_h] + [Qw_T \times TUF_w] + [Qww_T \times TUF_{ww}] + [Qc_T \times TUF_c]$

where:

Qm_T, Qh_T, Qw_T, Qww_T, and Qc_T are defined in sections 4.2.6 through 4.2.10 of this appendix.

TUF_m, TUF_h, TUF_w, TUF_{ww}, and TUF_c are defined in Table 4.1.1 of this appendix.

4.2.12 *Integrated water factor.* Calculate the integrated water factor, IWF, expressed in gallons per cycle per cubic foot (or liters per cycle per liter), as:

$IWF = Q_T/C$

where:

Q_T = As defined in section 4.2.11 of this appendix.

C = As defined in section 3.1.7 of this appendix.

4.3 *Per-cycle energy consumption for removal of moisture from test load*. Calculate the per-cycle energy required to remove the remaining moisture of the test load, D_E, expressed in kilowatt-hours per cycle and defined as:

$D_E = [(F_{max} \times \text{Maximum test load weight}) + (F_{avg} \times \text{Average test load weight}) + (F_{min} \times \text{Minimum test load weight})] \times (RMC_{corr} - 4\%) \times (DEF) \times (DUF)$

where:

F_{max}, F_{avg}, and F_{min} are defined in Table 4.1.3 of this appendix.

Maximum, average, and minimum test load weights are defined in Table 5.1 of this appendix.

RMC_{corr} = As defined in section 3.8.2.6, 3.8.3.5, or 3.8.4.1 of this Appendix.

DEF = Nominal energy required for a clothes dryer to remove moisture from clothes = 0.5 kWh/lb (1.1 kWh/kg).

DUF = Dryer usage factor, percentage of washer loads dried in a clothes dryer = 0.91.

4.4 *Per-cycle combined low-power mode energy consumption*. Calculate the per-cycle combined low-power mode energy consumption, E_{TLP}, expressed in kilowatt-hours per cycle and defined as:

$E_{TLP} = [(P_{default} \times S_{default}) + (P_{lowest} \times S_{lowest})] \times K_p/295$

where:

$P_{default}$ = Default inactive/off mode power, in watts, as measured in section 3.9.3 of this appendix.

P_{lowest} = Lowest-power inactive/off mode power, in watts, as measured in section 3.9.4 of this appendix for clothes washers with a switch, dial, or button that can be optionally selected by the end user to achieve a lower-power inactive/off mode than the default inactive/off mode; otherwise, P_{lowest}=0.

$S_{default}$= Annual hours in default inactive/off mode, defined as 8,465 if no optional lowest-power inactive/off mode is available; otherwise 4,232.5.

S_{lowest}= Annual hours in lowest-power inactive/off mode, defined as 0 if no optional lowest-power inactive/off mode is available; otherwise 4,232.5.

K_p = Conversion factor of watt-hours to kilowatt-hours = 0.001.

295 = Representative average number of clothes washer cycles in a year.

8,465 = Combined annual hours for inactive and off mode.

4,232.5 = One-half of the combined annual hours for inactive and off mode.

4.5 *Modified energy factor*. Calculate the modified energy factor, MEF_{J2}, expressed in cubic feet per kilowatt-hour per cycle (or liters per kilowatt-hour per cycle) and defined as:

$MEF_{J2} = C/(E_{TE} + D_E)$

where:

C = As defined in section 3.1.7 of this appendix.

E_{TE} = As defined in section 4.1.7 of this appendix.

D_E = As defined in section 4.3 of this appendix.

4.6 *Integrated modified energy factor*. Calculate the integrated modified energy factor, IMEF, expressed in cubic feet per kilowatt-hour per cycle (or liters per kilowatt-hour per cycle) and defined as:

$IMEF = C/(E_{TE} + D_E + E_{TLP})$

where:

C = As defined in section 3.1.7 of this appendix.

E_{TE} = As defined in section 4.1.7 of this appendix.

D_E = As defined in section 4.3 of this appendix.

E_{TLP} = As defined in section 4.4 of this appendix.

5. Test Loads

TABLE 5.1—TEST LOAD SIZES

Container volume		Minimum load		Maximum load		Average load	
cu. ft.	liter	lb	kg	lb	kg	lb	kg
≥ <	≥ <						
0.00–0.80	0.00–22.7	3.00	1.36	3.00	1.36	3.00	1.36
0.80–0.90	22.7–25.5	3.00	1.36	3.50	1.59	3.25	1.47
0.90–1.00	25.5–28.3	3.00	1.36	3.90	1.77	3.45	1.56
1.00–1.10	28.3–31.1	3.00	1.36	4.30	1.95	3.65	1.66
1.10–1.20	31.1–34.0	3.00	1.36	4.70	2.13	3.85	1.75
1.20–1.30	34.0–36.8	3.00	1.36	5.10	2.31	4.05	1.84
1.30–1.40	36.8–39.6	3.00	1.36	5.50	2.49	4.25	1.93
1.40–1.50	39.6–42.5	3.00	1.36	5.90	2.68	4.45	2.02
1.50–1.60	42.5–45.3	3.00	1.36	6.40	2.90	4.70	2.13
1.60–1.70	45.3–48.1	3.00	1.36	6.80	3.08	4.90	2.22

TABLE 5.1—TEST LOAD SIZES—Continued

Container volume		Minimum load		Maximum load		Average load	
cu. ft.	liter	lb	kg	lb	kg	lb	kg
≥ <	≥ <						
1.70–1.80	48.1–51.0	3.00	1.36	7.20	3.27	5.10	2.31
1.80–1.90	51.0–53.8	3.00	1.36	7.60	3.45	5.30	2.40
1.90–2.00	53.8–56.6	3.00	1.36	8.00	3.63	5.50	2.49
2.00–2.10	56.6–59.5	3.00	1.36	8.40	3.81	5.70	2.59
2.10–2.20	59.5–62.3	3.00	1.36	8.80	3.99	5.90	2.68
2.20–2.30	62.3–65.1	3.00	1.36	9.20	4.17	6.10	2.77
2.30–2.40	65.1–68.0	3.00	1.36	9.60	4.35	6.30	2.86
2.40–2.50	68.0–70.8	3.00	1.36	10.00	4.54	6.50	2.95
2.50–2.60	70.8–73.6	3.00	1.36	10.50	4.76	6.75	3.06
2.60–2.70	73.6–76.5	3.00	1.36	10.90	4.94	6.95	3.15
2.70–2.80	76.5–79.3	3.00	1.36	11.30	5.13	7.15	3.24
2.80–2.90	79.3–82.1	3.00	1.36	11.70	5.31	7.35	3.33
2.90–3.00	82.1–85.0	3.00	1.36	12.10	5.49	7.55	3.42
3.00–3.10	85.0–87.8	3.00	1.36	12.50	5.67	7.75	3.52
3.10–3.20	87.8–90.6	3.00	1.36	12.90	5.85	7.95	3.61
3.20–3.30	90.6–93.4	3.00	1.36	13.30	6.03	8.15	3.70
3.30–3.40	93.4–96.3	3.00	1.36	13.70	6.21	8.35	3.79
3.40–3.50	96.3–99.1	3.00	1.36	14.10	6.40	8.55	3.88
3.50–3.60	99.1–101.9	3.00	1.36	14.60	6.62	8.80	3.99
3.60–3.70	101.9–104.8	3.00	1.36	15.00	6.80	9.00	4.08
3.70–3.80	104.8–107.6	3.00	1.36	15.40	6.99	9.20	4.17
3.80–3.90	107.6–110.4	3.00	1.36	15.80	7.16	9.40	4.26
3.90–4.00	110.4–113.3	3.00	1.36	16.20	7.34	9.60	4.35
4.00–4.10	113.3–116.1	3.00	1.36	16.60	7.53	9.80	4.45
4.10–4.20	116.1–118.9	3.00	1.36	17.00	7.72	10.00	4.54
4.20–4.30	118.9–121.8	3.00	1.36	17.40	7.90	10.20	4.63
4.30–4.40	121.8–124.6	3.00	1.36	17.80	8.09	10.40	4.72
4.40–4.50	124.6–127.4	3.00	1.36	18.20	8.27	10.60	4.82
4.50–4.60	127.4–130.3	3.00	1.36	18.70	8.46	10.85	4.91
4.60–4.70	130.3–133.1	3.00	1.36	19.10	8.65	11.05	5.00
4.70–4.80	133.1–135.9	3.00	1.36	19.50	8.83	11.25	5.10
4.80–4.90	135.9–138.8	3.00	1.36	19.90	9.02	11.45	5.19
4.90–5.00	138.8–141.6	3.00	1.36	20.30	9.20	11.65	5.28
5.00–5.10	141.6–144.4	3.00	1.36	20.70	9.39	11.85	5.38
5.10–5.20	144.4–147.2	3.00	1.36	21.10	9.58	12.05	5.47
5.20–5.30	147.2–150.1	3.00	1.36	21.50	9.76	12.25	5.56
5.30–5.40	150.1–152.9	3.00	1.36	21.90	9.95	12.45	5.65
5.40–5.50	152.9–155.7	3.00	1.36	22.30	10.13	12.65	5.75
5.50–5.60	155.7–158.6	3.00	1.36	22.80	10.32	12.90	5.84
5.60–5.70	158.6–161.4	3.00	1.36	23.20	10.51	13.10	5.93
5.70–5.80	161.4–164.2	3.00	1.36	23.60	10.69	13.30	6.03
5.80–5.90	164.2–167.1	3.00	1.36	24.00	10.88	13.50	6.12
5.90–6.00	167.1–169.9	3.00	1.36	24.40	11.06	13.70	6.21
6.00–6.10	169.9–172.7	3.00	1.36	24.80	11.25	13.90	6.30
6.10–6.20	172.7–175.6	3.00	1.36	25.20	11.43	14.10	6.40
6.20–6.30	175.6–178.4	3.00	1.36	25.60	11.61	14.30	6.49
6.30–6.40	178.4–181.2	3.00	1.36	26.00	11.79	14.50	6.58
6.40–6.50	181.2–184.1	3.00	1.36	26.40	11.97	14.70	6.67
6.50–6.60	184.1–186.9	3.00	1.36	26.90	12.20	14.95	6.78
6.60–6.70	186.9–189.7	3.00	1.36	27.30	12.38	15.15	6.87
6.70–6.80	189.7–192.6	3.00	1.36	27.70	12.56	15.35	6.96
6.80–6.90	192.6–195.4	3.00	1.36	28.10	12.75	15.55	7.05
6.90–7.00	195.4–198.2	3.00	1.36	28.50	12.93	15.75	7.14
7.00–7.10	198.2–201.0	3.00	1.36	28.90	13.11	15.95	7.23
7.10–7.20	201.0–203.9	3.00	1.36	29.30	13.29	16.15	7.33
7.20–7.30	203.9–206.7	3.00	1.36	29.70	13.47	16.35	7.42
7.30–7.40	206.7–209.5	3.00	1.36	30.10	13.65	16.55	7.51
7.40–7.50	209.5–212.4	3.00	1.36	30.50	13.83	16.75	7.60
7.50–7.60	212.4–215.2	3.00	1.36	31.00	14.06	17.00	7.71
7.60–7.70	215.2–218.0	3.00	1.36	31.40	14.24	17.20	7.80
7.70–7.80	218.0–220.9	3.00	1.36	31.80	14.42	17.40	7.89
7.80–7.90	220.9–223.7	3.00	1.36	32.20	14.61	17.60	7.98
7.90–8.00	223.7–226.5	3.00	1.36	32.60	14.79	17.80	8.07

(1) All test load weights are bone-dry weights.
(2) Allowable tolerance on the test load weights is ±0.10 lbs (0.05 kg).

[80 FR 46767, Aug. 5, 2015; 80 FR 50757, Aug. 21, 2015, as amended at 80 FR 62443, Oct. 16, 2015; 87 FR 33395, June 1, 2022; 87 FR 78820, Dec. 23, 2022; 89 FR 84076, Oct. 21, 2024]

APPENDIX J3 TO SUBPART B OF PART 430—ENERGY TEST CLOTH SPECIFICATIONS AND PROCEDURES FOR DETERMINING CORRECTION COEFFICIENTS OF NEW ENERGY TEST CLOTH LOTS

NOTE: DOE maintains an historical record of the standard extractor test data and final correction curve coefficients for each approved lot of energy test cloth. These can be accessed through DOE's web page for standards and test procedures for residential clothes washers at DOE's Building Technologies Office Appliance and Equipment Standards website.

1. Objective

This appendix includes the following: (1) Specifications for the energy test cloth to be used for testing clothes washers; (2) procedures for verifying that new lots of energy test cloth meet the defined material specifications; and (3) procedures for developing a set of correction coefficients that correlate the measured remaining moisture content (RMC) values of each new test cloth lot with a set of standard RMC values established as an historical reference point. These correction coefficients are applied to the RMC measurements performed during testing according to appendix J or appendix J2 to this subpart, ensuring that the final corrected RMC measurement for a clothes washer remains independent of the test cloth lot used for testing.

2. Definitions

AHAM means the Association of Home Appliance Manufacturers.

Bone-dry means a condition of a load of test cloth that has been dried in a dryer at maximum temperature for a minimum of 10 minutes, removed and weighed before cool down, and then dried again for 10 minute periods until the final weight change of the load is 1 percent or less.

Lot means a quantity of cloth that has been manufactured with the same batches of cotton and polyester during one continuous process.

Roll means a subset of a lot.

3. Energy Test Cloth Specifications

The energy test cloths and energy stuffer cloths must meet the following specifications:

3.1 The test cloth material should come from a roll of material with a width of approximately 63 inches and approximately 500 yards per roll. However, other sizes may be used if the test cloth material meets the specifications listed in sections 3.2 through 3.6 of this appendix.

3.2 *Nominal fabric type.* Pure finished bleached cloth made with a momie or grain weave, which is nominally 50 percent cotton and 50 percent polyester.

3.3 *Fabric weight.* 5.60 ± 0.25 ounces per square yard (190.0 ± 8.4 g/m2).

3.4 *Thread count.* 65 x 57 per inch (warp × fill), ±2 percent.

3.5 *Fiber content of warp and filling yarn.* 50 percent ±4 percent cotton, with the balance being polyester, open end spun, 15/1 ±5 percent cotton count blended yarn.

3.6 Water repellent finishes, such as fluoropolymer stain resistant finishes, must not be applied to the test cloth.

3.7. *Test cloth dimensions.*

3.7.1 *Energy test cloth.* The energy test cloth must be made from energy test cloth material, as specified in section 3.1 of this appendix, that is 24 ± ½ inches by 36 ± ½ inches (61.0 ± 1.3 cm by 91.4 ± 1.3 cm) and has been hemmed to 22 ± ½ inches by 34 ± ½ inches (55.9 ± 1.3 cm by 86.4 ± 1.3 cm) before washing.

3.7.2 *Energy stuffer cloth.* The energy stuffer cloth must be made from energy test cloth material, as specified in section 3.1 of this appendix, that is 12 ± ¼ inches by 12 ± ¼ inches (30.5 ± 0.6 cm by 30.5 ± 0.6 cm) and has been hemmed to 10 ± ¼ inches by 10 ± ¼ inches (25.4 ± 0.6 cm by 25.4 ± 0.6 cm) before washing.

3.8 The test cloth must be clean and must not be used for more than 60 test runs (after pre-conditioning as specified in section 5 of this appendix). All test cloth must be permanently marked identifying the lot number of the material. Mixed lots of material must not be used for testing a clothes washer according to appendix J or appendix J2 to this subpart.

4. Equipment Specifications

4.1 *Extractor.* Use a North Star Engineered Products Inc. (formerly Bock) Model 215 extractor (having a basket diameter of 20 inches, height of 11.5 inches, and volume of 2.09 ft^3), with a variable speed drive (North Star Engineered Products, P.O. Box 5127, Toledo, OH 43611) or an equivalent extractor with same basket design (*i.e.,* diameter, height, volume, and hole configuration) and variable speed drive. Table 4.1 of this appendix shows the extractor spin speed, in revolutions per minute (RPM), that must be used to attain each required g-force level.

TABLE 4.1—EXTRACTOR SPIN SPEEDS FOR EACH TEST CONDITION

"g Force"	RPM
100	594 ± 1
200	840 ± 1
350	1,111 ± 1
500	1,328 ± 1
650	1,514 ± 1

4.2 *Bone-dryer*. The dryer used for drying the cloth to bone-dry must heat the test cloth and energy stuffer cloths above 210 °F (99 °C).

5. Test Cloth Pre-Conditioning Instructions

Use the following instructions for performing pre-conditioning of new energy test cloths and energy stuffer cloths as specified throughout section 7 and section 8 of this appendix, and before any clothes washer testing using appendix J or appendix J2 to this subpart: Perform five complete wash-rinse-spin cycles, the first two with current AHAM Standard detergent Formula 3 and the last three without detergent. Place the test cloth in a clothes washer set at the maximum water level. Wash the load for ten minutes in soft water (17 ppm hardness or less) using 27.0 grams + 4.0 grams per pound of cloth load of AHAM Standard detergent Formula 3. The wash temperature is to be controlled to 135 °F ± 5 °F (57.2 °C ± 2.8 °C) and the rinse temperature is to be controlled to 60 °F ± 5 °F (15.6 °C ± 2.8 °C). Dry the load to bone-dry between each of the five wash-rinse-spin cycles. The maximum shrinkage after pre-conditioning must not be more than 5 percent of the length and width. Measure per AATCC Test Method 135–2010 (incorporated by reference; see §430.3).

6. Extractor Run Instructions

Use the following instructions for performing each of the extractor runs specified throughout section 7 and section 8 of this appendix:

6.1 *Test load size*. Use a test load size of 8.4 lbs.

6.2 Measure the average RMC for each sample loads as follows:

6.2.1 Dry the test cloth until it is bone-dry according to the definition in section 2 of this appendix. Record the bone-dry weight of the test load (WI).

6.2.2 Prepare the test load for soak by grouping four test cloths into loose bundles. Create the bundles by hanging four cloths vertically from one corner and loosely wrapping the test cloth onto itself to form the bundle. Bundles should be wrapped loosely to ensure consistency of water extraction. Then place the bundles into the water to soak. Eight to nine bundles will be formed depending on the test load. The ninth bundle may not equal four cloths but can incorporate energy stuffer cloths to help offset the size difference.

6.2.3 Soak the test load for 20 minutes in 10 gallons of soft (<17 ppm) water. The entire test load must be submerged. Maintain a water temperature of 100 °F ± 5 °F (37.8 °C ± 2.8 °C) at all times between the start and end of the soak.

6.2.4 Remove the test load and allow each of the test cloth bundles to drain over the water bath for a maximum of 5 seconds.

6.2.5 Manually place the test cloth bundles in the basket of the extractor, distributing them evenly by eye. The draining and loading process must take no longer than 1 minute. Spin the load at a fixed speed corresponding to the intended centripetal acceleration level (measured in units of the acceleration of gravity, g) ± 1g for the intended time period ± 5 seconds. Begin the timer when the extractor meets the required spin speed for each test.

6.2.6 Record the weight of the test load immediately after the completion of the extractor spin cycle (WC).

6.2.7 Calculate the remaining moisture content of the test load as (WC–WI)/WI.

6.2.8 Draining the soak tub is not necessary if the water bath is corrected for water level and temperature before the next extraction.

6.2.9 Drying the test load in between extraction runs is not necessary. However, the bone-dry weight must be checked after every 12 extraction runs to make sure the bone-dry weight is within tolerance (8.4 ± 0.1 lbs). Following this, the test load must be soaked and extracted once before continuing with the remaining extraction runs. Perform this extraction at the same spin speed used for the extraction run prior to checking the bone-dry weight, for a time period of 4 minutes. Either warm or cold soak temperature may be used.

7. Test Cloth Material Verification Procedure

7.1 *Material Properties Verification*. The test cloth manufacturer must supply a certificate of conformance to ensure that the energy test cloth and stuffer cloth samples used for prequalification testing meet the specifications in section 3 of this appendix. The material properties of one energy test cloth from each of the first, middle, and last rolls must be evaluated as follows, prior to pre-conditioning:

7.1.1 *Dimensions*. Each hemmed energy test cloth must meet the size specifications in section 3.7.1 of this appendix. Each hemmed stuffer cloth must meet the size specifications in section 3.7.2 of this appendix.

7.1.2 *Oil repellency*. Perform AATCC Test Method 118–2007, Oil Repellency: Hydrocarbon Resistance Test, (incorporated by reference, see §430.3), to confirm the absence of Scotchguard™ or other water-repellent finish. An Oil Repellency Grade of 0 (Fails Kaydol) is required.

7.1.3 *Absorbency*. Perform AATCC Test Method 79–2010, Absorbency of Textiles, (incorporated by reference, see §430.3), to confirm the absence of Scotchguard™ or other water-repellent finish. The time to absorb one drop must be on the order of 1 second.

7.2 *Uniformity Verification*. The uniformity of each test cloth lot must be evaluated as follows.

7.2.1 *Pre-conditioning*. Pre-condition the energy test cloths and energy stuffer cloths used for uniformity verification, as specified in section 5 of this appendix.

7.2.2 *Distribution of samples*. Test loads must be comprised of cloth from three different rolls from the sample lot. Each roll from a lot must be marked in the run order that it was made. The three rolls are selected based on the run order such that the first, middle, and last rolls are used. As the rolls are cut into cloth, fabric must be selected from the beginning, middle, and end of the roll to create separate loads from each location, for a total of nine sample loads according to Table 7.2.2.

TABLE 7.2.2—DISTRIBUTION OF SAMPLE LOADS FOR PREQUALIFICATION TESTING

Roll No.	Roll location
First	Beginning.
	Middle.
	End.
Middle	Beginning.
	Middle.
	End.
Last	Beginning.
	Middle.
	End.

7.2.3 Measure the remaining moisture content of each of the nine sample test loads, as specified in section 6 of this appendix, using a centripetal acceleration of 350g (corresponding to 1111 ± 1 RPM) and a spin duration of 15 minutes ± 5 seconds.

7.2.4 Repeat section 7.2.3 of this appendix an additional two times and calculate the arithmetic average of the three RMC values to determine the average RMC value for each sample load. It is not necessary to dry the load to bone-dry the load before the second and third replications.

7.2.5 Calculate the coefficient of variation (CV) of the nine average RMC values from each sample load. The CV must be less than or equal to 1 percent for the test cloth lot to be considered acceptable and to perform the standard extractor RMC testing.

8. RMC Correction Curve Procedure

8.1 *Pre-conditioning*. Pre-condition the energy test cloths and energy stuffer cloths used for RMC correction curve measurements, as specified in section 5 of this appendix.

8.2 *Distribution of samples*. Test loads must be comprised of randomly selected cloth at the beginning, middle and end of a lot. Two test loads may be used, with each load used for half of the total number of required tests. Separate test loads must be used from the loads used for uniformity verification.

8.3 Measure the remaining moisture content of the test load, as specified in section 6 of this appendix at five g-force levels: 100 g, 200 g, 350 g, 500 g, and 650 g, using two different spin times at each g level: 4 minutes and 15 minutes. Table 4.1 of this appendix provides the corresponding spin speeds for each g-force level.

8.4 Repeat section 8.3 of this appendix using soft (<17 ppm) water at 60 °F ± 5 °F (15.6 °C ± 2.8 °C).

8.5 Repeat sections 8.3.3 and 8.3.4 of this appendix an additional two times, so that three replications at each extractor condition are performed. When this procedure is performed in its entirety, a total of 60 extractor RMC test runs are required.

8.6 Average the values of the 3 replications performed for each extractor condition specified in section 8.3 of this appendix.

8.7 Perform a linear least-squares fit to determine coefficients A and B such that the standard RMC values shown in Table 8.7 of this appendix ($RMC_{standard}$) are linearly related to the average RMC values calculated in section 8.6 of this appendix (RMC_{cloth}):

$$RMC_{standard} \sim A \times RMC_{cloth} + B$$

where A and B are coefficients of the linear least-squares fit.

TABLE 8.7—STANDARD RMC VALUES

"g Force"	RMC percentage			
	Warm soak		Cold soak	
	15 min. spin (percent)	4 min. spin (percent)	15 min. spin (percent)	4 min. spin (percent)
100	45.9	49.9	49.7	52.8
200	35.7	40.4	37.9	43.1
350	29.6	33.1	30.7	35.8
500	24.2	28.7	25.5	30.0
650	23.0	26.4	24.1	28.0

8.8 Perform an analysis of variance with replication test using two factors, spin speed and lot, to check the interaction of speed and lot. Use the values from section 8.6 of this appendix and Table 8.7 of this appendix in the calculation. The ''P'' value of the F-

statistic for interaction between spin speed and lot in the variance analysis must be greater than or equal to 0.1. If the ''P'' value is less than 0.1, the test cloth is unacceptable. ''P'' is a theoretically based measure of interaction based on an analysis of variance.

9. Application of the RMC Correction Curve

9.1 Using the coefficients A and B calculated in section 8.7 of this appendix:

$RMC_{corr} = A \times RMC + B$

9.2 Apply this RMC correction curve to measured RMC values in appendix J and appendix J2 to this subpart.

[87 FR 33403, June 1, 2022, as amended at 87 FR 78820, Dec. 23, 2022]

APPENDIXES K–L TO SUBPART B OF PART 430 [RESERVED]

APPENDIX M TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CENTRAL AIR CONDITIONERS AND HEAT PUMPS

NOTE: Prior to January 1, 2023, if using the appendix M test procedure for representations, including compliance certifications, with respect to the energy use, power, or efficiency of central air conditioners and central air conditioning heat pumps, any such representations must be based on the results of testing pursuant to either this appendix or the procedures in appendix M as it appeared at 10 CFR part 430, subpart B, in the 10 CFR parts 200 to 499 edition revised as of January 1, 2022. Any representations made with respect to the energy use or efficiency of such central air conditioners and central air conditioning heat pumps must be in accordance with whichever version is selected. Any representations, including compliance certifications, made with respect to the energy use, power, or efficiency of central air conditioners and central air conditioning heat pumps made on or after January 1, 2023, must be based on the results of testing pursuant the procedures in appendix M1 to this subpart.

On or after July 5, 2017 and prior to January 1, 2023, any representations, including compliance certifications, made with respect to the energy use, power, or efficiency of central air conditioners and central air conditioning heat pumps must be based on the results of testing pursuant to this appendix.

On or after January 1, 2023, any representations, including compliance certifications, made with respect to the energy use, power, or efficiency of central air conditioners and central air conditioning heat pumps must be based on the results of testing pursuant to appendix M1 of this subpart.

1. SCOPE AND DEFINITIONS

1.1 Scope

This test procedure provides a method of determining SEER, EER, HSPF and $P_{W,OFF}$ for central air conditioners and central air conditioning heat pumps including the following categories:

(a) Split-system air conditioners, including single-split, multi-head mini-split, multi-split (including VRF), and multi-circuit systems
(b) Split-system heat pumps, including single-split, multi-head mini-split, multi-split (including VRF), and multi-circuit systems
(c) Single-package air conditioners
(d) Single-package heat pumps
(e) Small-duct, high-velocity systems (including VRF)
(f) Space-constrained products—air conditioners
(g) Space-constrained products—heat pumps

For purposes of this appendix, the Department of Energy incorporates by reference specific sections of several industry standards, as listed in §430.3. In cases where there is a conflict, the language of the test procedure in this appendix takes precedence over the incorporated standards.

All section references refer to sections within this appendix unless otherwise stated.

1.2 Definitions

Airflow-control settings are programmed or wired control system configurations that control a fan to achieve discrete, differing ranges of airflow—often designated for performing a specific function (*e.g.*, cooling, heating, or constant circulation)—without manual adjustment other than interaction with a user-operable control (*i.e.*, a thermostat) that meets the manufacturer specifications for installed-use. For the purposes of this appendix, manufacturer specifications for installed-use are those found in the product literature shipped with the unit.

Air sampling device is an assembly consisting of a manifold with several branch tubes with multiple sampling holes that draws an air sample from a critical location from the unit under test (*e.g.* indoor air inlet, indoor air outlet, outdoor air inlet, etc.).

Airflow prevention device denotes a device that prevents airflow via natural convection by mechanical means, such as an air damper box, or by means of changes in duct height, such as an upturned duct.

Aspirating psychrometer is a piece of equipment with a monitored airflow section that draws uniform airflow through the measurement section and has probes for measurement of air temperature and humidity.

Blower coil indoor unit means an indoor unit either with an indoor blower housed with the coil or with a separate designated

air mover such as a furnace or a modular blower (as defined in appendix AA to the subpart).

Blower coil system refers to a split system that includes one or more blower coil indoor units.

Cased coil means a coil-only indoor unit with external cabinetry.

Coefficient of Performance (COP) means the ratio of the average rate of space heating delivered to the average rate of electrical energy consumed by the heat pump. These rate quantities must be determined from a single test or, if derived via interpolation, must be determined at a single set of operating conditions. COP is a dimensionless quantity. When determined for a ducted coil-only system, COP must include the sections 3.7 and 3.9.1 of this appendix: Default values for the heat output and power input of a fan motor.

Coil-only indoor unit means an indoor unit that is distributed in commerce without an indoor blower or separate designated air mover. A coil-only indoor unit installed in the field relies on a separately-installed furnace or a modular blower for indoor air movement. *Coil-only system* refers to a system that includes only (one or more) coil-only indoor units.

Condensing unit removes the heat absorbed by the refrigerant to transfer it to the outside environment and consists of an outdoor coil, compressor(s), and air moving device.

Constant-air-volume-rate indoor blower means a fan that varies its operating speed to provide a fixed air-volume-rate from a ducted system.

Continuously recorded, when referring to a dry bulb measurement, dry bulb temperature used for test room control, wet bulb temperature, dew point temperature, or relative humidity measurements, means that the specified value must be sampled at regular intervals that are equal to or less than 15 seconds.

Cooling load factor (CLF) means the ratio having as its numerator the total cooling delivered during a cyclic operating interval consisting of one ON period and one OFF period, and as its denominator the total cooling that would be delivered, given the same ambient conditions, had the unit operated continuously at its steady-state, space-cooling capacity for the same total time (ON + OFF) interval.

Crankcase heater means any electrically powered device or mechanism for intentionally generating heat within and/or around the compressor sump volume. Crankcase heater control may be achieved using a timer or may be based on a change in temperature or some other measurable parameter, such that the crankcase heater is not required to operate continuously. A crankcase heater without controls operates continuously when the compressor is not operating.

Cyclic Test means a test where the unit's compressor is cycled on and off for specific time intervals. A cyclic test provides half the information needed to calculate a degradation coefficient.

Damper box means a short section of duct having an air damper that meets the performance requirements of section 2.5.7 of this appendix.

Degradation coefficient (C_D) means a parameter used in calculating the part load factor. The degradation coefficient for cooling is denoted by C_D^c. The degradation coefficient for heating is denoted by C_D^h.

Demand-defrost control system means a system that defrosts the heat pump outdoor coil-only when measuring a predetermined degradation of performance. The heat pump's controls either:

(1) Monitor one or more parameters that always vary with the amount of frost accumulated on the outdoor coil (*e.g.*, coil to air differential temperature, coil differential air pressure, outdoor fan power or current, optical sensors) at least once for every ten minutes of compressor ON-time when space heating or

(2) operate as a feedback system that measures the length of the defrost period and adjusts defrost frequency accordingly. In all cases, when the frost parameter(s) reaches a predetermined value, the system initiates a defrost. In a demand-defrost control system, defrosts are terminated based on monitoring a parameter(s) that indicates that frost has been eliminated from the coil. (NOTE: Systems that vary defrost intervals according to outdoor dry-bulb temperature are not demand-defrost systems.) A demand-defrost control system, which otherwise meets the above requirements, may allow time-initiated defrosts if, and only if, such defrosts occur after 6 hours of compressor operating time.

Design heating requirement (DHR) predicts the space heating load of a residence when subjected to outdoor design conditions. Estimates for the minimum and maximum DHR are provided for six generalized U.S. climatic regions in section 4.2 of this appendix.

Dry-coil tests are cooling mode tests where the wet-bulb temperature of the air supplied to the indoor unit is maintained low enough that no condensate forms on the evaporator coil.

Ducted system means an air conditioner or heat pump that is designed to be permanently installed equipment and delivers conditioned air to the indoor space through a duct(s). The air conditioner or heat pump may be either a split-system or a single-package unit.

Energy efficiency ratio (EER) means the ratio of the average rate of space cooling delivered to the average rate of electrical energy consumed by the air conditioner or heat pump. Determine these rate quantities from

a single test or, if derived via interpolation, determine at a single set of operating conditions. EER is expressed in units of

$$\frac{Btu/h}{W}.$$

When determined for a ducted coil-only system, EER must include, from this appendix, the section 3.3 and 3.5.1 default values for the heat output and power input of a fan motor.

Evaporator coil means an assembly that absorbs heat from an enclosed space and transfers the heat to a refrigerant.

Heat pump means a kind of central air conditioner that utilizes an indoor conditioning coil, compressor, and refrigerant-to-outdoor air heat exchanger to provide air heating, and may also provide air cooling, air dehumidifying, air humidifying, air circulating, and air cleaning.

Heat pump having a heat comfort controller means a heat pump with controls that can regulate the operation of the electric resistance elements to assure that the air temperature leaving the indoor section does not fall below a specified temperature. Heat pumps that actively regulate the rate of electric resistance heating when operating below the balance point (as the result of a second stage call from the thermostat) but do not operate to maintain a minimum delivery temperature are not considered as having a heat comfort controller.

Heating load factor (HLF) means the ratio having as its numerator the total heating delivered during a cyclic operating interval consisting of one ON period and one OFF period, and its denominator the heating capacity measured at the same test conditions used for the cyclic test, multiplied by the total time interval (ON plus OFF) of the cyclic-test.

Heating season means the months of the year that require heating, *e.g.*, typically, and roughly, October through April.

Heating seasonal performance factor (HSPF) means the total space heating required during the heating season, expressed in Btu, divided by the total electrical energy consumed by the heat pump system during the same season, expressed in watt-hours. The HSPF used to evaluate compliance with 10 CFR 430.32(c) is based on Region IV and the sampling plan stated in 10 CFR 429.16(a). HSPF is determined in accordance with appendix M.

Independent coil manufacturer (ICM) means a manufacturer that manufactures indoor units but does not manufacture single-package units or outdoor units.

Indoor unit means a separate assembly of a split system that includes—

(1) An arrangement of refrigerant-to-air heat transfer coil(s) for transfer of heat between the refrigerant and the indoor air,

(2) A condensate drain pan, and may or may not include

(3) Sheet metal or plastic parts not part of external cabinetry to direct/route airflow over the coil(s),

(4) A cooling mode expansion device,

(5) External cabinetry, and

(6) An integrated indoor blower (*i.e.* a device to move air including its associated motor). A separate designated air mover that may be a furnace or a modular blower (as defined in appendix AA to the subpart) may be considered to be part of the indoor unit. A service coil is not an indoor unit.

Multi-head mini-split system means a split system that has one outdoor unit and that has two or more indoor units connected with a single refrigeration circuit. The indoor units operate in unison in response to a single indoor thermostat.

Multiple-circuit (or multi-circuit) system means a split system that has one outdoor unit and that has two or more indoor units installed on two or more refrigeration circuits such that each refrigeration circuit serves a compressor and one and only one indoor unit, and refrigerant is not shared from circuit to circuit.

Multiple-split (or multi-split) system means a split system that has one outdoor unit and two or more coil-only indoor units and/or blower coil indoor units connected with a single refrigerant circuit. The indoor units operate independently and can condition multiple zones in response to at least two indoor thermostats or temperature sensors. The outdoor unit operates in response to independent operation of the indoor units based on control input of multiple indoor thermostats or temperature sensors, and/or based on refrigeration circuit sensor input (*e.g.*, suction pressure).

Nominal capacity means the capacity that is claimed by the manufacturer on the product name plate. *Nominal cooling capacity* is approximate to the air conditioner cooling capacity tested at A or A_2 condition. *Nominal heating capacity* is approximate to the heat pump heating capacity tested in $H1_N$ test.

Non-ducted indoor unit means an indoor unit that is designed to be permanently installed, mounted on room walls and/or ceilings, and that directly heats or cools air within the conditioned space.

Normalized Gross Indoor Fin Surface (NGIFS) means the gross fin surface area of the indoor unit coil divided by the cooling capacity measured for the A or A2 Test, whichever applies.

Off-mode power consumption means the power consumption when the unit is connected to its main power source but is neither providing cooling nor heating to the building it serves.

Off-mode season means, for central air conditioners other than heat pumps, the shoulder season and the entire heating season; and for heat pumps, the shoulder season only.

Outdoor unit means a separate assembly of a split system that transfers heat between the refrigerant and the outdoor air, and consists of an outdoor coil, compressor(s), an air moving device, and in addition for heat pumps, may include a heating mode expansion device, reversing valve, and/or defrost controls.

Outdoor unit manufacturer (OUM) means a manufacturer of single-package units, outdoor units, and/or both indoor units and outdoor units.

Part-load factor (PLF) means the ratio of the cyclic EER (or COP for heating) to the steady-state EER (or COP), where both EERs (or COPs) are determined based on operation at the same ambient conditions.

Seasonal energy efficiency ratio (SEER) means the total heat removed from the conditioned space during the annual cooling season, expressed in Btu's, divided by the total electrical energy consumed by the central air conditioner or heat pump during the same season, expressed in watt-hours. SEER is determined in accordance with appendix M.

Service coil means an arrangement of refrigerant-to-air heat transfer coil(s), condensate drain pan, sheet metal or plastic parts to direct/route airflow over the coil(s), which may or may not include external cabinetry and/or a cooling mode expansion device, distributed in commerce solely for replacing an uncased coil or cased coil that has already been placed into service, and that has been labeled ''for indoor coil replacement only'' on the nameplate and in manufacturer technical and product literature. The model number for any service coil must include some mechanism (*e.g.*, an additional letter or number) for differentiating a service coil from a coil intended for an indoor unit.

Shoulder season means the months of the year in between those months that require cooling and those months that require heating, *e.g.*, typically, and roughly, April through May, and September through October.

Single-package unit means any central air conditioner or heat pump that has all major assemblies enclosed in one cabinet.

Single-split system means a split system that has one outdoor unit and one indoor unit connected with a single refrigeration circuit. *Small-duct, high-velocity system* means a split system for which all indoor units are blower coil indoor units that produce at least 1.2 inches (of water column) of external static pressure when operated at the full-load air volume rate certified by the manufacturer of at least 220 scfm per rated ton of cooling.

Split system means any air conditioner or heat pump that has at least two separate assemblies that are connected with refrigerant piping when installed. One of these assemblies includes an indoor coil that exchanges heat with the indoor air to provide heating or cooling, while one of the others includes an outdoor coil that exchanges heat with the outdoor air. Split systems may be either blower coil systems or coil-only systems.

Standard Air means dry air having a mass density of 0.075 lb/ft^3.

Steady-state test means a test where the test conditions are regulated to remain as constant as possible while the unit operates continuously in the same mode.

Temperature bin means the 5 °F increments that are used to partition the outdoor dry-bulb temperature ranges of the cooling (≥65 °F) and heating (<65 °F) seasons.

Test condition tolerance means the maximum permissible difference between the average value of the measured test parameter and the specified test condition.

Test operating tolerance means the maximum permissible range that a measurement may vary over the specified test interval. The difference between the maximum and minimum sampled values must be less than or equal to the specified test operating tolerance.

Tested combination means a multi-head mini-split, multi-split, or multi-circuit system having the following features:

(1) The system consists of one outdoor unit with one or more compressors matched with between two and five indoor units;

(2) The indoor units must:

(i) Collectively, have a nominal cooling capacity greater than or equal to 95 percent and less than or equal to 105 percent of the nominal cooling capacity of the outdoor unit;

(ii) Each represent the highest sales volume model family, if this is possible while meeting all the requirements of this section. If this is not possible, one or more of the indoor units may represent another indoor model family in order that all the other requirements of this section are met.

(iii) Individually not have a nominal cooling capacity greater than 50 percent of the nominal cooling capacity of the outdoor

unit, unless the nominal cooling capacity of the outdoor unit is 24,000 Btu/h or less;

(iv) Operate at fan speeds consistent with manufacturer's specifications; and

(v) All be subject to the same minimum external static pressure requirement while able to produce the same external static pressure at the exit of each outlet plenum when connected in a manifold configuration as required by the test procedure.

(3) Where referenced, ''nominal cooling capacity'' means, for indoor units, the highest cooling capacity listed in published product literature for 95 °F outdoor dry bulb temperature and 80 °F dry bulb, 67 °F wet bulb indoor conditions, and for outdoor units, the lowest cooling capacity listed in published product literature for these conditions. If incomplete or no operating conditions are published, the highest (for indoor units) or lowest (for outdoor units) such cooling capacity available for sale must be used.

Time-adaptive defrost control system is a demand-defrost control system that measures the length of the prior defrost period(s) and uses that information to automatically determine when to initiate the next defrost cycle.

Time-temperature defrost control systems initiate or evaluate initiating a defrost cycle only when a predetermined cumulative compressor ON-time is obtained. This predetermined ON-time is generally a fixed value (*e.g.*, 30, 45, 90 minutes) although it may vary based on the measured outdoor dry-bulb temperature. The ON-time counter accumulates if controller measurements (*e.g.*, outdoor temperature, evaporator temperature) indicate that frost formation conditions are present, and it is reset/remains at zero at all other times. In one application of the control scheme, a defrost is initiated whenever the counter time equals the predetermined ON-time. The counter is reset when the defrost cycle is completed.

In a second application of the control scheme, one or more parameters are measured (*e.g.*, air and/or refrigerant temperatures) at the predetermined, cumulative, compressor ON-time. A defrost is initiated only if the measured parameter(s) falls within a predetermined range. The ON-time counter is reset regardless of whether or not a defrost is initiated. If systems of this second type use cumulative ON-time intervals of 10 minutes or less, then the heat pump may qualify as having a demand defrost control system (see definition).

Triple-capacity, northern heat pump means a heat pump that provides two stages of cooling and three stages of heating. The two common stages for both the cooling and heating modes are the low capacity stage and the high capacity stage. The additional heating mode stage is the booster capacity stage, which offers the highest heating capacity output for a given set of ambient operating conditions.

Triple-split system means a split system that is composed of three separate assemblies: An outdoor fan coil section, a blower coil indoor unit, and an indoor compressor section.

Two-capacity (or two-stage) compressor system means a central air conditioner or heat pump that has a compressor or a group of compressors operating with only two stages of capacity. For such systems, low capacity means the compressor(s) operating at low stage, or at low load test conditions. The low compressor stage that operates for heating mode tests may be the same or different from the low compressor stage that operates for cooling mode tests. For such systems, high capacity means the compressor(s) operating at high stage, or at full load test conditions.

Two-capacity, northern heat pump means a heat pump that has a factory or field-selectable lock-out feature to prevent space cooling at high-capacity. Two-capacity heat pumps having this feature will typically have two sets of ratings, one with the feature disabled and one with the feature enabled. The heat pump is a two-capacity northern heat pump only when this feature is enabled at all times. The certified indoor coil model number must reflect whether the ratings pertain to the lockout enabled option via the inclusion of an extra identifier, such as ''+LO''. When testing as a two-capacity, northern heat pump, the lockout feature must remain enabled for all tests.

Uncased coil means a coil-only indoor unit without external cabinetry.

Variable refrigerant flow (VRF) system means a multi-split system with at least three compressor capacity stages, distributing refrigerant through a piping network to multiple indoor blower coil units each capable of individual zone temperature control, through proprietary zone temperature control devices and a common communications network. NOTE: Single-phase VRF systems less than 65,000 Btu/h are central air conditioners and central air conditioning heat pumps.

Variable-speed compressor system means a central air conditioner or heat pump that has a compressor that uses a variable-speed drive to vary the compressor speed to achieve variable capacities.

Wet-coil test means a test conducted at test conditions that typically cause water vapor to condense on the test unit evaporator coil.

2. TESTING OVERVIEW AND CONDITIONS

(A) Test VRF systems using AHRI 1230–2010 (incorporated by reference, see §430.3) and appendix M. Where AHRI 1230–2010 refers to the appendix C therein substitute the provisions of this appendix. In cases where there

is a conflict, the language of the test procedure in this appendix takes precedence over AHRI 1230–2010.

For definitions use section 1 of appendix M and section 3 of AHRI 1230–2010 (incorporated by reference, see §430.3). For rounding requirements, refer to §430.23(m). For determination of certified ratings, refer to §429.16 of this chapter.

For test room requirements, refer to section 2.1 of this appendix. For test unit installation requirements refer to sections 2.2.a, 2.2.b, 2.2.c, 2.2.1, 2.2.2, 2.2.3(a), 2.2.3(c), 2.2.4, 2.2.5, and 2.4 to 2.12 of this appendix, and sections 5.1.3 and 5.1.4 of AHRI 1230–2010. The ''manufacturer's published instructions,'' as stated in section 8.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) and ''manufacturer's installation instructions'' discussed in this appendix mean the manufacturer's installation instructions that come packaged with or appear in the labels applied to the unit. This does not include online manuals. Installation instructions that appear in the labels applied to the unit take precedence over installation instructions that are shipped with the unit.

For general requirements for the test procedure, refer to section 3.1 of this appendix, except for sections 3.1.3 and 3.1.4, which are requirements for indoor air volume and outdoor air volume. For indoor air volume and outdoor air volume requirements, refer instead to section 6.1.5 (except where section 6.1.5 refers to Table 8, refer instead to Table 4 of this appendix) and 6.1.6 of AHRI 1230–2010.

For the test method, refer to sections 3.3 to 3.5 and 3.7 to 3.13 of this appendix. For cooling mode and heating mode test conditions, refer to section 6.2 of AHRI 1230–2010. For calculations of seasonal performance descriptors, refer to section 4 of this appendix.

(B) For systems other than VRF, only a subset of the sections listed in this test procedure apply when testing and determining represented values for a particular unit. Table 1 shows the sections of the test procedure that apply to each system. This table is meant to assist manufacturers in finding the appropriate sections of the test procedure; the appendix sections rather than the table provide the specific requirements for testing, and given the varied nature of available units, manufacturers are responsible for determining which sections apply to each unit tested based on the unit's characteristics. To use this table, first refer to the sections listed under ''all units''. Then refer to additional requirements based on:

(1) System configuration(s),

(2) The compressor staging or modulation capability, and

(3) Any special features.

Testing requirements for space-constrained products do not differ from similar equipment that is not space-constrained and thus are not listed separately in this table. Air conditioners and heat pumps are not listed separately in this table, but heating procedures and calculations apply only to heat pumps.

Table 1 Informative Guidance for Using Appendix M

		Testing conditions	Testing procedures			Calculations		
		General	General	Cooling*	Heating**	General	Cooling*	Heating**
Requirements for all units (except VRF)		2.1; 2.2a-c; 2.2.1; 2.2.4; 2.2.4.1; 2.2.4.1 (1); 2.2.4.2; 2.2.5.1-5; 2.2.5.7-8; 2.3; 2.3.1; 2.3.2; 2.4; 2.4.1a,d; 2.5a-c; 2.5.1; 2.5.2 - 2.5.4.2; 2.5.5 – 2.13	3.1; 3.1.1-3; 3.1.5-9; 3.11; 3.12	3.3; 3.4; 3.5a-i	3.1.4.7; 3.1.10; 3.7a,b,d; 3.8a,d; 3.8.1; 3.9; 3.10	4.4; 4.5	4.1	4.2
Additional Requirements	System Configurations (more than one may apply)							
	Single-split system – blower coil	2.2a(1)		3.1.4.1.1; 3.1.4.1.1a,b; 3.1.4.2a-b; 3.1.4.3a-b	3.1.4.4.1; 3.1.4.4.2; 3.1.4.4.3a-b; 3.1.4.5.1; 3.1.4.5.2a-c; 3.1.4.6a-b			
	Single-split system - coil-only	2.2a(1); 2.2d,e; 2.4.2		3.1.4.1.1; 3.1.4.1.1c; 3.1.4.2c; 3.5.1	3.1.4.4.1; 3.1.4.4.2; 3.1.4.4.3c; 3.1.4.5.2d; 3.7c; 3.8b; 3.9f; 3.9.1b			
	Tri-split	2.2a(2)						
	Outdoor unit with no match	2.2c						
	Single-package	2.2.4.1(2); 2.2.5.6b; 2.4.2		3.1.4.1.1; 3.1.4.1.1a,b; 3.1.4.2a-b; 3.1.4.3a-b	3.1.4.4.1; 3.1.4.4.2; 3.1.4.4.3a-b; 3.1.4.5.1; 3.1.4.5.2a-c; 3.1.4.6a-b			
	Heat pump	2.2.5.6.a						
	Heating-only heat pump			3.1.4.1.1 Table 5	3.1.4.4.3			
	Two-capacity northern heat pump		3.1.4.4.2c; 3.1.4.5.2 c- d	3.2.3c	3.6.3			
	Triple-capacity northern heat pump			3.2.5	3.6.6			4.2.6

	SDHV (non-VRF)	2.2b; 2.4.1c; 2.5.4.3							
Special Features	Single- zone-multi-coil split and non-VRF multiple-split with duct	2.2a(1),(3); 2.2.3; 2.4.1b		3.1.4.1.1; 3.1.4.1.1a-b; 3.1.4.2a-b; 3.1.4.3a-b	3.1.4.4.1; 3.1.4.4.2; 3.1.4.4.3a-b; 3.1.4.5.1; 3.1.4.5.2a-e; 3.1.4.6a-b				
	Single-zone-multi-coil split and non-VRF multiple-split, ductless	2.2.a(1),(3); 2.2.3		3.1.4.1.2; 3.1.4.2d; 3.1.4.3c; 3.2.4c; 3.5c,g,h; 3.5.2; 3.8c	3.1.4.4.4; 3.1.4.5.2e; 3.1.4.6c; 3.6.4.e; 3.8c				
Modulation Capability	VRF multiple-split† and VRF SDHV†	2.1; 2.2.a; 2.2.b; 2.2.c; 2.2.1; 2.2.2; 2.2.3(a); 2.2.3(c)i; 2.2.4; 2.2.5; 2.4-2.12	3.1 (except 3.1.3, 3.1.4) 3.1.4.1.1c; 3.11-3.13	3.3-3.5	3.7–3.10	4.4; 4.5	4.1	4.2	
	Single speed compressor, fixed air volume rate			3.2.1	3.6.1		4.1.1	4.2.1	
	Single speed compressor, VAV fan			3.2.2	3.6.2		4.1.2	4.2.2	
	Two-capacity compressor		3.1.10	3.2.3	3.6.3		4.1.3	4.2.3	
	Variable speed compressor			3.2.4	3.6.4		4.1.4	4.2.4	
Special Features	Heat pump with heat comfort controller				3.6.5			4.2.5	
	Units with a multi-speed outdoor fan	2.2.2							
	Single indoor unit having multiple indoor blowers			3.2.6	3.6.2; 3.6.7		4.1.5	4.2.7	

*Does not apply to heating-only heat pumps.

**Applies only to heat pumps; not to air conditioners.

†Use AHRI 1230-2010 (incorporated by reference, see § 430.3), with the sections referenced in section 2(A) of this appendix, in conjunction with the sections set forth in the table to perform test setup, testing, and calculations for determining represented values for VRF multiple-split and VRF SDHV systems.

NOTE: For all units, use section 3.13 of this appendix for off mode testing procedures and section 4.3 of this appendix for off mode calculations. For all units subject to an EER standard, use section 4.6 of this appendix to determine the energy efficiency ratio.

2.1 Test Room Requirements

a. Test using two side-by-side rooms: An indoor test room and an outdoor test room. For multiple-split, single-zone-multi-coil or multi-circuit air conditioners and heat pumps, however, use as many indoor test rooms as needed to accommodate the total number of indoor units. These rooms must

comply with the requirements specified in sections 8.1.2 and 8.1.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3).

b. Inside these test rooms, use artificial loads during cyclic tests and frost accumulation tests, if needed, to produce stabilized room air temperatures. For one room, select an electric resistance heater(s) having a heating capacity that is approximately equal to the heating capacity of the test unit's condenser. For the second room, select a heater(s) having a capacity that is close to the sensible cooling capacity of the test unit's evaporator. Cycle the heater located in the same room as the test unit evaporator coil ON and OFF when the test unit cycles ON and OFF. Cycle the heater located in the same room as the test unit condensing coil ON and OFF when the test unit cycles OFF and ON.

2.2 Test Unit Installation Requirements

a. Install the unit according to section 8.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3), subject to the following additional requirements:

(1) When testing split systems, follow the requirements given in section 6.1.3.5 of AHRI 210/240–2008 (incorporated by reference, see §430.3). For the vapor refrigerant line(s), use the insulation included with the unit; if no insulation is provided, use insulation meeting the specifications for the insulation in the installation instructions included with the unit by the manufacturer; if no insulation is included with the unit and the installation instructions do not contain provisions for insulating the line(s), fully insulate the vapor refrigerant line(s) with vapor proof insulation having an inside diameter that matches the refrigerant tubing and a nominal thickness of at least 0.5 inches. For the liquid refrigerant line(s), use the insulation included with the unit; if no insulation is provided, use insulation meeting the specifications for the insulation in the installation instructions included with the unit by the manufacturer; if no insulation is included with the unit and the installation instructions do not contain provisions for insulating the line(s), leave the liquid refrigerant line(s) exposed to the air for air conditioners and heat pumps that heat and cool; or, for heating-only heat pumps, insulate the liquid refrigerant line(s) with insulation having an inside diameter that matches the refrigerant tubing and a nominal thickness of at least 0.5 inches. However, these requirements do not take priority over instructions for application of insulation for the purpose of improving refrigerant temperature measurement accuracy as required by sections 2.10.2 and 2.10.3 of this appendix. Insulation must be the same for the cooling and heating tests.

(2) When testing split systems, if the indoor unit does not ship with a cooling mode expansion device, test the system using the device as specified in the installation instructions provided with the indoor unit. If none is specified, test the system using a fixed orifice or piston type expansion device that is sized appropriately for the system.

(3) When testing triple-split systems (see section 1.2 of this appendix, Definitions), use the tubing length specified in section 6.1.3.5 of AHRI 210/240–2008 (incorporated by reference, see §430.3) to connect the outdoor coil, indoor compressor section, and indoor coil while still meeting the requirement of exposing 10 feet of the tubing to outside conditions;

(4) When testing split systems having multiple indoor coils, connect each indoor blower coil unit to the outdoor unit using:

(a) 25 feet of tubing, or

(b) tubing furnished by the manufacturer, whichever is longer.

At least 10 feet of the system interconnection tubing shall be exposed to the outside conditions. If they are needed to make a secondary measurement of capacity or for verification of refrigerant charge, install refrigerant pressure measuring instruments as described in section 8.2.5 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). Section 2.10 of this appendix specifies which secondary methods require refrigerant pressure measurements and section 2.2.5.5 of this appendix discusses use of pressure measurements to verify charge. At a minimum, insulate the low-pressure line(s) of a split system with insulation having an inside diameter that matches the refrigerant tubing and a nominal thickness of 0.5 inch.

b. For units designed for both horizontal and vertical installation or for both up-flow and down-flow vertical installations, use the orientation for testing specified by the manufacturer in the certification report. Conduct testing with the following installed:

(1) The most restrictive filter(s);

(2) Supplementary heating coils; and

(3) Other equipment specified as part of the unit, including all hardware used by a heat comfort controller if so equipped (see section 1 of this appendix, Definitions). For small-duct, high-velocity systems, configure all balance dampers or restrictor devices on or inside the unit to fully open or lowest restriction.

c. Testing a ducted unit without having an indoor air filter installed is permissible as long as the minimum external static pressure requirement is adjusted as stated in Table 4, note 3 (see section 3.1.4 of this appendix). Except as noted in section 3.1.10 of this appendix, prevent the indoor air supplementary heating coils from operating during all tests. For uncased coils, create an enclosure using 1 inch fiberglass foil-faced ductboard having a nominal density of 6 pounds per cubic foot. Or alternatively, construct an enclosure using sheet metal or a

similar material and insulating material having a thermal resistance (''R'' value) between 4 and 6 hr·ft^{2,} °F/Btu. Size the enclosure and seal between the coil and/or drainage pan and the interior of the enclosure as specified in installation instructions shipped with the unit. Also seal between the plenum and inlet and outlet ducts.

d. When testing a coil-only system, install a toroidal-type transformer to power the system's low-voltage components, complying with any additional requirements for the transformer mentioned in the installation manuals included with the unit by the system manufacturer. If the installation manuals do not provide specifications for the transformer, use a transformer having the following features:

(1) A nominal volt-amp rating such that the transformer is loaded between 25 and 90 percent of this rating for the highest level of power measured during the off mode test (section 3.13 of this appendix);

(2) Designed to operate with a primary input of 230 V, single phase, 60 Hz; and

(3) That provides an output voltage that is within the specified range for each low-voltage component. Include the power consumption of the components connected to the transformer as part of the total system power consumption during the off mode tests; do not include the power consumed by the transformer when no load is connected to it.

e. Test an outdoor unit with no match (*i.e.*, that is not distributed in commerce with any indoor units) using a coil-only indoor unit with a single cooling air volume rate whose coil has:

(1) Round tubes of outer diameter no less than 0.375 inches, and

(2) a normalized gross indoor fin surface (NGIFS) no greater than 1.0 square inches per British thermal unit per hour (sq. in./Btu/hr). NGIFS is calculated as follows:

$$NGIFS = 2 \times L_f \times W_f \times N_f \div \dot{Q}_c(95)$$

where:

L_f = Indoor coil fin length in inches, also height of the coil transverse to the tubes.

W_f = Indoor coil fin width in inches, also depth of the coil.

N_f = Number of fins.

$\dot{Q}_c(95)$ = the measured space cooling capacity of the tested outdoor unit/indoor unit combination as determined from the A2 or A Test whichever applies, Btu/h.

f. If the outdoor unit or the outdoor portion of a single-package unit has a drain pan heater to prevent freezing of defrost water, the heater shall be energized, subject to control to de-energize it when not needed by the heater's thermostat or the unit's control system, for all tests.

g. If pressure measurement devices are connected to a cooling/heating heat pump refrigerant circuit, the refrigerant charge M_t that could potentially transfer out of the connected pressure measurement systems (transducers, gauges, connections, and lines) between operating modes must be less than 2 percent of the factory refrigerant charge listed on the nameplate of the outdoor unit. If the outdoor unit nameplate has no listed refrigerant charge, or the heat pump is shipped without a refrigerant charge, use a factory refrigerant charge equal to 30 ounces per ton of certified cooling capacity. Use Equation 2.2–1 to calculate M_t for heat pumps that have a single expansion device located in the outdoor unit to serve each indoor unit, and use Equation 2.2–2 to calculate M_t for heat pumps that have two expansion devices per indoor unit.

Equation 2.2-1 $$M_t = \rho * (V_5 * f_5 + V_6 * f_6 + V_3 + V_4 - V_2)$$

Equation 2.2-2 $$M_t = \rho * (V_5 * f_5 + V_6 * f_6)$$

where:

V_i (i=2,3,4. . .) = the internal volume of the pressure measurement system (pressure lines, fittings, and gauge and/or transducer) at the location i (as indicated in Table 2), (cubic inches)

f_i (i=5,6) = 0 if the pressure measurement system is pitched upwards from the pressure tap location to the gauge or transducer, 1 if it is not.

ρ = the density associated with liquid refrigerant at 100 °F bubble point conditions (ounces per cubic inch)

TABLE 2—PRESSURE MEASUREMENT LOCATIONS

Location	
Compressor Discharge	1
Between Outdoor Coil and Outdoor Expansion Valve(s)	2
Liquid Service Valve	3
Indoor Coil Inlet	4
Indoor Coil Outlet	5
Common Suction Port (i.e. vapor service valve)	6
Compressor Suction	7

Calculate the internal volume of each pressure measurement system using internal volume reported for pressure transducers and gauges in product literature, if available. If such information is not available, use the value of 0.1 cubic inches internal volume for each pressure transducer, and 0.2 cubic inches for each pressure gauge.

In addition, for heat pumps that have a single expansion device located in the outdoor unit to serve each indoor unit, the internal volume of the pressure system at location 2 (as indicated in Table 2) must be no more than 1 cubic inch. Once the pressure measurement lines are set up, no change should be made until all tests are finished.

2.2.1 Defrost Control Settings

Set heat pump defrost controls at the normal settings which most typify those encountered in generalized climatic region IV. (Refer to Figure 1 and Table 20 of section 4.2 of this appendix for information on region IV.) For heat pumps that use a time-adaptive defrost control system (see section 1.2 of this appendix, Definitions), the manufacturer must specify in the certification report the frosting interval to be used during frost accumulation tests and provide the procedure for manually initiating the defrost at the specified time.

2.2.2 Special Requirements for Units Having a Multiple-Speed Outdoor Fan

Configure the multiple-speed outdoor fan according to the installation manual included with the unit by the manufacturer, and thereafter, leave it unchanged for all tests. The controls of the unit must regulate the operation of the outdoor fan during all lab tests except dry coil cooling mode tests. For dry coil cooling mode tests, the outdoor fan must operate at the same speed used during the required wet coil test conducted at the same outdoor test conditions.

2.2.3 Special Requirements for Multi-Split Air Conditioners and Heat Pumps and Ducted Systems Using a Single Indoor Section Containing Multiple Indoor Blowers That Would Normally Operate Using Two or More Indoor Thermostats

Because these systems will have more than one indoor blower and possibly multiple outdoor fans and compressor systems, references in this test procedure to a singular indoor blower, outdoor fan, and/or compressor means all indoor blowers, all outdoor fans, and all compressor systems that are energized during the test.

a. Additional requirements for multi-split air conditioners and heat pumps. For any test where the system is operated at part load (*i.e.,* one or more compressors ''off'', operating at the intermediate or minimum compressor speed, or at low compressor capacity), record the indoor coil(s) that are not providing heating or cooling during the test. For variable-speed systems, the manufacturer must designate in the certification report at least one indoor unit that is not providing heating or cooling for all tests conducted at minimum compressor speed.

b. Additional requirements for ducted split systems with a single indoor unit containing multiple indoor blowers (or for single-package units with an indoor section containing multiple indoor blowers) where the indoor blowers are designed to cycle on and off independently of one another and are not controlled such that all indoor blowers are modulated to always operate at the same air volume rate or speed. For any test where the system is operated at its lowest capacity—*i.e.,* the lowest total air volume rate allowed when operating the single-speed compressor or when operating at low compressor capacity—indoor blowers accounting for at least one-third of the full-load air volume rate must be turned off unless prevented by the controls of the unit. In such cases, turn off as many indoor blowers as permitted by the unit's controls. Where more than one option exists for meeting this ''off'' requirement, the manufacturer shall indicate in its certification report which indoor blower(s) are turned off. The chosen configuration shall remain unchanged for all tests conducted at the same lowest capacity configuration. For any indoor coil turned off during a test, cease forced airflow through any outlet duct connected to a switched-off indoor blower.

c. For test setups where the laboratory's physical limitations requires use of more than the required line length of 25 feet as listed in section 2.2.a(4) of this appendix, then the actual refrigerant line length used by the laboratory may exceed the required length and the refrigerant line length correction factors in Table 4 of AHRI 1230–2010 are applied to the cooling capacity measured for each cooling mode test.

2.2.4 Wet-Bulb Temperature Requirements for the Air Entering the Indoor and Outdoor Coils

2.2.4.1 Cooling Mode Tests

For wet-coil cooling mode tests, regulate the water vapor content of the air entering the indoor unit so that the wet-bulb temperature is as listed in Tables 5 to 8. As noted in these same tables, achieve a wet-bulb temperature during dry-coil cooling mode tests that results in no condensate forming on the indoor coil. Controlling the water vapor content of the air entering the outdoor side of the unit is not required for cooling mode tests except when testing:

(1) Units that reject condensate to the outdoor coil during wet coil tests. Tables 5–8 list the applicable wet-bulb temperatures.

(2) Single-package units where all or part of the indoor section is located in the outdoor test room. The average dew point temperature of the air entering the outdoor coil during wet coil tests must be within ±3.0 °F of the average dew point temperature of the air entering the indoor coil over the 30-minute data collection interval described in section 3.3 of this appendix. For dry coil tests on such units, it may be necessary to limit the moisture content of the air entering the outdoor coil of the unit to meet the requirements of section 3.4 of this appendix.

2.2.4.2 Heating Mode Tests

For heating mode tests, regulate the water vapor content of the air entering the outdoor unit to the applicable wet-bulb temperature listed in Tables 12 to 15. The wet-bulb temperature entering the indoor side of the heat pump must not exceed 60 °F. Additionally, if the Outdoor Air Enthalpy test method (section 2.10.1 of this appendix) is used while testing a single-package heat pump where all or part of the outdoor section is located in the indoor test room, adjust the wet-bulb temperature for the air entering the indoor side to yield an indoor-side dew point temperature that is as close as reasonably possible to the dew point temperature of the outdoor-side entering air.

2.2.5 Additional Refrigerant Charging Requirements

2.2.5.1 Instructions To Use for Charging

a. Where the manufacturer's installation instructions contain two sets of refrigerant charging criteria, one for field installations and one for lab testing, use the field installation criteria.

b. For systems consisting of an outdoor unit manufacturer's outdoor section and indoor section with differing charging procedures, adjust the refrigerant charge per the outdoor installation instructions.

c. For systems consisting of an outdoor unit manufacturer's outdoor unit and an independent coil manufacturer's indoor unit with differing charging procedures, adjust the refrigerant charge per the indoor unit's installation instructions. If instructions are provided only with the outdoor unit or are provided only with an independent coil manufacturer's indoor unit, then use the provided instructions.

2.2.5.2 Test(s) To Use for Charging

a. Use the tests or operating conditions specified in the manufacturer's installation instructions for charging. The manufacturer's installation instructions may specify use of tests other than the A or A_2 test for charging, but, unless the unit is a heating-only heat pump, the air volume rate must be determined by the A or A_2 test as specified in section 3.1 of this appendix.

b. If the manufacturer's installation instructions do not specify a test or operating conditions for charging or there are no manufacturer's instructions, use the following test(s):

(1) For air conditioners or cooling and heating heat pumps, use the A or A_2 test.

(2) For cooling and heating heat pumps that do not operate in the H1 or $H1_2$ test (*e.g.* due to shut down by the unit limiting devices) when tested using the charge determined at the A or A_2 test, and for heating-only heat pumps, use the H1 or $H1_2$ test.

2.2.5.3 Parameters To Set and Their Target Values

a. Consult the manufacturer's installation instructions regarding which parameters (*e.g.*, superheat) to set and their target values. If the instructions provide ranges of values, select target values equal to the midpoints of the provided ranges.

b. In the event of conflicting information between charging instructions (*i.e.*, multiple conditions given for charge adjustment where all conditions specified cannot be met), follow the following hierarchy.

(1) For fixed orifice systems:

(i) Superheat

(ii) High side pressure or corresponding saturation or dew-point temperature

(iii) Low side pressure or corresponding saturation or dew-point temperature

(iv) Low side temperature

(v) High side temperature

(vi) Charge weight

(2) For expansion valve systems:

(i) Subcooling

(ii) High side pressure or corresponding saturation or dew-point temperature

(iii) Low side pressure or corresponding saturation or dew-point temperature

(iv) Approach temperature (difference between temperature of liquid leaving condenser and condenser average inlet air temperature)

(v) Charge weight

c. If there are no installation instructions and/or they do not provide parameters and target values, set superheat to a target value of 12 °F for fixed orifice systems or set subcooling to a target value of 10 °F for expansion valve systems.

2.2.5.4 Charging Tolerances

a. If the manufacturer's installation instructions specify tolerances on target values for the charging parameters, set the values within these tolerances.

b. Otherwise, set parameter values within the following test condition tolerances for the different charging parameters:

1. Superheat: ± 2.0 °F

2. Subcooling: ± 2.0 °F

3. High side pressure or corresponding saturation or dew point temperature: ± 4.0 psi or ± 1.0 °F
4. Low side pressure or corresponding saturation or dew point temperature: ± 2.0 psi or ± 0.8 °F
5. High side temperature: ±2.0 °F
6. Low side temperature: ±2.0 °F
7. Approach temperature: ± 1.0 °F
8. Charge weight: ± 2.0 ounce

2.2.5.5 Special Charging Instructions

a. Cooling and Heating Heat Pumps

If, using the initial charge set in the A or A_2 test, the conditions are not within the range specified in manufacturer's installation instructions for the H1 or $H1_2$ test, make as small as possible an adjustment to obtain conditions for this test in the specified range. After this adjustment, recheck conditions in the A or A_2 test to confirm that they are still within the specified range for the A or A_2 test.

b. Single-Package Systems

Unless otherwise directed by the manufacturer's installation instructions, install one or more refrigerant line pressure gauges during the setup of the unit, located depending on the parameters used to verify or set charge, as described:

(1) Install a pressure gauge at the location of the service valve on the liquid line if charging is on the basis of subcooling, or high side pressure or corresponding saturation or dew point temperature;

(2) Install a pressure gauge at the location of the service valve on the suction line if charging is on the basis of superheat, or low side pressure or corresponding saturation or dew point temperature.

Use methods for installing pressure gauge(s) at the required location(s) as indicated in manufacturer's instructions if specified.

2.2.5.6 Near-Azeotropic and Zeotropic Refrigerants.

Perform charging of near-azeotropic and zeotropic refrigerants only with refrigerant in the liquid state.

2.2.5.7 Adjustment of Charge Between Tests.

After charging the system as described in this test procedure, use the set refrigerant charge for all tests used to determine performance. Do not adjust the refrigerant charge at any point during testing. If measurements indicate that refrigerant charge has leaked during the test, repair the refrigerant leak, repeat any necessary set-up steps, and repeat all tests.

2.3 Indoor Air Volume Rates.

If a unit's controls allow for overspeeding the indoor blower (usually on a temporary basis), take the necessary steps to prevent overspeeding during all tests.

2.3.1 Cooling Tests

a. Set indoor blower airflow-control settings (*e.g.*, fan motor pin settings, fan motor speed) according to the requirements that are specified in section 3.1.4 of this appendix.

b. Express the Cooling full-load air volume rate, the Cooling Minimum Air Volume Rate, and the Cooling Intermediate Air Volume Rate in terms of standard air.

2.3.2 Heating Tests

a. Set indoor blower airflow-control settings (*e.g.*, fan motor pin settings, fan motor speed) according to the requirements that are specified in section 3.1.4 of this appendix.

b. Express the heating full-load air volume rate, the heating minimum air volume rate, the heating intermediate air volume rate, and the heating nominal air volume rate in terms of standard air.

2.4 Indoor Coil Inlet and Outlet Duct Connections

Insulate and/or construct the outlet plenum as described in section 2.4.1 of this appendix and, if installed, the inlet plenum described in section 2.4.2 of this appendix with thermal insulation having a nominal overall resistance (R-value) of at least 19 $hr{\cdot}ft^{2\cdot}$ °F/Btu.

2.4.1 Outlet Plenum for the Indoor Unit

a. Attach a plenum to the outlet of the indoor coil. (NOTE: For some packaged systems, the indoor coil may be located in the outdoor test room.)

b. For systems having multiple indoor coils, or multiple indoor blowers within a single indoor section, attach a plenum to each indoor coil or indoor blower outlet. In order to reduce the number of required airflow measurement apparati (section 2.6 of this appendix), each such apparatus may serve multiple outlet plenums connected to a single common duct leading to the apparatus. More than one indoor test room may be used, which may use one or more common ducts leading to one or more airflow measurement apparati within each test room that contains multiple indoor coils. At the plane where each plenum enters a common duct, install an adjustable airflow damper and use it to equalize the static pressure in each plenum. Each outlet air temperature grid (section 2.5.4 of this appendix) and airflow measuring apparatus are located downstream of the inlet(s) to the common duct. For multiple-circuit (or multi-circuit) systems for which each indoor coil outlet is measured

separately and its outlet plenum is not connected to a common duct connecting multiple outlet plenums, the outlet air temperature grid and airflow measuring apparatus must be installed at each outlet plenum.

c. For small-duct, high-velocity systems, install an outlet plenum that has a diameter that is equal to or less than the value listed in Table 3. The limit depends only on the Cooling full-load air volume rate (see section 3.1.4.1.1 of this appendix) and is effective regardless of the flange dimensions on the outlet of the unit (or an air supply plenum adapter accessory, if installed in accordance with the manufacturer's installation instructions).

d. Add a static pressure tap to each face of the (each) outlet plenum, if rectangular, or at four evenly distributed locations along the circumference of an oval or round plenum. Create a manifold that connects the four static pressure taps. Figure 9 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) shows allowed options for the manifold configuration. The cross-sectional dimensions of plenum shall be equal to the dimensions of the indoor unit outlet. See Figures 7a, 7b, and 7c of ANSI/ASHRAE 37–2009 for the minimum length of the (each) outlet plenum and the locations for adding the static pressure taps for ducted blower coil indoor units and single-package systems. See Figure 8 of ANSI/ASHRAE 37–2009 for coil-only indoor units.

TABLE 3—SIZE OF OUTLET PLENUM FOR SMALL-DUCT HIGH-VELOCITY INDOOR UNITS

Cooling full-load air volume rate (scfm)	Maximum diameter * of outlet plenum (inches)
≤500	6
501 to 700	7
701 to 900	8
901 to 1100	9
1101 to 1400	10
1401 to 1750	11

* If the outlet plenum is rectangular, calculate its equivalent diameter using ($4A/P$,) where A is the cross-sectional area and P is the perimeter of the rectangular plenum, and compare it to the listed maximum diameter.

2.4.2 Inlet Plenum for the Indoor Unit

Install an inlet plenum when testing a coil-only indoor unit, a ducted blower coil indoor unit, or a single-package system. See Figures 7b and 7c of ANSI/ASHRAE 37–2009 for cross-sectional dimensions, the minimum length of the inlet plenum, and the locations of the static-pressure taps for ducted blower coil indoor units and single-package systems. See Figure 8 of ANSI/ASHRAE 37–2009 for coil-only indoor units. The inlet plenum duct size shall equal the size of the inlet opening of the air-handling (blower coil) unit or furnace. For a ducted blower coil indoor unit the set up may omit the inlet plenum if an inlet airflow prevention device is installed with a straight internally unobstructed duct on its outlet end with a minimum length equal to 1.5 times the square root of the cross-sectional area of the indoor unit inlet. See section 2.5.1.2 of this appendix for requirements for the locations of static pressure taps built into the inlet airflow prevention device. For all of these arrangements, make a manifold that connects the four static-pressure taps using one of the three configurations specified in section 2.4.1.d of this appendix. Never use an inlet plenum when testing non-ducted indoor units.

2.5 Indoor Coil Air Property Measurements and Airflow Prevention Devices

Follow instructions for indoor coil air property measurements as described in section 2.14 of this appendix, unless otherwise instructed in this section.

a. Measure the dry-bulb temperature and water vapor content of the air entering and leaving the indoor coil. If needed, use an air sampling device to divert air to a sensor(s) that measures the water vapor content of the air. See section 5.3 of ANSI/ASHRAE 41.1–2013 (incorporated by reference, see §430.3) for guidance on constructing an air sampling device. No part of the air sampling device or the tubing transferring the sampled air to the sensor shall be within two inches of the test chamber floor, and the transfer tubing shall be insulated. The sampling device may also be used for measurement of dry bulb temperature by transferring the sampled air to a remotely located sensor(s). The air sampling device and the remotely located temperature sensor(s) may be used to determine the entering air dry bulb temperature during any test. The air sampling device and the remotely located sensor(s) may be used to determine the leaving air dry bulb temperature for all tests except:

(1) Cyclic tests; and

(2) Frost accumulation tests.

b. Install grids of temperature sensors to measure dry bulb temperatures of both the entering and leaving airstreams of the indoor unit. These grids of dry bulb temperature sensors may be used to measure average dry bulb temperature entering and leaving the indoor unit in all cases (as an alternative to the dry bulb sensor measuring the sampled air). The leaving airstream grid is required for measurement of average dry bulb temperature leaving the indoor unit for the two special cases noted above. The grids are also required to measure the air temperature distribution of the entering and leaving

airstreams as described in sections 3.1.8 and 3.1.9 of this appendix. Two such grids may applied as a thermopile, to directly obtain the average temperature difference rather than directly measuring both entering and leaving average temperatures.

c. Use of airflow prevention devices. Use an inlet and outlet air damper box, or use an inlet upturned duct and an outlet air damper box when conducting one or both of the cyclic tests listed in sections 3.2 and 3.6 of this appendix on ducted systems. If not conducting any cyclic tests, an outlet air damper box is required when testing ducted and non-ducted heat pumps that cycle off the indoor blower during defrost cycles and there is no other means for preventing natural or forced convection through the indoor unit when the indoor blower is off. Never use an inlet damper box or an inlet upturned duct when testing non-ducted indoor units. An inlet upturned duct is a length of ductwork installed upstream from the inlet such that the indoor duct inlet opening, facing upwards, is sufficiently high to prevent natural convection transfer out of the duct. If an inlet upturned duct is used, install a dry bulb temperature sensor near the inlet opening of the indoor duct at a centerline location not higher than the lowest elevation of the duct edges at the inlet, and ensure that any pair of 5-minute averages of the dry bulb temperature at this location, measured at least every minute during the compressor OFF period of the cyclic test, do not differ by more than 1.0 °F.

2.5.1 Test Set-Up on the Inlet Side of the Indoor Coil: For Cases Where the Inlet Airflow Prevention Device Is Installed

a. Install an airflow prevention device as specified in section 2.5.1.1 or 2.5.1.2 of this appendix, whichever applies.

b. For an inlet damper box, locate the grid of entering air dry-bulb temperature sensors, if used, and the air sampling device, or the sensor used to measure the water vapor content of the inlet air, at a location immediately upstream of the damper box inlet. For an inlet upturned duct, locate the grid of entering air dry-bulb temperature sensors, if used, and the air sampling device, or the sensor used to measure the water vapor content of the inlet air, at a location at least one foot downstream from the beginning of the insulated portion of the duct but before the static pressure measurement.

2.5.1.1 If the Section 2.4.2 Inlet Plenum Is Installed

Construct the airflow prevention device having a cross-sectional flow area equal to or greater than the flow area of the inlet plenum. Install the airflow prevention device upstream of the inlet plenum and construct ductwork connecting it to the inlet plenum. If needed, use an adaptor plate or a transition duct section to connect the airflow prevention device with the inlet plenum. Insulate the ductwork and inlet plenum with thermal insulation that has a nominal overall resistance (R-value) of at least 19 hr · ft^2 · °F/Btu.

2.5.1.2 If the Section 2.4.2 Inlet Plenum Is Not Installed

Construct the airflow prevention device having a cross-sectional flow area equal to or greater than the flow area of the air inlet of the indoor unit. Install the airflow prevention device immediately upstream of the inlet of the indoor unit. If needed, use an adaptor plate or a short transition duct section to connect the airflow prevention device with the unit's air inlet. Add static pressure taps at the center of each face of a rectangular airflow prevention device, or at four evenly distributed locations along the circumference of an oval or round airflow prevention device. Locate the pressure taps at a distance from the indoor unit inlet equal to 0.5 times the square root of the cross sectional area of the indoor unit inlet. This location must be between the damper and the inlet of the indoor unit, if a damper is used. Make a manifold that connects the four static pressure taps using one of the configurations shown in Figure 9 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). Insulate the ductwork with thermal insulation that has a nominal overall resistance (R-value) of at least 19 hr · ft^2 · °F/Btu.

2.5.2 Test Set-Up on the Inlet Side of the Indoor Unit: for Cases Where No Airflow Prevention Device is Installed

If using the section 2.4.2 inlet plenum and a grid of dry bulb temperature sensors, mount the grid at a location upstream of the static pressure taps described in section 2.4.2 of this appendix, preferably at the entrance plane of the inlet plenum. If the section 2.4.2 inlet plenum is not used (*i.e.* for non-ducted units) locate a grid approximately 6 inches upstream of the indoor unit inlet. In the case of a system having multiple non-ducted indoor units, do this for each indoor unit. Position an air sampling device, or the sensor used to measure the water vapor content of the inlet air, immediately upstream of the (each) entering air dry-bulb temperature sensor grid. If a grid of sensors is not used, position the entering air sampling device (or the sensor used to measure the water vapor content of the inlet air) as if the grid were present.

2.5.3 Indoor Coil Static Pressure Difference Measurement

Fabricate pressure taps meeting all requirements described in section 6.5.2 of

ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) and illustrated in Figure 2A of AMCA 210–2007 (incorporated by reference, see §430.3), however, if adhering strictly to the description in section 6.5.2 of ANSI/ASHRAE 37–2009, the minimum pressure tap length of 2.5 times the inner diameter of Figure 2A of AMCA 210–2007 is waived. Use a differential pressure measuring instrument that is accurate to within ±0.01 inches of water and has a resolution of at least 0.01 inches of water to measure the static pressure difference between the indoor coil air inlet and outlet. Connect one side of the differential pressure instrument to the manifolded pressure taps installed in the outlet plenum. Connect the other side of the instrument to the manifolded pressure taps located in either the inlet plenum or incorporated within the airflow prevention device. For non-ducted indoor units that are tested with multiple outlet plenums, measure the static pressure within each outlet plenum relative to the surrounding atmosphere.

2.5.4 Test Set-Up on the Outlet Side of the Indoor Coil

a. Install an interconnecting duct between the outlet plenum described in section 2.4.1 of this appendix and the airflow measuring apparatus described below in section 2.6 of this appendix. The cross-sectional flow area of the interconnecting duct must be equal to or greater than the flow area of the outlet plenum or the common duct used when testing non-ducted units having multiple indoor coils. If needed, use adaptor plates or transition duct sections to allow the connections. To minimize leakage, tape joints within the interconnecting duct (and the outlet plenum). Construct or insulate the entire flow section with thermal insulation having a nominal overall resistance (R-value) of at least 19 $hr \cdot ft^{2, \circ}F/Btu$.

b. Install a grid(s) of dry-bulb temperature sensors inside the interconnecting duct. Also, install an air sampling device, or the sensor(s) used to measure the water vapor content of the outlet air, inside the interconnecting duct. Locate the dry-bulb temperature grid(s) upstream of the air sampling device (or the in-duct sensor(s) used to measure the water vapor content of the outlet air). Turn off the sampler fan motor during the cyclic tests. Air leaving an indoor unit that is sampled by an air sampling device for remote water-vapor-content measurement must be returned to the interconnecting duct at a location:

(1) Downstream of the air sampling device;

(2) On the same side of the outlet air damper as the air sampling device; and

(3) Upstream of the section 2.6 airflow measuring apparatus.

2.5.4.1 Outlet Air Damper Box Placement and Requirements

If using an outlet air damper box (see section 2.5 of this appendix), the leakage rate from the combination of the outlet plenum, the closed damper, and the duct section that connects these two components must not exceed 20 cubic feet per minute when a negative pressure of 1 inch of water column is maintained at the plenum's inlet.

2.5.4.2 Procedures To Minimize Temperature Maldistribution

Use these procedures if necessary to correct temperature maldistributions. Install a mixing device(s) upstream of the outlet air, dry-bulb temperature grid (but downstream of the outlet plenum static pressure taps). Use a perforated screen located between the mixing device and the dry-bulb temperature grid, with a maximum open area of 40 percent. One or both items should help to meet the maximum outlet air temperature distribution specified in section 3.1.8 of this appendix. Mixing devices are described in sections 5.3.2 and 5.3.3 of ANSI/ASHRAE 41.1–2013 and section 5.2.2 of ASHRAE 41.2–1987 (RA 1992) (incorporated by reference, see §430.3).

2.5.4.3 Minimizing Air Leakage

For small-duct, high-velocity systems, install an air damper near the end of the interconnecting duct, just prior to the transition to the airflow measuring apparatus of section 2.6 of this appendix. To minimize air leakage, adjust this damper such that the pressure in the receiving chamber of the airflow measuring apparatus is no more than 0.5 inch of water higher than the surrounding test room ambient. If applicable, in lieu of installing a separate damper, use the outlet air damper box of sections 2.5 and 2.5.4.1 of this appendix if it allows variable positioning. Also apply these steps to any conventional indoor blower unit that creates a static pressure within the receiving chamber of the airflow measuring apparatus that exceeds the test room ambient pressure by more than 0.5 inches of water column.

2.5.5 Dry Bulb Temperature Measurement

a. Measure dry bulb temperatures as specified in sections 4, 5.3, 6, and 7 of ANSI/ASHRAE 41.1–2013 (incorporated by reference, see §430.3).

b. Distribute the sensors of a dry-bulb temperature grid over the entire flow area. The required minimum is 9 sensors per grid.

2.5.6 Water Vapor Content Measurement

Determine water vapor content by measuring dry-bulb temperature combined with

the air wet-bulb temperature, dew point temperature, or relative humidity. If used, construct and apply wet-bulb temperature sensors as specified in sections 4, 5, 6, 7.2, 7.3, and 7.4 of ASHRAE 41.6–2014 (incorporated by reference, see §430.3). The temperature sensor (wick removed) must be accurate to within ±0.2 °F. If used, apply dew point hygrometers as specified in sections 4, 5, 6, 7.1, and 7.4 of ASHRAE 41.6–2014 (incorporated by reference, see §430.3). The dew point hygrometers must be accurate to within ±0.4 °F when operated at conditions that result in the evaluation of dew points above 35 °F. If used, a relative humidity (RH) meter must be accurate to within ±0.7% RH. Other means to determine the psychrometric state of air may be used as long as the measurement accuracy is equivalent to or better than the accuracy achieved from using a wet-bulb temperature sensor that meets the above specifications.

2.5.7 Air Damper Box Performance Requirements

If used (see section 2.5 of this appendix), the air damper box(es) must be capable of being completely opened or completely closed within 10 seconds for each action.

2.6 Airflow Measuring Apparatus

a. Fabricate and operate an airflow measuring apparatus as specified in section 6.2 and 6.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). Place the static pressure taps and position the diffusion baffle (settling means) relative to the chamber inlet as indicated in Figure 12 of AMCA 210–2007 and/or Figure 14 of ASHRAE 41.2–1987 (RA 1992) (incorporated by reference, see §430.3). When measuring the static pressure difference across nozzles and/or velocity pressure at nozzle throats using electronic pressure transducers and a data acquisition system, if high frequency fluctuations cause measurement variations to exceed the test tolerance limits specified in section 9.2 and Table 2 of ANSI/ASHRAE 37–2009, dampen the measurement system such that the time constant associated with response to a step change in measurement (time for the response to change 63% of the way from the initial output to the final output) is no longer than five seconds.

b. Connect the airflow measuring apparatus to the interconnecting duct section described in section 2.5.4 of this appendix. See sections 6.1.1, 6.1.2, and 6.1.4, and Figures 1, 2, and 4 of ANSI/ASHRAE 37–2009; and Figures D1, D2, and D4 of AHRI 210/240–2008 (incorporated by reference, see §430.3) for illustrative examples of how the test apparatus may be applied within a complete laboratory set-up. Instead of following one of these examples, an alternative set-up may be used to handle the air leaving the airflow measuring apparatus and to supply properly conditioned air to the test unit's inlet. The alternative set-up, however, must not interfere with the prescribed means for measuring airflow rate, inlet and outlet air temperatures, inlet and outlet water vapor contents, and external static pressures, nor create abnormal conditions surrounding the test unit. (NOTE: Do not use an enclosure as described in section 6.1.3 of ANSI/ASHRAE 37–2009 when testing triple-split units.)

2.7 Electrical Voltage Supply

Perform all tests at the voltage specified in section 6.1.3.2 of AHRI 210/240–2008 (incorporated by reference, see §430.3) for ''Standard Rating Tests.'' If either the indoor or the outdoor unit has a 208V or 200V nameplate voltage and the other unit has a 230V nameplate rating, select the voltage supply on the outdoor unit for testing. Otherwise, supply each unit with its own nameplate voltage. Measure the supply voltage at the terminals on the test unit using a volt meter that provides a reading that is accurate to within ±1.0 percent of the measured quantity.

2.8 Electrical Power and Energy Measurements

a. Use an integrating power (watt-hour) measuring system to determine the electrical energy or average electrical power supplied to all components of the air conditioner or heat pump (including auxiliary components such as controls, transformers, crankcase heater, integral condensate pump on non-ducted indoor units, etc.). The watt-hour measuring system must give readings that are accurate to within ±0.5 percent. For cyclic tests, this accuracy is required during both the ON and OFF cycles. Use either two different scales on the same watt-hour meter or two separate watt-hour meters. Activate the scale or meter having the lower power rating within 15 seconds after beginning an OFF cycle. Activate the scale or meter having the higher power rating within 15 seconds prior to beginning an ON cycle. For ducted blower coil systems, the ON cycle lasts from compressor ON to indoor blower OFF. For ducted coil-only systems, the ON cycle lasts from compressor ON to compressor OFF. For non-ducted units, the ON cycle lasts from indoor blower ON to indoor blower OFF. When testing air conditioners and heat pumps having a variable-speed compressor, avoid using an induction watt/watt-hour meter.

b. When performing section 3.5 and/or 3.8 cyclic tests on non-ducted units, provide instrumentation to determine the average electrical power consumption of the indoor blower motor to within ±1.0 percent. If required according to sections 3.3, 3.4, 3.7, 3.9.1 of this appendix, and/or 3.10 of this appendix, this same instrumentation requirement (to

determine the average electrical power consumption of the indoor blower motor to within ±1.0 percent) applies when testing air conditioners and heat pumps having a variable-speed constant-air-volume-rate indoor blower or a variable-speed, variable-air-volume-rate indoor blower.

2.9 Time Measurements

Make elapsed time measurements using an instrument that yields readings accurate to within ±0.2 percent.

2.10 Test Apparatus for the Secondary Space Conditioning Capacity Measurement

For all tests, use the indoor air enthalpy method to measure the unit's capacity. This method uses the test set-up specified in sections 2.4 to 2.6 of this appendix. In addition, for all steady-state tests, conduct a second, independent measurement of capacity as described in section 3.1.1 of this appendix. For split systems, use one of the following secondary measurement methods: Outdoor air enthalpy method, compressor calibration method, or refrigerant enthalpy method. For single-package units, use either the outdoor air enthalpy method or the compressor calibration method as the secondary measurement.

2.10.1 Outdoor Air Enthalpy Method

a. To make a secondary measurement of indoor space conditioning capacity using the outdoor air enthalpy method, do the following:

(1) Measure the electrical power consumption of the test unit;

(2) Measure the air-side capacity at the outdoor coil; and

(3) Apply a heat balance on the refrigerant cycle.

b. The test apparatus required for the outdoor air enthalpy method is a subset of the apparatus used for the indoor air enthalpy method. Required apparatus includes the following:

(1) On the outlet side, an outlet plenum containing static pressure taps (sections 2.4, 2.4.1, and 2.5.3 of this appendix),

(2) An airflow measuring apparatus (section 2.6 of this appendix),

(3) A duct section that connects these two components and itself contains the instrumentation for measuring the dry-bulb temperature and water vapor content of the air leaving the outdoor coil (sections 2.5.4, 2.5.5, and 2.5.6 of this appendix), and

(4) On the inlet side, a sampling device and temperature grid (section 2.11.b of this appendix).

c. During the free outdoor air tests described in sections 3.11.1 and 3.11.1.1 of this appendix, measure the evaporator and condenser temperatures or pressures. On both the outdoor coil and the indoor coil, solder a thermocouple onto a return bend located at or near the midpoint of each coil or at points not affected by vapor superheat or liquid subcooling. Alternatively, if the test unit is not sensitive to the refrigerant charge, install pressure gages to the access valves or to ports created from tapping into the suction and discharge lines according to sections 7.4.2 and 8.2.5 of ANSI/ASHRAE 37–2009. Use this alternative approach when testing a unit charged with a zeotropic refrigerant having a temperature glide in excess of 1 °F at the specified test conditions.

2.10.2 Compressor Calibration Method

Measure refrigerant pressures and temperatures to determine the evaporator superheat and the enthalpy of the refrigerant that enters and exits the indoor coil. Determine refrigerant flow rate or, when the superheat of the refrigerant leaving the evaporator is less than 5 °F, total capacity from separate calibration tests conducted under identical operating conditions. When using this method, install instrumentation and measure refrigerant properties according to section 7.4.2 and 8.2.5 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). If removing the refrigerant before applying refrigerant lines and subsequently recharging, use the steps in 7.4.2 of ANSI/ASHRAE 37–2009 in addition to the methods of section 2.2.5 of this appendix to confirm the refrigerant charge. Use refrigerant temperature and pressure measuring instruments that meet the specifications given in sections 5.1.1 and 5.2 of ANSI/ASHRAE 37–2009.

2.10.3 Refrigerant Enthalpy Method

For this method, calculate space conditioning capacity by determining the refrigerant enthalpy change for the indoor coil and directly measuring the refrigerant flow rate. Use section 7.5.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) for the requirements for this method, including the additional instrumentation requirements, and information on placing the flow meter and a sight glass. Use refrigerant temperature, pressure, and flow measuring instruments that meet the specifications given in sections 5.1.1, 5.2, and 5.5.1 of ANSI/ASHRAE 37–2009. Refrigerant flow measurement device(s), if used, must be either elevated at least two feet from the test chamber floor or placed upon insulating material having a total thermal resistance of at least R–12 and extending at least one foot laterally beyond each side of the device(s)' exposed surfaces.

2.11 Measurement of Test Room Ambient Conditions

Follow instructions for setting up air sampling device and aspirating psychrometer as

described in section 2.14 of this appendix, unless otherwise instructed in this section.

a. If using a test set-up where air is ducted directly from the conditioning apparatus to the indoor coil inlet (see Figure 2, Loop Air-Enthalpy Test Method Arrangement, of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3)), add instrumentation to permit measurement of the indoor test room dry-bulb temperature.

b. On the outdoor side, use one of the following two approaches, except that approach (1) is required for all evaporatively-cooled units and units that transfer condensate to the outdoor unit for evaporation using condenser heat.

(1) Use sampling tree air collection on all air-inlet surfaces of the outdoor unit.

(2) Use sampling tree air collection on one or more faces of the outdoor unit and demonstrate air temperature uniformity as follows. Install a grid of evenly-distributed thermocouples on each air-permitting face on the inlet of the outdoor unit. Install the thermocouples on the air sampling device, locate them individually or attach them to a wire structure. If not installed on the air sampling device, install the thermocouple grid 6 to 24 inches from the unit. The thermocouples shall be evenly spaced across the coil inlet surface and be installed to avoid sampling of discharge air or blockage of air recirculation. The grid of thermocouples must provide at least 16 measuring points per face or one measurement per square foot of inlet face area, whichever is less. This grid must be constructed and used as per section 5.3 of ANSI/ASHRAE 41.1–2013 (incorporated by reference, see §430.3). The maximum difference between the average temperatures measured during the test period of any two pairs of these individual thermocouples located at any of the faces of the inlet of the outdoor unit, must not exceed 2.0 °F, otherwise approach (1) must be used.

The air sampling devices shall be located at the geometric center of each side; the branches may be oriented either parallel or perpendicular to the longer edges of the air inlet area. The air sampling devices in the outdoor air inlet location shall be sized such that they cover at least 75% of the face area of the side of the coil that they are measuring.

Air distribution at the test facility point of supply to the unit shall be reviewed and may require remediation prior to the beginning of testing. Mixing fans can be used to ensure adequate air distribution in the test room. If used, mixing fans shall be oriented such that they are pointed away from the air intake so that the mixing fan exhaust does not affect the outdoor coil air volume rate. Particular attention should be given to prevent the mixing fans from affecting (enhancing or limiting) recirculation of condenser fan exhaust air back through the unit. Any fan used to enhance test room air mixing shall not cause air velocities in the vicinity of the test unit to exceed 500 feet per minute.

The air sampling device may be larger than the face area of the side being measured, however care shall be taken to prevent discharge air from being sampled. If an air sampling device dimension extends beyond the inlet area of the unit, holes shall be blocked in the air sampling device to prevent sampling of discharge air. Holes can be blocked to reduce the region of coverage of the intake holes both in the direction of the trunk axis or perpendicular to the trunk axis. For intake hole region reduction in the direction of the trunk axis, block holes of one or more adjacent pairs of branches (the branches of a pair connect opposite each other at the same trunk location) at either the outlet end or the closed end of the trunk. For intake hole region reduction perpendicular to the trunk axis, block off the same number of holes on each branch on both sides of the trunk.

A maximum of four (4) air sampling devices shall be connected to each aspirating psychrometer. In order to proportionately divide the flow stream for multiple air sampling devices for a given aspirating psychrometer, the tubing or conduit conveying sampled air to the psychrometer shall be of equivalent lengths for each air sampling device. Preferentially, the air sampling device should be hard connected to the aspirating psychrometer, but if space constraints do not allow this, the assembly shall have a means of allowing a flexible tube to connect the air sampling device to the aspirating psychrometer. The tubing or conduit shall be insulated and routed to prevent heat transfer to the air stream. Any surface of the air conveying tubing in contact with surrounding air at a different temperature than the sampled air shall be insulated with thermal insulation with a nominal thermal resistance (R-value) of at least 19 hr · ft^2 · °F/Btu. Alternatively the conduit may have lower thermal resistance if additional sensor(s) are used to measure dry bulb temperature at the outlet of each air sampling device. No part of the air sampling device or the tubing conducting the sampled air to the sensors shall be within two inches of the test chamber floor.

Pairs of measurements (*e.g.*, dry bulb temperature and wet bulb temperature) used to determine water vapor content of sampled air shall be measured in the same location.

2.12 Measurement of Indoor Blower Speed

When required, measure fan speed using a revolution counter, tachometer, or stroboscope that gives readings accurate to within ±1.0 percent.

2.13 Measurement of Barometric Pressure

Determine the average barometric pressure during each test. Use an instrument that meets the requirements specified in section 5.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3).

2.14 Air Sampling Device and Aspirating Psychrometer Requirements

Air temperature measurements shall be made in accordance with ANSI/ASHRAE 41.1–2013, unless otherwise instructed in this section.

2.14.1 Air Sampling Device Requirements

The air sampling device is intended to draw in a sample of the air at the critical locations of a unit under test. It shall be constructed of stainless steel, plastic or other suitable, durable materials. It shall have a main flow trunk tube with a series of branch tubes connected to the trunk tube. Holes shall be on the side of the sampler facing the upstream direction of the air source. Other sizes and rectangular shapes can be used, and shall be scaled accordingly with the following guidelines:

(1) Minimum hole density of 6 holes per square foot of area to be sampled

(2) Sampler branch tube pitch (spacing) of 6 ± 3 in

(3) Manifold trunk to branch diameter ratio having a minimum of 3:1 ratio

(4) Hole pitch (spacing) shall be equally distributed over the branch (½ pitch from the closed end to the nearest hole)

(5) Maximum individual hole to branch diameter ratio of 1:2 (1:3 preferred)

The minimum average velocity through the air sampling device holes shall be 2.5 ft/s as determined by evaluating the sum of the open area of the holes as compared to the flow area in the aspirating psychrometer.

2.14.2 Aspirating Psychrometer

The psychrometer consists of a flow section and a fan to draw air through the flow section and measures an average value of the sampled air stream. At a minimum, the flow section shall have a means for measuring the dry bulb temperature (typically, a resistance temperature device (RTD) and a means for measuring the humidity (RTD with wetted sock, chilled mirror hygrometer, or relative humidity sensor). The aspirating psychrometer shall include a fan that either can be adjusted manually or automatically to maintain required velocity across the sensors.

The psychrometer shall be made from suitable material which may be plastic (such as polycarbonate), aluminum or other metallic materials. All psychrometers for a given system being tested, shall be constructed of the same material. Psychrometers shall be designed such that radiant heat from the motor (for driving the fan that draws sampled air through the psychrometer) does not affect sensor measurements. For aspirating psychrometers, velocity across the wet bulb sensor shall be 1000 ± 200 ft/min. For all other psychrometers, velocity shall be as specified by the sensor manufacturer.

3. Testing Procedures

3.1 General Requirements

If, during the testing process, an equipment set-up adjustment is made that would have altered the performance of the unit during any already completed test, then repeat all tests affected by the adjustment. For cyclic tests, instead of maintaining an air volume rate, for each airflow nozzle, maintain the static pressure difference or velocity pressure during an ON period at the same pressure difference or velocity pressure as measured during the steady-state test conducted at the same test conditions.

Use the testing procedures in this section to collect the data used for calculating

(1) Performance metrics for central air conditioners and heat pumps during the cooling season;

(2) Performance metrics for heat pumps during the heating season; and

(3) Power consumption metric(s) for central air conditioners and heat pumps during the off mode season(s).

3.1.1 Primary and Secondary Test Methods

For all tests, use the indoor air enthalpy method test apparatus to determine the unit's space conditioning capacity. The procedure and data collected, however, differ slightly depending upon whether the test is a steady-state test, a cyclic test, or a frost accumulation test. The following sections described these differences. For the full-capacity cooling-mode test and (for a heat pump) the full-capacity heating-mode test, use one of the acceptable secondary methods specified in section 2.10 of this appendix to determine indoor space conditioning capacity. Calculate this secondary check of capacity according to section 3.11 of this appendix. The two capacity measurements must agree to within 6 percent to constitute a valid test. For this capacity comparison, use the Indoor Air Enthalpy Method capacity that is calculated in section 7.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3) (and, if testing a coil-only system, compare capacities before making the after-test fan heat adjustments described in section 3.3, 3.4, 3.7, and 3.10 of this appendix). However, include the appropriate section 3.3 to 3.5 and 3.7 to 3.10 fan heat adjustments within the indoor air enthalpy method capacities used for the section 4 seasonal calculations of this appendix.

3.1.2 Manufacturer-Provided Equipment Overrides

Where needed, the manufacturer must provide a means for overriding the controls of the test unit so that the compressor(s) operates at the specified speed or capacity and the indoor blower operates at the specified speed or delivers the specified air volume rate.

3.1.3 Airflow Through the Outdoor Coil

For all tests, meet the requirements given in section 6.1.3.4 of AHRI 210/240–2008 (incorporated by reference, see §430.3) when obtaining the airflow through the outdoor coil.

3.1.3.1 Double-Ducted

For products intended to be installed with the outdoor airflow ducted, the unit shall be installed with outdoor coil ductwork installed per manufacturer installation instructions and shall operate between 0.10 and 0.15 in H_2O external static pressure. External static pressure measurements shall be made in accordance with ANSI/ASHRAE 37–2009 section 6.4 and 6.5.

3.1.4 Airflow Through the Indoor Coil

Airflow setting(s) shall be determined before testing begins. Unless otherwise specified within this or its subsections, no changes shall be made to the airflow setting(s) after initiation of testing.

3.1.4.1 Cooling Full-Load Air Volume Rate

3.1.4.1.1. Cooling Full-Load Air Volume Rate for Ducted Units

Identify the certified cooling full-load air volume rate and certified instructions for setting fan speed or controls. If there is no certified Cooling full-load air volume rate, use a value equal to the certified cooling capacity of the unit times 400 scfm per 12,000 Btu/h. If there are no instructions for setting fan speed or controls, use the as-shipped settings. Use the following procedure to confirm and, if necessary, adjust the Cooling full-load air volume rate and the fan speed or control settings to meet each test procedure requirement:

a. For all ducted blower coil systems, except those having a constant-air-volume-rate indoor blower:

Step (1) Operate the unit under conditions specified for the A (for single-stage units) or A_2 test using the certified fan speed or controls settings, and adjust the exhaust fan of the airflow measuring apparatus to achieve the certified Cooling full-load air volume rate;

Step (2) Measure the external static pressure;

Step (3) If this external static pressure is equal to or greater than the applicable minimum external static pressure cited in Table 4, the pressure requirement is satisfied; proceed to step 7 of this section. If this external static pressure is not equal to or greater than the applicable minimum external static pressure cited in Table 4, proceed to step 4 of this section;

Step (4) Increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until either

(i) The applicable Table 4 minimum is equaled or

(ii) The measured air volume rate equals 90 percent or less of the Cooling full-load air volume rate, whichever occurs first;

Step (5) If the conditions of step 4 (i) of this section occur first, the pressure requirement is satisfied; proceed to step 7 of this section. If the conditions of step 4 (ii) of this section occur first, proceed to step 6 of this section;

Step (6) Make an incremental change to the setup of the indoor blower (*e.g.*, next highest fan motor pin setting, next highest fan motor speed) and repeat the evaluation process beginning above, at step 1 of this section. If the indoor blower setup cannot be further changed, increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until the applicable Table 4 minimum is equaled; proceed to step 7 of this section;

Step (7) The airflow constraints have been satisfied. Use the measured air volume rate as the Cooling full-load air volume rate. Use the final fan speed or control settings for all tests that use the Cooling full-load air volume rate.

b. For ducted blower coil systems with a constant-air-volume-rate indoor blower. For all tests that specify the Cooling full-load air volume rate, obtain an external static pressure as close to (but not less than) the applicable Table 4 value that does not cause automatic shutdown of the indoor blower or air volume rate variation Q_{Var}, defined as follows, greater than 10 percent.

$$Q_{Var} = \left[\frac{Q_{max} - Q_{min}}{\left(\frac{Q_{max} + Q_{min}}{2}\right)}\right] * 100$$

where:

Q_{max} = maximum measured airflow value
Q_{min} = minimum measured airflow value
Q_{var} = airflow variance, percent

Additional test steps as described in section 3.3.(e) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For coil-only indoor units. For the A or A_2 Test, (exclusively), the pressure drop across the indoor coil assembly must not exceed 0.30 inches of water. If this pressure drop is exceeded, reduce the air volume rate until the measured pressure drop equals the specified maximum. Use this reduced air volume rate for all tests that require the Cooling full-load air volume rate.

TABLE 4—MINIMUM EXTERNAL STATIC PRESSURE FOR DUCTED BLOWER COIL SYSTEMS

Rated Cooling [1] or Heating [2] Capacity (Btu/h)	Minimum external resistance [3] (Inches of water)	
	Small-duct, high-velocity systems [4 5]	All other systems
Up Thru 28,800	1.10	0.10
29,000 to 42,500	1.15	0.15
43,000 and Above	1.20	0.20

[1] For air conditioners and air-conditioning heat pumps, the value certified by the manufacturer for the unit's cooling capacity when operated at the *A* or A_2 Test conditions.
[2] For heating-only heat pumps, the value certified by the manufacturer for the unit's heating capacity when operated at the *H1* or $H1_2$ Test conditions.
[3] For ducted units tested without an air filter installed, increase the applicable tabular value by 0.08 inches of water.
[4] See section 1.2 of this appendix, Definitions, to determine if the equipment qualifies as a small-duct, high-velocity system.
[5] If a closed-loop, air-enthalpy test apparatus is used on the indoor side, limit the resistance to airflow on the inlet side of the blower coil indoor unit to a maximum value of 0.1 inch of water. Impose the balance of the airflow resistance on the outlet side of the indoor blower.

d. For ducted systems having multiple indoor blowers within a single indoor section, obtain the full-load air volume rate with all indoor blowers operating unless prevented by the controls of the unit. In such cases, turn on the maximum number of indoor blowers permitted by the unit's controls. Where more than one option exists for meeting this ''on'' indoor blower requirement, which indoor blower(s) are turned on must match that specified in the certification report. Conduct section 3.1.4.1.1 setup steps for each indoor blower separately. If two or more indoor blowers are connected to a common duct as per section 2.4.1 of this appendix, temporarily divert their air volume to the test room when confirming or adjusting the setup configuration of individual indoor blowers. The allocation of the system's full-load air volume rate assigned to each ''on'' indoor blower must match that specified by the manufacturer in the certification report.

3.1.4.1.2. Cooling Full-Load Air Volume Rate for Non-Ducted Units

For non-ducted units, the Cooling full-load air volume rate is the air volume rate that results during each test when the unit is operated at an external static pressure of zero inches of water.

3.1.4.2 Cooling Minimum Air Volume Rate

Identify the certified cooling minimum air volume rate and certified instructions for setting fan speed or controls. If there is no certified cooling minimum air volume rate, use the final indoor blower control settings as determined when setting the cooling full-load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full load air volume obtained in section 3.1.4.1 of this appendix. Otherwise, calculate the target external static pressure and follow instructions a, b, c, d, or e below. The target external static pressure, ΔP_{st_i}, for any test ''i'' with a specified air volume rate not equal to the Cooling full-load air volume rate is determined as follows:

$$\Delta P_{st_i} = \Delta P_{st_full} \left[\frac{Q_i}{Q_{full}} \right]^2$$

where:

ΔP_{st_i} = target minimum external static pressure for test i;

ΔP_{st_full} = minimum external static pressure for test A or A_2 (Table 4);

Q_i = air volume rate for test i; and

Q_{full} = Cooling full-load air volume rate as measured after setting and/or adjustment as described in section 3.1.4.1.1 of this appendix.

a. For a ducted blower coil system without a constant-air-volume indoor blower, adjust for external static pressure as follows:

Step (1) Operate the unit under conditions specified for the B1 test using the certified fan speed or controls settings, and adjust the exhaust fan of the airflow measuring apparatus to achieve the certified cooling minimum air volume rate;

Step (2) Measure the external static pressure;

Step (3) If this pressure is equal to or greater than the minimum external static pressure computed above, the pressure requirement is satisfied; proceed to step 7 of this section. If this pressure is not equal to or greater than the minimum external static pressure computed above, proceed to step 4 of this section;

Step (4) Increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until either

(i) The pressure is equal to the minimum external static pressure computed above or

(ii) The measured air volume rate equals 90 percent or less of the cooling minimum air volume rate, whichever occurs first;

Step (5) If the conditions of step 4 (i) of this section occur first, the pressure requirement is satisfied; proceed to step 7 of this section. If the conditions of step 4 (ii) of this section occur first, proceed to step 6 of this section;

Step (6) Make an incremental change to the setup of the indoor blower (*e.g.*, next highest fan motor pin setting, next highest fan motor speed) and repeat the evaluation process beginning above, at step 1 of this section. If the indoor blower setup cannot be further changed, increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until it equals the minimum external static pressure computed above; proceed to step 7 of this section;

Step (7) The airflow constraints have been satisfied. Use the measured air volume rate as the cooling minimum air volume rate. Use the final fan speed or control settings for all tests that use the cooling minimum air volume rate.

b. For ducted units with constant-air-volume indoor blowers, conduct all tests that specify the cooling minimum air volume rate—(*i.e.*, the A_1, B_1, C_1, F_1, and G_1 Tests)—at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{Var}, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.3(e) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For ducted two-capacity coil-only systems, the cooling minimum air volume rate is the higher of (1) the rate specified by the installation instructions included with the unit by the manufacturer or (2) 75 percent of the cooling full-load air volume rate. During the laboratory tests on a coil-only (fanless) system, obtain this cooling minimum air volume rate regardless of the pressure drop across the indoor coil assembly.

d. For non-ducted units, the cooling minimum air volume rate is the air volume rate that results during each test when the unit operates at an external static pressure of zero inches of water and at the indoor blower setting used at low compressor capacity (two-capacity system) or minimum compressor speed (variable-speed system). For units having a single-speed compressor and a variable-speed variable-air-volume-rate indoor blower, use the lowest fan setting allowed for cooling.

e. For ducted systems having multiple indoor blowers within a single indoor section, operate the indoor blowers such that the lowest air volume rate allowed by the unit's controls is obtained when operating the lone single-speed compressor or when operating at low compressor capacity while meeting the requirements of section 2.2.3.b of this appendix for the minimum number of blowers that must be turned off. Using the target external static pressure and the certified air volume rates, follow the procedures described in section 3.1.4.2.a of this appendix if the indoor blowers are not constant-air-volume indoor blowers or as described in section 3.1.4.2.b of this appendix if the indoor blowers are constant-air-volume indoor blowers. The sum of the individual ''on'' indoor blowers' air volume rates is the cooling minimum air volume rate for the system.

3.1.4.3 Cooling Intermediate Air Volume Rate

Identify the certified cooling intermediate air volume rate and certified instructions for setting fan speed or controls. If there is no certified cooling intermediate air volume rate, use the final indoor blower control settings as determined when setting the cooling full load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full load air volume obtained in section 3.1.4.1 of this appendix. Otherwise, calculate target

minimum external static pressure as described in section 3.1.4.2 of this appendix, and set the air volume rate as follows.

a. For a ducted blower coil system without a constant-air-volume indoor blower, adjust for external static pressure as described in section 3.1.4.2.a of this appendix for cooling minimum air volume rate.

b. For a ducted blower coil system with a constant-air-volume indoor blower, conduct the E_V Test at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{var}, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.3(e) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For non-ducted units, the cooling intermediate air volume rate is the air volume rate that results when the unit operates at an external static pressure of zero inches of water and at the fan speed selected by the controls of the unit for the E_V Test conditions.

3.1.4.4 Heating Full-Load Air Volume Rate

3.1.4.4.1. Ducted Heat Pumps Where the Heating and Cooling Full-Load Air Volume Rates Are the Same

a. Use the Cooling full-load air volume rate as the heating full-load air volume rate for:

(1) Ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, and that operate at the same airflow-control setting during both the A (or A_2) and the H1 (or $H1_2$) Tests;

(2) Ducted blower coil system heat pumps with constant-air-flow indoor blowers that provide the same air flow for the A (or A_2) and the H1 (or $H1_2$) Tests; and

(3) Ducted heat pumps that are tested with a coil-only indoor unit (except two-capacity northern heat pumps that are tested only at low capacity cooling—see section 3.1.4.4.2 of this appendix).

b. For heat pumps that meet the above criteria ''1'' and ''3,'' no minimum requirements apply to the measured external or internal, respectively, static pressure. Use the final indoor blower control settings as determined when setting the Cooling full-load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full-load air volume obtained in section 3.1.4.1 of this appendix. For heat pumps that meet the above criterion ''2,'' test at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{var}, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than, the same Table 4 minimum external static pressure as was specified for the A (or A_2) cooling mode test. Additional test steps as described in section 3.9.1(c) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

3.1.4.4.2. Ducted Heat Pumps Where the Heating and Cooling Full-Load Air Volume Rates Are Different Due to Changes in Indoor Blower Operation, *i.e.* Speed Adjustment by the System Controls

Identify the certified heating full-load air volume rate and certified instructions for setting fan speed or controls. If there is no certified heating full-load air volume rate, use the final indoor blower control settings as determined when setting the cooling full-load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full load air volume obtained in section 3.1.4.1 of this appendix. Otherwise, calculate target minimum external static pressure as described in section 3.1.4.2 of this appendix and set the air volume rate as follows.

a. For ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, adjust for external static pressure as described in section 3.1.4.2.a of this appendix for cooling minimum air volume rate.

b. For ducted heat pumps tested with constant-air-volume indoor blowers installed, conduct all tests that specify the heating full-load air volume rate at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{var}, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.9.1(c) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. When testing ducted, two-capacity blower coil system northern heat pumps (see section 1.2 of this appendix, Definitions), use the appropriate approach of the above two cases. For coil-only system northern heat pumps, the heating full-load air volume rate is the lesser of the rate specified by the manufacturer in the installation instructions included with the unit or 133 percent of the cooling full-load air volume rate. For this latter case, obtain the heating full-load air volume rate regardless of the pressure drop across the indoor coil assembly.

d. For ducted systems having multiple indoor blowers within a single indoor section, obtain the heating full-load air volume rate using the same ''on'' indoor blowers as used for the Cooling full-load air volume rate. Using the target external static pressure and

the certified air volume rates, follow the procedures as described in section 3.1.4.4.2.a of this appendix if the indoor blowers are not constant-air-volume indoor blowers or as described in section 3.1.4.4.2.b of this appendix if the indoor blowers are constant-air-volume indoor blowers. The sum of the individual ''on'' indoor blowers' air volume rates is the heating full load air volume rate for the system.

3.1.4.4.3. Ducted Heating-Only Heat Pumps

Identify the certified heating full-load air volume rate and certified instructions for setting fan speed or controls. If there is no certified heating full-load air volume rate, use a value equal to the certified heating capacity of the unit times 400 scfm per 12,000 Btu/h. If there are no instructions for setting fan speed or controls, use the as-shipped settings.

a. For all ducted heating-only blower coil system heat pumps, except those having a constant-air-volume-rate indoor blower. Conduct the following steps only during the first test, the H1 or $H1_2$ Test:

Step (1) Adjust the exhaust fan of the airflow measuring apparatus to achieve the certified heating full-load air volume rate.

Step (2) Measure the external static pressure.

Step (3) If this pressure is equal to or greater than the Table 4 minimum external static pressure that applies given the heating-only heat pump's rated heating capacity, the pressure requirement is satisfied; proceed to step 7 of this section. If this pressure is not equal to or greater than the applicable Table 4 minimum external static pressure, proceed to step 4 of this section;

Step (4) Increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until either (i) the pressure is equal to the applicable Table 4 minimum external static pressure or (ii) the measured air volume rate equals 90 percent or less of the heating full-load air volume rate, whichever occurs first;

Step (5) If the conditions of step 4(i) of this section occur first, the pressure requirement is satisfied; proceed to step 7 of this section. If the conditions of step 4(ii) of this section occur first, proceed to step 6 of this section;

Step (6) Make an incremental change to the setup of the indoor blower (*e.g.*, next highest fan motor pin setting, next highest fan motor speed) and repeat the evaluation process beginning above, at step 1 of this section. If the indoor blower setup cannot be further changed, increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until it equals the applicable Table 4 minimum external static pressure; proceed to step 7 of this section;

Step (7) The airflow constraints have been satisfied. Use the measured air volume rate as the heating full-load air volume rate. Use the final fan speed or control settings for all tests that use the heating full-load air volume rate.

b. For ducted heating-only blower coil system heat pumps having a constant-air-volume-rate indoor blower. For all tests that specify the heating full-load air volume rate, obtain an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{Var}, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than, the applicable Table 4 minimum. Additional test steps as described in section 3.9.1(c) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For ducted heating-only coil-only system heat pumps in the H1 or $H1_2$ Test, (exclusively), the pressure drop across the indoor coil assembly must not exceed 0.30 inches of water. If this pressure drop is exceeded, reduce the air volume rate until the measured pressure drop equals the specified maximum. Use this reduced air volume rate for all tests that require the heating full-load air volume rate.

3.1.4.4.4. Non-Ducted Heat Pumps, Including Non-Ducted Heating-Only Heat Pumps

For non-ducted heat pumps, the heating full-load air volume rate is the air volume rate that results during each test when the unit operates at an external static pressure of zero inches of water.

3.1.4.5 Heating Minimum Air Volume Rate

3.1.4.5.1. Ducted Heat Pumps Where the Heating and Cooling Minimum Air Volume Rates Are the Same

a. Use the cooling minimum air volume rate as the heating minimum air volume rate for:

(1) Ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, and that operate at the same airflow-control setting during both the A_1 and the $H1_1$ tests;

(2) Ducted blower coil system heat pumps with constant-air-flow indoor blowers installed that provide the same air flow for the A_1 and the $H1_1$ Tests; and

(3) Ducted coil-only system heat pumps.

b. For heat pumps that meet the above criteria ''1'' and ''3,'' no minimum requirements apply to the measured external or internal, respectively, static pressure. Use the final indoor blower control settings as determined when setting the cooling minimum air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling minimum air volume

rate obtained in section 3.1.4.2 of this appendix. For heat pumps that meet the above criterion ''2,'' test at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{Var}, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than, the same target minimum external static pressure as was specified for the A_1 cooling mode test. Additional test steps as described in section 3.9.1(c) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

3.1.4.5.2. Ducted Heat Pumps Where the Heating and Cooling Minimum Air Volume Rates Are Different Due to Changes in Indoor Blower Operation, *i.e.* Speed Adjustment by the System Controls

Identify the certified heating minimum air volume rate and certified instructions for setting fan speed or controls. If there is no certified heating minimum air volume rate, use the final indoor blower control settings as determined when setting the cooling minimum air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling minimum air volume obtained in section 3.1.4.2 of this appendix. Otherwise, calculate the target minimum external static pressure as described in section 3.1.4.2 of this appendix.

a. For ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, adjust for external static pressure as described in section 3.1.4.2.a of this appendix for cooling minimum air volume rate.

b. For ducted heat pumps tested with constant-air-volume indoor blowers installed, conduct all tests that specify the heating minimum air volume rate—(*i.e.*, the $H0_1$, $H1_1$, $H2_1$, and $H3_1$ Tests)—at an external static pressure that does not cause an automatic shutdown of the indoor blower while being as close to, but not less than the air volume rate variation Q_{Var}, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.9.1.c of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For ducted two-capacity blower coil system northern heat pumps, use the appropriate approach of the above two cases.

d. For ducted two-capacity coil-only system heat pumps, use the cooling minimum air volume rate as the heating minimum air volume rate. For ducted two-capacity coil-only system northern heat pumps, use the cooling full-load air volume rate as the heating minimum air volume rate. For ducted two-capacity heating-only coil-only system heat pumps, the heating minimum air volume rate is the higher of the rate specified by the manufacturer in the test setup instructions included with the unit or 75 percent of the heating full-load air volume rate. During the laboratory tests on a coil-only system, obtain the heating minimum air volume rate without regard to the pressure drop across the indoor coil assembly.

e. For non-ducted heat pumps, the heating minimum air volume rate is the air volume rate that results during each test when the unit operates at an external static pressure of zero inches of water and at the indoor blower setting used at low compressor capacity (two-capacity system) or minimum compressor speed (variable-speed system). For units having a single-speed compressor and a variable-speed, variable-air-volume-rate indoor blower, use the lowest fan setting allowed for heating.

f. For ducted systems with multiple indoor blowers within a single indoor section, obtain the heating minimum air volume rate using the same ''on'' indoor blowers as used for the cooling minimum air volume rate. Using the target external static pressure and the certified air volume rates, follow the procedures as described in section 3.1.4.5.2.a of this appendix if the indoor blowers are not constant-air-volume indoor blowers or as described in section 3.1.4.5.2.b of this appendix if the indoor blowers are constant-air-volume indoor blowers. The sum of the individual ''on'' indoor blowers' air volume rates is the heating full-load air volume rate for the system.

3.1.4.6 Heating Intermediate Air Volume Rate

Identify the certified heating intermediate air volume rate and certified instructions for setting fan speed or controls. If there is no certified heating intermediate air volume rate, use the final indoor blower control settings as determined when setting the heating full-load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full load air volume obtained in section 3.1.4.2 of this appendix. Calculate the target minimum external static pressure as described in section 3.1.4.2 of this appendix.

a. For ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, adjust for external static pressure as described in section 3.1.4.2.a of this appendix for cooling minimum air volume rate.

b. For ducted heat pumps tested with constant-air-volume indoor blowers installed, conduct the $H2_V$ Test at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{Var}, defined in section 3.1.4.1.1.b of this appendix, greater than 10

percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.9.1(c) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For non-ducted heat pumps, the heating intermediate air volume rate is the air volume rate that results when the heat pump operates at an external static pressure of zero inches of water and at the fan speed selected by the controls of the unit for the $H2_V$ Test conditions.

3.1.4.7 Heating Nominal Air Volume Rate

The manufacturer must specify the heating nominal air volume rate and the instructions for setting fan speed or controls. Calculate target minimum external static pressure as described in section 3.1.4.2 of this appendix. Make adjustments as described in section 3.1.4.6 of this appendix for heating intermediate air volume rate so that the target minimum external static pressure is met or exceeded.

3.1.5 Indoor Test Room Requirement When the Air Surrounding the Indoor Unit Is Not Supplied From the Same Source as the Air Entering the Indoor Unit

If using a test set-up where air is ducted directly from the air reconditioning apparatus to the indoor coil inlet (see Figure 2, Loop Air-Enthalpy Test Method Arrangement, of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3)), maintain the dry bulb temperature within the test room within ±5.0 °F of the applicable sections 3.2 and 3.6 dry bulb temperature test condition for the air entering the indoor unit. Dew point shall be within 2 °F of the required inlet conditions.

3.1.6 Air Volume Rate Calculations

For all steady-state tests and for frost accumulation ($H2$, $H2_1$, $H2_2$, $H2_V$) tests, calculate the air volume rate through the indoor coil as specified in sections 7.7.2.1 and 7.7.2.2 of ANSI/ASHRAE 37–2009. When using the outdoor air enthalpy method, follow sections 7.7.2.1 and 7.7.2.2 of ANSI/ASHRAE 37–2009 to calculate the air volume rate through the outdoor coil. To express air volume rates in terms of standard air, use:

Equation 3-1

$$\overline{\dot{V}_s} = \frac{\overline{\dot{V}_{mx}}}{0.075\,\frac{lbm_{da}}{ft^3} * v_n' * [1+W_n]} = \frac{\overline{\dot{V}_{mx}}}{0.075\,\frac{lbm_{da}}{ft^3} * v_n}$$

Where:

$\overline{V}_s$ = air volume rate of standard (dry) air, $(ft^3/min)_{da}$

$\overline{V}_{mx}$ = air volume rate of the air-water vapor mixture, $(ft^3/min)_{mx}$

v_n' = specific volume of air-water vapor mixture at the nozzle, ft^3 per lbm of the air-water vapor mixture

W_n = humidity ratio at the nozzle, lbm of water vapor per lbm of dry air

0.075 = the density associated with standard (dry) air, (lbm/ft^3)

v_n = specific volume of the dry air portion of the mixture evaluated at the dry-bulb temperature, vapor content, and barometric pressure existing at the nozzle, ft^3 per lbm of dry air.

NOTE: In the first printing of ANSI/ASHRAE 37–2009, the second IP equation for Q_{mi} should read

$$Q_{mi} = 1097 C A_n \sqrt{P_V v_n'}$$

3.1.7 Test Sequence

Before making test measurements used to calculate performance, operate the equipment for the ''break-in'' period specified in the certification report, which may not exceed 20 hours. Each compressor of the unit must undergo this ''break-in'' period. When testing a ducted unit (except if a heating-only heat pump), conduct the A or A_2 Test first to establish the cooling full-load air volume rate. For ducted heat pumps where the heating and cooling full-load air volume rates are different, make the first heating mode test one that requires the heating full-load air volume rate. For ducted heating-only heat pumps, conduct the H1 or $H1_2$ Test first to establish the heating full-load air volume rate. When conducting a cyclic test, always conduct it immediately after the steady-state test that requires the same test conditions. For variable-speed systems, the

first test using the cooling minimum air volume rate should precede the E_V Test, and the first test using the heating minimum air volume rate must precede the $H2_V$ Test. The test laboratory makes all other decisions on the test sequence.

3.1.8 Requirement for the Air Temperature Distribution Leaving the Indoor Coil

For at least the first cooling mode test and the first heating mode test, monitor the temperature distribution of the air leaving the indoor coil using the grid of individual sensors described in sections 2.5 and 2.5.4 of this appendix. For the 30-minute data collection interval used to determine capacity, the maximum spread among the outlet dry bulb temperatures from any data sampling must not exceed 1.5 °F. Install the mixing devices described in section 2.5.4.2 of this appendix to minimize the temperature spread.

3.1.9 Requirement for the Air Temperature Distribution Entering the Outdoor Coil

Monitor the temperatures of the air entering the outdoor coil using air sampling devices and/or temperature sensor grids, maintaining the required tolerances, if applicable, as described in section 2.11 of this appendix.

3.1.10 Control of Auxiliary Resistive Heating Elements

Except as noted, disable heat pump resistance elements used for heating indoor air at all times, including during defrost cycles and if they are normally regulated by a heat comfort controller. For heat pumps equipped with a heat comfort controller, enable the heat pump resistance elements only during the below-described, short test. For single-speed heat pumps covered under section 3.6.1 of this appendix, the short test follows the H1 or, if conducted, the H1C Test. For two-capacity heat pumps and heat pumps covered under section 3.6.2 of this appendix, the short test follows the $H1_2$ Test. Set the heat comfort controller to provide the maximum supply air temperature. With the heat pump operating and while maintaining the heating full-load air volume rate, measure the temperature of the air leaving the indoor-side beginning 5 minutes after activating the heat comfort controller. Sample the outlet dry-bulb temperature at regular intervals that span 5 minutes or less. Collect data for 10 minutes, obtaining at least 3 samples. Calculate the average outlet temperature over the 10-minute interval, T_{CC}.

3.2 Cooling Mode Tests for Different Types of Air Conditioners and Heat Pumps

3.2.1 Tests for a System Having a Single-Speed Compressor and Fixed Cooling Air Volume Rate

This set of tests is for single-speed-compressor units that do not have a cooling minimum air volume rate or a cooling intermediate air volume rate that is different than the cooling full load air volume rate. Conduct two steady-state wet coil tests, the A and B Tests. Use the two optional dry-coil tests, the steady-state C Test and the cyclic D Test, to determine the cooling mode cyclic degradation coefficient, C_D^c. If the two optional tests are conducted but yield a tested C_D^c that exceeds the default C_D^c or if the two optional tests are not conducted, assign C_D^c the default value of 0.25 (for outdoor units with no match) or 0.20 (for all other systems). Table 5 specifies test conditions for these four tests.

TABLE 5—COOLING MODE TEST CONDITIONS FOR UNITS HAVING A SINGLE-SPEED COMPRESSOR AND A FIXED COOLING AIR VOLUME RATE

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
A Test—required (steady, wet coil)	80	67	95	[1] 75	Cooling full-load.[2]
B Test—required (steady, wet coil)	80	67	82	[1] 65	Cooling full-load.[2]
C Test—optional (steady, dry coil)	80	[3]	82		Cooling full-load.[2]
D Test—optional (cyclic, dry coil)	80	[3]	82		[4].

[1] The specified test condition only applies if the unit rejects condensate to the outdoor coil.
[2] Defined in section 3.1.4.1 of this appendix.
[3] The entering air must have a low enough moisture content so no condensate forms on the indoor coil. (It is recommended that an indoor wet-bulb temperature of 57 °F or less be used.)
[4] Maintain the airflow nozzles static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the C Test.

3.2.2 Tests for a Unit Having a Single-Speed Compressor Where the Indoor Section Uses a Single Variable-Speed Variable-Air-Volume Rate Indoor Blower or Multiple Indoor Blowers

3.2.2.1 Indoor Blower Capacity Modulation That Correlates With the Outdoor Dry Bulb Temperature or Systems With a Single Indoor Coil but Multiple Indoor Blowers

Conduct four steady-state wet coil tests: The A_2, A_1, B_2, and B_1 tests. Use the two optional dry-coil tests, the steady-state C_1 test and the cyclic D_1 test, to determine the cooling mode cyclic degradation coefficient, $C_D{}^c$. If the two optional tests are conducted but yield a tested C_Dc that exceeds the default C_Dc or if the two optional tests are not conducted, assign C_Dc the default value of 0.20.

3.2.2.2 Indoor Blower Capacity Modulation Based on Adjusting the Sensible to Total (S/T) Cooling Capacity Ratio

The testing requirements are the same as specified in section 3.2.1 of this appendix and Table 5. Use a cooling full-load air volume rate that represents a normal installation. If performed, conduct the steady-state C Test and the cyclic D Test with the unit operating in the same S/T capacity control mode as used for the B Test.

TABLE 6—COOLING MODE TEST CONDITIONS FOR UNITS WITH A SINGLE-SPEED COMPRESSOR THAT MEET THE SECTION 3.2.2.1 INDOOR UNIT REQUIREMENTS

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
A_2 Test—required (steady, wet coil)	80	67	95	[1] 75	Cooling full-load.[2]
A_1 Test—required (steady, wet coil)	80	67	95	[1] 75	Cooling minimum.[3]
B_2 Test—required (steady, wet coil)	80	67	82	[1] 65	Cooling full-load.[2]
B_1 Test—required (steady, wet coil)	80	67	82	[1] 65	Cooling minimum.[3]
C_1 Test[4]—optional (steady, dry coil)	80	([4])	82		Cooling minimum.[3]
D_1 Test[4]—optional (cyclic, dry coil)	80	([4])	82		([5]).

[1] The specified test condition only applies if the unit rejects condensate to the outdoor coil.
[2] Defined in section 3.1.4.1 of this appendix.
[3] Defined in section 3.1.4.2 of this appendix.
[4] The entering air must have a low enough moisture content so no condensate forms on the indoor coil. (It is recommended that an indoor wet-bulb temperature of 5 °F or less be used.)
[5] Maintain the airflow nozzles static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the C_1 Test.

3.2.3 Tests for a Unit Having a Two-Capacity Compressor (See Section 1.2 of This Appendix, Definitions)

a. Conduct four steady-state wet coil tests: the A_2, B_2, B_1, and F_1 Tests. Use the two optional dry-coil tests, the steady-state C_1 Test and the cyclic D_1 Test, to determine the cooling-mode cyclic-degradation coefficient, $C_D{}^c$. If the two optional tests are conducted but yield a tested C_Dc that exceeds the default C_Dc or if the two optional tests are not conducted, assign C_Dc the default value of 0.20. Table 6 specifies test conditions for these six tests.

b. For units having a variable speed indoor blower that is modulated to adjust the sensible to total (S/T) cooling capacity ratio, use cooling full-load and cooling minimum air volume rates that represent a normal installation. Additionally, if conducting the dry-coil tests, operate the unit in the same S/T capacity control mode as used for the B_1 Test.

c. Test two-capacity, northern heat pumps (see section 1.2 of this appendix, Definitions) in the same way as a single speed heat pump with the unit operating exclusively at low compressor capacity (see section 3.2.1 of this appendix and Table 5).

d. If a two-capacity air conditioner or heat pump locks out low-capacity operation at higher outdoor temperatures, then use the two dry-coil tests, the steady-state C_2 Test and the cyclic D_2 Test, to determine the cooling-mode cyclic-degradation coefficient that only applies to on/off cycling from high capacity, $C_D{}^c(k=2)$. If the two optional tests are conducted but yield a tested CD^c $(k = 2)$ that exceeds the default CD^c $(k = 2)$ or if the two optional tests are not conducted, assign CD^c $(k = 2)$ the default value. The default $C_D{}^c(k=2)$ is the same value as determined or assigned for the low-capacity cyclic-degradation coefficient, $C_D{}^c$ [or equivalently, $C_D{}^c(k=1)$].

TABLE 7—COOLING MODE TEST CONDITIONS FOR UNITS HAVING A TWO-CAPACITY COMPRESSOR

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor capacity	Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
A_2 Test—required (steady, wet coil)	80	67	95	[1] 75	High	Cooling Full-Load.[2]
B_2 Test—required (steady, wet coil)	80	67	82	[1] 65	High	Cooling Full-Load.[2]
B_1 Test—required (steady, wet coil)	80	67	82	[1] 65	Low	Cooling Minimum.[3]
C_2 Test—optional (steady, dry-coil)	80	([4])	82		High	Cooling Full-Load.[2]
D_2 Test—optional (cyclic, dry-coil)	80	([4])	82		High	([5]).
C_1 Test—optional (steady, dry-coil)	80	([4])	82		Low	Cooling Minimum.[3]
D_1 Test—optional (cyclic, dry-coil)	80	([4])	82		Low	([6]).
F_1 Test—required (steady, wet coil)	80	67	67	[1] 53.5	Low	Cooling Minimum.[3]

[1] The specified test condition only applies if the unit rejects condensate to the outdoor coil.
[2] Defined in section 3.1.4.1 of this appendix.
[3] Defined in section 3.1.4.2 of this appendix.
[4] The entering air must have a low enough moisture content so no condensate forms on the indoor coil. DOE recommends using an indoor air wet-bulb temperature of 57 °F or less.
[5] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the C_2 Test.
[6] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the C_1 Test.

3.2.4 Tests for a Unit Having a Variable-Speed Compressor

a. Conduct five steady-state wet coil tests: The A_2, E_V, B_2, B_1, and F_1 Tests. Use the two optional dry-coil tests, the steady-state G_1 Test and the cyclic I_1 Test, to determine the cooling mode cyclic degradation coefficient, $C_D{}^c$. If the two optional tests are conducted but yield a tested $C_D c$ that exceeds the default $C_D c$ or if the two optional tests are not conducted, assign $C_D c$ the default value of 0.25. Table 8 specifies test conditions for these seven tests. The compressor shall operate at the same cooling full speed, measured by RPM or power input frequency (Hz), for both the A_2 and B_2 tests. The compressor shall operate at the same cooling minimum speed, measured by RPM or power input frequency (Hz), for the B_1, F_1, G_1, and I_1 tests. Determine the cooling intermediate compressor speed cited in Table 8 using:

$$\text{Cooling intermediate speed} = \text{Cooling minimum speed} + \frac{\text{Cooling full speed} - \text{Cooling minimum speed}}{3}$$

where a tolerance of plus 5 percent or the next higher inverter frequency step from that calculated is allowed.

b. For units that modulate the indoor blower speed to adjust the sensible to total (S/T) cooling capacity ratio, use cooling full-load, cooling intermediate, and cooling minimum air volume rates that represent a normal installation. Additionally, if conducting the dry-coil tests, operate the unit in the same S/T capacity control mode as used for the F_1 Test.

c. For multiple-split air conditioners and heat pumps (except where noted), the following procedures supersede the above requirements: For all Table 8 tests specified for a minimum compressor speed, at least one indoor unit must be turned off. The manufacturer shall designate the particular indoor unit(s) that is turned off. The manufacturer must also specify the compressor speed used for the Table 8 E_V Test, a cooling-mode intermediate compressor speed that falls within ¼ and ¾ of the difference between the full and minimum cooling-mode speeds. The manufacturer should prescribe an intermediate speed that is expected to yield the highest EER for the given E_V Test conditions and bracketed compressor speed range. The manufacturer can designate that one or more indoor units are turned off for the E_V Test.

TABLE 8—COOLING MODE TEST CONDITION FOR UNITS HAVING A VARIABLE-SPEED COMPRESSOR

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor speed	Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
A_2 Test—required (steady, wet coil).	80	67	95	[1] 75	Cooling Full	Cooling Full-Load.[2]

TABLE 8—COOLING MODE TEST CONDITION FOR UNITS HAVING A VARIABLE-SPEED COMPRESSOR—Continued

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor speed	Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
B_2 Test—required (steady, wet coil).	80	67	82	[1] 65	Cooling Full	Cooling Full-Load.[2]
E_V Test—required (steady, wet coil).	80	67	87	[1] 69	Cooling Intermediate.	Cooling Intermediate.[3]
B_1 Test—required (steady, wet coil).	80	67	82	[1] 65	Cooling Minimum	Cooling Minimum.[4]
F_1 Test—required (steady, wet coil).	80	67	67	[1] 53.5	Cooling Minimum	Cooling Minimum.[4]
G_1 Test[5]—optional (steady, dry-coil).	80	([6])	67	.....	Cooling Minimum	Cooling Minimum.[4]
I_1 Test[5]—optional (cyclic, dry-coil).	80	([6])	67	.....	Cooling Minimum	([6]).

[1] The specified test condition only applies if the unit rejects condensate to the outdoor coil.
[2] Defined in section 3.1.4.1 of this appendix.
[3] Defined in section 3.1.4.3 of this appendix.
[4] Defined in section 3.1.4.2 of this appendix.
[5] The entering air must have a low enough moisture content so no condensate forms on the indoor coil. DOE recommends using an indoor air wet bulb temperature of 57 °F or less.
[6] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the G_1 Test.

3.2.5 Cooling Mode Tests for Northern Heat Pumps With Triple-Capacity Compressors

Test triple-capacity, northern heat pumps for the cooling mode in the same way as specified in section 3.2.3 of this appendix for units having a two-capacity compressor.

3.2.6 Tests for an Air Conditioner or Heat Pump Having a Single Indoor Unit Having Multiple Indoor Blowers and Offering Two Stages of Compressor Modulation

Conduct the cooling mode tests specified in section 3.2.3 of this appendix.

3.3 Test Procedures for Steady-State Wet Coil Cooling Mode Tests (the A, A_2, A_1, B, B_2, B_1, E_V, and F_1 Tests)

a. For the pretest interval, operate the test room reconditioning apparatus and the unit to be tested until maintaining equilibrium conditions for at least 30 minutes at the specified section 3.2 test conditions. Use the exhaust fan of the airflow measuring apparatus and, if installed, the indoor blower of the test unit to obtain and then maintain the indoor air volume rate and/or external static pressure specified for the particular test. Continuously record (see section 1.2 of this appendix, Definitions):

(1) The dry-bulb temperature of the air entering the indoor coil,

(2) The water vapor content of the air entering the indoor coil,

(3) The dry-bulb temperature of the air entering the outdoor coil, and

(4) For the section 2.2.4 of this appendix cases where its control is required, the water vapor content of the air entering the outdoor coil.

Refer to section 3.11 of this appendix for additional requirements that depend on the selected secondary test method.

b. After satisfying the pretest equilibrium requirements, make the measurements specified in Table 3 of ANSI/ASHRAE 37–2009 for the indoor air enthalpy method and the user-selected secondary method. Make said Table 3 measurements at equal intervals that span 5 minutes or less. Continue data sampling until reaching a 30-minute period (*e.g.*, seven consecutive 5-minute samples) where the test tolerances specified in Table 9 are satisfied. For those continuously recorded parameters, use the entire data set from the 30-minute interval to evaluate Table 9 compliance. Determine the average electrical power consumption of the air conditioner or heat pump over the same 30-minute interval.

c. Calculate indoor-side total cooling capacity and sensible cooling capacity as specified in sections 7.3.3.1 and 7.3.3.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). To calculate capacity, use the averages of the measurements (*e.g.* inlet and outlet dry bulb and wet bulb temperatures measured at the psychrometers) that are continuously recorded for the same 30-minute interval used as described above to evaluate compliance with test tolerances. Do not adjust the parameters used in calculating capacity for the permitted variations in test conditions. Evaluate air enthalpies based on the measured barometric pressure. Use the values of the specific heat of air given in section 7.3.3.1 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) for calculation of the sensible cooling capacities. Assign the average total space cooling capacity, average sensible cooling capacity,

and electrical power consumption over the 30-minute data collection interval to the variables $\dot{Q}_c^k(T)$, $\dot{Q}_{sc}^k(T)$ and $\dot{E}_c^k(T)$, respectively. For these three variables, replace the ''T'' with the nominal outdoor temperature at which the test was conducted. The superscript k is used only when testing multi-capacity units.

Use the superscript k=2 to denote a test with the unit operating at high capacity or full speed, k=1 to denote low capacity or minimum speed, and k=v to denote the intermediate speed.

d. For coil-only system tests, decrease $\dot{Q}_c^k(T)$ by

$$\frac{1250\ Btu/h}{1000\ scfm} * \overline{\dot{V}}_s$$

and increase $\dot{E}_c^k(T)$ by,

$$\frac{365\ W}{1000\ scfm} * \overline{\dot{V}}_s$$

where $\overline{\dot{V}}_s$ is the average measured indoor air volume rate expressed in units of cubic feet per minute of standard air (scfm).

TABLE 9—TEST OPERATING AND TEST CONDITION TOLERANCES FOR SECTION 3.3 STEADY-STATE WET COIL COOLING MODE TESTS AND SECTION 3.4 DRY COIL COOLING MODE TESTS

	Test operating tolerance [1]	Test condition tolerance [1]
Indoor dry-bulb, °F		
Entering temperature	2.0	0.5
Leaving temperature	2.0	
Indoor wet-bulb, °F		
Entering temperature	1.0	[2] 0.3
Leaving temperature	[2] 1.0	
Outdoor dry-bulb, °F		
Entering temperature	2.0	0.5
Leaving temperature	[3] 2.0	
Outdoor wet-bulb, °F		
Entering temperature	1.0	[4] 0.3
Leaving temperature	[3] 1.0	
External resistance to airflow, inches of water	0.05	[5] 0.02
Electrical voltage, % of rdg.	2.0	1.5
Nozzle pressure drop, % of rdg.	2.0	

[1] See section 1.2 of this appendix, Definitions.

[2] Only applies during wet coil tests; does not apply during steady-state, dry coil cooling mode tests.

[3] Only applies when using the outdoor air enthalpy method.

[4] Only applies during wet coil cooling mode tests where the unit rejects condensate to the outdoor coil.

[5] Only applies when testing non-ducted units.

e. For air conditioners and heat pumps having a constant-air-volume-rate indoor blower, the five additional steps listed below are required if the average of the measured external static pressures exceeds the applicable sections 3.1.4 minimum (or target) external static pressure (ΔP_{min}) by 0.03 inches of water or more.

(1) Measure the average power consumption of the indoor blower motor ($\dot{E}_{fan,1}$) and record the corresponding external static pressure (ΔP_1) during or immediately following the 30-minute interval used for determining capacity.

(2) After completing the 30-minute interval and while maintaining the same test conditions, adjust the exhaust fan of the airflow measuring apparatus until the external static pressure increases to approximately $\Delta P_1 + (\Delta P_1 - \Delta P_{min})$.

(3) After re-establishing steady readings of the fan motor power and external static pressure, determine average values for the indoor blower power ($\dot{E}_{fan,2}$) and the external static pressure (ΔP_2) by making measurements over a 5-minute interval.

(4) Approximate the average power consumption of the indoor blower motor at ΔP_{min} using linear extrapolation:

$$\dot{E}_{fan,\min} = \frac{\dot{E}_{fan,2} - \dot{E}_{fan,1}}{\Delta P_2 - \Delta P_1}(\Delta P_{\min} - \Delta P_1) + \dot{E}_{fan,1}$$

(5) Increase the total space cooling capacity, $\dot{Q}_c^k(T)$, by the quantity $(\dot{E}_{fan,1} - \dot{E}_{fan,min})$, when expressed on a Btu/h basis. Decrease the total electrical power, $\dot{E}_c^k(T)$, by the same fan power difference, now expressed in watts.

3.4 Test Procedures for the Steady-State Dry-Coil Cooling-Mode Tests (the C, C_1, C_2, and G_1 Tests)

a. Except for the modifications noted in this section, conduct the steady-state dry coil cooling mode tests as specified in section 3.3 of this appendix for wet coil tests. Prior to recording data during the steady-state dry coil test, operate the unit at least one hour after achieving dry coil conditions. Drain the drain pan and plug the drain opening. Thereafter, the drain pan should remain completely dry.

b. Denote the resulting total space cooling capacity and electrical power derived from the test as $\dot{Q}_{ss,dry}$ and $\dot{E}_{ss,dry}$. With regard to a section 3.3 deviation, do not adjust $\dot{Q}_{ss,dry}$ for duct losses (*i.e.*, do not apply section 7.3.3.3 of ANSI/ASHRAE 37–2009). In preparing for the section 3.5 cyclic tests of this appendix, record the average indoor-side air volume rate, $\bar{V}$, specific heat of the air, Cp,a (expressed on dry air basis), specific volume of the air at the nozzles, v'_n, humidity ratio at the nozzles, W_n, and either pressure difference or velocity pressure for the flow nozzles. For units having a variable-speed indoor blower (that provides either a constant or variable air volume rate) that will or may be tested during the cyclic dry coil cooling mode test with the indoor blower turned off (see section 3.5 of this appendix), include the electrical power used by the indoor blower motor among the recorded parameters from the 30-minute test.

c. If the temperature sensors used to provide the primary measurement of the indoor-side dry bulb temperature difference during the steady-state dry-coil test and the subsequent cyclic dry-coil test are different, include measurements of the latter sensors among the regularly sampled data. Beginning at the start of the 30-minute data collection period, measure and compute the indoor-side air dry-bulb temperature difference using both sets of instrumentation, ΔT (Set SS) and ΔT (Set CYC), for each equally spaced data sample. If using a consistent data sampling rate that is less than 1 minute, calculate and record minutely averages for the two temperature differences. If using a consistent sampling rate of one minute or more, calculate and record the two temperature differences from each data sample. After having recorded the seventh (i=7) set of temperature differences, calculate the following ratio using the first seven sets of values:

$$F_{CD} = \frac{1}{7}\sum_{i-6}^{i}\frac{\Delta T(Set\ SS)}{\Delta T(Set\ CYC)}$$

Each time a subsequent set of temperature differences is recorded (if sampling more frequently than every 5 minutes), calculate F_{CD} using the most recent seven sets of values. Continue these calculations until the 30-minute period is completed or until a value for F_{CD} is calculated that falls outside the allowable range of 0.94–1.06. If the latter occurs, immediately suspend the test and identify the cause for the disparity in the two temperature difference measurements. Recalibration of one or both sets of instrumentation may be required. If all the values for F_{CD} are within the allowable range, save the final value of the ratio from the 30-minute test as F_{CD}*. If the temperature sensors used to provide the primary measurement of the indoor-side dry bulb temperature difference during the steady-state dry-coil test and the subsequent cyclic dry-coil test are the same, set F_{CD}*= 1.

3.5 Test Procedures for the Cyclic Dry-Coil Cooling-Mode Tests (the D, D_1, D_2, and I_1 Tests)

After completing the steady-state dry-coil test, remove the outdoor air enthalpy method test apparatus, if connected, and begin manual OFF/ON cycling of the unit's compressor. The test set-up should otherwise be identical to the set-up used during the steady-state dry coil test. When testing heat pumps, leave the reversing valve during the

compressor OFF cycles in the same position as used for the compressor ON cycles, unless automatically changed by the controls of the unit. For units having a variable-speed indoor blower, the manufacturer has the option of electing at the outset whether to conduct the cyclic test with the indoor blower enabled or disabled. Always revert to testing with the indoor blower disabled if cyclic testing with the fan enabled is unsuccessful.

a. For all cyclic tests, the measured capacity must be adjusted for the thermal mass stored in devices and connections located between measured points. Follow the procedure outlined in section 7.4.3.4.5 of ASHRAE 116–2010 (incorporated by reference, see §430.3) to ensure any required measurements are taken.

b. For units having a single-speed or two-capacity compressor, cycle the compressor OFF for 24 minutes and then ON for 6 minutes ($\Delta\tau_{cyc,dry}$ = 0.5 hours). For units having a variable-speed compressor, cycle the compressor OFF for 48 minutes and then ON for 12 minutes ($\Delta\tau_{cyc,dry}$ = 1.0 hours). Repeat the OFF/ON compressor cycling pattern until the test is completed. Allow the controls of the unit to regulate cycling of the outdoor fan. If an upturned duct is used, measure the dry-bulb temperature at the inlet of the device at least once every minute and ensure that its test operating tolerance is within 1.0 °F for each compressor OFF period.

c. Sections 3.5.1 and 3.5.2 of this appendix specify airflow requirements through the indoor coil of ducted and non-ducted indoor units, respectively. In all cases, use the exhaust fan of the airflow measuring apparatus (covered under section 2.6 of this appendix) along with the indoor blower of the unit, if installed and operating, to approximate a step response in the indoor coil airflow. Regulate the exhaust fan to quickly obtain and then maintain the flow nozzle static pressure difference or velocity pressure at the same value as was measured during the steady-state dry coil test. The pressure difference or velocity pressure should be within 2 percent of the value from the steady-state dry coil test within 15 seconds after airflow initiation. For units having a variable-speed indoor blower that ramps when cycling on and/or off, use the exhaust fan of the airflow measuring apparatus to impose a step response that begins at the initiation of ramp up and ends at the termination of ramp down.

d. For units having a variable-speed indoor blower, conduct the cyclic dry coil test using the pull-thru approach described below if any of the following occur when testing with the fan operating:

(1) The test unit automatically cycles off;

(2) Its blower motor reverses; or

(3) The unit operates for more than 30 seconds at an external static pressure that is 0.1 inches of water or more higher than the value measured during the prior steady-state test.

For the pull-thru approach, disable the indoor blower and use the exhaust fan of the airflow measuring apparatus to generate the specified flow nozzles static pressure difference or velocity pressure. If the exhaust fan cannot deliver the required pressure difference because of resistance created by the unpowered indoor blower, temporarily remove the indoor blower.

e. Conduct three complete compressor OFF/ON cycles with the test tolerances given in Table 10 satisfied. Calculate the degradation coefficient C_D for each complete cycle. If all three C_D values are within 0.02 of the average C_D then stability has been achieved, and the highest C_D value of these three shall be used. If stability has not been achieved, conduct additional cycles, up to a maximum of eight cycles total, until stability has been achieved between three consecutive cycles. Once stability has been achieved, use the highest C_D value of the three consecutive cycles that establish stability. If stability has not been achieved after eight cycles, use the highest C_D from cycle one through cycle eight, or the default C_D, whichever is lower.

f. With regard to the Table 10 parameters, continuously record the dry-bulb temperature of the air entering the indoor and outdoor coils during periods when air flows through the respective coils. Sample the water vapor content of the indoor coil inlet air at least every 2 minutes during periods when air flows through the coil. Record external static pressure and the air volume rate indicator (either nozzle pressure difference or velocity pressure) at least every minute during the interval that air flows through the indoor coil. (These regular measurements of the airflow rate indicator are in addition to the required measurement at 15 seconds after flow initiation.) Sample the electrical voltage at least every 2 minutes beginning 30 seconds after compressor start-up. Continue until the compressor, the outdoor fan, and the indoor blower (if it is installed and operating) cycle off.

g. For ducted units, continuously record the dry-bulb temperature of the air entering (as noted above) and leaving the indoor coil. Or if using a thermopile, continuously record the difference between these two temperatures during the interval that air flows through the indoor coil. For non-ducted units, make the same dry-bulb temperature measurements beginning when the compressor cycles on and ending when indoor coil airflow ceases.

h. Integrate the electrical power over complete cycles of length $\Delta\tau_{cyc,dry}$. For ducted blower coil systems tested with the unit's indoor blower operating for the cycling test, integrate electrical power from indoor blower OFF to indoor blower OFF. For all other

ducted units and for non-ducted units, integrate electrical power from compressor OFF to compressor OFF. (Some cyclic tests will use the same data collection intervals to determine the electrical energy and the total space cooling. For other units, terminate data collection used to determine the electrical energy before terminating data collection used to determine total space cooling.)

TABLE 10—TEST OPERATING AND TEST CONDITION TOLERANCES FOR CYCLIC DRY COIL COOLING MODE TESTS

	Test operating tolerance [1]	Test condition tolerance [1]
Indoor entering dry-bulb temperature,[2] °F	2.0	0.5
Indoor entering wet-bulb temperature, °F		([3])
Outdoor entering dry-bulb temperature,[2] °F	2.0	0.5
External resistance to airflow,[2] inches of water	0.05	
Airflow nozzle pressure difference or velocity pressure,[2] % of reading	2.0	[4]2.0
Electrical voltage,[5] % of rdg	2.0	1.5

[1] See section 1.2 of this appendix, Definitions.
[2] Applies during the interval that air flows through the indoor (outdoor) coil except for the first 30 seconds after flow initiation. For units having a variable-speed indoor blower that ramps, the tolerances listed for the external resistance to airflow apply from 30 seconds after achieving full speed until ramp down begins.
[3] Shall at no time exceed a wet-bulb temperature that results in condensate forming on the indoor coil.
[4] The test condition shall be the average nozzle pressure difference or velocity pressure measured during the steady-state dry coil test.
[5] Applies during the interval when at least one of the following—the compressor, the outdoor fan, or, if applicable, the indoor blower—are operating except for the first 30 seconds after compressor start-up.

If the Table 10 tolerances are satisfied over the complete cycle, record the measured electrical energy consumption as $e_{cyc,dry}$ and express it in units of watt-hours. Calculate the total space cooling delivered, $q_{cyc,dry}$, in units of Btu using,

$$q_{cyc,dry} = \frac{60*\overline{\dot{V}}*C_{p,a}*\Gamma}{[v_n'*(1+W_n)]} = \frac{60*\overline{\dot{V}}*C_{p,a}*\Gamma}{v_n} \quad \text{and} \quad \Gamma = F_{CD}^{*}\int_{\tau_1}^{\tau_2}[T_{a1}(\tau) - T_{a2}(\tau)]\delta\tau,\ hr*°F$$

Where,

$\overline{\dot{V}}$, $C_{p,a}$, v_n' (or v_n), W_n, and F_{CD}* are the values recorded during the section 3.4 dry coil steady-state test and

$T_{a1}(\tau)$ = dry bulb temperature of the air entering the indoor coil at time τ, °F.

$T_{a2}(\tau)$ = dry bulb temperature of the air leaving the indoor coil at time τ, °F.

τ_1 = for ducted units, the elapsed time when airflow is initiated through the indoor coil; for non-ducted units, the elapsed time when the compressor is cycled on, hr.

τ_2 = the elapsed time when indoor coil airflow ceases, hr.

Adjust the total space cooling delivered, $q_{cyc,dry}$, according to calculation method outlined in section 7.4.3.4.5 of ASHRAE 116–2010 (incorporated by reference, see §430.3).

3.5.1 Procedures When Testing Ducted Systems

The automatic controls that are installed in the test unit must govern the OFF/ON cycling of the air moving equipment on the indoor side (exhaust fan of the airflow measuring apparatus and the indoor blower of the test unit). For ducted coil-only systems rated based on using a fan time-delay relay, control the indoor coil airflow according to the OFF delay listed by the manufacturer in the certification report. For ducted units having a variable-speed indoor blower that has been disabled (and possibly removed), start and stop the indoor airflow at the same instances as if the fan were enabled. For all other ducted coil-only systems, cycle the indoor coil airflow in unison with the cycling of the compressor. If air damper boxes are used, close them on the inlet and outlet side during the OFF period. Airflow through the indoor coil should stop within 3 seconds after the automatic controls of the test unit (act to) de-energize the indoor blower. For ducted coil-only systems (excluding the special case where a variable-speed fan is temporarily removed), increase $e_{cyc,dry}$ by the quantity,

$$\text{Equation 3.5-2.} \qquad \frac{365\ W}{1000\ scfm} * \overline{\dot{V}}_s * [\tau_2 - \tau_1]$$

and decrease $q_{cyc,dry}$ by,

$$\text{Equation 3.5-3.} \qquad \frac{1250\ Btu/h}{1000\ scfm} * \overline{\dot{V}}_s * [\tau_2 - \tau_1]$$

where $\overline{\dot{V}}_s$ is the average indoor air volume rate from the section 3.4 dry coil steady-state test and is expressed in units of cubic feet per minute of standard air (scfm). For units having a variable-speed indoor blower that is disabled during the cyclic test, increase $e_{cyc,dry}$ and decrease $q_{cyc,dry}$ based on:

a. The product of $[\tau_2 - \tau_1]$ and the indoor blower power measured during or following the dry coil steady-state test; or,
b. The following algorithm if the indoor blower ramps its speed when cycling.

(1) Measure the electrical power consumed by the variable-speed indoor blower at a minimum of three operating conditions: At the speed/air volume rate/external static pressure that was measured during the steady-state test, at operating conditions associated with the midpoint of the ramp-up interval, and at conditions associated with the midpoint of the ramp-down interval. For these measurements, the tolerances on the airflow volume or the external static pressure are the same as required for the section 3.4 steady-state test.

(2) For each case, determine the fan power from measurements made over a minimum of 5 minutes.

(3) Approximate the electrical energy consumption of the indoor blower if it had operated during the cyclic test using all three power measurements. Assume a linear profile during the ramp intervals. The manufacturer must provide the durations of the ramp-up and ramp-down intervals. If the test setup instructions included with the unit by the manufacturer specifies a ramp interval that exceeds 45 seconds, use a 45-second ramp interval nonetheless when estimating the fan energy.

3.5.2 Procedures When Testing Non-Ducted Indoor Units

Do not use airflow prevention devices when conducting cyclic tests on non-ducted indoor units. Until the last OFF/ON compressor cycle, airflow through the indoor coil must cycle off and on in unison with the compressor. For the last OFF/ON compressor cycle—the one used to determine $e_{cyc,dry}$ and $q_{cyc,dry}$—use the exhaust fan of the airflow measuring apparatus and the indoor blower of the test unit to have indoor airflow start 3 minutes prior to compressor cut-on and end three minutes after compressor cutoff. Subtract the electrical energy used by the indoor blower during the 3 minutes prior to compressor cut-on from the integrated electrical energy, $e_{cyc,dry}$. Add the electrical energy used by the indoor blower during the 3 minutes after compressor cutoff to the integrated cooling capacity, $q_{cyc,dry}$. For the case where the non-ducted indoor unit uses a variable-speed indoor blower which is disabled during the cyclic test, correct $e_{cyc,dry}$ and $q_{cyc,dry}$ using the same approach as prescribed in section 3.5.1 of this appendix for ducted units having a disabled variable-speed indoor blower.

3.5.3 Cooling-Mode Cyclic-Degradation Coefficient Calculation

Use the two dry-coil tests to determine the cooling-mode cyclic-degradation coefficient, C_D^c. Append ''(k=2)'' to the coefficient if it corresponds to a two-capacity unit cycling at high capacity. If the two optional tests are conducted but yield a tested CD^c that exceeds the default CD^c or if the two optional tests are not conducted, assign CD^c the default value of 0.25 for variable-speed compressor systems and outdoor units with no match, and 0.20 for all other systems. The default value for two-capacity units cycling at high capacity, however, is the low-capacity coefficient, *i.e.*, $C_D^c(k=2) = C_D^c$. Evaluate C_D^c using the above results and those from the section 3.4 dry-coil steady-state test.

$$C_D^c = \frac{1 - \frac{EER_{cyc,dry}}{EER_{ss,dry}}}{1 - CLF}$$

where:

$$EER_{cyc,dry} = \frac{q_{cyc,dry}}{e_{cyc,dry}}$$

the average energy efficiency ratio during the cyclic dry coil cooling mode test, Btu/W·h

$$EER_{ss,dry} = \frac{\dot{Q}_{ss,dry}}{\dot{E}_{ss,dry}}$$

the average energy efficiency ratio during the steady-state dry coil cooling mode test, Btu/W·h

$$CLF = \frac{q_{cyc,dry}}{Q_{ss,dry} * \Delta\tau_{cyc,dry}}$$

the cooling load factor dimensionless

Round the calculated value for C_D^c to the nearest 0.01. If C_D^c is negative, then set it equal to zero.

3.6 Heating Mode Tests for Different Types of Heat Pumps, Including Heating-Only Heat Pumps

3.6.1 Tests for a Heat Pump Having a Single-Speed Compressor and Fixed Heating Air Volume Rate

This set of tests is for single-speed-compressor heat pumps that do not have a heating minimum air volume rate or a heating intermediate air volume rate that is different than the heating full load air volume rate. Conduct the optional high temperature cyclic (H1C) test to determine the heating mode cyclic-degradation coefficient, C_D^h. If this optional test is conducted but yields a tested C_D^h that exceeds the default C_D^h or if the optional test is not conducted, assign C_D^h the default value of 0.25. Test conditions for the four tests are specified in Table 10.

TABLE 11—HEATING MODE TEST CONDITIONS FOR UNITS HAVING A SINGLE-SPEED COMPRESSOR AND A FIXED-SPEED INDOOR BLOWER, A CONSTANT AIR VOLUME RATE INDOOR BLOWER, OR NO INDOOR BLOWER

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
H1 Test (required, steady)	70	60 (max)	47	43	Heating Full-load.[1]
H1C Test (optional, cyclic)	70	60 (max)	47	43	([2])
H2 Test (required)	70	60 (max)	35	33	Heating Full-load.[1]
H3 Test (required, steady)	70	60 (max)	17	15	Heating Full-load.[1]

[1] Defined in section 3.1.4.4 of this appendix.f[2] Maintain the airflow nozzles static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the H1 Test.

3.6.2 Tests for a Heat Pump Having a Single-Speed Compressor and a Single Indoor Unit Having Either (1) a Variable Speed, Variable-Air-Rate Indoor Blower Whose Capacity Modulation Correlates With Outdoor Dry Bulb Temperature or (2) Multiple Indoor Blowers

Conduct five tests: Two high temperature tests ($H1_2$ and $H1_1$), one frost accumulation test ($H2_2$), and two low temperature tests ($H3_2$ and $H3_1$). Conducting an additional frost accumulation test ($H2_1$) is optional. Conduct the optional high temperature cyclic ($H1C_1$) test to determine the heating mode cyclic-degradation coefficient, C_D^h. If this optional test is conducted but yields a tested C_D^h that exceeds the default C_D^h or if the optional test is not conducted, assign C_D^h the default value of 0.25. Test conditions for the seven tests are specified in Table 12. If the optional $H2_1$ test is not performed, use the following equations to approximate the capacity and electrical power of the heat pump at the $H2_1$ test conditions:

$$\dot{Q}_h^{k=1}(35) = QR_h^{k=2}(35) * \left\{\dot{Q}_h^{k=1}(17) + 0.6 * \left[\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(17)\right]\right\}$$

$$\dot{E}_h^{k=1}(35) = PR_h^{k=2}(35) * \left\{\dot{E}_h^{k=1}(17) + 0.6 * \left[\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(17)\right]\right\}$$

where:

$$\dot{Q}R_h^{k=2}(35) = \frac{\dot{Q}_h^{k=2}(35)}{\dot{Q}^{k=2}(17) + 0.6 * [\dot{Q}_h^{k=2}(47) - \dot{Q}_h^{k=2}(17)]}$$

$$PR_h^{k=2}(35) = \frac{\dot{E}_h^{k=2}(35)}{\dot{E}_h^{k=2}(17) + 0.6 * \left[\dot{E}_h^{k=2}(47) - \dot{E}_h^{k=2}(17)\right]}$$

The quantities $\dot{Q}_h^{k=2}(47)$, $\dot{E}_h^{k=2}(47)$, $\dot{Q}_h^{k=1}(47)$, and $\dot{E}_h^{k=1}(47)$ are determined from the $H1_2$ and $H1_1$ tests and evaluated as specified in section 3.7 of this appendix; the quantities $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ are determined from the $H2_2$ test and evaluated as specified in section 3.9 of this appendix; and the quantities $\dot{Q}_h^{k=2}(17)$, $\dot{E}_h^{k=2}(17)$, $\dot{Q}_h^{k=1}(17)$, and $\dot{E}_h^{k=1}(17)$, are determined from the $H3_2$ and $H3_1$ tests and evaluated as specified in section 3.10 of this appendix.

TABLE 12—TABLE HEATING MODE TEST CONDITIONS FOR UNITS WITH A SINGLE-SPEED COMPRESSOR THAT MEET THE SECTION 3.6.2 INDOOR UNIT REQUIREMENTS

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
$H1_2$ Test (required, steady)	70	60 (max)	47	43	Heating Full-load.[1]
$H1_1$ Test (required, steady)	70	60 (max)	47	43	Heating Minimum.[2]
$H1C_1$ Test (optional, cyclic)	70	60 (max)	47	43	[3]
$H2_2$ Test (required)	70	60 (max)	35	33	Heating Full-load.[1]
$H2_1$ Test (optional)	70	60 (max)	35	33	Heating Minimum.[2]
$H3_2$ Test (required, steady)	70	60 (max)	17	15	Heating Full-load.[1]
$H3_1$ Test (required, steady)	70	60 (max)	17	15	Heating Minimum.[2]

[1] Defined in section 3.1.4.4 of this appendix.
[2] Defined in section 3.1.4.5 of this appendix.
[3] Maintain the airflow nozzles static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the $H1_1$ test.

3.6.3 Tests for a Heat Pump Having a Two-Capacity Compressor (see section 1.2 of this appendix, Definitions), Including Two-Capacity, Northern Heat Pumps (see section 1.2 of this appendix, Definitions)

a. Conduct one maximum temperature test ($H0_1$), two high temperature tests ($H1_2$and $H1_1$), one frost accumulation test ($H2_2$), and one low temperature test ($H3_2$). Conduct an additional frost accumulation test ($H2_1$) and low temperature test ($H3_1$) if both of the following conditions exist:

(1) Knowledge of the heat pump's capacity and electrical power at low compressor capacity for outdoor temperatures of 37 °F and less is needed to complete the section 4.2.3 of this appendix seasonal performance calculations; and

(2) The heat pump's controls allow low-capacity operation at outdoor temperatures of 37 °F and less.

If the above two conditions are met, an alternative to conducting the $H2_1$ frost accumulation is to use the following equations to approximate the capacity and electrical power:

$$\dot{Q}_h^{k=1}(35) = 0.90 * \left\{\dot{Q}_h^{k=1}(17) + 0.6 * \left[\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(17)\right]\right\}$$

$$\dot{E}_h^{k=1}(35) = 0.985 * \left\{\dot{E}_h^{k=1}(17) + 0.6 * \left[\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(17)\right]\right\}$$

Determine the quantities $\dot{Q}_h^{k=1}$ (47) and $\dot{E}_h^{k=1}$ (47) from the $H1_1$ test and evaluate them according to section 3.7 of this appendix. Determine the quantities $\dot{Q}_h^{k=1}$ (17) and $\dot{E}_h^{k=1}$ (17) from the $H3_1$ test and evaluate them according to section 3.10 of this appendix.

b. Conduct the optional high temperature cyclic test ($H1C_1$) to determine the heating mode cyclic-degradation coefficient, C_D^h. If this optional test is conducted but yields a tested C_D^h that exceeds the default C_D^h or if the optional test is not conducted, assign C_D^h the default value of 0.25. If a two-capacity heat pump locks out low capacity operation at lower outdoor temperatures, conduct the high temperature cyclic test ($H1C_2$) to determine the high-capacity heating mode cyclic-degradation coefficient, C_D^h (k=2). If this optional test at high capacity is conducted but yields a tested C_D^h (k = 2) that exceeds the default C_D^h (k = 2) or if the optional test is not conducted, assign C_D^h the default value. The default C_D^h (k=2) is the same value as determined or assigned for the low-capacity cyclic-degradation coefficient, C_D^h [or equivalently, C_D^h (k=1)]. Table 13 specifies test conditions for these nine tests.

TABLE 13—HEATING MODE TEST CONDITIONS FOR UNITS HAVING A TWO-CAPACITY COMPRESSOR

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor capacity	Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
$H0_1$ Test (required, steady)	70	60 (max)	62	56.5	Low	Heating Minimum.[1]
$H1_2$ Test (required, steady)	70	60 (max)	47	43	High	Heating Full-Load.[2]
$H1C_2$ Test (optional[7], cyclic)	70	60 (max)	47	43	High	([3])
$H1_1$ Test (required)	70	60 (max)	47	43	Low	Heating Minimum.[1]
$H1C_1$ Test (optional, cyclic)	70	60 (max)	47	43	Low	([4])
$H2_2$ Test (required)	70	60 (max)	35	33	High	Heating Full-Load.[2]
$H2_1$ Test[5 6] (required)	70	60 (max)	35	33	Low	Heating Minimum.[1]
$H3_2$ Test (required, steady)	70	60 (max)	17	15	High	Heating Full-Load.[2]
$H3_1$ Test[5] (required, steady)	70	60 (max)	17	15	Low	Heating Minimum.[1]

[1] Defined in section 3.1.4.5 of this appendix.
[2] Defined in section 3.1.4.4 of this appendix.
[3] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the $H1_2$ test.
[4] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the $H1_1$ test.
[5] Required only if the heat pump's performance when operating at low compressor capacity and outdoor temperatures less than 37 °F is needed to complete the section 4.2.3 *HSPF* calculations.
[6] If table note #5 applies, the section 3.6.3 equations for $\dot{Q}_h^{k=1}$ (35) and $\dot{E}_h^{k=1}$ (17) may be used in lieu of conducting the $H2_1$ test.
[7] Required only if the heat pump locks out low capacity operation at lower outdoor temperatures.

3.6.4 Tests for a Heat Pump Having a Variable-Speed Compressor

a. Conduct one maximum temperature test ($H0_1$), two high temperature tests ($H1_N$ and $H1_1$), one frost accumulation test ($H2_V$), and one low temperature test ($H3_2$). Conducting one or both of the following tests is optional: An additional high temperature test ($H1_2$) and an additional frost accumulation test ($H2_2$). If desired, conduct the optional maximum temperature cyclic ($H0C_1$) test to determine the heating mode cyclic-degradation coefficient, C_D^h. If this optional test is conducted but yields a tested C_D^h that exceeds the default C_D^h or if the optional test is not conducted, assign C_D^h the default value of 0.25. Test conditions for the eight tests are specified in Table 14 to this appendix. The compressor shall operate at the same heating full speed, measured by RPM or power input frequency (Hz), for the $H1_2$, $H2_2$ and $H3_2$ tests. For a cooling/heating heat pump, the compressor shall operate for the $H1_N$ test at a speed, measured by RPM or power input frequency (Hz), no lower than the speed used in the A_2 test if the tested $H1_N$ heating capacity is less than the tested A_2 cooling capacity. The compressor shall operate at the same heating minimum speed, measured by RPM or power input frequency (Hz), for the $H0_1$, $H1C_1$, and $H1_1$ tests. Determine the heating intermediate compressor speed cited in Table 14 using the heating mode full and minimum compressors speeds and:

$$Heating\ intermediate\ speed = Heating\ minimum\ speed + \frac{Heating\ full\ speed - Heating\ minimum\ speed}{3}$$

Where a tolerance on speed of plus 5 percent or the next higher inverter frequency step from the calculated value is allowed.

b. If the $H1_2$ test is conducted, set the 47 °F capacity and power input values used for calculation of HSPF equal to the measured values for that test:

$$\dot{Q}_{hcalc}^{k=2}(47) = \dot{Q}_h^{k=2}(47);\ \dot{E}_{hcalc}^{k=2}(47) = \dot{E}_h^{k=2}(47)$$

Where:

$\dot{Q}_{hcalc}^{k=2}(47)$ and $\dot{E}_{hcalc}^{k=2}(47)$ are the capacity and power input representing full-speed operation at 47 °F for the HSPF calculations,

$\dot{Q}_h^{k=2}(47)$ is the capacity measured in the $H1_2$ test, and

$\dot{E}_h^{k=2}(47)$ is the power input measured in the $H1_2$ test.

Evaluate the quantities $\dot{Q}_h^{k=2}(47)$ and from $\dot{E}_h^{k=2}(47)$ according to section 3.7.

Otherwise, if the $H1_N$ test is conducted using the same compressor speed (RPM or power input frequency) as the $H3_2$ test, set the 47 °F capacity and power input values used for calculation of HSPF equal to the measured values for that test:

$$\dot{Q}_{hcalc}^{k=2}(47) = \dot{Q}_h^{k=N}(47);\ \dot{E}_{hcalc}^{k=2}(47) = \dot{E}_h^{k=N}(47)$$

Where:

$\dot{Q}_{hcalc}^{k=2}(47)$ and $\dot{E}_{hcalc}^{k=2}(47)$ are the capacity and power input representing full-speed operation at 47 °F for the HSPF calculations,

$\dot{Q}_h^{k=N}(47)$ is the capacity measured in the $H1_N$ test, and

$\dot{E}_h^{k=N}(47)$ is the power input measured in the $H1_N$ test.

Evaluate the quantities $\dot{Q}_h^{k=N}(47)$ and from $\dot{E}_h^{k=N}(47)$ according to section 3.7.

Otherwise (if no high temperature test is conducted using the same speed (RPM or power input frequency) as the $H3_2$ test), calculate the 47 °F capacity and power input values used for calculation of HSPF as follows:

$$\dot{Q}_{hcalc}^{k=2}(47) = \dot{Q}_{h}^{k=2}(17) * (1 + 30^{\circ}F * CSF);$$

$$\dot{E}_{hcalc}^{k=2}(47) = \dot{E}_{h}^{k=2}(17) * (1 + 30^{\circ}F * PSF)$$

Where:

$\dot{Q}_{hcalc}^{k=2}(47)$ and $\dot{E}_{hcalc}^{k=2}(47)$ are the capacity and power input representing full-speed operation at 47 °F for the HSPF calculations,

$\dot{Q}_{h}^{k=2}(17)$ is the capacity measured in the $H3_2$ test,

$\dot{E}_{h}^{k=2}(17)$ is the power input measured in the $H3_2$ test,

CSF is the capacity slope factor, equal to 0.0204/ °F for split systems and 0.0262/ °F for single-package systems, and

PSF is the Power Slope Factor, equal to 0.00455/ °F.

c. If the $H2_2$ test is not done, use the following equations to approximate the capacity and electrical power at the $H2_2$ test conditions:

$$\dot{Q}_{h}^{k=2}(35) = 0.90 * \left\{\dot{Q}_{h}^{k=2}(17) + 0.6 * \left[\dot{Q}_{hcalc}^{k=2}(47) - \dot{Q}_{h}^{k=2}(17)\right]\right\}$$

$$\dot{E}_{h}^{k=2}(35) = 0.985 * \left\{\dot{E}_{h}^{k=2}(17) + 0.6 * \left[\dot{E}_{hcalc}^{k=2}(47) - \dot{E}_{h}^{k=2}(17)\right]\right\}$$

Where:

$\dot{Q}_{hcalc}^{k=2}(47)$ and $\dot{E}_{hcalc}^{k=2}(47)$ are the capacity and power input representing full-speed operation at 47 °F for the HSPF calculations, calculated as described in section b above.

$\dot{Q}_{h}^{k=2}(17)$ and $\dot{E}_{h}^{k=2}(17)$ are the capacity and power input measured in the $H3_2$ test.

d. Determine the quantities $\dot{Q}_{h}^{k=2}(17)$ and $\dot{E}_{h}^{k=2}(17)$ from the $H3_2$ test, determine the quantities $\dot{Q}_{h}^{k=2}(5)$ and $\dot{E}_{h}^{k=2}(5)$ from the $H4_2$ test, and evaluate all four according to section 3.10.

TABLE 14—HEATING MODE TEST CONDITIONS FOR UNITS HAVING A VARIABLE-SPEED COMPRESSOR

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor speed	Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
$H0_1$ test (required, steady)	70	$60^{(max)}$	62	56.5	Heating minimum	Heating minimum.[1]
$H1_2$ test (optional, steady)	70	$60^{(max)}$	47	43	Heating full[4]	Heating full-load.[3]
$H1_1$ test (required, steady)	70	$60^{(max)}$	47	43	Heating minimum	Heating minimum.[1]
$H1_N$ test (required, steady)	70	$60^{(max)}$	47	43	Heating full	Heating full-load.[3]
$H1C_1$ test (optional, cyclic)	70	$60^{(max)}$	47	43	Heating minimum	([2])
$H2_2$ test (optional)	70	$60^{(max)}$	35	33	Heating full[4]	Heating full-load.[3]
$H2_V$ test (required)	70	$60^{(max)}$	35	33	Heating intermediate	Heating intermediate.[5]
$H3_2$ test (required, steady)	70	$60^{(max)}$	17	15	Heating full	Heating full-load.[3]

[1] Defined in section 3.1.4.5 of this appendix.
[2] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during an ON period at the same pressure or velocity as measured during the $H1_1$ test.
[3] Defined in section 3.1.4.4 of this appendix.
[4] The same compressor speed used in the $H3_2$ test. The $H1_2$ test is not needed if the $H1_N$ test uses this same compressor speed.
[5] Defined in section 3.1.4.6 of this appendix.

3.6.5 Additional Test for a Heat Pump Having a Heat Comfort Controller

Test any heat pump that has a heat comfort controller (see section 1.2 of this appendix, Definitions) according to section 3.6.1, 3.6.2, or 3.6.3, whichever applies, with the heat comfort controller disabled. Additionally, conduct the abbreviated test described in section 3.1.10 of this appendix with the heat comfort controller active to determine the system's maximum supply air temperature. (NOTE: Heat pumps having a variable speed compressor and a heat comfort controller are not covered in the test procedure at this time.)

3.6.6 Heating Mode Tests for Northern Heat Pumps With Triple-Capacity Compressors.

Test triple-capacity, northern heat pumps for the heating mode as follows:

a. Conduct one maximum-temperature test ($H0_1$), two high-temperature tests ($H1_2$ and $H1_1$), one frost accumulation test ($H2_2$), two low-temperature tests ($H3_2$, $H3_3$), and one minimum-temperature test ($H4_3$). Conduct an additional frost accumulation test ($H2_1$) and low-temperature test ($H3_1$) if both of the following conditions exist: (1) Knowledge of the heat pump's capacity and electrical power at low compressor capacity for outdoor temperatures of 37 °F and less is needed to complete the section 4.2.6 seasonal performance calculations; and (2) the heat pump's controls allow low-capacity operation at outdoor temperatures of 37 °F and less. If the above two conditions are met, an alternative to conducting the $H2_1$ frost accumulation test to determine $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ is to use the following equations to approximate this capacity and electrical power:

$$\dot{Q}_h^{k=1}(35) = 0.90 * \left\{\dot{Q}_h^{k=1}(17) + 0.6 * \left[\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(17)\right]\right\}$$

$$\dot{E}_h^{k=1}(35) = 0.985 * \left\{\dot{E}_h^{k=1}(17) + 0.6 * \left[\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(17)\right]\right\}$$

In evaluating the above equations, determine the quantities $\dot{Q}_h^{k=1}(47)$ from the $H1_1$ test and evaluate them according to section 3.7 of this appendix. Determine the quantities $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ from the $H3_1$ test and evaluate them according to section 3.10 of this appendix. Use the paired values of $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ derived from conducting the $H2_1$ frost accumulation test and evaluated as specified in section 3.9.1 of this appendix or use the paired values calculated using the above default equations, whichever contribute to a higher Region IV HSPF based on the DHRmin.

b. Conducting a frost accumulation test ($H2_3$) with the heat pump operating at its booster capacity is optional. If this optional test is not conducted, determine $\dot{Q}_h^{k=3}(35)$ and $\dot{E}_h^{k=3}(35)$ using the following equations to approximate this capacity and electrical power:

$$\dot{Q}_h^{k=3}(35) = QR_h^{k=2}(35) * \left\{\dot{Q}_h^{k=3}(17) + 1.20 * \left[\dot{Q}_h^{k=3}(17) - \dot{Q}_h^{k=3}(5)\right]\right\}$$

$$\dot{E}_h^{k=3}(35) = PR_h^{k=2}(35) * \left\{\dot{E}_h^{k=3}(17) + 1.20 * \left[\dot{E}_h^{k=3}(17) - \dot{E}_h^{k=3}(5)\right]\right\}$$

Where:

$$QR_h^{k=2}(35) = \frac{\dot{Q}_h^{k=2}(35)}{\dot{Q}_h^{k=2}(17) + 0.6 * \left[\dot{Q}_h^{k=2}(47) - \dot{Q}_h^{k=2}(17)\right]}$$

$$PR_h^{k=2}(35) = \frac{\dot{E}_h^{k=2}(35)}{\dot{E}_h^{k=2}(17) + 0.6 * \left[\dot{E}_h^{k=2}(47) - \dot{E}_h^{k=2}(17)\right]}$$

Determine the quantities $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the $H1_2$ test and evaluate them according to section 3.7 of this appendix. Determine the quantities $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the $H2_2$ test and evaluate them according to section 3.9.1 of this appendix. Determine the quantities $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test, determine the quantities $\dot{Q}_h^{k=3}(17)$ and $\dot{E}_h^{k=3}(17)$ from the $H3_3$ test, and determine the quantities $\dot{Q}_h^{k=3}(5)$ and $\dot{E}_h^{k=3}(5)$

from the $H4_3$ test. Evaluate all six quantities according to section 3.10 of this appendix. Use the paired values of $\dot{Q}_h^{k=3}(35)$ and $\dot{E}_h^{k=3}(35)$ derived from conducting the $H2_3$ frost accumulation test and calculated as specified in section 3.9.1 of this appendix or use the paired values calculated using the above default equations, whichever contribute to a higher Region IV HSPF based on the DHRmin.

c. Conduct the optional high-temperature cyclic test ($H1C_1$) to determine the heating mode cyclic-degradation coefficient, C_D^h. A default value for C_D^h may be used in lieu of conducting the cyclic. The default value of C_D^h is 0.25. If a triple-capacity heat pump locks out low capacity operation at lower outdoor temperatures, conduct the high-temperature cyclic test ($H1C_2$) to determine the high-capacity heating mode cyclic-degradation coefficient, C_D^h (k=2). The default C_D^h (k=2) is the same value as determined or assigned for the low-capacity cyclic-degradation coefficient, C_D^h [or equivalently, C_D^h (k=1)]. Finally, if a triple-capacity heat pump locks out both low and high capacity operation at the lowest outdoor temperatures, conduct the low-temperature cyclic test ($H3C_3$) to determine the booster-capacity heating mode cyclic-degradation coefficient, C_D^h (k=3). The default C_D^h (k=3) is the same value as determined or assigned for the high-capacity cyclic-degradation coefficient, C_D^h [or equivalently, C_D^h (k=2)]. Table 15 specifies test conditions for all 13 tests.

TABLE 15—HEATING MODE TEST CONDITIONS FOR UNITS WITH A TRIPLE-CAPACITY COMPRESSOR

Test description	Air entering indoor unit temperature deg;F		Air entering outdoor unit temperature deg;F		Compressor capacity	Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
$H0_1$ Test (required, steady)	70	60(max)	62	56.5	Low	Heating Minimum.[1]
$H1_2$ Test (required, steady)	70	60(max)	47	43	High	Heating Full-Load.[2]
$H1C_2$ Test (optional,[8] cyclic)	70	60(max)	47	43	High	([3]).
$H1_1$ Test (required)	70	60(max)	47	43	Low	Heating Minimum.[1]
$H1C_1$ Test (optional, cyclic)	70	60(max)	47	43	Low	([4]).
$H2_3$ Test (optional, steady)	70	60(max)	35	33	Booster	Heating Full-Load.[2]
$H2_2$ Test (required)	70	60(max)	35	33	High	Heating Full-Load.[2]
$H2_1$ Test (required)	70	60(max)	35	33	Low	Heating Minimum.[1]
$H3_3$ Test (required, steady)	70	60(max)	17	15	Booster	Heating Full-Load.[2]
$H3C_3$ Test[5 6] (optional, cyclic)	70	60(max)	17	15	Booster	([7]).
$H3_2$ Test (required, steady)	70	60(max)	17	15	High	Heating Full-Load.[2]
$H3_1$ Test[5] (required, steady)	70	60(max)	17	15	Low	Heating Minimum.[1]
$H4_3$ Test (required, steady)	70	60(max)	5	3(max)	Booster	Heating Full-Load.[2]

[1] Defined in section 3.1.4.5 of this appendix.
[2] Defined in section 3.1.4.4 of this appendix.
[3] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the $H1_2$ test.
[4] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the $H1_1$ test.
[5] Required only if the heat pump's performance when operating at low compressor capacity and outdoor temperatures less than 37 °F is needed to complete the section 4.2.6 HSPF calculations.
[6] If table note [5] applies, the section 3.6.6 equations for $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(17)$ may be used in lieu of conducting the $H2_1$ test.
[7] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the $H3_3$ test.
[8] Required only if the heat pump locks out low capacity operation at lower outdoor temperatures.

3.6.7 Tests for a Heat Pump Having a Single Indoor Unit Having Multiple Indoor Blowers and Offering Two Stages of Compressor Modulation

Conduct the heating mode tests specified in section 3.6.3 of this appendix.

3.7 Test Procedures for Steady-State Maximum Temperature and High Temperature Heating Mode Tests (the $H0_1$, H1, $H1_2$, $H1_1$, and $H1_N$ Tests)

a. For the pretest interval, operate the test room reconditioning apparatus and the heat pump until equilibrium conditions are maintained for at least 30 minutes at the specified section 3.6 test conditions. Use the exhaust fan of the airflow measuring apparatus and, if installed, the indoor blower of the heat pump to obtain and then maintain the indoor air volume rate and/or the external static pressure specified for the particular test. Continuously record the dry-bulb temperature of the air entering the indoor coil, and the dry-bulb temperature and water vapor content of the air entering the outdoor coil. Refer to section 3.11 of this appendix for additional requirements that depend on the selected secondary test method. After satisfying the pretest equilibrium requirements, make the measurements specified in Table 3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) for the indoor air enthalpy method and the user-selected secondary method. Make said Table 3 measurements at equal intervals that span 5 minutes

or less. Continue data sampling until a 30-minute period (*e.g.*, seven consecutive 5-minute samples) is reached where the test tolerances specified in Table 16 are satisfied. For those continuously recorded parameters, use the entire data set for the 30-minute interval when evaluating Table 16 compliance. Determine the average electrical power consumption of the heat pump over the same 30-minute interval.

TABLE 16—TEST OPERATING AND TEST CONDITION TOLERANCES FOR SECTION 3.7 AND SECTION 3.10 STEADY-STATE HEATING MODE TESTS

	Test operating tolerance [1]	Test condition tolerance [1]
Indoor dry-bulb, °F:		
Entering temperature	2.0	0.5
Leaving temperature	2.0	
Indoor wet-bulb, °F:		
Entering temperature	1.0	
Leaving temperature	1.0	
Outdoor dry-bulb, °F:		
Entering temperature	2.0	0.5
Leaving temperature	[2] 2.0	
Outdoor wet-bulb, °F:		
Entering temperature	1.0	0.3
Leaving temperature	[2] 1.0	
External resistance to airflow, inches of water	0.05	[3] 0.02
Electrical voltage, % of rdg	2.0	1.5
Nozzle pressure drop, % of rdg	2.0	

[1] See section 1.2 of this appendix, Definitions.
[2] Only applies when the Outdoor Air Enthalpy Method is used.
[3] Only applies when testing non-ducted units.

b. Calculate indoor-side total heating capacity as specified in sections 7.3.4.1 and 7.3.4.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3). To calculate capacity, use the averages of the measurements (*e.g.* inlet and outlet dry bulb temperatures measured at the psychrometers) that are continuously recorded for the same 30-minute interval used as described above to evaluate compliance with test tolerances. Do not adjust the parameters used in calculating capacity for the permitted variations in test conditions. Assign the average space heating capacity and electrical power over the 30-minute data collection interval to the variables $\dot{Q}_h^k$ and $\dot{E}_h^k(T)$ respectively. The ''T'' and superscripted ''k'' are the same as described in section 3.3 of this appendix. Additionally, for the heating mode, use the superscript to denote results from the optional $H1_N$ test, if conducted.

c. For coil-only system heat pumps, increase $\dot{Q}_h^k(T)$ by

$$\frac{1250\ BTU/h}{1000\ scfm} * \bar{\dot{V}}_s$$

and increase $\dot{E}_h^k(T)$ by,

$$\frac{365\ W}{1000\ scfm} * \bar{\dot{V}}_s$$

where $\bar{\dot{V}}_s$ is the average measured indoor air volume rate expressed in units of cubic feet per minute of standard air (scfm). During the 30-minute data collection interval of a high temperature test, pay attention to preventing a defrost cycle. Prior to this time, allow the heat pump to perform a defrost cycle if automatically initiated by its own controls. As in all cases, wait for the heat pump's defrost controls to automatically terminate the defrost cycle. Heat pumps that undergo a defrost should operate in the heating mode for at least 10 minutes after defrost termination prior to beginning the 30-minute data collection interval. For some heat pumps, frost may accumulate on the outdoor

coil during a high temperature test. If the indoor coil leaving air temperature or the difference between the leaving and entering air temperatures decreases by more than 1.5 °F over the 30-minute data collection interval, then do not use the collected data to determine capacity. Instead, initiate a defrost cycle. Begin collecting data no sooner than 10 minutes after defrost termination. Collect 30 minutes of new data during which the Table 16 test tolerances are satisfied. In this case, use only the results from the second 30-minute data collection interval to evaluate $\dot{Q}_h^k(47)$ and $\dot{E}_h^k(47)$.

d. If conducting the cyclic heating mode test, which is described in section 3.8 of this appendix, record the average indoor-side air volume rate, $\dot{V}$, specific heat of the air, $C_{p,a}$ (expressed on dry air basis), specific volume of the air at the nozzles, v_n' (or v_n), humidity ratio at the nozzles, W_n, and either pressure difference or velocity pressure for the flow nozzles. If either or both of the below criteria apply, determine the average, steady-state, electrical power consumption of the indoor blower motor ($\dot{E}_{fan,1}$):

(1) The section 3.8 cyclic test will be conducted and the heat pump has a variable-speed indoor blower that is expected to be disabled during the cyclic test; or

(2) The heat pump has a (variable-speed) constant-air volume-rate indoor blower and during the steady-state test the average external static pressure (ΔP_1) exceeds the applicable section 3.1.4.4 minimum (or targeted) external static pressure (ΔP_{min}) by 0.03 inches of water or more.

Determine $\dot{E}_{fan,1}$ by making measurements during the 30-minute data collection interval, or immediately following the test and prior to changing the test conditions. When the above ''2'' criteria applies, conduct the following four steps after determining $\dot{E}_{fan,1}$ (which corresponds to ΔP_1):

(i) While maintaining the same test conditions, adjust the exhaust fan of the airflow measuring apparatus until the external static pressure increases to approximately $\Delta P_1 + (\Delta P_1 - \Delta P_{min})$.

(ii) After re-establishing steady readings for fan motor power and external static pressure, determine average values for the indoor blower power ($\dot{E}_{fan,2}$) and the external static pressure (ΔP_2) by making measurements over a 5-minute interval.

(iii) Approximate the average power consumption of the indoor blower motor if the 30-minute test had been conducted at ΔP_{min} using linear extrapolation:

$$\dot{E}_{fan,\min} = \frac{\dot{E}_{fan,2} - \dot{E}_{fan,1}}{\Delta P_2 - \Delta P_1}(\Delta P_{\min} - \Delta P_1) + \dot{E}_{fan,1}$$

(iv) Decrease the total space heating capacity, $\dot{Q}_h^k(T)$, by the quantity ($\dot{E}_{fan,1} - \dot{E}_{fan,min}$), when expressed on a Btu/h basis. Decrease the total electrical power, $\dot{E}_h^k(T)$ by the same fan power difference, now expressed in watts.

e. If the temperature sensors used to provide the primary measurement of the indoor-side dry bulb temperature difference during the steady-state dry-coil test and the subsequent cyclic dry-coil test are different, include measurements of the latter sensors among the regularly sampled data. Beginning at the start of the 30-minute data collection period, measure and compute the indoor-side air dry-bulb temperature difference using both sets of instrumentation, ΔT (Set SS) and ΔT (Set CYC), for each equally spaced data sample. If using a consistent data sampling rate that is less than 1 minute, calculate and record minutely averages for the two temperature differences. If using a consistent sampling rate of one minute or more, calculate and record the two temperature differences from each data sample. After having recorded the seventh (i=7) set of temperature differences, calculate the following ratio using the first seven sets of values:

$$F_{CD} = \frac{1}{7}\sum_{i-6}^{i}\frac{\Delta T(Set\ SS)}{\Delta T(Set\ CYC)}$$

Each time a subsequent set of temperature differences is recorded (if sampling more frequently than every 5 minutes), calculate F_{CD} using the most recent seven sets of values. Continue these calculations until the 30-minute period is completed or until a value

for F_{CD} is calculated that falls outside the allowable range of 0.94–1.06. If the latter occurs, immediately suspend the test and identify the cause for the disparity in the two temperature difference measurements. Recalibration of one or both sets of instrumentation may be required. If all the values for F_{CD} are within the allowable range, save the final value of the ratio from the 30-minute test as F_{CD}*. If the temperature sensors used to provide the primary measurement of the indoor-side dry bulb temperature difference during the steady-state dry-coil test and the subsequent cyclic dry-coil test are the same, set F_{CD}*= 1.

3.8 Test Procedures for the Cyclic Heating Mode Tests (the H0C$_1$, H1C, H1C$_1$ and H1C$_2$ Tests)

a. Except as noted below, conduct the cyclic heating mode test as specified in section 3.5 of this appendix. As adapted to the heating mode, replace section 3.5 references to ''the steady-state dry coil test'' with ''the heating mode steady-state test conducted at the same test conditions as the cyclic heating mode test.'' Use the test tolerances in Table 17 rather than Table 10. Record the outdoor coil entering wet-bulb temperature according to the requirements given in section 3.5 of this appendix for the outdoor coil entering dry-bulb temperature. Drop the subscript ''dry'' used in variables cited in section 3.5 of this appendix when referring to quantities from the cyclic heating mode test. Determine the total space heating delivered during the cyclic heating test, q_{cyc}, as specified in section 3.5 of this appendix except for making the following changes:

(1) When evaluating Equation 3.5–1, use the values of $\bar{V}$, $C_{p,a}$,v_n', (or v_n), and W_n that were recorded during the section 3.7 steady-state test conducted at the same test conditions.

(2) Calculate Γ using

$$\Gamma \text{ using, } \Gamma = F_{CD}^{*}\int_{\tau_1}^{\tau_2}[T_{a1}(\tau) - T_{a2}(\tau)]\delta\tau, \ hr \times {}^{\circ}F,$$

where F_{CD}* is the value recorded during the section 3.7 steady-state test conducted at the same test condition.

b. For ducted coil-only system heat pumps (excluding the special case where a variable-speed fan is temporarily removed), increase q_{cyc} by the amount calculated using Equation 3.5–3. Additionally, increase e_{cyc} by the amount calculated using Equation 3.5–2. In making these calculations, use the average indoor air volume rate ($\bar{V}_s$) determined from the section 3.7 steady-state heating mode test conducted at the same test conditions.

c. For non-ducted heat pumps, subtract the electrical energy used by the indoor blower during the 3 minutes after compressor cutoff from the non-ducted heat pump's integrated heating capacity, q_{cyc}.

d. If a heat pump defrost cycle is manually or automatically initiated immediately prior to or during the OFF/ON cycling, operate the heat pump continuously until 10 minutes after defrost termination. After that, begin cycling the heat pump immediately or delay until the specified test conditions have been re-established. Pay attention to preventing defrosts after beginning the cycling process. For heat pumps that cycle off the indoor blower during a defrost cycle, make no effort here to restrict the air movement through the indoor coil while the fan is off. Resume the OFF/ON cycling while conducting a minimum of two complete compressor OFF/ON cycles before determining q_{cyc} and e_{cyc}.

3.8.1 Heating Mode Cyclic-Degradation Coefficient Calculation

Use the results from the required cyclic test and the required steady-state test that were conducted at the same test conditions to determine the heating mode cyclic-degradation coefficient C_D^h. Add ''(k=2)'' to the coefficient if it corresponds to a two-capacity unit cycling at high capacity. For the below calculation of the heating mode cyclic degradation coefficient, do not include the duct loss correction from section 7.3.3.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) in determining $\dot{Q}_h^k(T_{cyc})$ (or q_{cyc}). If the optional cyclic test is conducted but yields a tested C_D^h that exceeds the default C_D^h or if the optional test is not conducted, assign C_D^h the default value of 0.25. The default value for two-capacity units cycling at high capacity, however, is the low-capacity coefficient, *i.e.*, C_D^h (k=2) = C_D^h. The tested C_D^h is calculated as follows:

$$C_D^h = \frac{1 - \frac{COP_{cyc}}{COP_{ss}(T_{cyc})}}{1 - HLF}$$

where:

$$COP_{cyc} = \frac{q_{cyc}}{3.413\frac{Btu/h}{W} * e_{cyc}}$$

the average coefficient of performance during the cyclic heating mode test, dimensionless.

$$COP_{ss}(T_{cyc}) = \frac{\dot{Q}_h^k(T_{cyc})}{3.413\frac{Btu/h}{W} * \dot{E}_h^k(T_{cyc})}$$

the average coefficient of performance during the steady-state heating mode test conducted at the same test conditions—*i.e.*, same outdoor dry bulb temperature, T_{cyc}, and speed/capacity, k, if applicable—as specified for the cyclic heating mode test, dimensionless.

$$HLF = \frac{q_{cyc}}{\dot{Q}_h^k(T_{cyc}) * \Delta\tau_{cyc}}$$

the heating load factor, dimensionless.

T_{cyc} = the nominal outdoor temperature at which the cyclic heating mode test is conducted, 62 or 47 °F.

$\Delta\tau_{cyc}$ = the duration of the OFF/ON intervals; 0.5 hours when testing a heat pump having a single-speed or two-capacity compressor and 1.0 hour when testing a heat pump having a variable-speed compressor.

Round the calculated value for C_D^h to the nearest 0.01. If C_D^h is negative, then set it equal to zero.

TABLE 17—TEST OPERATING AND TEST CONDITION TOLERANCES FOR CYCLIC HEATING MODE TESTS

	Test operating tolerance [1]	Test condition tolerance [1]
Indoor entering dry-bulb temperature,[2] °F	2.0	0.5
Indoor entering wet-bulb temperature,[2] °F	1.0	
Outdoor entering dry-bulb temperature,[2] °F	2.0	0.5
Outdoor entering wet-bulb temperature,[2] °F	2.0	1.0
External resistance to air-flow,[2] inches of water	0.05	
Airflow nozzle pressure difference or velocity pressure,[2]% of reading	2.0	[3]2.0
Electrical voltage,[4] % of rdg	2.0	1.5

[1] See section 1.2 of this appendix, Definitions.

[2] Applies during the interval that air flows through the indoor (outdoor) coil except for the first 30 seconds after flow initiation. For units having a variable-speed indoor blower that ramps, the tolerances listed for the external resistance to airflow shall apply from 30 seconds after achieving full speed until ramp down begins.

[3] The test condition shall be the average nozzle pressure difference or velocity pressure measured during the steady-state test conducted at the same test conditions.

[4] Applies during the interval that at least one of the following—the compressor, the outdoor fan, or, if applicable, the indoor blower—are operating, except for the first 30 seconds after compressor start-up.

3.9 Test Procedures for Frost Accumulation Heating Mode Tests (the H2, $H2_2$, $H2_V$, and $H2_1$ tests)

a. Confirm that the defrost controls of the heat pump are set as specified in section 2.2.1 of this appendix. Operate the test room reconditioning apparatus and the heat pump for at least 30 minutes at the specified section 3.6 test conditions before starting the ''preliminary'' test period. The preliminary test period must immediately precede the ''official'' test period, which is the heating and defrost interval over which data are collected for evaluating average space heating capacity and average electrical power consumption.

b. For heat pumps containing defrost controls which are likely to cause defrosts at intervals less than one hour, the preliminary test period starts at the termination of an automatic defrost cycle and ends at the termination of the next occurring automatic defrost cycle. For heat pumps containing defrost controls which are likely to cause defrosts at intervals exceeding one hour, the preliminary test period must consist of a heating interval lasting at least one hour followed by a defrost cycle that is either manually or automatically initiated. In all cases, the heat pump's own controls must govern when a defrost cycle terminates.

c. The official test period begins when the preliminary test period ends, at defrost termination. The official test period ends at the termination of the next occurring automatic defrost cycle. When testing a heat pump that uses a time-adaptive defrost control system (see section 1.2 of this appendix, Definitions), however, manually initiate the defrost cycle that ends the official test period at the instant indicated by instructions provided by the manufacturer. If the heat pump has not undergone a defrost after 6 hours, immediately conclude the test and use the results from the full 6-hour period to calculate the average space heating capacity and average electrical power consumption.

For heat pumps that turn the indoor blower off during the defrost cycle, take steps to cease forced airflow through the indoor coil and block the outlet duct whenever the heat pump's controls cycle off the indoor blower. If it is installed, use the outlet damper box described in section 2.5.4.1 of this appendix to affect the blocked outlet duct.

d. Defrost termination occurs when the controls of the heat pump actuate the first change in converting from defrost operation to normal heating operation. Defrost initiation occurs when the controls of the heat pump first alter its normal heating operation in order to eliminate possible accumulations of frost on the outdoor coil.

e. To constitute a valid frost accumulation test, satisfy the test tolerances specified in Table 18 during both the preliminary and official test periods. As noted in Table 18, test operating tolerances are specified for two sub-intervals:

(1) When heating, except for the first 10 minutes after the termination of a defrost cycle (sub-interval H, as described in Table 18) and

(2) When defrosting, plus these same first 10 minutes after defrost termination (sub-interval D, as described in Table 18). Evaluate compliance with Table 18 test condition tolerances and the majority of the test operating tolerances using the averages from measurements recorded only during sub-interval H. Continuously record the dry bulb temperature of the air entering the indoor coil, and the dry bulb temperature and water vapor content of the air entering the outdoor coil. Sample the remaining parameters listed in Table 18 at equal intervals that span 5 minutes or less.

f. For the official test period, collect and use the following data to calculate average space heating capacity and electrical power. During heating and defrosting intervals when the controls of the heat pump have the indoor blower on, continuously record the dry-bulb temperature of the air entering (as noted above) and leaving the indoor coil. If using a thermopile, continuously record the difference between the leaving and entering dry-bulb temperatures during the interval(s) that air flows through the indoor coil. For coil-only system heat pumps, determine the corresponding cumulative time (in hours) of indoor coil airflow, $\Delta\tau_a$. Sample measurements used in calculating the air volume rate (refer to sections 7.7.2.1 and 7.7.2.2 of ANSI/ASHRAE 37–2009) at equal intervals that span 10 minutes or less. (NOTE: In the first printing of ANSI/ASHRAE 37–2009, the second IP equation for Q_{mi} should read:) Record the electrical energy consumed, expressed in watt-hours, from defrost termination to defrost termination, $e_{DEF}{}^{[K]}(35)$, as well as the corresponding elapsed time in hours, $\Delta\tau_{FR}$.

TABLE 18—TEST OPERATING AND TEST CONDITION TOLERANCES FOR FROST ACCUMULATION HEATING MODE TESTS

	Test operating tolerance [1]		Test condition tolerance [1]
	Sub-interval H [2]	Sub-interval D [3]	Sub-interval H [2]
Indoor entering dry-bulb temperature, °F	2.0	[4] 4.0	0.5
Indoor entering wet-bulb temperature, °F	1.0		

TABLE 18—TEST OPERATING AND TEST CONDITION TOLERANCES FOR FROST ACCUMULATION HEATING MODE TESTS—Continued

	Test operating tolerance [1]		Test condition tolerance [1]
	Sub-interval H [2]	Sub-interval D [3]	Sub-interval H [2]
Outdoor entering dry-bulb temperature, °F	2.0	10.0	1.0
Outdoor entering wet-bulb temperature, °F	1.5	.....	0.5
External resistance to airflow, inches of water	0.05	.....	[5] 0.02
Electrical voltage, % of rdg	2.0	.....	1.5

[1] See section 1.2 of this appendix, Definitions.
[2] Applies when the heat pump is in the heating mode, except for the first 10 minutes after termination of a defrost cycle.
[3] Applies during a defrost cycle and during the first 10 minutes after the termination of a defrost cycle when the heat pump is operating in the heating mode.
[4] For heat pumps that turn off the indoor blower during the defrost cycle, the noted tolerance only applies during the 10 minute interval that follows defrost termination.
[5] Only applies when testing non-ducted heat pumps.

3.9.1 Average Space Heating Capacity and Electrical Power Calculations

a. Evaluate average space heating capacity, $\dot{Q}_h^k(35)$, when expressed in units of Btu per hour, using:

$$\dot{Q}_h^k(35) = \frac{60 * \bar{\dot{V}} * C_{p,a} * \Gamma}{\Delta\tau_{FR}[\nu_n' * (1 + W_n)]} = \frac{60 * \bar{\dot{V}} * C_{p,a} * \Gamma}{\Delta\tau_{FR}\nu_n}$$

Where,

$\bar{\dot{V}}$ = the average indoor air volume rate measured during sub-interval H, cfm.

$C_{p,a}$ = 0.24 + 0.444 · W_n, the constant pressure specific heat of the air-water vapor mixture that flows through the indoor coil and is expressed on a dry air basis, Btu/lbm_{da} · °F.

ν_n' = specific volume of the air-water vapor mixture at the nozzle, ft^3/lbm_{mx}.

W_n = humidity ratio of the air-water vapor mixture at the nozzle, lbm of water vapor per lbm of dry air.

$\Delta\tau_{FR} = \tau_2 - \tau_1$, the elapsed time from defrost termination to defrost termination, hr.

$$\Gamma = \int_{\tau_1}^{\tau_2}[T_{a2}(\tau) - T_{a1}(\tau)]d\tau,\ hr * °F$$

$T_{al}(\tau)$ = dry bulb temperature of the air entering the indoor coil at elapsed time τ, °F; only recorded when indoor coil airflow occurs; assigned the value of zero during periods (if any) where the indoor blower cycles off.

$T_{a2}(\tau)$ = dry bulb temperature of the air leaving the indoor coil at elapsed time τ, °F; only recorded when indoor coil airflow occurs; assigned the value of zero during periods (if any) where the indoor blower cycles off.

τ_1 = the elapsed time when the defrost termination occurs that begins the official test period, hr.

τ_2 = the elapsed time when the next automatically occurring defrost termination occurs, thus ending the official test period, hr.

ν_n = specific volume of the dry air portion of the mixture evaluated at the dry-bulb temperature, vapor content, and barometric pressure existing at the nozzle, ft^3 per lbm of dry air.

To account for the effect of duct losses between the outlet of the indoor unit and the section 2.5.4 dry-bulb temperature grid, adjust $\dot{Q}_h^k(35)$ in accordance with section 7.3.4.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3).

b. Evaluate average electrical power, $\dot{E}_h^k(35)$, when expressed in units of watts, using:

$$\dot{E}_h^k(35) = \frac{e_{def}(35)}{\Delta\tau_{FR}}$$

For coil-only system heat pumps, increase $\dot{Q}_h^k(35)$ by,

$$\frac{1250\,Btu/h}{1000\,scfm} * \bar{\dot{V}}_s * \frac{\Delta\tau_a}{\Delta\tau_{FR}}$$

and increase $\dot{E}_h^k(35)$ by,

$$\frac{365\,W}{1000\,scfm} * \bar{\dot{V}}_s * \frac{\Delta\tau_a}{\Delta\tau_{FR}}$$

where $\bar{\dot{V}}_s$ is the average indoor air volume rate measured during the frost accumulation heating mode test and is expressed in units of cubic feet per minute of standard air (scfm).

c. For heat pumps having a constant-air-volume-rate indoor blower, the five additional steps listed below are required if the average of the external static pressures measured during sub-interval H exceeds the applicable section 3.1.4.4, 3.1.4.5, or 3.1.4.6 minimum (or targeted) external static pressure (ΔP_{min}) by 0.03 inches of water or more:

(1) Measure the average power consumption of the indoor blower motor ($\dot{E}_{fan,1}$) and record the corresponding external static pressure (ΔP_1) during or immediately following the frost accumulation heating mode test. Make the measurement at a time when the heat pump is heating, except for the first 10 minutes after the termination of a defrost cycle.

(2) After the frost accumulation heating mode test is completed and while maintaining the same test conditions, adjust the exhaust fan of the airflow measuring apparatus until the external static pressure increases to approximately $\Delta P_1 + (\Delta P_1 - \Delta P_{min})$.

(3) After re-establishing steady readings for the fan motor power and external static pressure, determine average values for the indoor blower power ($\dot{E}_{fan,2}$) and the external static pressure (ΔP_2) by making measurements over a 5-minute interval.

(4) Approximate the average power consumption of the indoor blower motor had the frost accumulation heating mode test been conducted at ΔP_{min} using linear extrapolation:

$$\dot{E}_{fan,\min} = \frac{\dot{E}_{fan,2} - \dot{E}_{fan,1}}{\Delta P_2 - \Delta P_1}(\Delta P_{\min} - \Delta P_1) + \dot{E}_{fan,1}$$

(5) Decrease the total heating capacity, $\dot{Q}_h^k(35)$, by the quantity $[(\dot{E}_{fan,1} - \dot{E}_{fan,min}) \cdot (\Delta\tau_a / \Delta\tau_{FR}]$, when expressed on a Btu/h basis. Decrease the total electrical power, $E_h^k(35)$, by the same quantity, now expressed in watts.

3.9.2 Demand Defrost Credit

a. Assign the demand defrost credit, F_{def}, that is used in section 4.2 of this appendix to the value of 1 in all cases except for heat pumps having a demand-defrost control system (see section 1.2 of this appendix, Definitions). For such qualifying heat pumps, evaluate F_{def} using,

$$F_{def} = 1 + 0.03 * \left[1 - \frac{\Delta\tau_{def} - 1.5}{\Delta\tau_{\max} - 1.5}\right]$$

where:

$\Delta\tau_{def}$ = the time between defrost terminations (in hours) or 1.5, whichever is greater. A value of 6 must be assigned to $\Delta\tau_{def}$ if this limit is reached during a frost accumulation test and the heat pump has not completed a defrost cycle.

$\Delta\tau_{max}$ = maximum time between defrosts as allowed by the controls (in hours) or 12, whichever is less, as provided in the certification report.

b. For two-capacity heat pumps and for section 3.6.2 units, evaluate the above equation using the $\Delta\tau_{def}$ that applies based on the frost accumulation test conducted at high capacity and/or at the heating full-load air volume rate. For variable-speed heat pumps, evaluate $\Delta\tau_{def}$ based on the required frost accumulation test conducted at the intermediate compressor speed.

3.10 Test Procedures for Steady-State Low Temperature Heating Mode Tests (the H3, $H3_2$, and $H3_1$ Tests)

Except for the modifications noted in this section, conduct the low temperature heating mode test using the same approach as specified in section 3.7 of this appendix for the maximum and high temperature tests. After satisfying the section 3.7 requirements for the pretest interval but before beginning to collect data to determine $\dot{Q}_h^k(17)$ and $\dot{E}_h^k(17)$, conduct a defrost cycle. This defrost cycle may be manually or automatically initiated. The defrost sequence must be terminated by the action of the heat pump's defrost controls. Begin the 30-minute data collection interval described in section 3.7 of this appendix, from which $\dot{Q}_h^k(17)$ and $\dot{E}_h^k(17)$ are determined, no sooner than 10 minutes after defrost termination. Defrosts should be prevented over the 30-minute data collection interval.

3.11 Additional Requirements for the Secondary Test Methods

3.11.1 If Using the Outdoor Air Enthalpy Method as the Secondary Test Method

a. For all cooling mode and heating mode tests, first conduct a test without the outdoor air-side test apparatus described in section 2.10.1 of this appendix connected to the outdoor unit (''free outdoor air'' test).

b. For the first section 3.2 steady-state cooling mode test and the first section 3.6 steady-state heating mode test, conduct a second test in which the outdoor-side apparatus is connected (''ducted outdoor air'' test). No other cooling mode or heating mode tests require the ducted outdoor air test so long as the unit operates the outdoor fan during all cooling mode steady-state tests at the same speed and all heating mode steady-state tests at the same speed. If using more than one outdoor fan speed for the cooling mode steady-state tests, however, conduct the ducted outdoor air test for each cooling mode test where a different fan speed is first used. This same requirement applies for the heating mode tests.

3.11.1.1 Free Outdoor Air Test

a. For the free outdoor air test, connect the indoor air-side test apparatus to the indoor coil; do not connect the outdoor air-side test apparatus. Allow the test room reconditioning apparatus and the unit being tested to operate for at least one hour. After attaining equilibrium conditions, measure the following quantities at equal intervals that span 5 minutes or less:

(1) The section 2.10.1 evaporator and condenser temperatures or pressures;

(2) Parameters required according to the indoor air enthalpy method.

Continue these measurements until a 30-minute period (*e.g.*, seven consecutive 5-minute samples) is obtained where the Table 9 or Table 16, whichever applies, test tolerances are satisfied.

b. For cases where a ducted outdoor air test is not required per section 3.11.1.b of this appendix, the free outdoor air test constitutes the ''official'' test for which validity is not based on comparison with a secondary test.

c. For cases where a ducted outdoor air test is required per section 3.11.1.b of this appendix, the following conditions must be met for the free outdoor air test to constitute a valid ''official'' test:

(1) Achieve the energy balance specified in section 3.1.1 of this appendix for the ducted outdoor air test (*i.e.*, compare the capacities determined using the indoor air enthalpy method and the outdoor air enthalpy method).

(2) The capacities determined using the indoor air enthalpy method from the ducted outdoor air and free outdoor tests must agree within 2 percent.

3.11.1.2 Ducted Outdoor Air Test

a. The test conditions and tolerances for the ducted outdoor air test are the same as specified for the free outdoor air test described in Section 3.11.1.1 of this appendix.

b. After collecting 30 minutes of steady-state data during the free outdoor air test,

connect the outdoor air-side test apparatus to the unit for the ducted outdoor air test. Adjust the exhaust fan of the outdoor airflow measuring apparatus until averages for the evaporator and condenser temperatures, or the saturated temperatures corresponding to the measured pressures, agree within ±0.5 °F of the averages achieved during the free outdoor air test. Collect 30 minutes of steady-state data after re-establishing equilibrium conditions.

c. During the ducted outdoor air test, at intervals of 5 minutes or less, measure the parameters required according to the indoor air enthalpy method and the outdoor air enthalpy method for the prescribed 30 minutes.

d. For cooling mode ducted outdoor air tests, calculate capacity based on outdoor air-enthalpy measurements as specified in sections 7.3.3.2 and 7.3.3.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). For heating mode ducted tests, calculate heating capacity based on outdoor air-enthalpy measurements as specified in sections 7.3.4.2 and 7.3.3.4.3 of the same ANSI/ASHRAE Standard. Adjust the outdoor-side capacity according to section 7.3.3.4 of ANSI/ASHRAE 37–2009 to account for line losses when testing split systems. As described in section 8.6.2 of ANSI/ASHRAE 37–2009, use the outdoor air volume rate as measured during the ducted outdoor air tests to calculate capacity for checking the agreement with the capacity calculated using the indoor air enthalpy method.

3.11.2 If Using the Compressor Calibration Method as the Secondary Test Method

a. Conduct separate calibration tests using a calorimeter to determine the refrigerant flow rate. Or for cases where the superheat of the refrigerant leaving the evaporator is less than 5 °F, use the calorimeter to measure total capacity rather than refrigerant flow rate. Conduct these calibration tests at the same test conditions as specified for the tests in this appendix. Operate the unit for at least one hour or until obtaining equilibrium conditions before collecting data that will be used in determining the average refrigerant flow rate or total capacity. Sample the data at equal intervals that span 5 minutes or less. Determine average flow rate or average capacity from data sampled over a 30-minute period where the Table 9 (cooling) or the Table 16 (heating) tolerances are satisfied. Otherwise, conduct the calibration tests according to sections 5, 6, 7, and 8 of ASHRAE 23.1–2010 (incorporated by reference, see §430.3); sections 5, 6, 7, 8, 9, and 11 of ASHRAE 41.9–2011 (incorporated by reference, see §430.3); and section 7.4 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3).

b. Calculate space cooling and space heating capacities using the compressor calibration method measurements as specified in section 7.4.5 and 7.4.6 respectively, of ANSI/ASHRAE 37–2009.

3.11.3 If Using the Refrigerant-Enthalpy Method as the Secondary Test Method

Conduct this secondary method according to section 7.5 of ANSI/ASHRAE 37–2009. Calculate space cooling and heating capacities using the refrigerant-enthalpy method measurements as specified in sections 7.5.4 and 7.5.5, respectively, of the same ASHRAE Standard.

3.12 Rounding of Space Conditioning Capacities for Reporting Purposes

a. When reporting rated capacities, round them off as specified in §430.23 (for a single unit) and in 10 CFR 429.16 (for a sample).

b. For the capacities used to perform the calculations in section 4 of this appendix, however, round only to the nearest integer.

3.13 Laboratory Testing to Determine Off Mode Average Power Ratings

Voltage tolerances: As a percentage of reading, test operating tolerance shall be 2.0 percent and test condition tolerance shall be 1.5 percent (see section 1.2 of this appendix for definitions of these tolerances).

Conduct one of the following tests: If the central air conditioner or heat pump lacks a compressor crankcase heater, perform the test in section 3.13.1 of this appendix; if the central air conditioner or heat pump has a compressor crankcase heater that lacks controls and is not self-regulating, perform the test in section 3.13.1 of this appendix; if the central air conditioner or heat pump has a crankcase heater with a fixed power input controlled with a thermostat that measures ambient temperature and whose sensing element temperature is not affected by the heater, perform the test in section 3.13.1 of this appendix; if the central air conditioner or heat pump has a compressor crankcase heater equipped with self-regulating control or with controls for which the sensing element temperature is affected by the heater, perform the test in section 3.13.2 of this appendix.

3.13.1 This Test Determines the Off Mode Average Power Rating for Central Air Conditioners and Heat Pumps That Lack a Compressor Crankcase Heater, or Have a Compressor Crankcase Heating System That Can Be Tested Without Control of Ambient Temperature During the Test. This Test Has No Ambient Condition Requirements

a. Test Sample Set-up and Power Measurement: For coil-only systems, provide a furnace or modular blower that is compatible with the system to serve as an interface with the thermostat (if used for the test) and to provide low-voltage control circuit power.

Make all control circuit connections between the furnace (or modular blower) and the outdoor unit as specified by the manufacturer's installation instructions. Measure power supplied to both the furnace or modular blower and power supplied to the outdoor unit. Alternatively, provide a compatible transformer to supply low-voltage control circuit power, as described in section 2.2.d of this appendix. Measure transformer power, either supplied to the primary winding or supplied by the secondary winding of the transformer, and power supplied to the outdoor unit. For blower coil and single-package systems, make all control circuit connections between components as specified by the manufacturer's installation instructions, and provide power and measure power supplied to all system components.

b. Configure Controls: Configure the controls of the central air conditioner or heat pump so that it operates as if connected to a building thermostat that is set to the OFF position. Use a compatible building thermostat if necessary to achieve this configuration. For a thermostat-controlled crankcase heater with a fixed power input, bypass the crankcase heater thermostat if necessary to energize the heater.

c. Measure $P2_x$: If the unit has a crankcase heater time delay, make sure that time delay function is disabled or wait until delay time has passed. Determine the average power from non-zero value data measured over a 5-minute interval of the non-operating central air conditioner or heat pump and designate the average power as $P2_x$, the heating season total off mode power.

d. Measure P_x for coil-only split systems and for blower coil split systems for which a furnace or a modular blower is the designated air mover: Disconnect all low-voltage wiring for the *outdoor* components and *outdoor* controls from the low-voltage transformer. Determine the average power from non-zero value data measured over a 5-minute interval of the power supplied to the (remaining) low-voltage components of the central air conditioner or heat pump, or low-voltage power, P_x. This power measurement does not include line power supplied to the outdoor unit. It is the line power supplied to the air mover, or, if a compatible transformer is used instead of an air mover, it is the line power supplied to the transformer primary coil. If a compatible transformer is used instead of an air mover and power output of the low-voltage secondary circuit is measured, P_x is zero.

e. Calculate *P2*: Set the number of compressors equal to the unit's number of single-stage compressors plus 1.75 times the unit's number of compressors that are not single-stage.

For single-package systems and blower coil split systems for which the designated air mover is not a furnace or modular blower, divide the heating season total off mode power ($P2_x$) by the number of compressors to calculate *P2*, the heating season per-compressor off mode power. Round *P2* to the nearest watt. The expression for calculating *P2* is as follows:

$$P2 = \frac{P2_x}{number\ of\ compressors}.$$

For coil-only split systems and blower coil split systems for which a furnace or a modular blower is the designated air mover, subtract the low-voltage power (P_x) from the heating season total off mode power ($P2_x$) and divide by the number of compressors to calculate *P2*, the heating season per-compressor off mode power. Round *P2* to the nearest watt. The expression for calculating *P2* is as follows:

$$P2 = \frac{P2_x - P_x}{number\ of\ compressors}.$$

f. Shoulder-season per-compressor off mode power, P1: If the system does not have a crankcase heater, has a crankcase heater without controls that is not self-regulating, or has a value for the crankcase heater turn-on temperature (as certified in the DOE Compliance Certification Database) that is higher than 71 °F, P1 is equal to P2.

Otherwise, de-energize the crankcase heater (by removing the thermostat bypass or otherwise disconnecting only the power supply to the crankcase heater) and repeat the measurement as described in section 3.13.1.c of this appendix. Designate the measured average power as $P1_x$, the shoulder season total off mode power.

Determine the number of compressors as described in section 3.13.1.e of this appendix.

For single-package systems and blower coil systems for which the designated air mover is not a furnace or modular blower, divide the shoulder season total off mode power ($P1_x$) by the number of compressors to calculate *P1*, the shoulder season per-compressor off mode power. Round *P1* to the nearest watt. The expression for calculating *P1* is as follows:

$$P1 = \frac{P1_x}{number\ of\ compressors}.$$

For coil-only split systems and blower coil split systems for which a furnace or a modular blower is the designated air mover, subtract the low-voltage power (P_x) from the shoulder season total off mode power ($P1_x$) and divide by the number of compressors to calculate *P1*, the shoulder season per-compressor off mode power. Round *P1* to the nearest watt. The expression for calculating *P1* is as follows:

$$P1 = \frac{P1_x - P_x}{number\ of\ compressors}.$$

3.13.2 This Test Determines the Off Mode Average Power Rating for Central Air Conditioners and Heat Pumps for Which Ambient Temperature Can Affect the Measurement of Crankcase Heater Power

a. Test Sample Set-up and Power Measurement: Set up the test and measurement as described in section 3.13.1.a of this appendix.

b. Configure Controls: Position a temperature sensor to measure the outdoor dry-bulb temperature in the air between 2 and 6 inches from the crankcase heater control temperature sensor or, if no such temperature sensor exists, position it in the air between 2 and 6 inches from the crankcase heater. Utilize the temperature measurements from this sensor for this portion of the test procedure. Configure the controls of the central air conditioner or heat pump so that it operates as if connected to a building thermostat that is set to the OFF position. Use a compatible building thermostat if necessary to achieve this configuration.

Conduct the test after completion of the B, B_1, or B_2 test. Alternatively, start the test when the outdoor dry-bulb temperature is at 82 °F and the temperature of the compressor shell (or temperature of each compressor's shell if there is more than one compressor) is at least 81 °F. Then adjust the outdoor temperature at a rate of change of no more than 20 °F per hour and achieve an outdoor dry-bulb temperature of 72 °F. Maintain this temperature within ±2 °F while making the power measurement, as described in section 3.13.2.c of this appendix.

c. Measure $P1_x$: If the unit has a crankcase heater time delay, make sure that time delay function is disabled or wait until delay time has passed. Determine the average power from non-zero value data measured over a 5-minute interval of the non-operating central air conditioner or heat pump and designate the average power as $P1_x$, the shoulder season total off mode power. For units with crankcase heaters which operate during this part of the test and whose controls cycle or vary crankcase heater power over time, the test period shall consist of three complete crankcase heater cycles or 18 hours, whichever comes first. Designate the average power over the test period as $P1_x$, the shoulder season total off mode power.

d. Reduce outdoor temperature: Approach the target outdoor dry-bulb temperature by adjusting the outdoor temperature at a rate of change of no more than 20 °F per hour. This target temperature is five degrees Fahrenheit less than the temperature specified by the manufacturer in the DOE Compliance Certification Database at which the crankcase heater turns on. Maintain the target temperature within ±2 °F while making the power measurement, as described in section 3.13.2.e of this appendix.

e. Measure $P2_x$: If the unit has a crankcase heater time delay, make sure that time delay function is disabled or wait until delay time has passed. Determine the average non-zero power of the non-operating central air conditioner or heat pump over a 5-minute interval and designate it as $P2_x$, the heating season total off mode power. For units with crankcase heaters whose controls cycle or vary crankcase heater power over time, the test period shall consist of three complete crankcase heater cycles or 18 hours, whichever comes first. Designate the average power over the test period as $P2_x$, the heating season total off mode power.

f. Measure P_x for coil-only split systems and for blower coil split systems for which a furnace or modular blower is the designated air mover: Disconnect all low-voltage wiring for the *outdoor* components and *outdoor* controls from the low-voltage transformer. Determine the average power from non-zero value data measured over a 5-minute interval of the power supplied to the (remaining) low-voltage components of the central air conditioner or heat pump, or low-voltage power, P_x.. This power measurement does not include line power supplied to the outdoor unit. It is the line power supplied to the air mover, or, if a compatible transformer is used instead of an air mover, it is the line power supplied to the transformer primary coil. If a compatible transformer is used instead of an air mover and power output of the low-voltage secondary circuit is measured, P_x is zero.

g. Calculate *P1*:

Set the number of compressors equal to the unit's number of single-stage compressors plus 1.75 times the unit's number of compressors that are not single-stage.

For single-package systems and blower coil split systems for which the air mover is not a furnace or modular blower, divide the shoulder season total off mode power ($P1_x$) by the number of compressors to calculate *P1*, the shoulder season per-compressor off mode power. Round to the nearest watt. The expression for calculating *P1* is as follows:

$$P1 = \frac{P1_x}{number\ of\ compressors}.$$

For coil-only split systems and blower coil split systems for which a furnace or a modular blower is the designated air mover, subtract the low-voltage power (P_x) from the shoulder season total off mode power ($P1_x$) and divide by the number of compressors to calculate *P1*, the shoulder season per-compressor off mode power. Round to the nearest watt. The expression for calculating *P1* is as follows:

$$P1 = \frac{P1_x - P_x}{number\ of\ compressors}.$$

h. Calculate *P2*:

Determine the number of compressors as described in section 3.13.2.g of this appendix.

For single-package systems and blower coil split systems for which the air mover is not a furnace, divide the heating season total off mode power ($P2_x$) by the number of compressors to calculate *P2*, the heating season per-compressor off mode power. Round to the nearest watt. The expression for calculating *P2* is as follows:

$$P2 = \frac{P2_x}{number\ of\ compressors}.$$

For coil-only split systems and blower coil split systems for which a furnace or a modular blower is the designated air mover, subtract the low-voltage power (P_x) from the heating season total off mode power ($P2_x$) and divide by the number of compressors to calculate *P2*, the heating season per-compressor off mode power. Round to the nearest watt. The expression for calculating *P2* is as follows:

$$P2 = \frac{P2_x - P_x}{number\ of\ compressors}.$$

4. CALCULATIONS OF SEASONAL PERFORMANCE DESCRIPTORS

4.1 Seasonal Energy Efficiency Ratio (SEER) Calculations. SEER must be calculated as follows: For equipment covered under sections 4.1.2, 4.1.3, and 4.1.4 of this appendix, evaluate the seasonal energy efficiency ratio,

$$\text{Equation 4.1-1 } SEER = \frac{\sum_{j=1}^{8} q_c(T_j)}{\sum_{j=1}^{8} e_c(T_j)} = \frac{\sum_{j=1}^{8} \frac{q_c(T_j)}{N}}{\sum_{j=1}^{8} \frac{e_c(T_j)}{N}}$$

where:

$\frac{q_c(T_j)}{N}$ = the ratio of the total space cooling provided during periods of the space cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season (N), Btu/h.

$\frac{e_c(T_j)}{N}$ = the electrical energy consumed by the test unit during periods of the space cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season (N), W.

T_j = the outdoor bin temperature, °F. Outdoor temperatures are grouped or ''binned.'' Use bins of 5 °F with the 8 cooling season bin temperatures being 67, 72, 77, 82, 87, 92, 97, and 102 °F.

j = the bin number. For cooling season calculations, j ranges from 1 to 8.

Additionally, for sections 4.1.2, 4.1.3, and 4.1.4 of this appendix, use a building cooling load, $BL(T_j)$. When referenced, evaluate $BL(T_j)$ for cooling using,

$$\text{Equation 4.1-2 } BL(T_j) = \frac{(T_j - 65)}{95 - 65} * \frac{\dot{Q}_c^{k=2}(95)}{1.1}$$

where:

$\dot{Q}_c^{k=2}(95)$ = the space cooling capacity determined from the A_2 test and calculated as specified in section 3.3 of this appendix, Btu/h.

1.1 = sizing factor, dimensionless.

The temperatures 95 °F and 65 °F in the building load equation represent the selected outdoor design temperature and the zero-load base temperature, respectively.

4.1.1 SEER Calculations for a Blower Coil System Having a Single-Speed Compressor and Either a Fixed-Speed Indoor Blower or a Constant-Air-Volume-Rate Indoor Blower, or a Coil-Only System Air Conditioner or Heat Pump

a. Evaluate the seasonal energy efficiency ratio, expressed in units of Btu/watt-hour, using:

$SEER = PLF(0.5) * EER_B$

where:

$EER_B = \frac{\dot{Q}_c(82)}{\dot{E}_c(82)}$ = the energy efficiency ratio determined from the B test described in sections 3.2.1, 3.1.4.1, and 3.3 of this appendix, Btu/h per watt.

PLF(0.5) = 1 − 0.5 · C_D^c, the part-load performance factor evaluated at a cooling load factor of 0.5, dimensionless.

b. Refer to section 3.3 of this appendix regarding the definition and calculation of $\dot{Q}_c(82)$ and $\dot{E}_c(82)$. Evaluate the cooling mode cyclic degradation factor C_D^c as specified in section 3.5.3 of this appendix.

4.1.2 SEER Calculations for an Air Conditioner or Heat Pump Having a Single-Speed Compressor and a Variable-Speed Variable-Air-Volume-Rate Indoor Blower

4.1.2.1 Units Covered by Section 3.2.2.1 of This Appendix Where Indoor Blower Capacity Modulation Correlates With the Outdoor Dry Bulb Temperature

The manufacturer must provide information on how the indoor air volume rate or the indoor blower speed varies over the outdoor temperature range of 67 °F to 102 °F. Calculate SEER using Equation 4.1–1. Evaluate the quantity $q_c(T_j)/N$ in Equation 4.1–1 using,

Equation 4.1.2-1 $$\frac{q_c(T_j)}{N} = X(T_j) * \dot{Q}_c(T_j) * \frac{n_j}{N}$$

where:

$X(T_j) = \begin{Bmatrix} BL(T_j)/\dot{Q}_c(T_j) \\ or \\ 1 \end{Bmatrix}$ whichever is less; the cooling mode load factor for temperature bin j, dimensionless.

$\dot{Q}_c(T_j)$ = the space cooling capacity of the test unit when operating at outdoor temperature, T_j, Btu/h.

n_j/N = fractional bin hours for the cooling season; the ratio of the number of hours during the cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season, dimensionless.

a. For the space cooling season, assign n_j/N as specified in Table 19. Use Equation 4.1–2 to calculate the building load, $BL(T_j)$. Evaluate $\dot{Q}_c(T_j)$ using,

Equation 4.1.2-2 $$\dot{Q}_c(T_j) = \dot{Q}_c^{k=1}(T_j) + \frac{\dot{Q}_c^{k=2}(T_j) - \dot{Q}_c^{k=1}(T_j)}{FP_c^{k=2} - FP_c^{k=1}} * \left[FP_c(T_j) - FP_c^{k=1}\right]$$

where:

$$\dot{Q}_c^{k=1}(T_j) = \dot{Q}_c^{k=1}(82) + \frac{\dot{Q}_c^{k=1}(95) - \dot{Q}_c^{k=1}(82)}{95 - 82} * (T_j - 82)$$

the space cooling capacity of the test unit at outdoor temperature T_j if operated at the cooling minimum air volume rate, Btu/h.

$$\dot{Q}_c^{k=2}(T_j) = \dot{Q}_c^{k=2}(82) + \frac{\dot{Q}_c^{k=2}(95) - \dot{Q}_c^{k=2}(82)}{95 - 82} * (T_j - 82)$$

the space cooling capacity of the test unit at outdoor temperature T_j if operated at the Cooling full-load air volume rate, Btu/h.

b. For units where indoor blower speed is the primary control variable, $FP_c^{k=1}$ denotes the fan speed used during the required A_1 and B_1 tests (see section 3.2.2.1 of this appendix), $FP_c^{k=2}$ denotes the fan speed used during the required A_2 and B_2 tests, and $FP_c(T_j)$ denotes the fan speed used by the unit when the outdoor temperature equals T_j. For units where indoor air volume rate is the primary control variable, the three FP_c's are similarly defined only now being expressed in terms of air volume rates rather than fan speeds. Refer to sections 3.2.2.1, 3.1.4 to 3.1.4.2, and 3.3 of this appendix regarding the definitions and calculations of $\dot{Q}_c^{k=1}(82)$, $\dot{Q}_c^{k=1}(95)$, $\dot{Q}_c^{k=2}(82)$, and $\dot{Q}_c^{k=2}(95)$.

Calculate $e_c(T_j)/N$ in Equation 4.1-1 using, Equation 4.1.2-3 $\frac{e_c(T_j)}{N} = \frac{X(T_j) * \dot{E}_c(T_j)}{PLF_j} * \frac{n_j}{N}$

where:

$PLF_j = 1 - C_D^c \cdot [1 - X(T_j)]$, the part load factor, dimensionless.

$\dot{E}_c(T_j)$ = the electrical power consumption of the test unit when operating at outdoor temperature T_j, W.

c. The quantities $X(T_j)$ and n_j/N are the same quantities as used in Equation 4.1.2–1. Evaluate the cooling mode cyclic degradation factor C_D^c as specified in section 3.5.3 of this appendix.

d. Evaluate $\dot{E}_c(T_j)$ using,

$$\dot{E}_c(T_j) = \dot{E}_c^{k=1}(T_j) + \frac{\dot{E}_c^{k=2}(T_j) - \dot{E}_c^{k=1}(T_j)}{\mathrm{FP}_c^{k=2} - \mathrm{FP}_c^{k=1}} * \left[\mathrm{FP}_c(T_j) - \mathrm{FP}_c^{k=1}\right]$$

where:

$$\dot{E}_c^{k=1}(T_j) = \dot{E}_c^{k=1}(82) + \frac{\dot{E}_c^{k=1}(95) - \dot{E}_c^{k=1}(82)}{95-82} * (T_j - 82)$$

the electrical power consumption of the test unit at outdoor temperature T_j if operated at the Cooling Minimum Air Volume Rate, W.

$\dot{E}_c^{k=2}(T_j) = \dot{E}_c^{k=2}(82) + \frac{\dot{E}_c^{k=2}(95) - \dot{E}_c^{k=2}(82)}{95-82} * (T_j - 82)$ the electrical power consumption of the test unit at outdoor temperature T_j if operated at the cooling full-load air volume rate, W.

e. The parameters $FP_c^{k=1}$, and $FP_c^{k=2}$, and $FP_c(T_j)$ are the same quantities that are used when evaluating Equation 4.1.2–2. Refer to sections 3.2.2.1, 3.1.4 to 3.1.4.2, and 3.3 of this appendix regarding the definitions and calculations of $\dot{E}_c^{k=1}(82)$, $\dot{E}_c^{k=1}(95)$, $\dot{E}_c^{k=2}(82)$, and $\dot{E}_c^{k=2}(95)$.

4.1.2.2 Units Covered by Section 3.2.2.2 of This Appendix Where Indoor Blower Capacity Modulation Is Used To Adjust the Sensible to Total Cooling Capacity Ratio.

Calculate SEER as specified in section 4.1.1 of this appendix.

4.1.3 SEER Calculations for an Air Conditioner or Heat Pump Having a Two-Capacity Compressor

Calculate SEER using Equation 4.1–1. Evaluate the space cooling capacity, $\dot{Q}_c^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=1}(T_j)$, of the test unit when operating at low compressor capacity and outdoor temperature T_j using,

Equation 4.1.3-1 $$\dot{Q}_c^{k=1}(T_j) = \dot{Q}_c^{k=1}(67) + \frac{\dot{Q}_c^{k=1}(82) - \dot{Q}_c^{k=1}(67)}{82-67} * (T_j - 67)$$

Equation 4.1.3-2 $$\dot{E}_c^{k=1}(T_j) = \dot{E}_c^{k=1}(67) + \frac{\dot{E}_c^{k=1}(82) - \dot{E}_c^{k=1}(67)}{82-67} * (T_j - 67)$$

where $\dot{Q}_c^{k=1}(82)$ and $\dot{E}_c^{k=1}(82)$ are determined from the B_1 test, $\dot{Q}_c^{k=1}(67)$ and $\dot{E}_c^{k=1}(67)$ are determined from the F_1 test, and all four quantities are calculated as specified in section 3.3 of this appendix.

Evaluate the space cooling capacity, $\dot{Q}_c^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=2}(T_j)$, of the test unit when operating at high compressor capacity and outdoor temperature T_j using,

Equation 4.1.3-3 $$\dot{Q}_c^{k=2}(T_j) = \dot{Q}_c^{k=2}(82) + \frac{\dot{Q}_c^{k=2}(95) - \dot{Q}_c^{k=2}(82)}{95-82} * (T_j - 82)$$

Equation 4.1.3-4 $$\dot{E}_c^{k=2}(T_j) = \dot{E}_c^{k=2}(82) + \frac{\dot{E}_c^{k=2}(95) - \dot{E}_c^{k=2}(82)}{95-82} * (T_j - 82)$$

where $\dot{Q}_c^{k=2}(95)$ and $\dot{E}_c^{k=2}(95)$ are determined from the A_2 test, $\dot{Q}_c^{k=2}(82)$, and $\dot{E}_c^{k=2}(82)$, are determined from the B_2test, and all are calculated as specified in section 3.3 of this appendix.

The calculation of Equation 4.1–1 quantities $q_c(T_j)/N$ and $e_c(T_j)/N$ differs depending on whether the test unit would operate at low capacity (section 4.1.3.1 of this appendix), cycle between low and high capacity (section 4.1.3.2 of this appendix), or operate at high capacity (sections 4.1.3.3 and 4.1.3.4 of this appendix) in responding to the building load. For units that lock out low capacity operation at higher outdoor temperatures, the outdoor temperature at which the unit locks out must be that specified by the manufacturer in the certification report so that the appropriate equations are used. Use Equation 4.1–2 to calculate the building load, $BL(T_j)$, for each temperature bin.

4.1.3.1 Steady-State Space Cooling Capacity at Low Compressor Capacity Is Greater Than or Equal to the Building Cooling Load at Temperature T_j, $\dot{Q}_c^{k=1}(T_j) \geq BL(T_j)$

$$\frac{q_c(T_j)}{N} = X^{k=1}(T_j) * \dot{Q}_c^{k=1}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \frac{X^{k=1}(T_j) * \dot{E}_c^{k=1}(T_j)}{PLF_j} * \frac{n_j}{N}$$

where:

$X^{k=1}(T_j) = BL(T_j)/\dot{Q}_c^{k=1}(T_j)$, the cooling mode low capacity load factor for temperature bin j, dimensionless.

$PLF_j = 1 - C_D^c \cdot [1 - X^{k=1}(T_j)]$, the part load factor, dimensionless.

$\frac{n_j}{N}$ = fractional bin hours for the cooling season; the ratio of the number of hours during the cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season, dimensionless.

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19. Use Equations 4.1.3–1 and 4.1.3–2, respectively, to evaluate $\dot{Q}_c^{k=1}(T_j)$ and $\dot{E}_c^{k=1}(T_j)$. Evaluate the cooling mode cyclic degradation factor C_D^c as specified in section 3.5.3 of this appendix.

TABLE 19—DISTRIBUTION OF FRACTIONAL HOURS WITHIN COOLING SEASON TEMPERATURE BINS

Bin number, j	Bin temperature range deg;F	Representative temperature for bin deg;F	Fraction of total temperature bin hours, n_j/N
1	65–69	67	0.214
2	70–74	72	0.231
3	75–79	77	0.216
4	80–84	82	0.161
5	85–89	87	0.104
6	90–94	92	0.052
7	95–99	97	0.018
8	100–104	102	0.004

4.1.3.2 Unit Alternates Between High (k=2) and Low (k=1) Compressor Capacity to Satisfy the Building Cooling Load at Temperature T_j, $\dot{Q}_c^{k=1}(T_j) < BL(T_j) < \dot{Q}_c^{k=2}(T_j)$

$$\frac{q_c(T_j)}{N} = [X^{k=1}(T_j) * \dot{Q}_c^{k=1}(T_j) + X^{k=2}(T_j) * \dot{Q}_c^{k=2}(T_j)] * \frac{n_j}{N}$$

$$\frac{e_c(T_j)}{N} = [X^{k=1}(T_j) * \dot{E}_c^{k=1}(T_j) + X^{k=2}(T_j) * \dot{E}_c^{k=2}(T_j)] * \frac{n_j}{N}$$

where:

$X^{k=1}(T_j) = \frac{\dot{Q}_c^{k=2}(T_j) - BL(T_j)}{\dot{Q}_c^{k=2}(T_j) - \dot{Q}_c^{k=1}(T_j)}$ the cooling mode, low capacity load factor for temperature bin j, dimensionless.

$X^{k=2}(T_j) = 1 - X^{k=1}(T_j)$, the cooling mode, high capacity load factor for temperature bin j, dimensionless.

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19. Use Equations 4.1.3–1 and 4.1.3–2, respectively, to evaluate $\dot{Q}_c^{k=1}(T_j)$ and $\dot{E}_c^{k=1}(T_j)$. Use Equations 4.1.3–3 and 4.1.3–4, respectively, to evaluate $\dot{Q}_c^{k=2}(T_j)$ and $\dot{E}_c^{k=2}(T_j)$.

4.1.3.3 Unit Only Operates at High (k=2) Compressor Capacity at Temperature T_j and Its Capacity Is Greater Than the Building Cooling Load, $BL(T_j)$ $\dot{Q}_c^{k=2}(T_j)$. This section applies to units that lock out low compressor capacity operation at higher outdoor temperatures.

$$\frac{q_c(T_j)}{N} = X^{k=2}(T_j) * \dot{Q}_c^{k=2}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \frac{X^{k=2}(T_j) * \dot{E}_c^{k=2}(T_j)}{PLF_j} * \frac{n_j}{N}$$

where:

$X^{k=2}(T_j) = BL(T_j)/\dot{Q}_c^{k=2}(T_j)$, the cooling mode high capacity load factor for temperature bin j, dimensionless.

$PLF_j = 1 - C_D^c(k = 2) * [1 - X^{k=2}(T_j)$ the part load factor, dimensionless.

Obtain the fraction bin hours for the cooling season, $\frac{n_j}{N}$, from Table 19. Use Equations 4.1.3-3 and 4.1.3-4, respectively, to evaluate $\dot{Q}_c^{k=2}(T_j)$ and $\dot{E}_c^{k=2}(T_j)$. If the C_2 and D_2 tests described in section 3.2.3 and Table 7 of this appendix are not conducted, set C_D^c (k=2) equal to the default value specified in section 3.5.3 of this appendix.

4.1.3.4 Unit Must Operate Continuously at High (k=2) Compressor Capacity at Temperature T_j, $BL(T_j) \geq \dot{Q}_c^{k=2}(T_j)$

$$\frac{q_c(T_j)}{N} = \dot{Q}_c^{k=2}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \dot{E}_c^{k=2}(T_j) * \frac{n_j}{N}$$

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19. Use Equations 4.1.3–3 and 4.1.3–4, respectively, to evaluate $\dot{Q}_c^{k=2}(T_j)$ and $\dot{E}_c^{k=2}(T_j)$.

4.1.4 SEER Calculations for an Air Conditioner or Heat Pump Having a Variable-Speed Compressor

Calculate SEER using Equation 4.1–1. Evaluate the space cooling capacity, $\dot{Q}_c^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=1}(T_j)$, of the test unit when operating at minimum compressor speed and outdoor temperature T_j. Use,

$$\text{Equation 4.1.4-1} \quad \dot{Q}_c^{k=1}(T_j) = \dot{Q}_c^{k=1}(67) + \frac{\dot{Q}_c^{k=1}(82) - \dot{Q}_c^{k=1}(67)}{82-67} * (T_j - 67)$$

$$\text{Equation 4.1.4-2} \quad \dot{E}_c^{k=1}(T_j) = \dot{E}_c^{k=1}(67) + \frac{\dot{E}_c^{k=1}(82) - \dot{E}_c^{k=1}(67)}{82-67} * (T_j - 67)$$

where $\dot{Q}_c^{k=1}(82)$ and $\dot{E}_c^{k=1}(82)$ are determined from the B_1 test, $\dot{Q}_c^{k=1}(67)$ and $\dot{E}_c^{k=1}(67)$ are determined from the F1 test, and all four quantities are calculated as specified in section 3.3 of this appendix.

Evaluate the space cooling capacity, $\dot{Q}_c^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=2}(T_j)$, of the test unit when operating at full compressor speed and outdoor temperature T_j. Use Equations 4.1.3–3 and 4.1.3–4, respectively, where $\dot{Q}_c^{k=2}(95)$ and $\dot{E}_c^{k=2}(95)$ are determined from the A_2 test, $\dot{Q}_c^{k=2}(82)$ and $\dot{E}_c^{k=2}(82)$ are determined from the B_2 test, and all four quantities are calculated as specified in section 3.3 of this appendix. Calculate the space cooling capacity, $\dot{Q}_c^{k=v}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=v}(T_j)$, of the test unit when operating at outdoor temperature T_j and the intermediate compressor speed used during the section 3.2.4 (and Table 8) E_V test of this appendix using,

$$\text{Equation 4.1.4-3} \quad \dot{Q}_c^{k=v}(T_j) = \dot{Q}_c^{k=v}(87) + M_Q * (T_j - 87)$$

$$\text{Equation 4.1.4-4} \quad \dot{E}_c^{k=v}(T_j) = \dot{E}_h^{k=v}(87) + M_E * (T_j - 87)$$

where $\dot{Q}_c^{k=v}(87)$ and $\dot{E}_c^{k=v}(87)$ are determined from the E_V test and calculated as specified in section 3.3 of this appendix. Approximate the slopes of the k=v intermediate speed cooling capacity and electrical power input curves, M_Q and M_E, as follows:

$$M_Q = \left[\frac{\dot{Q}_c^{k=1}(82) - \dot{Q}_c^{k=1}(67)}{82-67} * (1 - N_Q)\right] + \left[N_Q * \frac{\dot{Q}_c^{k=2}(95) - \dot{Q}_c^{k=2}(82)}{95-82}\right]$$

$$M_E = \left[\frac{\dot{E}_c^{k=1}(82) - \dot{E}_c^{k=1}(67)}{82-67} * (1 - N_E)\right] + \left[N_E * \frac{\dot{E}_c^{k=2}(95) - \dot{E}_c^{k=2}(82)}{95-82}\right]$$

where,

$$N_Q = \frac{\dot{Q}_c^{k=v}(87) - \dot{Q}_c^{k=1}(87)}{\dot{Q}_c^{k=2}(87) - \dot{Q}_c^{k=1}(87)} \qquad N_E = \frac{\dot{E}_c^{k=v}(87) - \dot{E}_c^{k=1}(87)}{\dot{E}_c^{k=2}(87) - \dot{E}_c^{k=1}(87)}$$

Use Equations 4.1.4–1 and 4.1.4–2, respectively, to calculate $\dot{Q}_c^{k=1}(87)$ and $\dot{E}_c^{k=1}(87)$.

4.1.4.1 Steady-State Space Cooling Capacity When Operating at Minimum Compressor Speed Is Greater Than or Equal to the Building Cooling Load at Temperature T_j, $\dot{Q}_c^{k=1}(T_j) \geq BL(T_j)$

$$\frac{q_c(T_j)}{N} = X^{k=1}(T_j) * \dot{Q}_c^{k=1}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \frac{X^{k=1}(T_j) * \dot{E}_c^{k=1}(T_j)}{PLF_j} * \frac{n_j}{N}$$

where:

$X^{k=1}(T_j)$ = $BL(T_j)/\dot{Q}_c^{k=1}(T_j)$, the cooling mode minimum speed load factor for temperature bin j, dimensionless.

$PLF_j = 1 - C_D^c \cdot [1 - X^{k=1}(T_j)]$, the part load factor, dimensionless.

n_j/N = fractional bin hours for the cooling season; the ratio of the number of hours during the cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season, dimensionless.

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19. Use Equations 4.1.3–1 and 4.1.3–2, respectively, to evaluate $\dot{Q}_c^{k=1}(T_j)$ and $\dot{E}_c^{k=1}(T_j)$. Evaluate the cooling mode cyclic degradation factor C_D^c as specified in section 3.5.3 of this appendix.

4.1.4.2 Unit Operates at an Intermediate Compressor Speed (k=i) In Order To Match the Building Cooling Load at Temperature T_j, $\dot{Q}_c^{k=1}(T_j) < BL(T_j) < \dot{Q}_c^{k=2}(T_j)$

$$\frac{q_c(T_j)}{N} = \dot{Q}_c^{k=i}(T_j) * \frac{n_j}{N}$$

$$\frac{e_c(T_j)}{N} = \dot{E}_c^{k=i}(T_j) * \frac{n_j}{N}$$

Where:

$\dot{Q}_c^{k=i}(T_j) = BL(T_j)$, the space cooling capacity delivered by the unit in matching the building load at temperature T_j, Btu/h. The matching occurs with the unit operating at compressor speed k=i.

$\dot{E}_c^{k=i}(T_j) = \frac{\dot{Q}_c^{k=i}(T_j)}{EER^{k=i}(T_j)}$, the electrical power input required by the test unit when operating at a compressor speed of k=i and temperature T_j, W.

$EER^{k=i}(T_j)$ = the steady-state energy efficiency ratio of the test unit when operating at a compressor speed of k=i and temperature T_j, Btu/h per W.

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19 to this appendix. For each temperature bin where the unit operates at an intermediate compressor speed, determine the energy efficiency ratio $EER^{k=i}(T_j)$ using, $EER^{k=i}(T_j) = A + B\ T_j + C * T^2_j$.

For each unit, determine the coefficients A, B, and C by conducting the following calculations once:

$$A = EER^{k=2}(T_2) - (B * T_2) - (C * T_2^2)$$

$$B = \frac{EER^{k=1}(T_1) - EER^{k=2}(T_2) - D * [EER^{k=1}(T_1) - EER^{k=v}(T_v)]}{T_1 - T_2 - D * (T_1 - T_v)}$$

$$C = \frac{EER^{k=1}(T_1) - EER^{k=2}(T_2) - B * (T_1 - T_2)}{T_1^2 - T_2^2}$$

$$D = \frac{T_2^2 - T_1^2}{T_v^2 - T_1^2}$$

Where:

T_1 = the outdoor temperature at which the unit, when operating at minimum compressor speed, provides a space cooling capacity that is equal to the building load ($\dot{Q}_c^{k=1}(T_1) = BL(T_1)$), °F. Determine T_1 by equating Equations 4.1.3–1 and 4.1–2 to this appendix and solving for outdoor temperature.

T_v = the outdoor temperature at which the unit, when operating at the intermediate compressor speed used during the section 3.2.4 E_v test of this appendix, provides a space cooling capacity that is equal to the building load ($\dot{Q}_c^{k=v}(T_v) = BL(T_v)$), °F. Determine T_v by equating Equations 4.1.4–3 and 4.1–2 to this appendix and solving for outdoor temperature.

T_2 = the outdoor temperature at which the unit, when operating at full compressor speed, provides a space cooling capacity that is equal to the building load ($\dot{Q}_c^{k=2}(T_2) = BL(T_2)$), °F. Determine T_2 by equating Equations 4.1.3–3 and 4.1–2 to this appendix and solving for outdoor temperature.

$$EER^{k=1}(T_1) = \frac{\dot{Q}_c^{k=1}(T_1)\,[Equation\ 4.1.4{-}1,\ substituting\ T_1\ for\ T_j]}{\dot{E}_c^{k=1}(T_1)\,[Equation\ 4.1.4{-}2,\ substituting\ T_1\ for\ T_j]}, \text{ Btu/h per W}$$

$$EER^{k=v}(T_v) = \frac{\dot{Q}_c^{k=v}(T_v)\,[Equation\ 4.1.4{-}3,\ substituting\ T_v\ for\ T_j]}{\dot{E}_c^{k=v}(T_v)\,[Equation\ 4.1.4{-}4,\ substituting\ T_v\ for\ T_j]}, \text{ Btu/h per W}$$

$$EER^{k=2}(T_2) = \frac{\dot{Q}_c^{k=2}(T_2)\,[Equation\ 4.1.3{-}3,\ substituting\ T_2\ for\ T_j]}{\dot{E}_c^{k=2}(T_2)\,[Equation\ 4.1.3{-}4,\ substituting\ T_2\ for\ T_j]}, \text{ Btu/h per W}$$

4.1.4.3 Unit Must Operate Continuously at Full (k=2) Compressor Speed at Temperature Tj, $BL(T_j) \geq \dot{Q}_c^{k=2}(T_j)$. Evaluate the Equation 4.1–1 Quantities

$$\frac{q_c(T_j)}{N} \text{ and } \frac{e_c(T_j)}{N}$$

as specified in section 4.1.3.4 of this appendix with the understanding that $\dot{Q}_c^{k=2}(T_j)$ and $\dot{E}_c^{k=2}(T_j)$ correspond to full compressor speed operation and are derived from the results of the tests specified in section 3.2.4 of this appendix.

4.1.5 SEER Calculations for an Air Conditioner or Heat Pump Having a Single Indoor Unit With Multiple Indoor Blowers

Calculate SEER using Eq. 4.1–1, where $q_c(Tj)/N$ and $e_c(Tj)/N$ are evaluated as specified in the applicable subsection.

4.1.5.1 For Multiple Indoor Blower Systems That Are Connected to a Single, Single-Speed Outdoor Unit

a. Calculate the space cooling capacity, $\dot{Q}_c^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=1}(T_j)$, of the test unit when operating at the cooling minimum air volume rate and outdoor temperature T_j using the equations given in section 4.1.2.1 of this appendix. Calculate the space cooling capacity, $\dot{Q}_c^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=2}(T_j)$, of the test unit when operating at the cooling full-load air volume rate and outdoor temperature T_j using the equations given in section 4.1.2.1 of this appendix. In evaluating the section 4.1.2.1 equations, determine the quantities $\dot{Q}_c^{k=1}(82)$ and $\dot{E}_c^{k=1}(82)$ from the B1 test, $\dot{Q}_c^{k=1}(95)$ and $\dot{E}_c^{k=1}(95)$ from the A1 test, $\dot{Q}_c^{k=2}(82)$ and $\dot{E}_c^{k=2}(82)$ from the B2 test, and $\dot{Q}_c^{k=2}(95)$ and $\dot{E}_c^{k=2}(95)$ from the A2 test. Evaluate all eight quantities as specified in section 3.3 of this appendix. Refer to section 3.2.2.1 and Table 6 of this appendix for additional information on the four referenced laboratory tests.

b. Determine the cooling mode cyclic degradation coefficient, CD_c, as per sections 3.2.2.1 and 3.5 to 3.5.3 of this appendix. Assign this same value to $CD_c(K=2)$.

c. Except for using the above values of $\dot{Q}_c^{k=1}(T_j)$, $\dot{E}_c^{k=1}(T_j)$, $\dot{E}_c^{k=2}(T_j)$, $\dot{Q}_c^{k=2}(T_j)$, CD_c, and CD_c (K=2), calculate the quantities $q_c(T_j)/N$ and $e_c(T_j)/N$ as specified in section 4.1.3.1 of this appendix for cases where $\dot{Q}_c^{k=1}(T_j) \geq BL(T_j)$. For all other outdoor bin temperatures, T_j, calculate $q_c(Tj)/N$ and $e_c(Tj)/N$ as specified in section 4.1.3.3 of this appendix if $\dot{Q}_c^{k=2}(T_j) > BL(T_j)$ or as specified in section 4.1.3.4 of this appendix if $\dot{Q}_c^{k=2}(T_j) \leq BL(T_j)$.

4.1.5.2 Unit Operates at an Intermediate Compressor Speed (k=i) In Order To Match the Building Cooling Load at Temperature T_j, $\dot{Q}_c^{k=1}(T_j) < BL(T_j) < \dot{Q}_c^{k=2}(T_j)$

$$\frac{q_c(T_j)}{N} = \dot{Q}_c^{k=i}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \dot{E}_c^{k=i}(T_j) * \frac{n_j}{N}$$

where,

$\dot{Q}_c^{k=i}(T_j) = BL(T_j)$, the space cooling capacity delivered by the unit in matching the building load at temperature T_j, Btu/h. The matching occurs with the unit operating at compressor speed k = i.

$\dot{E}_c^{k=i}(T_j) = \frac{\dot{Q}_c^{k=i}(T_j)}{EER^{k=i}(T_j)}$, the electrical power input required by the test unit when operating at a compressor speed of k = i and temperature T_j, W.

$EER^{k=i}(T_j)$, the steady-state energy efficiency ratio of the test unit when operating at a compressor speed of k = i and temperature T_j, Btu/h per W.

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19. For each temperature bin where the unit operates at an intermediate compressor speed, determine the energy efficiency ratio $EER^{k=i}(T_j)$ using the following equations,

For each temperature bin where $\dot{Q}_c^{k=1}(T_j) < BL(T_j) < \dot{Q}_c^{k=v}(T_j)$,

$$EER^{k=i}(T_j) = EER^{k=1}(T_j) + \frac{EER^{k=v}(T_j) - EER^{k=1}(T_j)}{Q^{k=v}(T_j) - Q^{k=1}(T_j)} * (BL(T_j) - Q^{k=1}(T_j))$$

For each temperature bin where $\dot{Q}_c^{k=v}(T_j) \leq BL(T_j) < \dot{Q}_c^{k=2}(T_j)$,

$$EER^{k=i}(T_j) = EER^{k=v}(T_j) + \frac{EER^{k=2}(T_j) - EER^{k=v}(T_j)}{Q^{k=2}(T_j) - Q^{k=v}(T_j)} * (BL(T_j) - Q^{k=v}(T_j))$$

Where:

$EER^{k=1}(T_j)$ is the steady-state energy efficiency ratio of the test unit when operating at minimum compressor speed and temperature Tj, Btu/h per W, calculated using capacity $\dot{Q}_c^{k=1}(T_j)$ calculated using Equation 4.1.4–1 and electrical power consumption $\dot{E}_c^{k=1}(T_j)$ calculated using Equation 4.1.4–2;

$EER^{k=v}(T_j)$ is the steady-state energy efficiency ratio of the test unit when operating at intermediate compressor speed and temperature Tj, Btu/h per W, calculated using capacity $\dot{Q}_c^{k=v}(T_j)$ calculated using Equation 4.1.4–3 and electrical power consumption $\dot{E}_c^{k=v}(T_j)$ calculated using Equation 4.1.4–4;

$EER^{k=2}(T_j)$ is the steady-state energy efficiency ratio of the test unit when operating at full compressor speed and temperature Tj, Btu/h per W, calculated using capacity $\dot{Q}_c^{k=2}(T_j)$ and electrical power consumption $\dot{E}_c^{k=2}(T_j)$, both calculated as described in section 4.1.4; and

$BL(T_j)$ is the building cooling load at temperature T_j, Btu/h.

4.2 Heating Seasonal Performance Factor (HSPF) Calculations

Unless an approved alternative efficiency determination method is used, as set forth in 10 CFR 429.70(e), HSPF must be calculated as follows: Six generalized climatic regions are depicted in Figure 1 and otherwise defined in Table 20. For each of these regions and for each applicable standardized design heating requirement, evaluate the heating seasonal performance factor using,

Equation 4.2-1

$$HSPF = \frac{\sum_j^J n_j * BL(T_j)}{\sum_j^J e_h(T_j) + \sum_j^J RH(T_j)} * F_{def} = \frac{\sum_j^J \left[\frac{n_j}{N} * BL(T_j)\right]}{\sum_j^J \frac{e_h(T_j)}{N} + \sum_j^J \frac{RH(T_j)}{N}} * F_{def}$$

where:

$e2(T_j)/N$ = The ratio of the electrical energy consumed by the heat pump during periods of the space heating season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the heating season (N), W. For heat pumps having a heat comfort controller, this ratio may also include electrical energy used by resistive elements to maintain a minimum air delivery temperature (see 4.2.5).

$RH(T_j)/N$ = The ratio of the electrical energy used for resistive space heating during periods when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the heating season (N), W. Except as noted in section 4.2.5 of this appendix, resistive space heating is modeled as being used to meet that portion of the building load that the heat pump does not meet because of insufficient capacity or because the heat pump automatically turns off at the lowest outdoor temperatures. For heat pumps having a heat comfort controller, all or part of the electrical energy used by resistive heaters at a particular bin temperature may be reflected in $e_h(T_j)/N$ (see section 4.2.5 of this appendix).

T_j = the outdoor bin temperature, °F. Outdoor temperatures are ''binned'' such that calculations are only performed based one temperature within the bin. Bins of 5 °F are used.

n_j/N= Fractional bin hours for the heating season; the ratio of the number of hours during the heating season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the heating season, dimensionless. Obtain n_j/N values from Table 20.

j = the bin number, dimensionless.

J = for each generalized climatic region, the total number of temperature bins, dimensionless. Referring to Table 20, J is the highest bin number (j) having a nonzero entry for the fractional bin hours for the generalized climatic region of interest.

F_{def} = the demand defrost credit described in section 3.9.2 of this appendix, dimensionless.

$BL(T_j)$ = the building space conditioning load corresponding to an outdoor temperature of T_j; the heating season building load also depends on the generalized climatic region's outdoor design temperature and the design heating requirement, Btu/h.

TABLE 20—GENERALIZED CLIMATIC REGION INFORMATION

	Region No.					
	I	II	III	IV	V	VI
Heating Load Hours, HLH	750	1,250	1,750	2,250	2,750	*2,750
Outdoor Design Temperature, T_{OD}	37	27	17	5	−10	30
j T_j (°F)	Fractional Bin Hours, n_j/N					
1 62	.291	.215	.153	.132	.106	.113
2 57	.239	.189	.142	.111	.092	.206
3 52	.194	.163	.138	.103	.086	.215
4 47	.129	.143	.137	.093	.076	.204
5 42	.081	.112	.135	.100	.078	.141
6 37	.041	.088	.118	.109	.087	.076
7 32	.019	.056	.092	.126	.102	.034
8 27	.005	.024	.047	.087	.094	.008
9 22	.001	.008	.021	.055	.074	.003
10 17	0	.002	.009	.036	.055	0
11 12	0	0	.005	.026	.047	0
12 7	0	0	.002	.013	.038	0
13 2	0	0	.001	.006	.029	0
14 −3	0	0	0	.002	.018	0
15 −8	0	0	0	.001	.010	0
16 −13	0	0	0	0	.005	0
17 −18	0	0	0	0	.002	0
18 −23	0	0	0	0	.001	0

*Pacific Coast Region.

Evaluate the building heating load using

$$\text{Equation 4.2-2} \qquad BL(T_j) = \frac{(65-T_j)}{65-T_{OD}} * C * DHR$$

Where:

T_{OD} = the outdoor design temperature, °F. An outdoor design temperature is specified for each generalized climatic region in Table 20.

C = 0.77, a correction factor which tends to improve the agreement between calculated and measured building loads, dimensionless.

DHR = the design heating requirement (see section 1.2 of this appendix, Definitions), Btu/h.

Calculate the minimum and maximum design heating requirements for each generalized climatic region as follows:

$$DHR_{min} = \begin{Bmatrix} \dot{Q}_h^k(47) * \left[\frac{65 - T_{OD}}{60}\right], for\ Regions\ I, II, III, IV, \& VI \\ \dot{Q}_h^k(47), \qquad for\ Region\ V \end{Bmatrix}$$

and

$$DHR_{max} = \begin{Bmatrix} 2 * \dot{Q}_h^k(47) * \left[\frac{65 - T_{OD}}{60}\right], for\ Regions\ I, II, III, IV, \& VI \\ 2.2 * \dot{Q}_h^k(47), \qquad for\ Region\ V \end{Bmatrix}$$

Rounded to the nearest standardized DHR given in Table 20

where $\dot{Q}_h^k(47)$ is expressed in units of Btu/h and otherwise defined as follows:

a. For a single-speed heat pump tested as per section 3.6.1 of this appendix, $\dot{Q}_h^k(47) = \dot{Q}_h(47)$, the space heating capacity determined from the H1 test.

b. For a section 3.6.2 single-speed heat pump or a two-capacity heat pump not covered by item d, $\dot{Q}_h^k(47) = \dot{Q}_h^{k=2}(47)$, the space heating capacity determined from the H1 or $H1_2$ test.

c. For a variable-speed heat pump, $\dot{Q}_h^k(47) = \dot{Q}_h^{k=N}(47)$, the space heating capacity determined from the $H1_N$ test.

d. For two-capacity, northern heat pumps (see section 1.2 of this appendix, Definitions), $\dot{Q}^k{}_h(47) = \dot{Q}^{k=1}{}_h(47)$, the space heating capacity determined from the $H1_1$ test.

For all heat pumps, HSPF accounts for the heating delivered and the energy consumed by auxiliary resistive elements when operating below the balance point. This condition occurs when the building load exceeds the space heating capacity of the heat pump condenser. For HSPF calculations for all heat pumps, see either section 4.2.1, 4.2.2, 4.2.3, or 4.2.4 of this appendix, whichever applies.

For heat pumps with heat comfort controllers (see section 1.2 of this appendix, Definitions), HSPF also accounts for resistive heating contributed when operating above the heat-pump-plus-comfort-controller balance point as a result of maintaining a minimum supply temperature. For heat pumps having a heat comfort controller, see section 4.2.5 of this appendix for the additional steps required for calculating the HSPF.

TABLE 21—STANDARDIZED DESIGN HEATING REQUIREMENTS

[Btu/h]
5,000
10,000
15,000
20,000
25,000
30,000
35,000
40,000
50,000
60,000
70,000
80,000
90,000
100,000
110,000
130,000

4.2.1 Additional Steps for Calculating the HSPF of a Blower Coil System Heat Pump Having a Single-Speed Compressor and Either a Fixed-Speed Indoor Blower or a Constant-Air-Volume-Rate Indoor Blower Installed, or a Coil-Only System Heat Pump

Equation 4.2.1-1 $$\frac{e_h(T_j)}{N} = \frac{X(T_j)*\dot{E}_h(T_j)*\delta(T_j)}{PLF_j} * \frac{n_j}{N}$$

Equation 4.2.1-2 $$\frac{RH(T_j)}{N} = \frac{BL(T_j)-[X(T_j)*\dot{Q}_h(T_j)*\delta(T_j)]}{3.413\frac{Btu/h}{W}} * \frac{n_j}{N}$$

Where:

$$X(T_j) = \left\{ \begin{matrix} BL(T_J)/\dot{Q}_h(T_j) \\ or \\ 1 \end{matrix} \right\}$$

whichever is less; the heating mode load factor for temperature bin j, dimensionless.

$\dot{Q}_h(T_j)$ = the space heating capacity of the heat pump when operating at outdoor temperature T_j, Btu/h.

$\dot{E}_h(T_j)$ = the electrical power consumption of the heat pump when operating at outdoor temperature T_j, W.

$\delta(T_j)$ = the heat pump low temperature cut-out factor, dimensionless.

$PLF_j = 1 - \dot{C}_D{}^h \cdot [1 - X(T_j)]$ the part load factor, dimensionless.

Use Equation 4.2–2 to determine $BL(T_j)$. Obtain fractional bin hours for the heating season, n_j/N, from Table 20. Evaluate the heating mode cyclic degradation factor $\dot{C}_D{}^h$ as specified in section 3.8.1 of this appendix.

Determine the low temperature cut-out factor using

Equation 4.2.1-3 $$\delta(T_j) = \left\{ \begin{matrix} 0, if\ T_j \le T_{off}\ or\ \frac{\dot{Q}_h(T_j)}{3.413*\dot{E}_h(T_j)} < 1 \\ 1/2\,, if\ T_{off} < T_j \le T_{on}\ and\ \frac{\dot{Q}_h(T_j)}{3.413*\dot{E}_h(T_j)} \ge 1 \\ 1, if\ T_j > T_{on}\ and\ \frac{\dot{Q}_h(T_j)}{3.413*\dot{E}_h(T_j)} \ge 1 \end{matrix} \right\}$$

Where:

T_{off} = the outdoor temperature when the compressor is automatically shut off, °F. (If no such temperature exists, T_j is always greater than T_{off} and T_{on}).

T_{on} = the outdoor temperature when the compressor is automatically turned back on, if applicable, following an automatic shut-off, °F.

Calculate $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using,

Equation 4.2.1-4

$$\dot{Q}_h(T_j) = \begin{cases} \dot{Q}_h(17) + \frac{[\dot{Q}_h(47) - \dot{Q}_h(17)] * (T_j - 17)}{47 - 17}, & if\ T_j \geq 45\ °\text{F}\ or\ T_j \leq 17\ °\text{F} \\ \dot{Q}_h(17) + \frac{[\dot{Q}_h(35) - \dot{Q}_h(17)] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} < T_j < 45\ °\text{F} \end{cases}$$

Equation 4.2.1-5

$$\dot{E}_h(T_j) = \begin{cases} \dot{E}_h(17) + \frac{\left[\dot{E}_h(47) - \dot{E}_h(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j \geq 45\ °\text{F}\ or\ T_j \leq 17\ °\text{F} \\ \dot{E}_h(17) + \frac{\left[\dot{E}_h(35) - \dot{E}_h(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} < T_j < 45\ °\text{F} \end{cases}$$

where $\dot{Q}_h(47)$ and $\dot{E}_h(47)$ are determined from the H1 test and calculated as specified in section 3.7 of this appendix; $\dot{Q}_h(35)$ and $\dot{E}_h(35)$ are determined from the H2 test and calculated as specified in section 3.9.1 of this appendix; and $\dot{Q}_h(17)$ and $\dot{E}_h(17)$ are determined from the H3 test and calculated as specified in section 3.10 of this appendix.

4.2.2 Additional Steps for Calculating the HSPF of a Heat Pump Having a Single-Speed Compressor and a Variable-Speed, Variable-Air-Volume-Rate Indoor Blower

The manufacturer must provide information about how the indoor air volume rate or the indoor blower speed varies over the outdoor temperature range of 65 °F to −23 °F. Calculate the quantities

$$\frac{e_h(T_j)}{N} \text{ and } \frac{RH(T_j)}{N}$$

in Equation 4.2–1 as specified in section 4.2.1 of this appendix with the exception of replacing references to the H1C test and section 3.6.1 of this appendix with the $H1C_1$ test and section 3.6.2 of this appendix. In addition, evaluate the space heating capacity and electrical power consumption of the heat pump $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using

Equation 4.2.2-1

$$\dot{Q}_h(T_j) = \dot{Q}_h^{k=1}(T_j) + \frac{\dot{Q}_h^{k=2}(T_j) - \dot{Q}_h^{k=1}(T_j)}{FP_h^{k=2} - FP_h^{k=1}} * \left[FP_h(T_j) - FP_h^{k=1}\right]$$

Equation 4.2.2-2

$$\dot{E}_h(T_j) = \dot{E}_h^{k=1}(T_j) + \frac{\dot{E}_h^{k=2}(T_j) - \dot{E}_h^{k=1}(T_j)}{FP_h^{k=2} - FP_h^{k=1}} * \left[FP_h(T_j) - FP_h^{k=1}\right]$$

where the space heating capacity and electrical power consumption at both low capacity (k=1) and high capacity (k=2) at outdoor temperature Tj are determined using

Equation 4.2.2-3 $$\dot{Q}_h^k(T_j) = \begin{cases} \dot{Q}_h^k(17) + \frac{\left[\dot{Q}_h^k(47) - \dot{Q}_h^k(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j \geq 45\ °\text{F}\ or\ T_j \leq 17\ °\text{F} \\ \dot{Q}_h^k(17) + \frac{\left[\dot{Q}_h^k(35) - \dot{Q}_h^k(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} < T_j < 45\ °\text{F} \end{cases}$$

Equation 4.2.2-4

$$\dot{E}_h^k(T_j) = \begin{cases} \dot{E}_h^k(17) + \frac{\left[\dot{E}_h^k(47) - \dot{E}_h^k(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j \geq 45\ °\text{F}\ or\ T_j \leq 17\ °\text{F} \\ \dot{E}_h^k(17) + \frac{\left[\dot{E}_h^k(35) - \dot{E}_h^k(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} < T_j < 45\ °\text{F} \end{cases}$$

For units where indoor blower speed is the primary control variable, $FP_h^{k=1}$ denotes the fan speed used during the required $H1_1$ and $H3_1$ tests (see Table 12), $FP_h^{k=2}$ denotes the fan speed used during the required $H1_2$, $H2_2$, and $H3_2$ tests, and $FP_h(T_j)$ denotes the fan speed used by the unit when the outdoor temperature equals T_j. For units where indoor air volume rate is the primary control variable, the three FP_h's are similarly defined only now being expressed in terms of air volume rates rather than fan speeds. Determine $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the $H1_1$ test, and $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the $H1_2$ test. Calculate all four quantities as specified in section 3.7 of this appendix. Determine $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ as specified in section 3.6.2 of this appendix; determine $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ and from the $H2_2$ test and the calculation specified in section 3.9 of this appendix. Determine $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ from the $H3_1$ test, and $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test. Calculate all four quantities as specified in section 3.10 of this appendix.

4.2.3 Additional Steps for Calculating the HSPF of a Heat Pump Having a Two-Capacity Compressor

The calculation of the Equation 4.2–1 to this appendix quantities differ depending upon whether the heat pump would operate at low capacity (section 4.2.3.1 of this appendix), cycle between low and high capacity (section 4.2.3.2 of this appendix), or operate at high capacity (sections 4.2.3.3 and 4.2.3.4 of this appendix) in responding to the building load. For heat pumps that lock out low capacity operation at low outdoor temperatures, the outdoor temperature at which the unit locks out must be that specified by the manufacturer in the certification report so that the appropriate equations can be selected.

a. Evaluate the space heating capacity and electrical power consumption of the heat pump when operating at low compressor capacity and outdoor temperature T_j using

$$\dot{Q}_h^{k=1}(T_j) = \begin{cases} \dot{Q}_h^{k=1}(47) + \frac{\left[\dot{Q}_h^{k=1}(62) - \dot{Q}_h^{k=1}(47)\right] * (T_j - 47)}{62 - 47}, & if\ T_j \geq 40\ °\text{F} \\ \dot{Q}_h^{k=1}(17) + \frac{\left[\dot{Q}_h^{k=1}(35) - \dot{Q}_h^{k=1}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} \leq T_j < 40\ °\text{F} \\ \dot{Q}_h^{k=1}(17) + \frac{\left[\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j < 17\ °\text{F} \end{cases}$$

$$\dot{E}_h^{k=1}(T_j) = \begin{cases} \dot{E}_h^{k=1}(47) + \frac{\left[\dot{E}_h^{k=1}(62) - \dot{E}_h^{k=1}(47)\right] * (T_j - 47)}{62 - 47}, & if\ T_j \geq 40\ °\text{F} \\ \dot{E}_h^{k=1}(17) + \frac{\left[\dot{E}_h^{k=1}(35) - \dot{E}_h^{k=1}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} \leq T_j < 40\ °\text{F} \\ \dot{E}_h^{k=1}(17) + \frac{\left[\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j < 17\ °\text{F} \end{cases}$$

b. Evaluate the space heating capacity and electrical power consumption ($\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$) of the heat pump when operating at high compressor capacity and outdoor temperature Tj by solving Equations 4.2.2–3 and 4.2.2–4, respectively, for k=2. Determine $\dot{Q}_h^{k=1}(62)$ and $\dot{E}_h^{k=1}(62)$ from the $H0_1$ test, $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the $H1_1$ test, and $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the $H1_2$ test. Calculate all six quantities as specified in section 3.7 of this appendix. Determine $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the $H2_2$ test and, if required as described in section 3.6.3 of this appendix, determine $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ from the $H2_1$ test. Calculate the required 35 °F quantities as specified in section 3.9 of this appendix. Determine $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test and, if required as described in section 3.6.3 of this appendix, determine $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ from the $H3_1$ test. Calculate the required 17 °F quantities as specified in section 3.10 of this appendix.

4.2.3.1 Steady-State Space Heating Capacity When Operating at Low Compressor Capacity is Greater Than or Equal to the Building Heating Load at Temperature T_j, $\dot{Q}_h^{k=1}(T_j) \geq BL(T_j)$

$$\text{Equation 4.2.3-1} \quad \frac{e_h(T_j)}{N} = \frac{X^{k=1}(T_j) * \dot{E}_h^{k=1}(T_j) * \delta(T_j)}{PLF_j} * \frac{n_j}{N}$$

$$\text{Equation 4.2.3-2} \quad \frac{RH(T_j)}{N} = \frac{BL(T_j) * [1 - \delta(T_j)]}{3.413 \frac{Btu/h}{W}} * \frac{n_j}{N}$$

Where:

$X^{k=1}(T_j) = BL(T_j)/\dot{Q}_h^{k=1}(T_j)$, the heating mode low capacity load factor for temperature bin *j*, dimensionless.

$PLF_j = 1 - C_D^h \cdot [\, 1 - X^{k=1}(T_j) \,]$, the part load factor, dimensionless.

$\delta'(T_j)$ = the low temperature cutoff factor, dimensionless.

Evaluate the heating mode cyclic degradation factor C_D^h as specified in section 3.8.1 of this appendix.

Determine the low temperature cut-out factor using

$$\text{Equation 4.2.3-3} \quad \delta(T_j) = \begin{cases} 0, \ if \ T_j \leq T_{off} \\ 1/2, \ if \ T_{off} < T_j \leq T_{on} \\ 1, \ if \ T_j > T_{on} \end{cases}$$

where T_{off} and T_{on} are defined in section 4.2.1 of this appendix. Use the calculations given in section 4.2.3.3 of this appendix, and not the above, if:

a. The heat pump locks out low capacity operation at low outdoor temperatures and

b. T_j is below this lockout threshold temperature.

4.2.3.2 Heat Pump Alternates Between High (k=2) and Low (k=1) Compressor Capacity To Satisfy the Building Heating Load at a Temperature T_j, $\dot{Q}_h^{k=1}(T_j) < BL(T_j) < \dot{Q}_h^{k=2}(T_j)$

Calculate $\frac{RH(T_j)}{N}$ using Equation 4.2.3-2. Evaluate $\frac{e_h(T_j)}{N}$ using

$$\frac{e_h(T_j)}{N} = [X^{k=1}(T_j) * \dot{E}_h^{k=1}(T_j) + X^{k=2}(T_j) * \dot{E}_h^{k=2}(T_j)] * \delta(T_j) * \frac{n_j}{N}$$

where:

$$X^{k=1}(T_j) = \frac{\dot{Q}_h^{k=2}(T_j) - BL(T_j)}{\dot{Q}_h^{k=2}(T_j) - \dot{Q}_h^{k=1}(T_j)}$$

$X^{k=2}(T_j) = 1 - X^{k=1}(T_j)$ the heating mode, high capacity load factor for temperaturebin $_j$, dimensionless.

Determine the low temperature cut-out factor, $\delta'(T_j)$, using Equation 4.2.3–3.

4.2.3.3 Heat Pump Only Operates at High (k=2) Compressor Capacity at Temperature T_j and its Capacity Is Greater Than the Building Heating Load, $BL(T_j) < \dot{Q}_h^{k=2}(T_j)$

This section applies to units that lock out low compressor capacity operation at low outdoor temperatures.

Calculate $\frac{RH(T_j)}{N}$ using Equation 4.2.3-2. Evaluate $\frac{e_h(T_j)}{N}$ using

$$\frac{e_h(T_j)}{N} = \frac{X^{k=2}(T_j) * \dot{E}_h^{k=2}(T_j) * \delta(T_j)}{PLF_j} * \frac{n_j}{N}$$

Where:

$X^{k=2}(T_j) = BL(T_j)/\dot{Q}_h^{k=2}(T_j)$; and
$PLF_j = 1 - C^h{}_D\ (k = 2) * [1 - X^{k=2}(T_j)]$.

If the $H1C_2$ test described in section 3.6.3 and Table 13 of this appendix is not conducted, set $C_D{}^h$ (k=2) equal to the default value specified in section 3.8.1 of this appendix.

Determine the low temperature cut-out factor, $\delta(T_j)$, using Equation 4.2.3–3.

4.2.3.4 Heat Pump Must Operate Continuously at High (k=2) Compressor Capacity at Temperature T_j, $BL(T_j) \geq \dot{Q}_h{}^{k=2}(T_j)$

$$\frac{e_h(T_j)}{N} = \dot{E}_h^{k=2}(T_j) * \delta'(T_j) * \frac{n_j}{N}$$

$$\frac{RH(T_j)}{N} = \frac{BL(T_j) - [\dot{Q}_h^{k=2}(T_j) * \delta'(T_j)]}{3.413\frac{Btu}{Wh}} * \frac{n_j}{N}$$

Where:

$$\delta'(T_j) = \begin{cases} 0, & if\ T_j \le T_{off}\ or\ \dfrac{\dot{Q}_h^{k=2}(T_j)}{3.413 * \dot{E}_h^{k=2}(T_j)} < 1 \\ \dfrac{1}{2}, & if\ T_{off} < T_j \le T_{on}\ and\ \dfrac{\dot{Q}_h^{k=2}(T_j)}{3.413 * \dot{E}_h^{k=2}(T_j)} \ge 1 \\ 1, & if\ T_j > T_{on}\ and\ \dfrac{\dot{Q}_h^{k=2}(T_j)}{3.413 * \dot{E}_h^{k=2}(T_j)} \ge 1 \end{cases}$$

4.2.4 Additional Steps for Calculating the HSPF of a Heat Pump Having a Variable-Speed Compressor

Calculate HSPF using Equation 4.2–1. Evaluate the space heating capacity, $\dot{Q}_h^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=1}(T_j)$, of the heat pump when operating at minimum compressor speed and outdoor temperature T_j using

$$\text{Equation 4.2.4-1}\quad \dot{Q}_h^{k=1}(T_j) = \dot{Q}_h^{k=1}(47) + \frac{\dot{Q}_h^{k=1}(62) - \dot{Q}_h^{k=1}(47)}{62-47} * (T_j - 47)$$

$$\text{Equation 4.2.4-2}\quad \dot{E}_h^{k=1}(T_j) = \dot{E}_h^{k=1}(47) + \frac{\dot{E}_h^{k=1}(62) - \dot{E}_h^{k=1}(47)}{62-47} * (T_j - 47)$$

where $\dot{Q}_h^{k=1}(62)$ and $\dot{E}_h^{k=1}(62)$ are determined from the $H0_1$ test, $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ are determined from the $H1_1$ test, and all four quantities are calculated as specified in section 3.7 of this appendix.

Evaluate the space heating capacity, $\dot{Q}_h^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=2}(T_j)$, of the heat pump when operating at full compressor speed and outdoor temperature T_j by solving Equations 4.2.2–3 and 4.2.2–4, respectively, for k=2. For Equation 4.2.2–3, use $\dot{Q}_{hcalc}^{k=2}(47)$ to represent $\dot{Q}_h^{k=2}(47)$, and for Equation 4.2.2–4, use $\dot{E}_{hcalc}^{k=2}(47)$ to represent $\dot{E}_{hcalc}^{k=2}(47)$—evaluate $\dot{Q}_{hcalc}^{k=2}(47)$ and $\dot{E}_{hcalc}^{k=2}(47)$ as specified in section 3.6.4b of this appendix.

$$\text{Equation 4.2.4-3}\quad \dot{Q}_h^{k=v}(T_j) = \dot{Q}_h^{k=v}(35) + M_Q * (T_j - 35)$$

$$\text{Equation 4.2.4-4}\quad \dot{E}_h^{k=v}(T_j) = \dot{E}_h^{k=v}(35) + M_E * (T_j - 35)$$

where $\dot{Q}_h^{k=v}(35)$ and $\dot{E}_h^{k=v}(35)$ are determined from the $H2_V$ test and calculated as specified in section 3.9 of this appendix. Approximate the slopes of the k=v intermediate speed heating capacity and electrical power input curves, M_Q and M_E, as follows:

$$M_Q = \left[\frac{\dot{Q}_h^{k=1}(62) - \dot{Q}_h^{k=1}(47)}{62-47} * (1 - N_Q)\right] + \left[N_Q * \frac{\dot{Q}_h^{k=2}(35) - \dot{Q}_h^{k=2}(17)}{35-17}\right]$$

$$M_E = \left[\frac{\dot{E}_h^{k=1}(62) - \dot{E}_h^{k=1}(47)}{62-47} * (1 - N_E)\right] + \left[N_E * \frac{\dot{E}_h^{k=2}(35) - \dot{E}_h^{k=2}(17)}{35-17}\right]$$

where,

$$N_Q = \frac{\dot{Q}_h^{k=v}(35) - \dot{Q}_h^{k=1}(35)}{\dot{Q}_h^{k=2}(35) - \dot{Q}_h^{k=1}(35)} \qquad N_E = \frac{\dot{E}_h^{k=v}(35) - \dot{E}_h^{k=1}(35)}{\dot{E}_h^{k=2}(35) - \dot{E}_h^{k=1}(35)}$$

Use Equations 4.2.4-1 and 4.2.4-2, respectively, to calculate $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$.

The calculation of Equation 4.2-1 quantities $\frac{RH(T_j)}{N}$ and $\frac{e_h(T_j)}{N}$ differs depending upon whether the heat pump would operate at minimum speed (section 4.2.4.1 of this appendix), operate at an intermediate speed (section 4.2.4.2 of this appendix), or operate at full speed (section 4.2.4.3 of this appendix) in responding to the building load.

4.2.4.1 Steady-State Space Heating Capacity When Operating at Minimum Compressor Speed Is Greater Than or Equal to the Building Heating Load at Temperature T_j, $\dot{Q}_h^{k=1}(T_j) \geq BL(T_j)$

Evaluate the Equation 4.2–1 quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.1 of this appendix. Except now use Equations 4.2.4–1 and 4.2.4–2 to evaluate $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$, respectively, and replace section 4.2.3.1 references to ''low capacity'' and section 3.6.3 of this appendix with ''minimum speed'' and section 3.6.4 of this appendix. Also, the last sentence of section 4.2.3.1 of this appendix does not apply.

4.2.4.2 Heat Pump Operates at an Intermediate Compressor Speed (k=i) in Order To Match the Building Heating Load at a Temperature T_j, $\dot{Q}_h^{k=1}(T_j) < BL(T_j) < \dot{Q}_h^{k=2}(T_j)$

Calculate $\frac{RH(T_j)}{N}$ using Equation 4.2.3-2 while evaluating $\frac{e_h(T_j)}{N}$ using,

$$\frac{e_h(T_j)}{N} = \dot{E}_h^{k=i}(T_j) * \delta(T_j) * \frac{n_j}{N}$$

where,

$$\dot{E}_h^{k=i}(T_j) = \frac{\dot{Q}_h^{k=i}(T_j)}{3.413\frac{Btu/h}{W} * COP^{k=i}(T_j)}$$

and $\delta(T_j)$ is evaluated using Equation 4.2.3–3 while,

$\dot{Q}_h^{k=i}(T_j)$ = $BL(T_j)$, the space heating capacity delivered by the unit in matching the building load at temperature (T_j), Btu/h. The matching occurs with the heat pump operating at compressor speed k=i.

$COP^{k=i}(T_j)$ = the steady-state coefficient of performance of the heat pump when operating at compressor speed k=i and temperature T_j, dimensionless.

For each temperature bin where the heat pump operates at an intermediate compressor speed, determine $COP^{k=i}(T_j)$ using the following equations,

For each temperature bin where $\dot{Q}_h^{k=1}(T_j) < BL(T_j) < \dot{Q}_h^{k=v}(T_j)$,

$$COP_h^{k=i}(T_j) = COP_h^{k=1}(T_j) + \frac{COP_h^{k=v}(T_j) - COP_h^{k=1}(T_j)}{Q_h^{k=v}(T_j) - Q_h^{k=1}(T_j)} * (BL(T_j) - Q_h^{k=1}(T_j))$$

For each temperature bin where $\dot{Q}_h^{k=v}(T_j) \leq BL(T_j) < \dot{Q}_h^{k=2}(T_j)$,

$$COP_h^{k=i}(T_j) = COP_h^{k=v}(T_j) + \frac{COP_h^{k=2}(T_j) - COP_h^{k=v}(T_j)}{Q_h^{k=2}(T_j) - Q_h^{k=v}(T_j)} * (BL(T_j) - Q_h^{k=v}(T_j))$$

Where:

$COP_h^{k=1}(T_j)$ is the steady-state coefficient of performance of the heat pump when operating at minimum compressor speed and temperature Tj, dimensionless, calculated using capacity $\dot{Q}_h^{k=1}(T_j)$ calculated using Equation 4.2.4–1 and electrical power consumption $\dot{E}_h^{k=1}(T_j)$ calculated using Equation 4.2.4–2;

$COP_h^{k=v}(T_j)$ is the steady-state coefficient of performance of the heat pump when operating at intermediate compressor speed and temperature Tj, dimensionless, calculated using capacity $\dot{Q}_h^{k=v}(T_j)$ calculated using Equation 4.2.4–3 and electrical power consumption $\dot{E}_h^{k=v}(T_j)$ calculated using Equation 4.2.4–4;

$COP_h^{k=2}(T_j)$ is the steady-state coefficient of performance of the heat pump when operating at full compressor speed and temperature Tj, dimensionless, calculated using capacity $\dot{Q}_h^{k=2}(T_j)$ and electrical power consumption $\dot{E}_h^{k=2}(T_j)$, both calculated as described in section 4.2.4; and

$BL(T_j)$ is the building heating load at temperature T_j, Btu/h.

4.2.4.3 Heat Pump Must Operate Continuously at Full (k=2) Compressor Speed at Temperature T_j, $BL(T_j) \geq \dot{Q}_h^{k=2}(T_j)$

Evaluate the Equation 4.2–1 Quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.4 of this appendix with the understanding that $\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$ correspond to full compressor speed operation and are derived from the results of the specified section 3.6.4 tests of this appendix.

4.2.5 Heat Pumps Having a Heat Comfort Controller

Heat pumps having heat comfort controllers, when set to maintain a typical minimum air delivery temperature, will cause the heat pump condenser to operate less because of a greater contribution from the resistive elements. With a conventional heat pump, resistive heating is only initiated if the heat pump condenser cannot meet the building load (*i.e.*, is delayed until a second stage call from the indoor thermostat). With a heat comfort controller, resistive heating can occur even though the heat pump condenser has adequate capacity to meet the building load (*i.e.*, both on during a first stage call from the indoor thermostat). As a result, the outdoor temperature where the heat pump compressor no longer cycles (*i.e.*, starts to run continuously), will be lower than if the heat pump did not have the heat comfort controller.

4.2.5.1 Blower Coil System Heat Pump Having a Heat Comfort Controller: Additional Steps for Calculating the HSPF of a Heat Pump Having a Single-Speed Compressor and Either a Fixed-Speed Indoor Blower or a Constant-Air-Volume-Rate Indoor Blower Installed, or a Coil-Only System Heat Pump

Calculate the space heating capacity and electrical power of the heat pump without the heat comfort controller being active as specified in section 4.2.1 of this appendix (Equations 4.2.1–4 and 4.2.1–5) for each outdoor bin temperature, T_j, that is listed in Table 20. Denote these capacities and electrical powers by using the subscript ''hp'' instead of ''h.'' Calculate the mass flow rate (expressed in pounds-mass of dry air per hour) and the specific heat of the indoor air (expressed in $Btu/lbm_{da} \cdot °F$) from the results of the H1 test using:

$$\dot{m}_{da} = \overline{\dot{V}_s} * 0.075 \frac{lbm_{da}}{ft^3} * \frac{60_{min}}{hr} = \frac{\overline{\dot{V}}_{mx}}{v'_n * [1 + W_n]} * \frac{60_{min}}{hr} = \frac{\overline{\dot{V}}_{mx}}{v_n} * \frac{60_{min}}{hr}$$

where $\overline{\dot{V}}_s$, $\overline{\dot{V}}_{mx}$, v'_n (or v_n), and W_n are defined following Equation 3–1. For each outdoor bin temperature listed in Table 20, calculate the nominal temperature of the air leaving the heat pump condenser coil using,

$$T_0(T_j) = 70°F + \frac{\dot{Q}_{hp}(T_j)}{\dot{m}_{da} * C_{p,da}}$$

Evaluate $e_h(T_j/N)$, $RH(T_j)/N$, $X(T_j)$, PLF_j, and $\delta(T_j)$ as specified in section 4.2.1 of this appendix. For each bin calculation, use the space heating capacity and electrical power from Case 1 or Case 2, whichever applies.

Case 1. For outdoor bin temperatures where $T_o(T_j)$ is equal to or greater than T_{CC} (the maximum supply temperature determined according to section 3.1.10 of this appendix), determine $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ as specified in section 4.2.1 of this appendix (*i.e.*, $\dot{Q}_h(T_j) = \dot{Q}_{hp}(T_j)$ and $\dot{E}_h(T_j) = \dot{E}_{hp}(T_j)$). NOTE: Even though $T_o(T_j) \geq T_{cc}$, resistive heating

may be required; evaluate Equation 4.2.1–2 for all bins.

Case 2. For outdoor bin temperatures where $T_o(T_j) < T_{CC}$, determine $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using,

$$\dot{Q}_h(T_j) = \dot{Q}_{hp}(T_j) + \dot{Q}_{CC}(T_j) \qquad \dot{E}_h(T_j) = \dot{E}_{hp}(T_j) + \dot{E}_{CC}(T_j)$$

where,

$$\dot{Q}_{CC}(T_j) = \dot{m}_{da} * C_{p,da} * [T_{CC} - T_0(T_j)] \qquad \dot{E}_{CC}(T_j) = \frac{\dot{Q}_{CC}(T_j)}{3.413\frac{Btu/h}{W}}$$

NOTE: Even though $T_o(T_j)$ T_{cc}, additional resistive heating may be required; evaluate Equation 4.2.1–2 for all bins.

4.2.5.2 Heat Pump Having a Heat Comfort Controller: Additional Steps for Calculating the HSPF of a Heat Pump Having a Single-Speed Compressor and a Variable-Speed, Variable-Air-Volume-Rate Indoor Blower

Calculate the space heating capacity and electrical power of the heat pump without the heat comfort controller being active as specified in section 4.2.2 of this appendix (Equations 4.2.2–1 and 4.2.2–2) for each outdoor bin temperature, T_j, that is listed in Table 20. Denote these capacities and electrical powers by using the subscript ''hp'' instead of ''h.'' Calculate the mass flow rate (expressed in pounds-mass of dry air per hour) and the specific heat of the indoor air (expressed in $Btu/lbm_{da} \cdot °F$) from the results of the $H1_2$ test using:

$$\dot{m}_{da} = \overline{\dot{V}}_s * 0.075\frac{lbm_{da}}{ft^3} * \frac{60_{min}}{hr} = \frac{\overline{\dot{V}}_{mx}}{v'_n * [1 + W_n]} * \frac{60_{min}}{hr} = \frac{\overline{\dot{V}}_{mx}}{v_n} * \frac{60_{min}}{hr}$$

$$C_{p,da} = 0.24 + 0.444 * W_n$$

where $\overline{\dot{V}}_S$, $\overline{\dot{V}}_{mx}$, v'_n (or v_n), and W_n are defined following Equation 3–1. For each outdoor bin temperature listed in Table 20, calculate the nominal temperature of the air leaving the heat pump condenser coil using,

$$T_0(T_j) = 70°\text{F} + \frac{\dot{Q}_{hp}(T_j)}{\dot{m}_{da} * C_{p,da}}$$

Evaluate $e_h(T_j)/N$, $RH(T_j)/N$, $X(T_j)$, PLF_j, and $\delta(T_j)$ as specified in section 4.2.1 of this appendix with the exception of replacing references to the H1C test and section 3.6.1 of this appendix with the $H1C_1$ test and section 3.6.2 of this appendix. For each bin calculation, use the space heating capacity and electrical power from Case 1 or Case 2, whichever applies.

Case 1. For outdoor bin temperatures where $T_o(T_j)$ is equal to or greater than T_{CC} (the maximum supply temperature determined according to section 3.1.10 of this appendix), determine $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ as specified in section 4.2.2 of this appendix (*i.e.* $\dot{Q}_h(T_j) = \dot{Q}_{hp}(T_j)$ and $\dot{E}_h(T_j) = \dot{E}_{hp}(T_j)$). Note: Even though $T_o(T_j) \geq T_{CC,}$ resistive heating may be required; evaluate Equation 4.2.1–2 for all bins.

Case 2. For outdoor bin temperatures where $T_o(T_j) < T_{CC}$, determine $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using,

$$\dot{Q}_h(T_j) = \dot{Q}_{hp}(T_j) + \dot{Q}_{CC}(T_j) \qquad \dot{E}_h(T_j) = \dot{E}_{hp}(T_j) + \dot{E}_{CC}(T_j)$$

where,

$$\dot{Q}_{CC}(T_j) = \dot{m}_{da} * C_{p,da} * [T_{CC} - T_0(T_j)] \qquad \dot{E}_{CC}(T_j) = \frac{\dot{Q}_{CC}(T_j)}{3.413\frac{Btu/h}{W}}$$

NOTE: Even though $T_0(T_j)$ T_{cc}, additional resistive heating may be required; evaluate Equation 4.2.1–2 for all bins.

4.2.5.3 Heat Pumps Having a Heat Comfort Controller: Additional Steps for Calculating the HSPF of a Heat Pump Having a Two-Capacity Compressor

Calculate the space heating capacity and electrical power of the heat pump without the heat comfort controller being active as specified in section 4.2.3 of this appendix for both high and low capacity and at each outdoor bin temperature, T_j, that is listed in Table 20. Denote these capacities and electrical powers by using the subscript ''hp'' instead of ''h.'' For the low capacity case, calculate the mass flow rate (expressed in pounds-mass of dry air per hour) and the specific heat of the indoor air (expressed in Btu/lbm_{da} · °F) from the results of the $H1_1$ test using:

$$\dot{m}_{da}^{k=1} = \overline{\dot{V}}_s * 0.075\frac{lbm_{da}}{ft^3} * \frac{60_{min}}{hr} = \frac{\overline{\dot{V}}_{mx}}{v'_n * [1 + W_n]} * \frac{60_{min}}{hr} = \frac{\overline{\dot{V}}_{mx}}{v_n} * \frac{60_{min}}{hr}$$

$$C_{p,da}^{k=1} = 0.24 + 0.444 * W_n$$

where $\overline{\dot{V}}_s$, $\overline{\dot{V}}_{mx}$, v'_n (or v_n), and W_n are defined following Equation 3–1. For each outdoor bin temperature listed in Table 20, calculate the nominal temperature of the air leaving the heat pump condenser coil when operating at low capacity using,

$$T_0^{k=1}(T_j) = 70°\text{F} + \frac{\dot{Q}_{hp}^{k=1}(T_j)}{\dot{m}_{da}^{k=1} * C_{p,da}^{k=1}}$$

Repeat the above calculations to determine the mass flow rate ($\dot{m}_{da}^{k=2}$) and the specific heat of the indoor air ($C_{p,da}^{k=2}$) when operating at high capacity by using the results of the $H1_2$ test. For each outdoor bin temperature listed in Table 20, calculate the nominal temperature of the air leaving the heat pump condenser coil when operating at high capacity using,

$$T_0^{k=2}(T_j) = 70°\text{F} + \frac{\dot{Q}_{hp}^{k=2}(T_j)}{\dot{m}_{da}^{k=2} * C_{p,da}^{k=2}}$$

Evaluate $e_h(T_j)/N$, $RH(T_j)/N$, $X^{k=1}(T_j)$, and/or $X^{k=2}(T_j)$, PLF_j, and $\delta'(T_j)$ or $\delta''(T_j)$ as specified in section 4.2.3.1. 4.2.3.2, 4.2.3.3, or 4.2.3.4 of this appendix, whichever applies, for each

temperature bin. To evaluate these quantities, use the low-capacity space heating capacity and the low-capacity electrical power from Case 1 or Case 2, whichever applies; use the high-capacity space heating capacity and the high-capacity electrical power from Case 3 or Case 4, whichever applies.

Case 1. For outdoor bin temperatures where $T_o^{k=1}(T_j)$ is equal to or greater than T_{CC} (the maximum supply temperature determined according to section 3.1.10 of this appendix), determine $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$ as specified in section 4.2.3 of this appendix (*i.e.*, $\dot{Q}_h^{k=1}(T_j) = \dot{Q}_{hp}^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j) = \dot{E}_{hp}^{k=1}(T_j)$).

NOTE: Even though $T_o^{k=1}(T_j) \geq T_{CC}$, resistive heating may be required; evaluate $RH(T_j)/N$ for all bins.

Case 2. For outdoor bin temperatures where $T_o^{k=1}(T_j) < T_{CC}$, determine $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$ using,

$$\dot{Q}_h^{k=1}(T_j) = \dot{Q}_{hp}^{k=1}(T_j) + \dot{Q}_{CC}^{k=1}(T_j) \qquad \dot{E}_h^{k=1}(T_j) = \dot{E}_{hp}^{k=1}(T_j) + \dot{E}_{CC}^{k=1}(T_j)$$

where,

$$\dot{Q}_{CC}^{k=1}(T_j) = \dot{m}_{da}^{k=1} * C_{p,da}^{k=1} * [T_{CC} - T_0^{k=1}(T_j)] \qquad \dot{E}_{CC}^{k=1}(T_j) = \frac{\dot{Q}_{CC}^{k=1}(T_j)}{3.413\frac{Btu/h}{W}}$$

NOTE: Even though $T_o^{k=1}(T_j) \geq T_{cc}$, additional resistive heating may be required; evaluate $RH(T_j)/N$ for all bins.

Case 3. For outdoor bin temperatures where $T_o^{k=2}(T_j)$ is equal to or greater than T_{CC}, determine $\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$ as specified in section 4.2.3 of this appendix (*i.e.*, $\dot{Q}_h^{k=2}(T_j) = \dot{Q}_{hp}^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j) = \dot{E}_{hp}^{k=2}(T_j)$).

NOTE: Even though $T_o^{k=2}(T_j) < T_{CC}$, resistive heating may be required; evaluate $RH(T_j)/N$ for all bins.

Case 4. For outdoor bin temperatures where $T_o^{k=2}(T_j) < T_{CC}$, determine $\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$ using,

$$\dot{Q}_h^{k=2}(T_j) = \dot{Q}_{hp}^{k=2}(T_j) + \dot{Q}_{CC}^{k=2}(T_j) \quad \dot{E}_h^{k=2}(T_j) = \dot{E}_{hp}^{k=2}(T_j) + \dot{E}_{CC}^{k=2}(T_j)$$

where,

$$\dot{Q}_{CC}^{k=2}(T_j) = \dot{m}_{da}^{k=2} * C_{p,da}^{k=2} * [T_{CC} - T_0^{k=2}(T_j)] \qquad \dot{E}_{CC}^{k=2}(T_j) = \frac{\dot{Q}_{CC}^{k=2}(T_j)}{3.413\frac{Btu/h}{W}}$$

NOTE: Even though $T_o^{k=2}(T_j) < T_{cc}$, additional resistive heating may be required; evaluate $RH(T_j)/N$ for all bins.

4.2.5.4 Heat Pumps Having a Heat Comfort Controller: Additional Steps for Calculating the HSPF of a Heat Pump Having a Variable-Speed Compressor. [Reserved]

4.2.6 Additional Steps for Calculating the HSPF of a Heat Pump Having a Triple-Capacity Compressor

The only triple-capacity heat pumps covered are triple-capacity, northern heat pumps. For such heat pumps, the calculation of the Eq. 4.2–1 quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

differ depending on whether the heat pump would cycle on and off at low capacity (section 4.2.6.1 of this appendix), cycle on and off at high capacity (section 4.2.6.2 of this appendix), cycle on and off at booster capacity (section 4.2.6.3 of this appendix), cycle between low and high capacity (section 4.2.6.4 of this appendix), cycle between high and booster capacity (section 4.2.6.5 of this appendix), operate continuously at low capacity (4.2.6.6 of this appendix), operate continuously at high capacity (section 4.2.6.7 of this appendix), operate continuously at booster capacity (section 4.2.6.8 of this appendix), or heat solely using resistive heating (also section 4.2.6.8 of this appendix) in responding to the building load. As applicable, the manufacturer must supply information regarding the outdoor temperature range at which each stage of compressor capacity is active. As an informative example, data may be submitted in this manner: At the low (k=1) compressor capacity, the outdoor temperature range of operation is 40 °F ≤ T ≤ 65 °F; At the high (k=2) compressor capacity, the outdoor temperature range of operation is 20 °F ≤ T ≤ 50 °F; At the booster (k=3) compressor capacity, the outdoor temperature range of operation is −20 °F ≤ T ≤ 30 °F.

a. Evaluate the space heating capacity and electrical power consumption of the heat pump when operating at low compressor capacity and outdoor temperature Tj using the equations given in section 4.2.3 of this appendix for $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$) In evaluating the section 4.2.3 equations, Determine $\dot{Q}_h^{k=1}(62)$ and $\dot{E}_h^{k=1}(62)$ from the $H0_1$ test, $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the $H1_1$ test, and $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the $H1_2$ test. Calculate all four quantities as specified in section 3.7 of this appendix. If, in accordance with section 3.6.6 of this appendix, the $H3_1$ test is conducted, calculate $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ as specified in section 3.10 of this appendix and determine $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ as specified in section 3.6.6 of this appendix.

b. Evaluate the space heating capacity and electrical power consumption ($\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$) of the heat pump when operating at high compressor capacity and outdoor temperature Tj by solving Equations 4.2.2–3 and 4.2.2–4, respectively, for k=2. Determine $\dot{Q}_h^{k=1}(62)$ and $\dot{E}_h^{k=1}(62)$ from the $H0_1$ test, $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the $H1_1$ test, and $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the $H1_2$ test, evaluated as specified in section 3.7 of this appendix. Determine the equation input for $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the $H2_2$, evaluated as specified in section 3.9.1 of this appendix. Also, determine $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test, evaluated as specified in section 3.10 of this appendix.

c. Evaluate the space heating capacity and electrical power consumption of the heat pump when operating at booster compressor capacity and outdoor temperature Tj using

$$\dot{Q}_h^{k=3}(T_j) = \begin{cases} \dot{Q}_h^{k=3}(17) + \dfrac{\left[\dot{Q}_h^{k=3}(35) - \dot{Q}_h^{k=3}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} < T_j \leq 45\ °\text{F} \\ \dot{Q}_h^{k=3}(5) + \dfrac{\left[\dot{Q}_h^{k=3}(17) - \dot{Q}_h^{k=3}(5)\right] * (T_j - 5)}{17 - 5}, & if\ T_j \leq 17\ °\text{F} \end{cases}$$

$$\dot{E}_h^{k=3}(T_j) = \begin{cases} \dot{E}_h^{k=3}(17) + \dfrac{\left[\dot{E}_h^{k=3}(35) - \dot{E}_h^{k=3}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} < T_j \leq 45\ °\text{F} \\ \dot{E}_h^{k=3}(5) + \dfrac{\left[\dot{E}_h^{k=3}(17) - \dot{E}_h^{k=3}(5)\right] * (T_j - 5)}{17 - 5}, & if\ T_j \leq 17\ °\text{F} \end{cases}$$

Determine $\dot{Q}_h^{k=3}(17)$ and $\dot{E}_h^{k=3}(17)$ from the $H3_3$ test and determine $\dot{Q}_h^{k=3}(5)$ and $\dot{E}_h^{k=3}(5)$ from the $H4_3$ test. Calculate all four quantities as specified in section 3.10 of this appendix. Determine the equation input for $\dot{Q}_h^{k=3}(35)$ and $\dot{E}_h^{k=3}(35)$ as specified in section 3.6.6 of this appendix.

4.2.6.1 Steady-State Space Heating Capacity when Operating at Low Compressor Capacity is Greater than or Equal to the Building Heating Load at Temperature T_j, $\dot{Q}_h^{k=1}(T_j) \geq BL(T_j)$., and the heat pump permits low compressor capacity at T_j.

Evaluate the quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

using Eqs. 4.2.3–1 and 4.2.3–2, respectively. Determine the equation inputs $X^{k=1}(T_j)$, PLF_j, and $\delta'(T_j)$ as specified in section 4.2.3.1 of this appendix. In calculating the part load factor, PLF_j, use the low-capacity cyclic-degradation coefficient $C_D{}^h$, [or equivalently, $C_D{}^h(k=1)$] determined in accordance with section 3.6.6 of this appendix.

4.2.6.2 Heat Pump Only Operates at High (k=2) Compressor Capacity at Temperature T_j and Its Capacity Is Greater Than or Equal to the Building Heating Load, $BL(T_j) \leq \dot{Q}_h^{k=2}(T_j)$

Evaluate the quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.3 of this appendix. Determine the equation inputs $X^{k=2}(T_j)$, PLF_j, and $\delta'(T_j)$ as specified in section 4.2.3.3 of this appendix. In calculating the part load factor, PLF_j, use the high-capacity cyclic-degradation coefficient, $C_D{}^h(k=2)$ determined in accordance with section 3.6.6 of this appendix.

4.2.6.3 Heat Pump Only Operates at Booster (k=3) Compressor Capacity at Temperature T_j, and its Capacity Is Greater Than or Equal to the Building Heating Load, $BL(T_j) \leq \dot{Q}_h^{k=3}(T_j)$.

Calculate $\frac{RH(T_j)}{N}$ and using Eq. 4.2.3-2. Evaluate $\frac{e_h(T_j)}{N}$ using

$$\frac{e_h(T_j)}{N} = \frac{X^{k=3}(T_j) * \dot{E}_h^{k=3}(T_j) * \delta'(T_j)}{PLF_j} * \frac{n_j}{N}$$

where:

$X^{k=3}(T_j) = BL(T_j)/\dot{Q}_h^{k=3}(T_j)$ and $PLF_j = 1 - C_D{}^h(k=3) * [1 - X^{k=3}(T_j)$

Determine the low temperature cut-out factor, $\delta'(T_j)$, using Eq. 4.2.3–3. Use the booster-capacity cyclic-degradation coefficient, $C_D{}^h(k=3)$ determined in accordance with section 3.6.6 of this appendix.

4.2.6.4 Heat Pump Alternates Between High (k=2) and Low (k=1) Compressor Capacity to Satisfy the Building Heating Load at a Temperature T_j, $\dot{Q}_h^{k=1}(T_j) < BL(T_j) < \dot{Q}_h^{k=2}(T_j)$

Evaluate the quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.2 of this appendix. Determine the equation inputs $X^{k=1}(T_j)$, $X^{k=2}(T_j)$, and $\delta'(T_j)$ as specified in section 4.2.3.2 of this appendix.

4.2.6.5 Heat Pump Alternates Between High (k=2) and Booster (k=3) Compressor Capacity To Satisfy the Building Heating Load at a Temperature T_j, $\dot{Q}_h^{k=2}(T_j) < BL(T_j) < \dot{Q}_h^{k=3}(T_j)$

Calculate $\frac{RH(T_j)}{N}$ and using Eq. 4.2.3-2. Evaluate $\frac{e_h(T_j)}{N}$ using

$$\frac{e_h(T_j)}{N} = [X^{k=2}(T_j) * \dot{E}_h^{k=2}(T_j) + X^{k=3}(T_j) * \dot{E}_h^{k=3}(T_j)] * \delta'(T_j) * \frac{n_j}{N}$$

where:

$$X^{k=2}(T_j) = \frac{\dot{Q}_h^{k=3}(T_j) - BL(T_j)}{\dot{Q}_h^{k=3}(T_j) - \dot{Q}_h^{k=2}(T_j)}$$

and $X^{k=3}(T_j) = X^{k=2}(T_j)$ = the heating mode, booster capacity load factor for temperature bin j, dimensionless. Determine the low temperature cut-out factor, $\delta'(T_j)$, using Eq. 4.2.3–3.

4.2.6.6 Heat Pump Only Operates at Low (k=1) Capacity at Temperature T_j and Its Capacity Is Less Than the Building Heating Load, $BL(T_j) > \dot{Q}_h^{k=1}(T_j)$

$$\frac{e_h(T_j)}{N} = \dot{E}_h^{k=1}(T_j) * \delta'(T_j) * \frac{n_j}{N} \quad \text{and} \frac{RH(T_j)}{N} = \frac{BL(T_j) - [\dot{Q}_h^{k=1}(T_j) * \delta\prime(T_j)]}{3.413\frac{Btu/h}{W}} * \frac{n_j}{N}$$

where the low temperature cut-out factor, $\delta'(Tj)$, is calculated using Eq. 4.2.3–3.

4.2.6.7 Heat Pump Only Operates at High (k=2) Capacity at Temperature Tj and Its Capacity Is Less Than the Building Heating Load, $BL(Tj) > \dot{Q}_h^{k=2}(T_j)$

Evaluate the quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.4 of this appendix. Calculate $\delta''(Tj)$ using the equation given in section 4.2.3.4 of this appendix.

4.2.6.8 Heat Pump Only Operates at Booster (k=3) Capacity at Temperature Tj and Its Capacity Is Less Than the Building Heating Load, $BL(T_j) > \dot{Q}_h^{k=3}(T_j)$ or the System Converts to Using Only Resistive Heating

$$\frac{e_h(T_j)}{N} = \dot{E}_h^{k=3}(T_j) * \delta'(T_j) * \frac{n_j}{N} \quad \text{and} \frac{RH(T_j)}{N} = \frac{BL(T_j) - [\dot{Q}_h^{k=3}(T_j) * \delta\prime(T_j)]}{3.413\frac{Btu/h}{W}} * \frac{n_j}{N}$$

where $\delta''(Tj)$ is calculated as specified in section 4.2.3.4 of this appendix if the heat pump is operating at its booster compressor capacity. If the heat pump system converts to using only resistive heating at outdoor temperature T_j, set $\delta'(T_j)$ equal to zero.

4.2.7 Additional Steps for Calculating the HSPF of a Heat Pump Having a Single Indoor Unit With Multiple Indoor Blowers

The calculation of the Eq. 4.2–1 quantities $e_h(T_j)/N$ and $RH(T_j)/N$ are evaluated as specified in the applicable subsection.

4.2.7.1 For Multiple Indoor Blower Heat Pumps That Are Connected to a Singular, Single-Speed Outdoor Unit

a. Calculate the space heating capacity, $\dot{Q}_h^{k=1}(Tj)$, and electrical power consumption, $\dot{E}_h^{k=1}(Tj)$, of the heat pump when operating at the heating minimum air volume rate and outdoor temperature T_j using Eqs. 4.2.2–3 and 4.2.2–4, respectively. Use these same equations to calculate the space heating capacity, $\dot{Q}_h^{k=2}(Tj)$ and electrical power consumption, $\dot{E}_h^{k=2}(Tj)$, of the test unit when operating at the heating full-load air volume rate and outdoor temperature T_j. In evaluating Eqs. 4.2.2–3 and 4.2.2– 4, determine the quantities $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the $H1_1$ test; determine $\dot{Q}_h^{k=2}$ (47) and $\dot{E}_h^{k=2}(47)$ from the $H1_2$ test. Evaluate all four quantities according to section 3.7 of this appendix. Determine the quantities $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ as specified in section 3.6.2 of this appendix. Determine $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the $H2_2$ frost accumulation test as calculated according to section 3.9.1 of this appendix. Determine the quantities $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ from the $H3_1$ test, and $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test. Evaluate all four quantities according to section 3.10 of this appendix. Refer to section 3.6.2 and Table 12 of this appendix for additional information on the referenced laboratory tests.

b. Determine the heating mode cyclic degradation coefficient, CD_h, as per sections 3.6.2 and 3.8 to 3.8.1 of this appendix. Assign this same value to $CD_h(k = 2)$.

c. Except for using the above values of $\dot{Q}_h^{k=1}(Tj)$, $\dot{E}_h^{k=1}(Tj)$, $\dot{Q}_h^{k=2}(Tj)$, $\dot{E}_h^{k=2}(Tj)$, CD_h, and $CD_h(k = 2)$, calculate the quantities $e_h(T_j)/N$ as specified in section 4.2.3.1 of this appendix for cases where $\dot{Q}_h^{k=1}(Tj) \geq BL(T_j)$. For all other outdoor bin temperatures, T_j, calculate $e_h(Tj)/N$ and $RH_h(Tj)/N$ as specified in section 4.2.3.3 of this appendix if $\dot{Q}_h^{k=2}(Tj) > BL(Tj)$ or as specified in section 4.2.3.4 of this appendix if $\dot{Q}_h^{k=2}(Tj) \leq BL(T_j)$.

4.2.7.2 For Multiple Indoor Blower Heat Pumps Connected to Either a Single Outdoor Unit With a Two-capacity Compressor or to Two Separate Single-Speed Outdoor Units of Identical Model, calculate the quantities $e_h(T_j)/N$ and $RH(T_j)/N$ as specified in section 4.2.3 of this appendix.

4.3 Calculations of Off-mode Power Consumption

For central air conditioners and heat pumps with a cooling capacity of:

Less than 36,000 Btu/h, determine the off mode represented value, $P_{W,OFF}$, with the following equation:

$$P_{W,OFF} = \frac{P1 + P2}{2};$$

greater than or equal to 36,000 Btu/h, calculate the capacity scaling factor according to:

$$F_{scale} = \frac{\dot{Q}_C(95)}{36{,}000},$$

where $\dot{Q}_C(95)$ is the total cooling capacity at the A or A_2 test condition, and determine the off mode represented value, $P_{W,OFF}$, with the following equation:

$$P_{W,OFF} = \frac{P1 + P2}{2 \times F_{scale}};$$

4.4 Rounding of SEER and HSPF for Reporting Purposes

After calculating SEER according to section 4.1 of this appendix and HSPF according to section 4.2 of this appendix round the values off as specified per §430.23(m) of title 10 of the Code of Federal Regulations.




Figure 1—Heating Load Hours (HLH_A) for the United States




Figure 2—Cooling Load Hours (CLH_A) for the United States

TABLE 22—REPRESENTATIVE COOLING AND HEATING LOAD HOURS FOR EACH GENERALIZED CLIMATIC REGION

Climatic region	Cooling load hours CLH_R	Heating load hours HLH_R
I	2,400	750
II	1,800	1,250
III	1,200	1,750
IV	800	2,250
Rating Values	1,000	2,080
V	400	2,750
VI	200	2,750

4.5 Calculations of the SHR, Which Should Be Computed for Different Equipment Configurations and Test Conditions Specified in Table 23

TABLE 23—APPLICABLE TEST CONDITIONS FOR CALCULATION OF THE SENSIBLE HEAT RATIO

Equipment configuration	Reference table Number of appendix M	SHR computation with results from	Computed values
Units Having a Single-Speed Compressor and a Fixed-Speed Indoor blower, a Constant Air Volume Rate Indoor blower, or No Indoor blower.	4	B Test	SHR(B).
Units Having a Single-Speed Compressor That Meet the section 3.2.2.1 Indoor Unit Requirements.	5	B2 and B1 Tests	SHR(B1), SHR(B2).
Units Having a Two-Capacity Compressor	6	B2 and B1 Tests	SHR(B1), SHR(B2).
Units Having a Variable-Speed Compressor	7	B2 and B1 Tests	SHR(B1), SHR(B2).

The SHR is defined and calculated as follows:

$$SHR = \frac{Sensible\ Cooling\ Capacity}{Total\ Cooling\ Capacity}$$

$$= \frac{\dot{Q}_{SC}^{k}(T)}{\dot{Q}_{C}^{k}(T)}$$

Where both the total and sensible cooling capacities are determined from the same cooling mode test and calculated from data collected over the same 30-minute data collection interval.

4.6 Calculations of the Energy Efficiency Ratio (EER).

Calculate the energy efficiency ratio using.

$$EER = \frac{Total\ Cooling\ Capacity}{Total\ Electrical\ Power\ Consumption}$$

$$= \frac{\dot{Q}_{C}^{k}(T)}{\dot{E}_{C}^{k}(T)}$$

where $\dot{Q}_{c}^{k}(T)$ and $\dot{E}_{c}^{k}(T)$ are the space cooling capacity and electrical power consumption determined from the 30-minute data collection interval of the same steady-state wet coil cooling mode test and calculated as specified in section 3.3 of this appendix. Add the letter identification for each steady-state test as a subscript (*e.g.*, EER_{A_2}) to differentiate among the resulting EER values.

[82 FR 1476, Jan. 5, 2017, as amended at 86 FR 68393, Dec. 2, 2021; 87 FR 64586, Oct. 25, 2022]

APPENDIX M1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CENTRAL AIR CONDITIONERS AND HEAT PUMPS

NOTE: On or after January 1, 2023, and prior to April 24, 2023, any representations, including compliance certifications, made with respect to the energy use, power, or efficiency of central air conditioners and central air conditioning heat pumps must be based on the results of testing pursuant to either this appendix or the procedures in appendix M1 as it appeared at 10 CFR part 430, subpart B, in the 10 CFR parts 200 to 499 edition revised as of January 1, 2022. Any representations made with respect to the energy use or efficiency of such central air conditioners and central air conditioning heat pumps must be in accordance with whichever version is selected.

On or after April 24, 2023, any representations, including compliance certifications, made with respect to the energy use, power, or efficiency of central air conditioners and central air conditioning heat pumps must be based on the results of testing pursuant to this appendix.

Prior to January 1, 2023, any representations, including compliance certifications, made with respect to the energy use, power, or efficiency of central air conditioners and central air conditioning heat pumps must be based on the results of testing pursuant to appendix M of this subpart.

On or after January 1, 2023, any representations, including compliance certifications, made with respect to the energy use, power, or efficiency of central air conditioners and central air conditioning heat pumps must be based on the results of testing pursuant to this appendix.

1 SCOPE AND DEFINITIONS

1.1 Scope

This test procedure provides a method of determining SEER2, EER2, HSPF2 and $P_{W,OFF}$

for central air conditioners and central air conditioning heat pumps including the following categories:

(h) Split-system air conditioners, including single-split, multi-head mini-split, multi-split (including VRF), and multi-circuit systems

(i) Split-system heat pumps, including single-split, multi-head mini-split, multi-split (including VRF), and multi-circuit systems

(j) Single-package air conditioners

(k) Single-package heat pumps

(l) Small-duct, high-velocity systems (including VRF)

(m) Space-constrained products—air conditioners

(n) Space-constrained products—heat pumps

For the purposes of this appendix, the Department of Energy incorporates by reference specific sections of several industry standards, as listed in §430.3. In cases where there is a conflict, the language of the test procedure in this appendix takes precedence over the incorporated standards.

All section references refer to sections within this appendix unless otherwise stated.

1.2 Definitions

Airflow-control settings are programmed or wired control system configurations that control a fan to achieve discrete, differing ranges of airflow—often designated for performing a specific function (*e.g.,* cooling, heating, or constant circulation)—without manual adjustment other than interaction with a user-operable control (*i.e.,* a thermostat) that meets the manufacturer specifications for installed-use. For the purposes of this appendix, manufacturer specifications for installed-use are those found in the product literature shipped with the unit.

Air sampling device is an assembly consisting of a manifold with several branch tubes with multiple sampling holes that draws an air sample from a critical location from the unit under test (*e.g.* indoor air inlet, indoor air outlet, outdoor air inlet, etc.).

Airflow prevention device denotes a device that prevents airflow via natural convection by mechanical means, such as an air damper box, or by means of changes in duct height, such as an upturned duct.

Aspirating psychrometer is a piece of equipment with a monitored airflow section that draws uniform airflow through the measurement section and has probes for measurement of air temperature and humidity.

Blower coil indoor unit means an indoor unit either with an indoor blower housed with the coil or with a separate designated air mover such as a furnace or a modular blower (as defined in appendix AA to this subpart).

Blower coil system refers to a split system that includes one or more blower coil indoor units.

Cased coil means a coil-only indoor unit with external cabinetry.

Ceiling-mount blower coil system means a split system for which a) the outdoor unit has a certified cooling capacity less than or equal to 36,000 Btu/h; b) the indoor unit(s) is/are shipped with manufacturer-supplied installation instructions that specify to secure the indoor unit only to the ceiling, within a furred-down space, or above a dropped ceiling of the conditioned space, with return air directly to the bottom of the unit without ductwork, or through the furred-down space, or optional insulated return air plenum that is shipped with the indoor unit; c) the installed height of the indoor unit is no more than 12 inches (not including condensate drain lines) and the installed depth (in the direction of airflow) of the indoor unit is no more than 30 inches; and d) supply air is discharged horizontally.

Coefficient of Performance (COP) means the ratio of the average rate of space heating delivered to the average rate of electrical energy consumed by the heat pump. Determine these rate quantities from a single test or, if derived via interpolation, determine at a single set of operating conditions. COP is a dimensionless quantity. When determined for a ducted coil-only system, COP must be calculated using the default values for heat output and power input of a fan motor specified in sections 3.7 and 3.9.1 of this appendix.

Coil-only indoor unit means an indoor unit that is distributed in commerce without an indoor blower or separate designated air mover. A coil-only indoor unit installed in the field relies on a separately installed furnace or a modular blower for indoor air movement.

Coil-only system means a system that includes only (one or more) coil-only indoor units.

Condensing unit removes the heat absorbed by the refrigerant to transfer it to the outside environment and consists of an outdoor coil, compressor(s), and air moving device.

Constant-air-volume-rate indoor blower means a fan that varies its operating speed to provide a fixed air-volume-rate from a ducted system.

Continuously recorded, when referring to a dry bulb measurement, dry bulb temperature used for test room control, wet bulb temperature, dew point temperature, or relative humidity measurements, means that the specified value must be sampled at regular intervals that are equal to or less than 15 seconds.

Cooling load factor (CLF) means the ratio having as its numerator the total cooling delivered during a cyclic operating interval

consisting of one ON period and one OFF period, and as its denominator the total cooling that would be delivered, given the same ambient conditions, had the unit operated continuously at its steady-state, space-cooling capacity for the same total time (ON + OFF) interval.

Crankcase heater means any electrically powered device or mechanism for intentionally generating heat within and/or around the compressor sump volume. Crankcase heater control may be achieved using a timer or may be based on a change in temperature or some other measurable parameter, such that the crankcase heater is not required to operate continuously. A crankcase heater without controls operates continuously when the compressor is not operating.

Cyclic Test means a test where the unit's compressor is cycled on and off for specific time intervals. A cyclic test provides half the information needed to calculate a degradation coefficient.

Damper box means a short section of duct having an air damper that meets the performance requirements of section 2.5.7 of this appendix.

Degradation coefficient (C_D) means a parameter used in calculating the part load factor. The degradation coefficient for cooling is denoted by C_D^c. The degradation coefficient for heating is denoted by C_D^h.

Demand-defrost control system means a system that defrosts the heat pump outdoor coil-only when measuring a predetermined degradation of performance. The heat pump's controls either:

(1) Monitor one or more parameters that always vary with the amount of frost accumulated on the outdoor coil (*e.g.*, coil to air differential temperature, coil differential air pressure, outdoor fan power or current, optical sensors) at least once for every ten minutes of compressor ON-time when space heating; or

(2) Operate as a feedback system that measures the length of the defrost period and adjusts defrost frequency accordingly. In all cases, when the frost parameter(s) reaches a predetermined value, the system initiates a defrost. In a demand-defrost control system, defrosts are terminated based on monitoring a parameter(s) that indicates that frost has been eliminated from the coil. (NOTE: Systems that vary defrost intervals according to outdoor dry-bulb temperature are not demand-defrost systems.) A demand-defrost control system, which otherwise meets the requirements, may allow time-initiated defrosts if, and only if, such defrosts occur after 6 hours of compressor operating time.

Design heating requirement (DHR) predicts the space heating load of a residence when subjected to outdoor design conditions. Estimates for the minimum and maximum DHR are provided for six generalized U.S. climatic regions in section 4.2 of this appendix.

Dry-coil tests are cooling mode tests where the wet-bulb temperature of the air supplied to the indoor unit is maintained low enough that no condensate forms on the evaporator coil.

Ducted system means an air conditioner or heat pump that is designed to be permanently installed equipment and delivers conditioned air to the indoor space through a duct(s). The air conditioner or heat pump may be either a split-system or a single-package unit.

Energy efficiency ratio (EER) means the ratio of the average rate of space cooling delivered to the average rate of electrical energy consumed by the air conditioner or heat pump. Determine these rate quantities from a single test or, if derived via interpolation, determine at a single set of operating conditions. EER is expressed in units of

$$\frac{Btu/h}{W}.$$

When determined for a ducted coil-only system, EER must include, from this appendix, the section 3.3 and 3.5.1 default values for the heat output and power input of a fan motor. The represented value of EER determined in accordance with appendix M1 is EER2.

Evaporator coil means an assembly that absorbs heat from an enclosed space and transfers the heat to a refrigerant.

Heat pump means a kind of central air conditioner that utilizes an indoor conditioning coil, compressor, and refrigerant-to-outdoor air heat exchanger to provide air heating, and may also provide air cooling, air dehumidifying, air humidifying, air circulating, and air cleaning.

Heat pump having a heat comfort controller means a heat pump with controls that can regulate the operation of the electric resistance elements to assure that the air temperature leaving the indoor section does not fall below a specified temperature. Heat pumps that actively regulate the rate of electric resistance heating when operating below the balance point (as the result of a second stage call from the thermostat) but do not operate to maintain a minimum delivery temperature are not considered as having a heat comfort controller.

Heating load factor (HLF) means the ratio having as its numerator the total heating delivered during a cyclic operating interval consisting of one ON period and one OFF period, and its denominator the heating capacity measured at the same test conditions used for the cyclic test, multiplied by the total time interval (ON plus OFF) of the cyclic-test.

Heating season means the months of the year that require heating, *e.g.*, typically, and roughly, October through April.

Heating seasonal performance factor 2 (HSPF2) means the total space heating required during the heating season, expressed in Btu, divided by the total electrical energy consumed by the heat pump system during the same season, expressed in watt-hours. The HSPF2 used to evaluate compliance with 10 CFR 430.32(c) is based on Region IV and the sampling plan stated in 10 CFR 429.16(a). HSPF2 is determined in accordance with appendix M1.

Independent coil manufacturer (ICM) means a manufacturer that manufactures indoor units but does not manufacture single-package units or outdoor units.

Indoor unit means a separate assembly of a split system that includes—

(a) An arrangement of refrigerant-to-air heat transfer coil(s) for transfer of heat between the refrigerant and the indoor air,

(b) A condensate drain pan, and may or may not include,

(c) Sheet metal or plastic parts not part of external cabinetry to direct/route airflow over the coil(s),

(d) A cooling mode expansion device,

(e) External cabinetry, and

(f) An integrated indoor blower (*i.e.* a device to move air including its associated motor). A separate designated air mover that may be a furnace or a modular blower (as defined in appendix AA to the subpart) may be considered to be part of the indoor unit. A service coil is not an indoor unit.

Low-static blower coil system means a ducted multi-split or multi-head mini-split system for which all indoor units produce greater than 0.01 in. wc. and a maximum of 0.35 in. wc. external static pressure when operated at the cooling full-load air volume rate not exceeding 400 cfm per rated ton of cooling.

Mid-static blower coil system means a ducted multi-split or multi-head mini-split system for which all indoor units produce greater than 0.20 in. wc. and a maximum of 0.65 in. wc. when operated at the cooling full-load air volume rate not exceeding 400 cfm per rated ton of cooling.

Minimum-speed-limiting variable-speed heat pump means a heat pump for which the compressor minimum speed (represented by revolutions per minute or motor power input frequency) is higher than its minimum value for operation in a 47 °F ambient temperature for any bin temperature T_j for which the calculated heating load is less than the calculated intermediate-speed capacity.

Mobile home blower coil system means a split system that contains an outdoor unit and an indoor unit that meet the following criteria:

(1) Both the indoor and outdoor unit are shipped with manufacturer-supplied installation instructions that specify installation only in a mobile home with the home and equipment complying with HUD Manufactured Home Construction Safety Standard 24 CFR part 3280;

(2) The indoor unit cannot exceed 0.40 in. wc. when operated at the cooling full-load air volume rate not exceeding 400 cfm per rated ton of cooling; and

(3) The indoor and outdoor unit each must bear a label in at least ¼ inch font that reads ''For installation only in HUD manufactured home per Construction Safety Standard 24 CFR part 3280.''

Mobile home coil-only system means a coil-only split system that includes an outdoor unit and coil-only indoor unit that meet the following criteria:

(1) The outdoor unit is shipped with manufacturer-supplied installation instructions that specify installation only for mobile homes that comply with HUD Manufactured Home Construction Safety Standard 24 CFR part 3280,

(2) The coil-only indoor unit is shipped with manufacturer-supplied installation instructions that specify installation only in or with a mobile home furnace, modular blower, or designated air mover that complies with HUD Manufactured Home Construction Safety Standard 24 CFR part 3280, and has dimensions no greater than 20'' wide, 34'' high and 21'' deep, and

(3) The coil-only indoor unit and outdoor unit each has a label in at least ¼ inch font that reads ''For installation only in HUD manufactured home per Construction Safety Standard 24 CFR part 3280.''

Multi-head mini-split system means a split system that has one outdoor unit and that has two or more indoor units connected with a single refrigeration circuit. The indoor units operate in unison in response to a single indoor thermostat.

Multiple-circuit (or multi-circuit) system means a split system that has one outdoor unit and that has two or more indoor units installed on two or more refrigeration circuits such that each refrigeration circuit serves a compressor and one and only one indoor unit, and refrigerant is not shared from circuit to circuit.

Multiple-split (or multi-split) system means a split system that has one outdoor unit and two or more coil-only indoor units and/or blower coil indoor units connected with a single refrigerant circuit. The indoor units operate independently and can condition multiple zones in response to at least two indoor thermostats or temperature sensors.

The outdoor unit operates in response to independent operation of the indoor units based on control input of multiple indoor thermostats or temperature sensors, and/or based on refrigeration circuit sensor input (*e.g.*, suction pressure).

*Nominal capacity means t*he capacity that is claimed by the manufacturer on the product name plate. Nominal cooling capacity is approximate to the air conditioner cooling capacity tested at A or A_2 condition. Nominal heating capacity is approximate to the heat pump heating capacity tested in the $H1_N$ test.

Non-ducted indoor unit means an indoor unit that is designed to be permanently installed, mounted on room walls and/or ceilings, and that directly heats or cools air within the conditioned space.

Normalized Gross Indoor Fin Surface (NGIFS) means the gross fin surface area of the indoor unit coil divided by the cooling capacity measured for the A or A_2 Test, whichever applies.

Off-mode power consumption means the power consumption when the unit is connected to its main power source but is neither providing cooling nor heating to the building it serves.

Off-mode season means, for central air conditioners other than heat pumps, the shoulder season and the entire heating season; and for heat pumps, the shoulder season only.

Outdoor unit means a separate assembly of a split system that transfers heat between the refrigerant and the outdoor air, and consists of an outdoor coil, compressor(s), an air moving device, and in addition for heat pumps, may include a heating mode expansion device, reversing valve, and/or defrost controls.

Outdoor unit manufacturer (OUM) means a manufacturer of single-package units, outdoor units, and/or both indoor units and outdoor units.

Part-load factor (PLF) means the ratio of the cyclic EER (or COP for heating) to the steady-state EER (or COP), where both EERs (or COPs) are determined based on operation at the same ambient conditions.

Seasonal energy efficiency ratio 2 (SEER2) means the total heat removed from the conditioned space during the annual cooling season, expressed in Btu's, divided by the total electrical energy consumed by the central air conditioner or heat pump during the same season, expressed in watt-hours. SEER2 is determined in accordance with appendix M1.

Service coil means an arrangement of refrigerant-to-air heat transfer coil(s), condensate drain pan, sheet metal or plastic parts to direct/route airflow over the coil(s), which may or may not include external cabinetry and/or a cooling mode expansion device, distributed in commerce solely for replacing an uncased coil or cased coil that has already been placed into service, and that has been labeled ''for indoor coil replacement only'' on the nameplate and in manufacturer technical and product literature. The model number for any service coil must include some mechanism (*e.g.*, an additional letter or number) for differentiating a service coil from a coil intended for an indoor unit.

Shoulder season means the months of the year in between those months that require cooling and those months that require heating, *e.g.*, typically, and roughly, April through May, and September through October.

Single-package unit means any central air conditioner or heat pump that has all major assemblies enclosed in one cabinet.

Single-split system means a split system that has one outdoor unit and one indoor unit connected with a single refrigeration circuit.

Small-duct, high-velocity system means a split system for which all indoor units are blower coil indoor units that produce at least 1.2 inches (of water column) of external static pressure when operated at the full-load air volume rate certified by the manufacturer of at least 220 scfm per rated ton of cooling.

Split system means any central air conditioner or heat pump that has at least two separate assemblies that are connected with refrigerant piping when installed. One of these assemblies includes an indoor coil that exchanges heat with the indoor air to provide heating or cooling, while one of the others includes an outdoor coil that exchanges heat with the outdoor air. Split systems may be either blower coil systems or coil-only systems.

Standard Air means dry air having a mass density of 0.075 lb/ft^3.

Steady-state test means a test where the test conditions are regulated to remain as constant as possible while the unit operates continuously in the same mode.

Temperature bin means the 5 °F increments that are used to partition the outdoor dry-bulb temperature ranges of the cooling (≥65 °F) and heating (<65 °F) seasons.

Test condition tolerance means the maximum permissible difference between the average value of the measured test parameter and the specified test condition.

Test operating tolerance means the maximum permissible range that a measurement may vary over the specified test interval. The difference between the maximum and minimum sampled values must be less than or equal to the specified test operating tolerance.

Tested combination means a multi-head mini-split, multi-split, or multi-circuit system having the following features:

(1) The system consists of one outdoor unit with one or more compressors matched with between two and five indoor units;

(2) The indoor units must:

(i) Collectively, have a nominal cooling capacity greater than or equal to 95 percent and less than or equal to 105 percent of the nominal cooling capacity of the outdoor unit;

(ii) Each represent the highest sales volume model family, if this is possible while meeting all the requirements of this section. If this is not possible, one or more of the indoor units may represent another indoor model family in order that all the other requirements of this section are met.

(iii) Individually not have a nominal cooling capacity greater than 50 percent of the nominal cooling capacity of the outdoor unit, unless the nominal cooling capacity of the outdoor unit is 24,000 Btu/h or less;

(iv) Operate at fan speeds consistent with manufacturer's specifications; and

(v) All be subject to the same minimum external static pressure requirement while able to produce the same external static pressure at the exit of each outlet plenum when connected in a manifold configuration as required by the test procedure.

(3) Where referenced, ''nominal cooling capacity'' means, for indoor units, the highest cooling capacity listed in published product literature for 95 °F outdoor dry bulb temperature and 80 °F dry bulb, 67 °F wet bulb indoor conditions, and for outdoor units, the lowest cooling capacity listed in published product literature for these conditions. If incomplete or no operating conditions are published, use the highest (for indoor units) or lowest (for outdoor units) such cooling capacity available for sale.

Time-adaptive defrost control system is a demand-defrost control system that measures the length of the prior defrost period(s) and uses that information to automatically determine when to initiate the next defrost cycle.

Time-temperature defrost control systems initiate or evaluate initiating a defrost cycle only when a predetermined cumulative compressor ON-time is obtained. This predetermined ON-time is generally a fixed value (*e.g.*, 30, 45, 90 minutes) although it may vary based on the measured outdoor dry-bulb temperature. The ON-time counter accumulates if controller measurements (*e.g.*, outdoor temperature, evaporator temperature) indicate that frost formation conditions are present, and it is reset/remains at zero at all other times. In one application of the control scheme, a defrost is initiated whenever the counter time equals the predetermined ON-time. The counter is reset when the defrost cycle is completed.

In a second application of the control scheme, one or more parameters are measured (*e.g.*, air and/or refrigerant temperatures) at the predetermined, cumulative, compressor ON-time. A defrost is initiated only if the measured parameter(s) falls within a predetermined range. The ON-time counter is reset regardless of whether or not a defrost is initiated. If systems of this second type use cumulative ON-time intervals of 10 minutes or less, then the heat pump may qualify as having a demand defrost control system (see definition).

Triple-capacity, northern heat pump means a heat pump that provides two stages of cooling and three stages of heating. The two common stages for both the cooling and heating modes are the low capacity stage and the high capacity stage. The additional heating mode stage is the booster capacity stage, which offers the highest heating capacity output for a given set of ambient operating conditions.

Triple-split system means a split system that is composed of three separate assemblies: An outdoor fan coil section, a blower coil indoor unit, and an indoor compressor section.

Two-capacity (or two-stage) compressor system means a central air conditioner or heat pump that has a compressor or a group of compressors operating with only two stages of capacity. For such systems, low capacity means the compressor(s) operating at low stage, or at low load test conditions. The low compressor stage that operates for heating mode tests may be the same or different from the low compressor stage that operates for cooling mode tests. For such systems, high capacity means the compressor(s) operating at high stage, or at full load test conditions.

Two-capacity, northern heat pump means a heat pump that has a factory or field-selectable lock-out feature to prevent space cooling at high-capacity. Two-capacity heat pumps having this feature will typically have two sets of ratings, one with the feature disabled and one with the feature enabled. The heat pump is a two-capacity northern heat pump only when this feature is enabled at all times. The certified indoor coil model number must reflect whether the ratings pertain to the lockout enabled option via the inclusion of an extra identifier, such as ''+LO''. When testing as a two-capacity, northern heat pump, the lockout feature must remain enabled for all tests.

Uncased coil means a coil-only indoor unit without external cabinetry.

Variable refrigerant flow (VRF) system means a multi-split system with at least three compressor capacity stages, distributing refrigerant through a piping network to multiple indoor blower coil units each capable of individual zone temperature control, through proprietary zone temperature control devices and a common communications network. Note: Single-phase VRF systems less than 65,000 Btu/h are central air conditioners and central air conditioning heat pumps.

Variable-speed communicating coil-only central air conditioner or heat pump means a variable-speed compressor system having a coil-only indoor unit that is installed with a control system that:

(a) Communicates the difference in space temperature and space setpoint temperature (not a setpoint value inferred from on/off thermostat signals) to the control that sets compressor speed;

(b) Provides a signal to the indoor fan to set fan speed appropriate for compressor staging; and

(c) Has installation instructions indicating that the control system having these capabilities must be installed.

Variable-speed compressor system means a central air conditioner or heat pump that has a compressor that uses a variable-speed drive to vary the compressor speed to achieve variable capacities.

Variable-speed non-communicating coil-only central air conditioner or heat pump means a variable-speed compressor system having a coil-only indoor unit that is does not meet the definition of variable-speed communicating coil-only central air conditioner or heat pump.

Wall-mount blower coil system means a split system air conditioner or heat pump for which:

(a) The outdoor unit has a certified cooling capacity less than or equal to 36,000 Btu/h;

(b) The indoor unit(s) is/are shipped with manufacturer-supplied installation instructions that specify mounting only by:

(1) Securing the back side of the unit to a wall within the conditioned space, or

(2) Securing the unit to adjacent wall studs or in an enclosure, such as a closet, such that the indoor unit's front face is flush with a wall in the conditioned space;

(c) Has front air return without ductwork and is not capable of horizontal air discharge; and

(d) Has a height no more than 45 inches, a depth (perpendicular to the wall) no more than 22 inches (including tubing connections), and a width no more than 24 inches (parallel to the wall).

Wet-coil test means a test conducted at test conditions that typically cause water vapor to condense on the test unit evaporator coil.

2 TESTING OVERVIEW AND CONDITIONS

(A) Test VRF systems using AHRI 1230–2010 (incorporated by reference, see §430.3) and appendix M. Where AHRI 1230–2010 refers to the appendix C therein substitute the provisions of this appendix. In cases where there is a conflict, the language of the test procedure in this appendix takes precedence over AHRI 1230–2010.

For definitions use section 1 of appendix M and section 3 of AHRI 1230–2010. For rounding requirements, refer to §430.23(m). For determination of certified ratings, refer to §429.16 of this chapter.

For test room requirements, refer to section 2.1 of this appendix. For test unit installation requirements refer to sections 2.2.a, 2.2.b, 2.2.c, 2.2.1, 2.2.2, 2.2.3.a, 2.2.3.c, 2.2.4, 2.2.5, and 2.4 to 2.12 of this appendix, and sections 5.1.3 and 5.1.4 of AHRI 1230–2010. The ''manufacturer's published instructions,'' as stated in section 8.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) and ''manufacturer's installation instructions'' discussed in this appendix mean the manufacturer's installation instructions that come packaged with or appear in the labels applied to the unit. This does not include online manuals. Installation instructions that appear in the labels applied to the unit take precedence over installation instructions that are shipped with the unit.

For general requirements for the test procedure, refer to section 3.1 of this appendix, except for sections 3.1.3 and 3.1.4, which are requirements for indoor air volume and outdoor air volume. For indoor air volume and outdoor air volume requirements, refer instead to section 6.1.5 (except where section 6.1.5 refers to Table 8, refer instead to Table 4 of this appendix) and 6.1.6 of AHRI 1230–2010.

For the test method, refer to sections 3.3 to 3.5 and 3.7 to 3.13 of this appendix. For cooling mode and heating mode test conditions, refer to section 6.2 of AHRI 1230–2010. For calculations of seasonal performance descriptors, refer to section 4 of this appendix.

(B) For systems other than VRF, only a subset of the sections listed in this test procedure apply when testing and determining represented values for a particular unit. Table 1 to this appendix shows the sections of the test procedure that apply to each system. Table 1 is meant to assist manufacturers in finding the appropriate sections of the test procedure. Manufacturers are responsible for determining which sections apply to each unit tested based on the model characteristics. The appendix sections provide the specific requirements for testing. To use Table 1, first refer to the sections listed under ''all units''. Then refer to additional requirements based on:

(1) System configuration(s),

(2) The compressor staging or modulation capability, and

(3) Any special features.

Testing requirements for space-constrained products do not differ from similar products that are not space-constrained, and thus space-constrained products are not listed separately in Table 1. Air conditioners and heat pumps are not listed separately in Table 1, but heating procedures and calculations apply only to heat pumps.

The ''manufacturer's published instructions,'' as stated in Section 8.2 of ANSI/

ASHRAE Standard 37–2009 (incorporated by reference, see §430.3) and ''manufacturer's installation instructions'' discussed in this appendix mean the manufacturer's installation instructions that come packaged with the unit or appear in the labels applied to the unit. Manufacturer's installation instructions do not include online manuals. Installation instructions that appear in the labels applied to the unit shall take precedence over installation instructions that come packaged with the unit.

Table 1 Informative Guidance for Using Appendix M1

		Testing conditions	Testing procedures			Calculations		
		General	General	Cooling*	Heating**	General	Cooling*	Heating**
Requirements for all units (except VRF)		2.1; 2.2a-c; 2.2.1; 2.2.4; 2.2.4.1; 2.2.4.1 (1); 2.2.4.2; 2.2.5.1-5; 2.2.5.7-8; 2.3; 2.3.1; 2.3.2; 2.4; 2.4.1a,d; 2.5a-c; 2.5.1; 2.5.2 - 2.5.4.2; 2.5.5 – 2.13	3.1; 3.1.1-3; 3.1.5-9; 3.11; 3.12	3.3; 3.4; 3.5a-i	3.1.4.7; 3.1.9; 3.7a,b,d; 3.8a,d; 3.8.1; 3.9; 3.10	4.4; 4.5	4.1	4.2
Additional Requirements	System Configurations (more than one may apply)							
	Single-split system – blower coil	2.2a(1)		3.1.4.1.1; 3.1.4.1.1a,b; 3.1.4.2a-b; 3.1.4.3a-b	3.1.4.4.1; 3.1.4.4.2; 3.1.4.4.3a-b; 3.1.4.5.1; 3.1.4.5.2a-c; 3.1.4.6a-b			
	Single-split system - coil-only	2.2a(1); 2.2d,e; 2.4.2		3.1.4.1.1; 3.1.4.1.1c; 3.1.4.2c; 3.5.1	3.1.4.4.1; 3.1.4.4.2; 3.1.4.4.3c; 3.1.4.5.2d; 3.7c; 3.8b; 3.9f; 3.9.1b			
	Tri-split	2.2a(2)						
	Outdoor unit with no match	2.2e						
	Single-package	2.2.4.1(2); 2.2.5.6b; 2.4.2		3.1.4.1.1; 3.1.4.1.1a,b; 3.1.4.2a-b; 3.1.4.3a-b	3.1.4.4.1; 3.1.4.4.2; 3.1.4.4.3a-b; 3.1.4.5.1; 3.1.4.5.2a-c; 3.1.4.6a-b			
	Heat pump	2.2.5.6.a						
	Heating-only heat pump			3.1.4.1.1 Table 5	3.1.4.4.3			

	Two-capacity northern heat pump		3.1.4.4.2c; 3.1.4.5.2 c- d	3.2.3c	3.6.3				
	Triple-capacity northern heat pump			3.2.5	3.6.6				4.2.6
	SDHV (non-VRF)	2.2b; 2.4.1c; 2.5.4.3							
	Single- zone-multi-coil split and non-VRF multiple-split with duct	2.2a(1),(3); 2.2.3; 2.4.1b		3.1.4.1.1; 3.1.4.1.1a-b; 3.1.4.2a-b; 3.1.4.3a-b	3.1.4.4.1; 3.1.4.4.2; 3.1.4.4.3a-b; 3.1.4.5.1; 3.1.4.5.2a-e; 3.1.4.6a-b				
	Single-zonc-multi-coil split and non-VRF multiple-split, ductless	2.2.a(1),(3); 2.2.3		3.1.4.1.2; 3.1.4.2d; 3.1.4.3c; 3.2.4c; 3.5c,g,h; 3.5.2; 3.8c	3.1.4.4.4; 3.1.4.5.2c; 3.1.4.6c; 3.6.4.c; 3.8c				
	VRF multiple-split[‡] and VRF SDHV[†]	2.1; 2.2.a; 2.2.b; 2.2.c; 2.2.1; 2.2.2; 2.2.3.a; 2.2.3.c; 2.2.4; 2.2.5; 2.4-2.12	3.1 (except 3.1.3, 3.1.4) 3.1.4.1.1c; 3.11-3.13	3.3-3.5	3.7-3.10	4.4; 4.5	4.1	4.2	
Modulation Capability	Single speed compressor, fixed air volume rate			3.2.1	3.6.1		4.1.1	4.2.1	
	Single speed compressor, VAV fan			3.2.2	3.6.2		4.1.2	4.2.2	
	Two-capacity compressor		3.1.9	3.2.3	3.6.3		4.1.3	4.2.3	
	Variable-speed compressor			3.2.4	3.6.4		4.1.4	4.2.4	
Special Features	Heat pump with heat comfort controller				3.6.5			4.2.5	
	Units with a multi-speed outdoor fan	2.2.2							
	Single indoor unit having multiple indoor blowers			3.2.6	3.6.2; 3.6.7		4.1.5	4.2.7	

*Does not apply to heating-only heat pumps.

**Applies only to heat pumps; not to air conditioners.

†Use AHRI 1230-2010 (incorporated by reference, see §430.3), with the sections referenced in section 2(A) of this appendix, in conjunction with the sections set forth in the table to perform test setup, testing, and calculations for determining represented values for VRF multiple-split and VRF SDHV systems.

NOTE: For all units, use section 3.13 of this appendix for off mode testing procedures and section 4.3 of this appendix for off mode calculations. For all units subject to an EER2 standard, use section 4.6 of this appendix to determine the energy efficiency ratio.

2.1 Test Room Requirements.

a. Test using two side-by-side rooms: An indoor test room and an outdoor test room. For multiple-split, single-zone-multi-coil or multi-circuit air conditioners and heat pumps, however, use as many indoor test rooms as needed to accommodate the total number of indoor units. These rooms must

comply with the requirements specified in sections 8.1.2 and 8.1.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3).

b. Inside these test rooms, use artificial loads during cyclic tests and frost accumulation tests, if needed, to produce stabilized room air temperatures. For one room, select an electric resistance heater(s) having a heating capacity that is approximately equal to the heating capacity of the test unit's condenser. For the second room, select a heater(s) having a capacity that is close to the sensible cooling capacity of the test unit's evaporator. Cycle the heater located in the same room as the test unit evaporator coil ON and OFF when the test unit cycles ON and OFF. Cycle the heater located in the same room as the test unit condensing coil ON and OFF when the test unit cycles OFF and ON.

2.2 Test Unit Installation Requirements.

a. Install the unit according to section 8.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3), subject to the following additional requirements:

(1) When testing split systems, follow the requirements given in section 6.1.3.5 of AHRI 210/240–2008 (incorporated by reference, see §430.3). For the vapor refrigerant line(s), use the insulation included with the unit; if no insulation is provided, use insulation meeting the specifications for the insulation in the installation instructions included with the unit by the manufacturer; if no insulation is included with the unit and the installation instructions do not contain provisions for insulating the line(s), fully insulate the vapor refrigerant line(s) with vapor proof insulation having an inside diameter that matches the refrigerant tubing and a nominal thickness of at least 0.5 inches. For the liquid refrigerant line(s), use the insulation included with the unit; if no insulation is provided, use insulation meeting the specifications for the insulation in the installation instructions included with the unit by the manufacturer; if no insulation is included with the unit and the installation instructions do not contain provisions for insulating the line(s), leave the liquid refrigerant line(s) exposed to the air for air conditioners and heat pumps that heat and cool; or, for heating-only heat pumps, insulate the liquid refrigerant line(s) with insulation having an inside diameter that matches the refrigerant tubing and a nominal thickness of at least 0.5 inches. However, these requirements do not take priority over instructions for application of insulation for the purpose of improving refrigerant temperature measurement accuracy as required by sections 2.10.2 and 2.10.3 of this appendix. Insulation must be the same for the cooling and heating tests.

(2) When testing split systems, if the indoor unit does not ship with a cooling mode expansion device, test the system using the device as specified in the installation instructions provided with the indoor unit. If none is specified, test the system using a fixed orifice or piston type expansion device that is sized appropriately for the system.

(3) When testing triple-split systems (see section 1.2 of this appendix, Definitions), use the tubing length specified in section 6.1.3.5 of AHRI 210/240–2008 (incorporated by reference, see §430.3) to connect the outdoor coil, indoor compressor section, and indoor coil while still meeting the requirement of exposing 10 feet of the tubing to outside conditions;

(4) When testing split systems having multiple indoor coils, connect each indoor blower coil unit to the outdoor unit using:

(a) 25 feet of tubing, or

(b) Tubing furnished by the manufacturer, whichever is longer.

(5) When testing split systems having multiple indoor coils, expose at least 10 feet of the system interconnection tubing to the outside conditions. If they are needed to make a secondary measurement of capacity or for verification of refrigerant charge, install refrigerant pressure measuring instruments as described in section 8.2.5 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). Section 2.10 of this appendix specifies which secondary methods require refrigerant pressure measurements and section 2.2.5.5 of this appendix discusses use of pressure measurements to verify charge. At a minimum, insulate the low-pressure line(s) of a split system with insulation having an inside diameter that matches the refrigerant tubing and a nominal thickness of 0.5 inch.

b. For units designed for both horizontal and vertical installation or for both up-flow and down-flow vertical installations, use the orientation for testing specified by the manufacturer in the certification report. Conduct testing with the following installed:

(1) The most restrictive filter(s);

(2) Supplementary heating coils; and

(3) Other equipment specified as part of the unit, including all hardware used by a heat comfort controller if so equipped (see section 1 of this appendix, Definitions). For small-duct, high-velocity systems, configure all balance dampers or restrictor devices on or inside the unit to fully open or lowest restriction.

c. Testing a ducted unit without having an indoor air filter installed is permissible as long as the minimum external static pressure requirement is adjusted as stated in Table 4, note 3 (see section 3.1.4 of this appendix). Except as noted in section 3.1.10 of this appendix, prevent the indoor air supplementary heating coils from operating during all tests. For uncased coils, create an enclosure using 1 inch fiberglass foil-faced ductboard having a nominal density of 6

pounds per cubic foot. Or alternatively, construct an enclosure using sheet metal or a similar material and insulating material having a thermal resistance (''R'' value) between 4 and 6 hr · ft^2 · °F/Btu. Size the enclosure and seal between the coil and/or drainage pan and the interior of the enclosure as specified in installation instructions shipped with the unit. Also seal between the plenum and inlet and outlet ducts.

d. When testing a coil-only system, install a toroidal-type transformer to power the system's low-voltage components, complying with any additional requirements for the transformer mentioned in the installation manuals included with the unit by the system manufacturer. If the installation manuals do not provide specifications for the transformer, use a transformer having the following features:

(1) A nominal volt-amp rating such that the transformer is loaded between 25 and 90 percent of this rating for the highest level of power measured during the off mode test (section 3.13 of this appendix);

(2) Designed to operate with a primary input of 230 V, single phase, 60 Hz; and

(3) That provides an output voltage that is within the specified range for each low-voltage component. Include the power consumption of the components connected to the transformer as part of the total system power consumption during the off mode tests; do not include the power consumed by the transformer when no load is connected to it.

e. Test an outdoor unit with no match (*i.e.*, that is not distributed in commerce with any indoor units) using a coil-only indoor unit with a single cooling air volume rate whose coil has:

(1) Round tubes of outer diameter no less than 0.375 inches, and

(2) A normalized gross indoor fin surface (NGIFS) no greater than 1.0 square inch per British thermal unit per hour (sq. in./Btu/hr). NGIFS is calculated as follows:

$NGIFS = 2 \times L_f \times W_f \times N_f \div \dot{Q}_c(95)$

where,

L_f = Indoor coil fin length in inches, also height of the coil transverse to the tubes.

W_f = Indoor coil fin width in inches, also depth of the coil.

N_f = Number of fins.

$\dot{Q}_c$ = the measured space cooling capacity of the tested outdoor unit/indoor unit combination as determined from the A_2 or A Test whichever applies, Btu/h.

f. If the outdoor unit or the outdoor portion of a single-package unit has a drain pan heater to prevent freezing of defrost water, energize the heater, subject to control to deenergize it when not needed by the heater's thermostat or the unit's control system, for all tests.

g. If pressure measurement devices are connected to a cooling/heating heat pump refrigerant circuit, the refrigerant charge M_t that could potentially transfer out of the connected pressure measurement systems (transducers, gauges, connections, and lines) between operating modes must be less than 2 percent of the factory refrigerant charge listed on the nameplate of the outdoor unit. If the outdoor unit nameplate has no listed refrigerant charge, or the heat pump is shipped without a refrigerant charge, use a factory refrigerant charge equal to 30 ounces per ton of certified cooling capacity. Use Equation 2.2–1 to calculate M_t for heat pumps that have a single expansion device located in the outdoor unit to serve each indoor unit, and use Equation 2.2–2 to calculate M_t for heat pumps that have two expansion devices per indoor unit.

Equation 2.2-1 $$M_t = \rho * (V_5 * f_5 + V_6 * f_6 + V_3 + V_4 - V_2)$$

Equation 2.2-2 $$M_t = \rho * (V_5 * f_5 + V_6 * f_6)$$

where:

V_i (i=2,3,4 . . .) = the internal volume of the pressure measurement system (pressure lines, fittings, and gauge and/or transducer) at the location i (as indicated in Table 2), (cubic inches)

f_i (i=5,6) = 0 if the pressure measurement system is pitched upwards from the pressure tap location to the gauge or transducer, 1 if it is not.

ρ = the density associated with liquid refrigerant at 100 °F bubble point conditions (ounces per cubic inch)

TABLE 2—PRESSURE MEASUREMENT LOCATIONS

Location	
Compressor Discharge	1
Between Outdoor Coil and Outdoor Expansion Valve(s)	2
Liquid Service Valve	3
Indoor Coil Inlet	4

TABLE 2—PRESSURE MEASUREMENT LOCATIONS—Continued

Location	
Indoor Coil Outlet	5
Common Suction Port (*i.e.*, vapor service valve)	6
Compressor Suction	7

Calculate the internal volume of each pressure measurement system using internal volume reported for pressure transducers and gauges in product literature, if available. If such information is not available, use the value of 0.1 cubic inch internal volume for each pressure transducer, and 0.2 cubic inches for each pressure gauge.

In addition, for heat pumps that have a single expansion device located in the outdoor unit to serve each indoor unit, the internal volume of the pressure system at location 2 (as indicated in Table 2) must be no more than 1 cubic inches. Once the pressure measurement lines are set up, no change should be made until all tests are finished.

2.2.1 Defrost Control Settings

Set heat pump defrost controls at the normal settings which most typify those encountered in generalized climatic region IV. (Refer to Figure 1 and Table 20 of section 4.2 of this appendix for information on region IV.) For heat pumps that use a time-adaptive defrost control system (see section 1.2 of this appendix, Definitions), the manufacturer must specify in the certification report the frosting interval to be used during frost accumulation tests and provide the procedure for manually initiating the defrost at the specified time.

2.2.2 Special Requirements for Units Having a Multiple-Speed Outdoor Fan

Configure the multiple-speed outdoor fan according to the installation manual included with the unit by the manufacturer, and thereafter, leave it unchanged for all tests. The controls of the unit must regulate the operation of the outdoor fan during all lab tests except dry coil cooling mode tests. For dry coil cooling mode tests, the outdoor fan must operate at the same speed used during the required wet coil test conducted at the same outdoor test conditions.

2.2.3 Special Requirements for Multi-Split Air Conditioners and Heat Pumps and Ducted Systems Using a Single Indoor Section Containing Multiple Indoor Blowers That Would Normally Operate Using Two or More Indoor Thermostats

Because these systems will have more than one indoor blower and possibly multiple outdoor fans and compressor systems, references in this test procedure to a singular indoor blower, outdoor fan, and/or compressor means all indoor blowers, all outdoor fans, and all compressor systems that are energized during the test.

a. Additional requirements for multi-split air conditioners and heat pumps. For any test where the system is operated at part load (*i.e.*, one or more compressors ''off'', operating at the intermediate or minimum compressor speed, or at low compressor capacity), the manufacturer must designate in the certification report the indoor coil(s) that are not providing heating or cooling during the test. For variable-speed systems, the manufacturer must designate in the certification report at least one indoor unit that is not providing heating or cooling for all tests conducted at minimum compressor speed. For all other part-load tests, the manufacturer must choose to turn off zero, one, two, or more indoor units. The chosen configuration must remain unchanged for all tests conducted at the same compressor speed/capacity. For any indoor coil that is not providing heating or cooling during a test, cease forced airflow through this indoor coil and block its outlet duct.

b. Additional requirements for ducted split systems with a single indoor unit containing multiple indoor blowers (or for single-package units with an indoor section containing multiple indoor blowers) where the indoor blowers are designed to cycle on and off independently of one another and are not controlled such that all indoor blowers are modulated to always operate at the same air volume rate or speed. For any test where the system is operated at its lowest capacity—*i.e.*, the lowest total air volume rate allowed when operating the single-speed compressor or when operating at low compressor capacity—turn off indoor blowers accounting for at least one-third of the full-load air volume rate unless prevented by the controls of the unit. In such cases, turn off as many indoor blowers as permitted by the unit's controls. Where more than one option exists for meeting this ''off'' requirement, the manufacturer must indicate in its certification report which indoor blower(s) are turned off. The chosen configuration shall remain unchanged for all tests conducted at the same lowest capacity configuration. For any indoor coil turned off during a test, cease forced airflow through any outlet duct connected to a switched-off indoor blower.

c. For test setups where the laboratory's physical limitations require use of more than the required line length of 25 feet as listed in section 2.2.a.(4) of this appendix, then the actual refrigerant line length used by the laboratory may exceed the required length and the refrigerant line length correction factors in Table 4 of AHRI 1230–2010 are applied to the cooling capacity measured for each cooling mode test.

2.2.4 Wet-Bulb Temperature Requirements for the Air Entering the Indoor and Outdoor Coils

2.2.4.1 Cooling Mode Tests

For wet-coil cooling mode tests, regulate the water vapor content of the air entering the indoor unit so that the wet-bulb temperature is as listed in Tables 5 to 8. As noted in these same tables, achieve a wet-bulb temperature during dry-coil cooling mode tests that results in no condensate forming on the indoor coil. Controlling the water vapor content of the air entering the outdoor side of the unit is not required for cooling mode tests except when testing:

(1) Units that reject condensate to the outdoor coil during wet coil tests. Tables 5–8 list the applicable wet-bulb temperatures.

(2) Single-package units where all or part of the indoor section is located in the outdoor test room. The average dew point temperature of the air entering the outdoor coil during wet coil tests must be within ±3.0 °F of the average dew point temperature of the air entering the indoor coil over the 30-minute data collection interval described in section 3.3 of this appendix. For dry coil tests on such units, it may be necessary to limit the moisture content of the air entering the outdoor coil of the unit to meet the requirements of section 3.4 of this appendix.

2.2.4.2 Heating Mode Tests

For heating mode tests, regulate the water vapor content of the air entering the outdoor unit to the applicable wet-bulb temperature listed in Tables 12 to 15. The wet-bulb temperature entering the indoor side of the heat pump must not exceed 60 °F. Additionally, if the Outdoor Air Enthalpy test method (section 2.10.1 of this appendix) is used while testing a single-package heat pump where all or part of the outdoor section is located in the indoor test room, adjust the wet-bulb temperature for the air entering the indoor side to yield an indoor-side dew point temperature that is as close as reasonably possible to the dew point temperature of the outdoor-side entering air.

2.2.5 Additional Refrigerant Charging Requirements

2.2.5.1 Instructions to Use for Charging

a. Where the manufacturer's installation instructions contain two sets of refrigerant charging criteria, one for field installations and one for lab testing, use the field installation criteria.

b. For systems consisting of an outdoor unit manufacturer's outdoor section and indoor section with differing charging procedures, adjust the refrigerant charge per the outdoor installation instructions.

c. For systems consisting of an outdoor unit manufacturer's outdoor unit and an independent coil manufacturer's indoor unit with differing charging procedures, adjust the refrigerant charge per the indoor unit's installation instructions. If instructions are provided only with the outdoor unit or are provided only with an independent coil manufacturer's indoor unit, then use the provided instructions.

2.2.5.2 Test(s) to Use for Charging

a. Use the tests or operating conditions specified in the manufacturer's installation instructions for charging. The manufacturer's installation instructions may specify use of tests other than the A or A_2 test for charging, but, unless the unit is a heating-only heat pump, determine the air volume rate by the A or A_2 test as specified in section 3.1 of this appendix.

b. If the manufacturer's installation instructions do not specify a test or operating conditions for charging or there are no manufacturer's instructions, use the following test(s):

(1) For air conditioners or cooling and heating heat pumps, use the A or A_2 test.

(2) For cooling and heating heat pumps that do not operate in the H1 or $H1_2$ test (*e.g.* due to shut down by the unit limiting devices) when tested using the charge determined at the A or A_2 test, and for heating-only heat pumps, use the H1 or $H1_2$ test.

2.2.5.3 Parameters to Set and Their Target Values

a. Consult the manufacturer's installation instructions regarding which parameters (*e.g.*, superheat) to set and their target values. If the instructions provide ranges of values, select target values equal to the midpoints of the provided ranges.

b. In the event of conflicting information between charging instructions (*i.e.*, multiple conditions given for charge adjustment where all conditions specified cannot be met), follow the following hierarchy.

(1) For fixed orifice systems:

(i) Superheat

(ii) High side pressure or corresponding saturation or dew-point temperature

(iii) Low side pressure or corresponding saturation or dew-point temperature

(iv) Low side temperature

(v) High side temperature

(vi) Charge weight

(2) For expansion valve systems:

(i) Subcooling

(ii) High side pressure or corresponding saturation or dew-point temperature

(iii) Low side pressure or corresponding saturation or dew-point temperature

(iv) Approach temperature (difference between temperature of liquid leaving condenser and condenser average inlet air temperature)

(v) Charge weight

c. If there are no installation instructions and/or they do not provide parameters and target values, set superheat to a target value of 12 °F for fixed orifice systems or set subcooling to a target value of 10 °F for expansion valve systems.

2.2.5.4 Charging Tolerances

a. If the manufacturer's installation instructions specify tolerances on target values for the charging parameters, set the values within these tolerances.

b. Otherwise, set parameter values within the following test condition tolerances for the different charging parameters:

11. Superheat: ± 2.0 °F

12. Subcooling: ± 2.0 °F

13. High side pressure or corresponding saturation or dew point temperature: ± 4.0 psi or ± 1.0 °F

14. Low side pressure or corresponding saturation or dew point temperature: ± 2.0 psi or ± 0.8 °F

15. High side temperature: ± 2.0 °F

16. Low side temperature: ± 2.0 °F

17. Approach temperature: ± 1.0 °F

18. Charge weight: ± 2.0 ounce

2.2.5.5 Special Charging Instructions

a. Cooling and Heating Heat Pumps

If, using the initial charge set in the A or A_2 test, the conditions are not within the range specified in manufacturer's installation instructions for the H1 or $H1_2$ test, make as small as possible an adjustment to obtain conditions for this test in the specified range. After this adjustment, recheck conditions in the A or A_2 test to confirm that they are still within the specified range for the A or A_2 test.

b. Single-Package Systems

i. Unless otherwise directed by the manufacturer's installation instructions, install one or more refrigerant line pressure gauges during the setup of the unit, located depending on the parameters used to verify or set charge, as described:

(1) Install a pressure gauge at the location of the service valve on the liquid line if charging is on the basis of subcooling, or high side pressure or corresponding saturation or dew point temperature;

(2) Install a pressure gauge at the location of the service valve on the suction line if charging is on the basis of superheat, or low side pressure or corresponding saturation or dew point temperature.

ii. Use methods for installing pressure gauge(s) at the required location(s) as indicated in manufacturer's instructions if specified.

2.2.5.6 Near-Azeotropic and Zeotropic Refrigerants

Perform charging of near-azeotropic and zeotropic refrigerants only with refrigerant in the liquid state.

2.2.5.7 Adjustment of Charge Between Tests

After charging the system as described in this test procedure, use the set refrigerant charge for all tests used to determine performance. Do not adjust the refrigerant charge at any point during testing. If measurements indicate that refrigerant charge has leaked during the test, repair the refrigerant leak, repeat any necessary set-up steps, and repeat all tests.

2.3 Indoor Air Volume Rates

If a unit's controls allow for overspeeding the indoor blower (usually on a temporary basis), take the necessary steps to prevent overspeeding during all tests.

2.3.1 Cooling Tests

a. Set indoor blower airflow-control settings (*e.g.,* fan motor pin settings, fan motor speed) according to the requirements that are specified in section 3.1.4 of this appendix.

b. Express the Cooling full-load air volume rate, the Cooling Minimum Air Volume Rate, and the Cooling Intermediate Air Volume Rate in terms of standard air.

2.3.2 Heating Tests

a. Set indoor blower airflow-control settings (*e.g.,* fan motor pin settings, fan motor speed) according to the requirements that are specified in section 3.1.4 of this appendix.

b. Express the heating full-load air volume rate, the heating minimum air volume rate, the heating intermediate air volume rate, and the heating nominal air volume rate in terms of standard air.

2.4 Indoor Coil Inlet and Outlet Duct Connections

Insulate and/or construct the outlet plenum as described in section 2.4.1 of this appendix and, if installed, the inlet plenum described in section 2.4.2 of this appendix with thermal insulation having a nominal overall resistance (R-value) of at least 19 hr·ft² °F/Btu.

2.4.1 Outlet Plenum for the Indoor Unit

a. Attach a plenum to the outlet of the indoor coil. (NOTE: For some packaged systems, the indoor coil may be located in the outdoor test room.)

b. For systems having multiple indoor coils, or multiple indoor blowers within a single indoor section, attach a plenum to

each indoor coil or indoor blower outlet. In order to reduce the number of required airflow measurement apparatuses (section 2.6 of this appendix), each such apparatus may serve multiple outlet plenums connected to a single common duct leading to the apparatus. More than one indoor test room may be used, which may use one or more common ducts leading to one or more airflow measurement apparatuses within each test room that contains multiple indoor coils. At the plane where each plenum enters a common duct, install an adjustable airflow damper and use it to equalize the static pressure in each plenum. The outlet air temperature grid(s) (section 2.5.4 of this appendix) and airflow measuring apparatus shall be located downstream of the inlet(s) to the common duct(s). For multiple-circuit (or multi-circuit) systems for which each indoor coil outlet is measured separately and its outlet plenum is not connected to a common duct connecting multiple outlet plenums, install the outlet air temperature grid and airflow measuring apparatus at each outlet plenum.

c. For small-duct, high-velocity systems, install an outlet plenum that has a diameter that is equal to or less than the value listed in Table 3. The limit depends only on the Cooling full-load air volume rate (see section 3.1.4.1.1 of this appendix) and is effective regardless of the flange dimensions on the outlet of the unit (or an air supply plenum adapter accessory, if installed in accordance with the manufacturer's installation instructions).

d. Add a static pressure tap to each face of the (each) outlet plenum, if rectangular, or at four evenly distributed locations along the circumference of an oval or round plenum. Create a manifold that connects the four static pressure taps. Figure 9 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) shows allowed options for the manifold configuration. The cross-sectional dimensions of plenum must be equal to the dimensions of the indoor unit outlet. See Figures 7a, 7b, and 7c of ANSI/ASHRAE 37–2009 for the minimum length of the (each) outlet plenum and the locations for adding the static pressure taps for ducted blower coil indoor units and single-package systems. See Figure 8 of ANSI/ASHRAE 37–2009 for coil-only indoor units.

TABLE 3—SIZE OF OUTLET PLENUM FOR SMALL-DUCT HIGH-VELOCITY INDOOR UNITS

Cooling full-load air volume rate (scfm)	Maximum diameter* of outlet plenum (inches)
≤500	6
501 to 700	7
701 to 900	8
901 to 1100	9
1101 to 1400	10
1401 to 1750	11

*If the outlet plenum is rectangular, calculate its equivalent diameter using ($4A/P$,) where A is the cross-sectional area and P is the perimeter of the rectangular plenum, and compare it to the listed maximum diameter.

2.4.2 Inlet Plenum for the Indoor Unit

Install an inlet plenum when testing a coil-only indoor unit, a ducted blower coil indoor unit, or a single-package system. See Figures 7b and 7c of ANSI/ASHRAE 37–2009 for cross-sectional dimensions, the minimum length of the inlet plenum, and the locations of the static-pressure taps for ducted blower coil indoor units and single-package systems. See Figure 8 of ANSI/ASHRAE 37–2009 for coil-only indoor units. The inlet plenum duct size shall equal the size of the inlet opening of the air-handling (blower coil) unit or furnace. For a ducted blower coil indoor unit the set up may omit the inlet plenum if an inlet airflow prevention device is installed with a straight internally unobstructed duct on its outlet end with a minimum length equal to 1.5 times the square root of the cross-sectional area of the indoor unit inlet. See section 2.1.5.2 of this appendix for requirements for the locations of static pressure taps built into the inlet airflow prevention device. For all of these arrangements, make a manifold that connects the four static-pressure taps using one of the three configurations specified in section 2.4.1.d. of this appendix. Never use an inlet plenum when testing a non-ducted system.

2.5 Indoor Coil Air Property Measurements and Airflow Prevention Devices.

Follow instructions for indoor coil air property measurements as described in section 2.14 of this appendix, unless otherwise instructed in this section.

a. Measure the dry-bulb temperature and water vapor content of the air entering and leaving the indoor coil. If needed, use an air sampling device to divert air to a sensor(s) that measures the water vapor content of the air. See section 5.3 of ANSI/ASHRAE 41.1–2013 (incorporated by reference, see §430.3) for guidance on constructing an air sampling device. No part of the air sampling device or the tubing transferring the sampled air to the sensor must be within two inches of the test chamber floor, and the transfer tubing must be insulated. The sampling device may also be used for measurement of dry bulb temperature by transferring the sampled air to a remotely located

sensor(s). The air sampling device and the remotely located temperature sensor(s) may be used to determine the entering air dry bulb temperature during any test. The air sampling device and the remotely located sensor(s) may be used to determine the leaving air dry bulb temperature for all tests except:

(1) Cyclic tests; and

(2) Frost accumulation tests.

b. Install grids of temperature sensors to measure dry bulb temperatures of both the entering and leaving airstreams of the indoor unit. These grids of dry bulb temperature sensors may be used to measure average dry bulb temperature entering and leaving the indoor unit in all cases (as an alternative to the dry bulb sensor measuring the sampled air). The leaving airstream grid is required for measurement of average dry bulb temperature leaving the indoor unit for cyclic tests and frost accumulation tests. The grids are also required to measure the air temperature distribution of the entering and leaving airstreams as described in sections 3.1.8 of this appendix. Two such grids may be applied as a thermopile, to directly obtain the average temperature difference rather than directly measuring both entering and leaving average temperatures.

c. Use of airflow prevention devices. Use an inlet and outlet air damper box, or use an inlet upturned duct and an outlet air damper box when conducting one or both of the cyclic tests listed in sections 3.2 and 3.6 of this appendix on ducted systems. If not conducting any cyclic tests, an outlet air damper box is required when testing ducted and non-ducted heat pumps that cycle off the indoor blower during defrost cycles and there is no other means for preventing natural or forced convection through the indoor unit when the indoor blower is off. Never use an inlet damper box or an inlet upturned duct when testing non-ducted indoor units. An inlet upturned duct is a length of ductwork installed upstream from the inlet such that the indoor duct inlet opening, facing upwards, is sufficiently high to prevent natural convection transfer out of the duct. If an inlet upturned duct is used, install a dry bulb temperature sensor near the inlet opening of the indoor duct at a centerline location not higher than the lowest elevation of the duct edges at the inlet, and ensure that any pair of 5-minute averages of the dry bulb temperature at this location, measured at least every minute during the compressor OFF period of the cyclic test, do not differ by more than 1.0 °F.

2.5.1 Test Set-Up on the Inlet Side of the Indoor Coil: for Cases Where the Inlet Airflow Prevention Device is Installed

a. Install an airflow prevention device as specified in section 2.5.1.1 or 2.5.1.2 of this appendix, whichever applies.

b. For an inlet damper box, locate the grid of entering air dry-bulb temperature sensors, if used, and the air sampling device, or the sensor used to measure the water vapor content of the inlet air, at a location immediately upstream of the damper box inlet. For an inlet upturned duct, locate the grid of entering air dry-bulb temperature sensors, if used, and the air sampling device, or the sensor used to measure the water vapor content of the inlet air, at a location at least one foot downstream from the beginning of the insulated portion of the duct but before the static pressure measurement.

2.5.1.1 If the section 2.4.2 inlet plenum is installed, construct the airflow prevention device having a cross-sectional flow area equal to or greater than the flow area of the inlet plenum. Install the airflow prevention device upstream of the inlet plenum and construct ductwork connecting it to the inlet plenum. If needed, use an adaptor plate or a transition duct section to connect the airflow prevention device with the inlet plenum. Insulate the ductwork and inlet plenum with thermal insulation that has a nominal overall resistance (R-value) of at least 19 $hr \cdot ft^2 \cdot °F/Btu$.

2.5.1.2 If the section 2.4.2 inlet plenum is not installed, construct the airflow prevention device having a cross-sectional flow area equal to or greater than the flow area of the air inlet of the indoor unit. Install the airflow prevention device immediately upstream of the inlet of the indoor unit. If needed, use an adaptor plate or a short transition duct section to connect the airflow prevention device with the unit's air inlet. Add static pressure taps at the center of each face of a rectangular airflow prevention device, or at four evenly distributed locations along the circumference of an oval or round airflow prevention device. Locate the pressure taps at a distance from the indoor unit inlet equal to 0.5 times the square root of the cross sectional area of the indoor unit inlet. This location must be between the damper and the inlet of the indoor unit, if a damper is used. Make a manifold that connects the four static pressure taps using one of the configurations shown in Figure 9 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). Insulate the ductwork with thermal insulation that has a nominal overall resistance (R-value) of at least 19 $hr \cdot ft^{2,} \cdot °F/Btu$.

2.5.2 Test Set-Up on the Inlet Side of the Indoor Unit: for Cases Where No Airflow Prevention Device is Installed

If using the section 2.4.2 inlet plenum and a grid of dry bulb temperature sensors, mount the grid at a location upstream of the static pressure taps described in section 2.4.2 of this appendix, preferably at the entrance plane of the inlet plenum. If the section 2.4.2

inlet plenum is not used (*i.e.* for non-ducted units) locate a grid approximately 6 inches upstream of the indoor unit inlet. In the case of a system having multiple non-ducted indoor units, do this for each indoor unit. Position an air sampling device, or the sensor used to measure the water vapor content of the inlet air, immediately upstream of the (each) entering air dry-bulb temperature sensor grid. If a grid of sensors is not used, position the entering air sampling device (or the sensor used to measure the water vapor content of the inlet air) as if the grid were present.

2.5.3 Indoor Coil Static Pressure Difference Measurement

Fabricate pressure taps meeting all requirements described in section 6.5.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) and illustrated in Figure 2A of AMCA 210–2007 (incorporated by reference, see §430.3), however, if adhering strictly to the description in section 6.5.2 of ANSI/ASHRAE 37–2009, the minimum pressure tap length of 2.5 times the inner diameter of Figure 2A of AMCA 210–2007 is waived. Use a differential pressure measuring instrument that is accurate to within ±0.01 inches of water and has a resolution of at least 0.01 inches of water to measure the static pressure difference between the indoor coil air inlet and outlet. Connect one side of the differential pressure instrument to the manifolded pressure taps installed in the outlet plenum. Connect the other side of the instrument to the manifolded pressure taps located in either the inlet plenum or incorporated within the airflow prevention device. For non-ducted systems that are tested with multiple outlet plenums, measure the static pressure within each outlet plenum relative to the surrounding atmosphere.

2.5.4 Test Set-Up on the Outlet Side of the Indoor Coil

a. Install an interconnecting duct between the outlet plenum described in section 2.4.1 of this appendix and the airflow measuring apparatus described below in section 2.6 of this appendix. The cross-sectional flow area of the interconnecting duct must be equal to or greater than the flow area of the outlet plenum or the common duct used when testing non-ducted units having multiple indoor coils. If needed, use adaptor plates or transition duct sections to allow the connections. To minimize leakage, tape joints within the interconnecting duct (and the outlet plenum). Construct or insulate the entire flow section with thermal insulation having a nominal overall resistance (R-value) of at least 19 $hr \cdot ft^{2,} \cdot °F/Btu$.

b. Install a grid(s) of dry-bulb temperature sensors inside the interconnecting duct. Also, install an air sampling device, or the sensor(s) used to measure the water vapor content of the outlet air, inside the interconnecting duct. Locate the dry-bulb temperature grid(s) upstream of the air sampling device (or the in-duct sensor(s) used to measure the water vapor content of the outlet air). Turn off the sampler fan motor during the cyclic tests. Air leaving an indoor unit that is sampled by an air sampling device for remote water-vapor-content measurement must be returned to the interconnecting duct at a location:

(1) Downstream of the air sampling device;

(2) On the same side of the outlet air damper as the air sampling device; and

(3) Upstream of the section 2.6 airflow measuring apparatus.

2.5.4.1 Outlet Air Damper Box Placement and Requirements

If using an outlet air damper box (see section 2.5 of this appendix), the leakage rate from the combination of the outlet plenum, the closed damper, and the duct section that connects these two components must not exceed 20 cubic feet per minute when a negative pressure of 1 inch of water column is maintained at the plenum's inlet.

2.5.4.2 Procedures to Minimize Temperature Maldistribution

Use these procedures if necessary to correct temperature maldistributions. Install a mixing device(s) upstream of the outlet air, dry-bulb temperature grid (but downstream of the outlet plenum static pressure taps). Use a perforated screen located between the mixing device and the dry-bulb temperature grid, with a maximum open area of 40 percent. One or both items should help to meet the maximum outlet air temperature distribution specified in section 3.1.8 of this appendix. Mixing devices are described in sections 5.3.2 and 5.3.3 of ANSI/ASHRAE 41.1–2013 and section 5.2.2 of ASHRAE 41.2–1987 (RA 1992) (incorporated by reference, see §430.3).

2.5.4.3 Minimizing Air Leakage

For small-duct, high-velocity systems, install an air damper near the end of the interconnecting duct, just prior to the transition to the airflow measuring apparatus of section 2.6 of this appendix. To minimize air leakage, adjust this damper such that the pressure in the receiving chamber of the airflow measuring apparatus is no more than 0.5 inch of water higher than the surrounding test room ambient. If applicable, in lieu of installing a separate damper, use the outlet air damper box of sections 2.5 and 2.5.4.1 of this appendix if it allows variable positioning. Also apply these steps to any conventional indoor blower unit that creates a static pressure within the receiving chamber

of the airflow measuring apparatus that exceeds the test room ambient pressure by more than 0.5 inches of water column.

2.5.5 Dry Bulb Temperature Measurement

a. Measure dry bulb temperatures as specified in sections 4, 5.3, 6, and 7 of ANSI/ASHRAE 41.1–2013 (incorporated by reference, see §430.3).

b. Distribute the sensors of a dry-bulb temperature grid over the entire flow area. The required minimum is 9 sensors per grid.

2.5.6 Water Vapor Content Measurement

Determine water vapor content by measuring dry-bulb temperature combined with the air wet-bulb temperature, dew point temperature, or relative humidity. If used, construct and apply wet-bulb temperature sensors as specified in sections 4, 5, 6, 7.2, 7.3, and 7.4 of ASHRAE 41.6–2014 (incorporated by reference, see §430.3). The temperature sensor (wick removed) must be accurate to within ±0.2 °F. If used, apply dew point hygrometers as specified in sections 4, 5, 6, 7.1, and 7.4 of ASHRAE 41.6–2014. The dew point hygrometers must be accurate to within ±0.4 °F when operated at conditions that result in the evaluation of dew points above 35 °F. If used, a relative humidity (RH) meter must be accurate to within ±0.7% RH. Other means to determine the psychrometric state of air may be used as long as the measurement accuracy is equivalent to or better than the accuracy achieved from using a wet-bulb temperature sensor that meets the above specifications.

2.5.7 Air Damper Box Performance Requirements

If used (see section 2.5 of this appendix), the air damper box(es) must be capable of being completely opened or completely closed within 10 seconds for each action.

2.6 Airflow Measuring Apparatus

a. Fabricate and operate an airflow measuring apparatus as specified in section 6.2 and 6.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). Place the static pressure taps and position the diffusion baffle (settling means) relative to the chamber inlet as indicated in Figure 12 of AMCA 210–07 and/or Figure 14 of ASHRAE 41.2–1987 (RA 1992) (incorporated by reference, see §430.3). When measuring the static pressure difference across nozzles and/or velocity pressure at nozzle throats using electronic pressure transducers and a data acquisition system, if high frequency fluctuations cause measurement variations to exceed the test tolerance limits specified in section 9.2 and Table 2 of ANSI/ASHRAE 37–2009, dampen the measurement system such that the time constant associated with response to a step change in measurement (time for the response to change 63% of the way from the initial output to the final output) is no longer than five seconds.

b. Connect the airflow measuring apparatus to the interconnecting duct section described in section 2.5.4 of this appendix. See sections 6.1.1, 6.1.2, and 6.1.4, and Figures 1, 2, and 4 of ANSI/ASHRAE 37–2009; and Figures D1, D2, and D4 of AHRI 210/240–2008 (incorporated by reference, see §430.3) with Addendum 1 and 2 for illustrative examples of how the test apparatus may be applied within a complete laboratory set-up. Instead of following one of these examples, an alternative set-up may be used to handle the air leaving the airflow measuring apparatus and to supply properly conditioned air to the test unit's inlet. The alternative set-up, however, must not interfere with the prescribed means for measuring airflow rate, inlet and outlet air temperatures, inlet and outlet water vapor contents, and external static pressures, nor create abnormal conditions surrounding the test unit. (NOTE: Do not use an enclosure as described in section 6.1.3 of ANSI/ASHRAE 37–2009 when testing triple-split units.)

2.7 Electrical Voltage Supply

Perform all tests at the voltage specified in section 6.1.3.2 of AHRI 210/240–2008 (incorporated by reference, see §430.3) for ''Standard Rating Tests.'' If either the indoor or the outdoor unit has a 208V or 200V nameplate voltage and the other unit has a 230V nameplate rating, select the voltage supply on the outdoor unit for testing. Otherwise, supply each unit with its own nameplate voltage. Measure the supply voltage at the terminals on the test unit using a volt meter that provides a reading that is accurate to within ±1.0 percent of the measured quantity.

2.8 Electrical Power and Energy Measurements

a. Use an integrating power (watt-hour) measuring system to determine the electrical energy or average electrical power supplied to all components of the air conditioner or heat pump (including auxiliary components such as controls, transformers, crankcase heater, integral condensate pump on non-ducted indoor units, etc.). The watt-hour measuring system must give readings that are accurate to within ±0.5 percent. For cyclic tests, this accuracy is required during both the ON and OFF cycles. Use either two different scales on the same watt-hour meter or two separate watt-hour meters. Activate the scale or meter having the lower power rating within 15 seconds after beginning an OFF cycle. Activate the scale or meter having the higher power rating within 15 seconds prior to beginning an ON cycle. For ducted blower coil systems, the ON cycle lasts from compressor ON to indoor blower OFF. For ducted coil-only systems, the ON

cycle lasts from compressor ON to compressor OFF. For non-ducted units, the ON cycle lasts from indoor blower ON to indoor blower OFF. When testing air conditioners and heat pumps having a variable-speed compressor, avoid using an induction watt/watt-hour meter.

b. When performing section 3.5 and/or 3.8 cyclic tests on non-ducted units, provide instrumentation to determine the average electrical power consumption of the indoor blower motor to within ±1.0 percent. If required according to sections 3.3, 3.4, 3.7, 3.9.1 of this appendix, and/or 3.10 of this appendix, this same instrumentation requirement (to determine the average electrical power consumption of the indoor blower motor to within ±1.0 percent) applies when testing air conditioners and heat pumps having a variable-speed constant-air-volume-rate indoor blower or a variable-speed, variable-air-volume-rate indoor blower.

2.9 Time Measurements

Make elapsed time measurements using an instrument that yields readings accurate to within ±0.2 percent.

2.10 Test Apparatus for the Secondary Space Conditioning Capacity Measurement

For all tests, use the indoor air enthalpy method to measure the unit's capacity. This method uses the test set-up specified in sections 2.4 to 2.6 of this appendix. In addition, for all steady-state tests, conduct a second, independent measurement of capacity as described in section 3.1.1 of this appendix. For split systems, use one of the following secondary measurement methods: outdoor air enthalpy method, compressor calibration method, or refrigerant enthalpy method. For single-package units, use either the outdoor air enthalpy method or the compressor calibration method as the secondary measurement.

2.10.1 Outdoor Air Enthalpy Method

a. To make a secondary measurement of indoor space conditioning capacity using the outdoor air enthalpy method, do the following:

(1) Measure the electrical power consumption of the test unit;

(2) Measure the air-side capacity at the outdoor coil; and

(3) Apply a heat balance on the refrigerant cycle.

b. The test apparatus required for the outdoor air enthalpy method is a subset of the apparatus used for the indoor air enthalpy method. Required apparatus includes the following:

(1) On the outlet side, an outlet plenum containing static pressure taps (sections 2.4, 2.4.1, and 2.5.3 of this appendix),

(2) An airflow measuring apparatus (section 2.6 of this appendix),

(3) A duct section that connects these two components and itself contains the instrumentation for measuring the dry-bulb temperature and water vapor content of the air leaving the outdoor coil (sections 2.5.4, 2.5.5, and 2.5.6 of this appendix), and

(4) On the inlet side, a sampling device and temperature grid (section 2.11.b of this appendix).

c. During the free outdoor air tests described in sections 3.11.1 and 3.11.1.1 of this appendix, measure the evaporator and condenser temperatures or pressures. On both the outdoor coil and the indoor coil, solder a thermocouple onto a return bend located at or near the midpoint of each coil or at points not affected by vapor superheat or liquid subcooling. Alternatively, if the test unit is not sensitive to the refrigerant charge, install pressure gages to the access valves or to ports created from tapping into the suction and discharge lines according to sections 7.4.2 and 8.2.5 of ANSI/ASHRAE 37–2009. Use this alternative approach when testing a unit charged with a zeotropic refrigerant having a temperature glide in excess of 1 °F at the specified test conditions.

2.10.2 Compressor Calibration Method

Measure refrigerant pressures and temperatures to determine the evaporator superheat and the enthalpy of the refrigerant that enters and exits the indoor coil. Determine refrigerant flow rate or, when the superheat of the refrigerant leaving the evaporator is less than 5 °F, total capacity from separate calibration tests conducted under identical operating conditions. When using this method, install instrumentation and measure refrigerant properties according to section 7.4.2 and 8.2.5 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). If removing the refrigerant before applying refrigerant lines and subsequently recharging, use the steps in 7.4.2 of ANSI/ASHRAE 37–2009 in addition to the methods of section 2.2.5 of this appendix to confirm the refrigerant charge. Use refrigerant temperature and pressure measuring instruments that meet the specifications given in sections 5.1.1 and 5.2 of ANSI/ASHRAE 37–2009.

2.10.3 Refrigerant Enthalpy Method

For this method, calculate space conditioning capacity by determining the refrigerant enthalpy change for the indoor coil and directly measuring the refrigerant flow rate. Use section 7.5.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) for the requirements for this method, including the additional instrumentation requirements, and information on placing the flow

meter and a sight glass. Use refrigerant temperature, pressure, and flow measuring instruments that meet the specifications given in sections 5.1.1, 5.2, and 5.5.1 of ANSI/ASHRAE 37–2009. Refrigerant flow measurement device(s), if used, must be either elevated at least two feet from the test chamber floor or placed upon insulating material having a total thermal resistance of at least R–12 and extending at least one foot laterally beyond each side of the device(s)' exposed surfaces.

2.11 Measurement of Test Room Ambient Conditions

Follow instructions for setting up air sampling device and aspirating psychrometer as described in section 2.14 of this appendix, unless otherwise instructed in this section.

a. If using a test set-up where air is ducted directly from the conditioning apparatus to the indoor coil inlet (see Figure 2, Loop Air-Enthalpy Test Method Arrangement, of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3)), add instrumentation to permit measurement of the indoor test room dry-bulb temperature.

b. On the outdoor side, use one of the following two approaches, except that approach (1) is required for all evaporatively cooled units and units that transfer condensate to the outdoor unit for evaporation using condenser heat.

(1) Use sampling tree air collection on all air-inlet surfaces of the outdoor unit.

(2) Use sampling tree air collection on one or more faces of the outdoor unit and demonstrate air temperature uniformity as follows. Install a grid of evenly distributed thermocouples on each air-permitting face on the inlet of the outdoor unit. Install the thermocouples on the air sampling device, locate them individually or attach them to a wire structure. If not installed on the air sampling device, install the thermocouple grid 6 to 24 inches from the unit. Evenly space the thermocouples across the coil inlet surface and install them to avoid sampling of discharge air or blockage of air recirculation. The grid of thermocouples must provide at least 16 measuring points per face or one measurement per square foot of inlet face area, whichever is less. Construct this grid and use as per section 5.3 of ANSI/ASHRAE 41.1–2013 (incorporated by reference, see §430.3). The maximum difference between the average temperatures measured during the test period of any two pairs of these individual thermocouples located at any of the faces of the inlet of the outdoor unit, must not exceed 2.0 °F, otherwise use approach (1).

Locate the air sampling devices at the geometric center of each side; the branches may be oriented either parallel or perpendicular to the longer edges of the air inlet area. Size the air sampling devices in the outdoor air inlet location such that they cover at least 75% of the face area of the side of the coil that they are measuring.

Review air distribution at the test facility point of supply to the unit and remediate as necessary prior to the beginning of testing. Mixing fans can be used to ensure adequate air distribution in the test room. If used, orient mixing fans such that they are pointed away from the air intake so that the mixing fan exhaust does not affect the outdoor coil air volume rate. Particular attention should be given to prevent the mixing fans from affecting (enhancing or limiting) recirculation of condenser fan exhaust air back through the unit. Any fan used to enhance test room air mixing shall not cause air velocities in the vicinity of the test unit to exceed 500 feet per minute.

The air sampling device may be larger than the face area of the side being measured. Take care, however, to prevent discharge air from being sampled. If an air sampling device dimension extends beyond the inlet area of the unit, block holes in the air sampling device to prevent sampling of discharge air. Holes can be blocked to reduce the region of coverage of the intake holes both in the direction of the trunk axis or perpendicular to the trunk axis. For intake hole region reduction in the direction of the trunk axis, block holes of one or more adjacent pairs of branches (the branches of a pair connect opposite each other at the same trunk location) at either the outlet end or the closed end of the trunk. For intake hole region reduction perpendicular to the trunk axis, block off the same number of holes on each branch on both sides of the trunk.

Connect a maximum of four (4) air sampling devices to each aspirating psychrometer. In order to proportionately divide the flow stream for multiple air sampling devices for a given aspirating psychrometer, the tubing or conduit conveying sampled air to the psychrometer must be of equivalent lengths for each air sampling device. Preferentially, the air sampling device should be hard connected to the aspirating psychrometer, but if space constraints do not allow this, the assembly shall have a means of allowing a flexible tube to connect the air sampling device to the aspirating psychrometer. Insulate and route the tubing or conduit to prevent heat transfer to the air stream. Insulate any surface of the air conveying tubing in contact with surrounding air at a different temperature than the sampled air with thermal insulation with a nominal thermal resistance (R-value) of at least 19 hr • ft^2 • °F/Btu. Alternatively the conduit may have lower thermal resistance if additional sensor(s) are used to measure dry bulb temperature at the outlet of each air sampling device. No part of the air sampling device or the tubing conducting the sampled air to the sensors may be within two inches of the test chamber floor.

Take pairs of measurements (*e.g.* dry bulb temperature and wet bulb temperature) used to determine water vapor content of sampled air in the same location.

2.12 Measurement of Indoor Blower Speed

When required, measure fan speed using a revolution counter, tachometer, or stroboscope that gives readings accurate to within ±1.0 percent.

2.13 Measurement of Barometric Pressure

Determine the average barometric pressure during each test. Use an instrument that meets the requirements specified in section 5.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3).

2.14 Air Sampling Device and Aspirating Psychrometer Requirements

Make air temperature measurements in accordance with ANSI/ASHRAE 41.1–2013 (incorporated by reference, see §430.3), unless otherwise instructed in this section.

2.14.1 Air Sampling Device Requirements

The air sampling device is intended to draw in a sample of the air at the critical locations of a unit under test. Construct the device from stainless steel, plastic or other suitable, durable materials. It shall have a main flow trunk tube with a series of branch tubes connected to the trunk tube. Holes must be on the side of the sampler facing the upstream direction of the air source. Use other sizes and rectangular shapes, and scale them accordingly with the following guidelines:

1. Minimum hole density of 6 holes per square foot of area to be sampled.
2. Sampler branch tube pitch (spacing) of 6 ± 3 in.
3. Manifold trunk to branch diameter ratio having a minimum of 3:1 ratio.
4. Distribute hole pitch (spacing) equally over the branch (½ pitch from the closed end to the nearest hole).
5. Maximum individual hole to branch diameter ratio of 1:2 (1:3 preferred).

The minimum average velocity through the air sampling device holes must be 2.5 ft/s as determined by evaluating the sum of the open area of the holes as compared to the flow area in the aspirating psychrometer.

2.14.2 Aspirating Psychrometer

The psychrometer consists of a flow section and a fan to draw air through the flow section and measures an average value of the sampled air stream. At a minimum, the flow section shall have a means for measuring the dry bulb temperature (typically, a resistance temperature device (RTD) and a means for measuring the humidity (RTD with wetted sock, chilled mirror hygrometer, or relative humidity sensor). The aspirating psychrometer shall include a fan that either can be adjusted manually or automatically to maintain required velocity across the sensors.

Construct the psychrometer using suitable material which may be plastic (such as polycarbonate), aluminum or other metallic materials. Construct all psychrometers for a given system being tested, using the same material. Design the psychrometers such that radiant heat from the motor (for driving the fan that draws sampled air through the psychrometer) does not affect sensor measurements. For aspirating psychrometers, velocity across the wet bulb sensor must be 1000 ± 200 ft/min. For all other psychrometers, velocity must be as specified by the sensor manufacturer.

3 Testing Procedures

3.1 General Requirements

If, during the testing process, an equipment set-up adjustment is made that would have altered the performance of the unit during any already completed test, then repeat all tests affected by the adjustment. For cyclic tests, instead of maintaining an air volume rate, for each airflow nozzle, maintain the static pressure difference or velocity pressure during an ON period at the same pressure difference or velocity pressure as measured during the steady-state test conducted at the same test conditions.

Use the testing procedures in this section to collect the data used for calculating

(1) Performance metrics for central air conditioners and heat pumps during the cooling season;

(2) Performance metrics for heat pumps during the heating season; and

(3) Power consumption metric(s) for central air conditioners and heat pumps during the off mode season(s).

3.1.1 Primary and Secondary Test Methods

For all tests, use the indoor air enthalpy method test apparatus to determine the unit's space conditioning capacity. The procedure and data collected, however, differ slightly depending upon whether the test is a steady-state test, a cyclic test, or a frost accumulation test. The following sections described these differences. For full-capacity cooling-mode test and (for a heat pump) the full-capacity heating-mode test, use one of the acceptable secondary methods specified in section 2.10 of this appendix to determine indoor space conditioning capacity. Calculate this secondary check of capacity according to section 3.11 of this appendix. The two capacity measurements must agree to within 6 percent to constitute a valid test. For this capacity comparison, use the Indoor Air Enthalpy Method capacity that is calculated in section 7.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3)

(and, if testing a coil-only system, compare capacities before making the after-test fan heat adjustments described in section 3.3, 3.4, 3.7, and 3.10 of this appendix). However, include the appropriate section 3.3 to 3.5 and 3.7 to 3.10 fan heat adjustments within the indoor air enthalpy method capacities used for the section 4 seasonal calculations of this appendix.

3.1.2 Manufacturer-Provided Equipment Overrides

Where needed, the manufacturer must provide a means for overriding the controls of the test unit so that the compressor(s) operates at the specified speed or capacity and the indoor blower operates at the specified speed or delivers the specified air volume rate. For variable-speed non-communicating coil-only air conditioners and heat pumps, the control system shall be provided with a control signal indicating operation at high or low stage, rather than testing with the compressor speed fixed at specific speeds, with the exception that compressor speed override may be used for heating mode test $H1_2$.

3.1.3 Airflow Through the Outdoor Coil

For all tests, meet the requirements given in section 6.1.3.4 of AHRI 210/240–2008 (incorporated by reference, see §430.3) when obtaining the airflow through the outdoor coil.

3.1.3.1 Double-Ducted

For products intended to be installed with the outdoor airflow ducted, install the unit with outdoor coil ductwork installed per manufacturer installation instructions. The unit must operate between 0.10 and 0.15 in H_2O external static pressure. Make external static pressure measurements in accordance with ANSI/ASHRAE 37–2009 section 6.4 and 6.5.

3.1.4 Airflow Through the Indoor Coil

Determine airflow setting(s) before testing begins. Unless otherwise specified within this or its subsections, make no changes to the airflow setting(s) after initiation of testing.

3.1.4.1 Cooling Full-Load Air Volume Rate

3.1.4.1.1 Cooling Full-Load Air Volume Rate for Ducted Units

Identify the certified Cooling full-load air volume rate and certified instructions for setting fan speed or controls. If there is no certified Cooling full-load air volume rate, use a value equal to the certified cooling capacity of the unit times 400 scfm per 12,000 Btu/h. If there are no instructions for setting fan speed or controls, use the as-shipped settings. Use the following procedure to confirm and, if necessary, adjust the Cooling full-load air volume rate and the fan speed or control settings to meet each test procedure requirement:

a. For all ducted blower-coil systems, except those having a constant-air-volume-rate indoor blower:

Step (1) Operate the unit under conditions specified for the A test (for single-stage units) or A_2 test (for non-single-stage units) using the certified fan speed or controls settings, and adjust the exhaust fan of the airflow measuring apparatus to achieve the certified cooling full-load air volume rate;

Step (2) Measure the external static pressure;

Step (3) If this external static pressure is equal to or greater than the applicable minimum external static pressure cited in Table 4 to this appendix, the pressure requirement is satisfied; proceed to step 7 of this section. If this external static pressure is not equal to or greater than the applicable minimum external static pressure cited in Table 4, proceed to step 4 of this section;

Step (4) Increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until the first to occur of:

(i) The applicable Table 4 to this appendix minimum is equaled or

(ii) The measured air volume rate equals 90 percent or less of the cooling full-load air volume rate;

Step (5) If the conditions of step 4 (i) of this section occur first, the pressure requirement is satisfied; proceed to step 7 of this section. If the conditions of step 4 (ii) of this section occur first, proceed to step 6 of this section;

Step (6) Make an incremental change to the setup of the indoor blower (*e.g.*, next highest fan motor pin setting, next highest fan motor speed) and repeat the evaluation process beginning at step 1 of this section. If the indoor blower setup cannot be further changed, increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until the applicable Table 4 to this appendix minimum is equaled; proceed to step 7 of this section;

Step (7) The airflow constraints have been satisfied. Use the measured air volume rate as the cooling full-load air volume rate. Use the final indoor fan speed or control settings of the unit under test for all tests that use the cooling full-load air volume rate. Adjust the fan of the airflow measurement apparatus if needed to obtain the same full-load air volume rate (in scfm) for all such tests, unless the system modulates indoor blower speed with outdoor dry bulb temperature or to adjust the sensible to total cooling capacity ratio—in this case, use an air volume rate that represents a normal installation and calculate the target external static pressure as described in section 3.1.4.2 of this appendix.

b. For ducted blower-coil systems with a constant-air-volume-rate indoor blower. For all tests that specify the cooling full-load air volume rate, obtain an external static pressure as close to (but not less than) the applicable Table 4 to this appendix value that does not cause either automatic shutdown of the indoor blower or a value of air volume rate variation Q_{Var}, defined as follows, that is greater than 10 percent.

$$Q_{var} = \left[\frac{Q_{max} - Q_{min}}{\left(\frac{Q_{max} + Q_{min}}{2}\right)}\right] * 100$$

Where:

Q_{max} = maximum measured airflow value
Q_{min} = minimum measured airflow value
Q_{Var} = airflow variance, percent

Additional test steps as described in section 3.3.f of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For coil-only indoor units. For the A or A_2 Test, (exclusively), the pressure drop across the indoor coil assembly must not exceed 0.30 inches of water. If this pressure drop is exceeded, reduce the air volume rate until the measured pressure drop equals the specified maximum. Use this reduced air volume rate for all tests that require the Cooling full-load air volume rate.

TABLE 4—MINIMUM EXTERNAL STATIC PRESSURE FOR DUCTED BLOWER COIL SYSTEMS

Product variety	Minimum external static pressure (in. wc.)
Conventional (*i.e.,* all central air conditioners and heat pumps not otherwise listed in this table)	0.50
Ceiling-mount and Wall-mount	0.30
Mobile Home	0.30
Low Static	0.10
Mid Static	0.30
Small Duct, High Velocity	1.15
Space-constrained	0.30

[1] For ducted units tested without an air filter installed, increase the applicable tabular value by 0.08 inches of water.
[2] See section 1.2, Definitions, to determine for which Table 4 product variety and associated minimum external static pressure requirement equipment qualifies.
[3] If a closed-loop, air-enthalpy test apparatus is used on the indoor side, limit the resistance to airflow on the inlet side of the indoor blower coil to a maximum value of 0.1 inch of water.

d. For ducted systems having multiple indoor blowers within a single indoor section, obtain the full-load air volume rate with all indoor blowers operating unless prevented by the controls of the unit. In such cases, turn on the maximum number of indoor blowers permitted by the unit's controls. Where more than one option exists for meeting this ''on'' indoor blower requirement, which indoor blower(s) are turned on must match that specified in the certification report. Conduct section 3.1.4.1.1 setup steps for each indoor blower separately. If two or more indoor blowers are connected to a common duct as per section 2.4.1 of this appendix, temporarily divert their air volume to the test room when confirming or adjusting the setup configuration of individual indoor blowers. The allocation of the system's full-load air volume rate assigned to each ''on'' indoor blower must match that specified by the manufacturer in the certification report.

3.1.4.1.2 Cooling Full-Load Air Volume Rate for Non-Ducted Units

For non-ducted units, the Cooling full-load air volume rate is the air volume rate that results during each test when the unit is operated at an external static pressure of zero inches of water.

3.1.4.2 Cooling Minimum Air Volume Rate

Identify the certified cooling minimum air volume rate and certified instructions for setting fan speed or controls. If there is no certified cooling minimum air volume rate, use the final indoor blower control settings as determined when setting the cooling full-load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full load air volume obtained in section 3.1.4.1 of this appendix. Otherwise, calculate the target external static pressure and follow instructions a, b, c, d, or e of this section. The target external static pressure, ΔP_{st_i}, for any test ''i'' with a specified air volume rate not equal to the Cooling full-load air volume rate is determined as follows:

$$\Delta P_{st_i} = \Delta P_{st_full} \left[\frac{Q_i}{Q_{full}}\right]^2$$

Where:

ΔP_{st_i} = target minimum external static pressure for test i;

ΔP_{st_full} = minimum external static pressure for test A or A_2 (Table 4);

Q_i = air volume rate for test i; and

Q_{full} = Cooling full-load air volume rate as measured after setting and/or adjustment as described in section 3.1.4.1.1 of this appendix.

a. For a ducted blower-coil system without a constant-air-volume indoor blower, adjust for external static pressure as follows:

Step (1) Operate the unit under conditions specified for the B_1 test using the certified fan speed or controls settings, and adjust the exhaust fan of the airflow measuring apparatus to achieve the certified cooling minimum air volume rate;

Step (2) Measure the external static pressure;

Step (3) If this pressure is equal to or greater than the minimum external static pressure computed in step 2 of this section, the pressure requirement is satisfied; proceed to step 7 of this section. If this pressure is not equal to or greater than the minimum external static pressure computed in step 2 of this section, proceed to step 4 of this section;

Step (4) Increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until either:

(i) The pressure is equal to the target minimum external static pressure, ΔP_{st_i}, computed in step 1 of this section; or

(ii) The measured air volume rate equals 90 percent or less of the cooling minimum air volume rate, whichever occurs first;

Step (5) If the conditions of step 4 (i) of this section occur first, the pressure requirement is satisfied; proceed to step 7 of this section. If the conditions of step 4 (ii) of this section occur first, proceed to step 6 of this section;

Step (6) Make an incremental change to the setup of the indoor blower (*e.g.*, next highest fan motor pin setting, next highest fan motor speed) and repeat the evaluation process beginning at step 1 of this section. If the indoor blower setup cannot be further changed, increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until it equals the minimum external static pressure computed in step 2 of this section; proceed to step 7 of this section;

Step (7) The airflow constraints have been satisfied. Use the measured air volume rate as the cooling minimum air volume rate. Use the final indoor fan speed or control settings of the unit under test for all tests that use the cooling minimum air volume rate. Adjust the fan of the airflow measurement apparatus if needed to obtain the same cooling minimum air volume rate (in scfm) for all such tests, unless the system modulates the indoor blower speed with outdoor dry bulb temperature or to adjust the sensible to total cooling capacity ratio—in this case, use an air volume rate that represents a normal installation and calculate the target minimum external static pressure as described in this section.

b. For ducted units with constant-air-volume indoor blowers, conduct all tests that specify the cooling minimum air volume rate—(*i.e.*, the A_1, B_1, C_1, F_1, and G_1 Tests)—at an external static pressure that does not cause either an automatic shutdown of the indoor blower or a value of air volume rate variation Q_{Var}, defined in section 3.1.4.1.1.b of this appendix, that is greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.3.f of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For ducted two-capacity coil-only systems, the cooling minimum air volume rate is the higher of—

(1) The rate specified by the installation instructions included with the unit by the manufacturer; or

(2) 75 percent of the cooling full-load air volume rate. During the laboratory tests on a coil-only (fanless) system, obtain this cooling minimum air volume rate regardless of the pressure drop across the indoor coil assembly.

d. For non-ducted units, the cooling minimum air volume rate is the air volume rate that results during each test when the unit operates at an external static pressure of zero inches of water and at the indoor blower setting used at low compressor capacity (two-capacity system) or minimum compressor speed (variable-speed system). For units having a single-speed compressor and a variable-speed variable-air-volume-rate indoor blower, use the lowest fan setting allowed for cooling.

e. For ducted systems having multiple indoor blowers within a single indoor section,

operate the indoor blowers such that the lowest air volume rate allowed by the unit's controls is obtained when operating the lone single-speed compressor or when operating at low compressor capacity while meeting the requirements of section 2.2.3.2 of this appendix for the minimum number of blowers that must be turned off. Using the target external static pressure and the certified air volume rates, follow the procedures described in section 3.1.4.2.a of this appendix if the indoor blowers are not constant-air-volume indoor blowers or as described in section 3.1.4.2.b of this appendix if the indoor blowers are not constant-air-volume indoor blowers. The sum of the individual ''on'' indoor blowers' air volume rates is the cooling minimum air volume rate for the system.

f. For ducted variable-speed compressor systems tested with a coil-only indoor unit, the cooling minimum air volume rate is the higher of:

(1) The rate specified by the installation instructions included with the unit by the manufacturer; or

(2) 75 percent of the cooling full-load air volume rate. During the laboratory tests on a coil-only (fanless) system, obtain this cooling minimum air volume rate regardless of the pressure drop across the indoor coil assembly.

3.1.4.3 Cooling Intermediate Air Volume Rate

Identify the certified cooling intermediate air volume rate and certified instructions for setting fan speed or controls. If there is no certified cooling intermediate air volume rate, use the final indoor blower control settings as determined when setting the cooling full load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full load air volume obtained in section 3.1.4.1 of this appendix. Otherwise, calculate target minimum external static pressure as described in section 3.1.4.2 of this appendix, and set the air volume rate as follows.

a. For a ducted blower coil system without a constant-air-volume indoor blower, adjust for external static pressure as described in section 3.1.4.2.a of this appendix for cooling minimum air volume rate.

b. For a ducted blower-coil system with a constant-air-volume indoor blower, conduct the E_V Test at an external static pressure that does not cause either an automatic shutdown of the indoor blower or a value of air volume rate variation Q_{Var}, defined in section 3.1.4.1.1.b of this appendix, that is greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.3.f of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For non-ducted units, the cooling intermediate air volume rate is the air volume rate that results when the unit operates at an external static pressure of zero inches of water and at the fan speed selected by the controls of the unit for the E_V Test conditions.

d. For ducted variable-speed compressor systems tested with a coil-only indoor unit, use the cooling minimum air volume rate as determined in section 3.1.4.2(f) of this appendix, without regard to the pressure drop across the indoor coil assembly.

3.1.4.4 Heating Full-Load Air Volume Rate

3.1.4.4.1 Ducted Heat Pumps Where the Heating and Cooling Full-Load Air Volume Rates Are the Same

a. Use the Cooling full-load air volume rate as the heating full-load air volume rate for:

(1) Ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, and that operate at the same airflow-control setting during both the A (or A_2) and the H1 (or $H1_2$) Tests;

(2) Ducted blower coil system heat pumps with constant-air-flow indoor blowers that provide the same airflow for the A (or A_2) and the H1 (or $H1_2$) Tests; and

(3) Ducted heat pumps that are tested with a coil-only indoor unit (except two-capacity northern heat pumps that are tested only at low capacity cooling—see section 3.1.4.4.2 of this appendix).

b. For heat pumps that meet the above criteria ''1'' and ''3,'' no minimum requirements apply to the measured external or internal, respectively, static pressure. Use the final indoor blower control settings as determined when setting the Cooling full-load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full-load air volume obtained in section 3.1.4.1 of this appendix. For heat pumps that meet the above criterion ''2,'' test at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{Var}, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than, the same Table 4 minimum external static pressure as was specified for the A (or A_2) cooling mode test. Additional test steps as described in section 3.9.1.c of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

3.1.4.4.2 Ducted Heat Pumps Where the Heating and Cooling Full-Load Air Volume Rates Are Different Due to Changes in Indoor Blower Operation, i.e. Speed Adjustment by the System Controls

Identify the certified heating full-load air volume rate and certified instructions for

setting fan speed or controls. If there is no certified heating full-load air volume rate, use the final indoor blower control settings as determined when setting the cooling full-load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full-load air volume obtained in section 3.1.4.1 of this appendix. Otherwise, calculate the target minimum external static pressure as described in section 3.1.4.2 of this appendix and set the air volume rate as follows.

a. For ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, adjust for external static pressure as described in section 3.1.4.2.a of this appendix for cooling minimum air volume rate.

b. For ducted heat pumps tested with constant-air-volume indoor blowers installed, conduct all tests that specify the heating full-load air volume rate at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{Var}, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.9.1.c of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. When testing ducted, two-capacity blower coil system northern heat pumps (see section 1.2 of this appendix, Definitions), use the appropriate approach of the above two cases. For coil-only system northern heat pumps, the heating full-load air volume rate is the lesser of the rate specified by the manufacturer in the installation instructions included with the unit or 133 percent of the cooling full-load air volume rate. For this latter case, obtain the heating full-load air volume rate regardless of the pressure drop across the indoor coil assembly.

d. For ducted systems having multiple indoor blowers within a single indoor section, obtain the heating full-load air volume rate using the same ''on'' indoor blowers as used for the Cooling full-load air volume rate. Using the target external static pressure and the certified air volume rates, follow the procedures as described in section 3.1.4.4.2.a of this appendix if the indoor blowers are not constant-air-volume indoor blowers or as described in section 3.1.4.4.2.b of this appendix if the indoor blowers are constant-air-volume indoor blowers. The sum of the individual ''on'' indoor blowers' air volume rates is the heating full-load air volume rate for the system.

3.1.4.4.3 Ducted Heating-Only Heat Pumps

Identify the certified heating full-load air volume rate and certified instructions for setting fan speed or controls. If there is no certified heating full-load air volume rate, use a value equal to the certified heating capacity of the unit times 400 scfm per 12,000 Btu/h. If there are no instructions for setting fan speed or controls, use the as-shipped settings.

a. For all ducted heating-only blower-coil system heat pumps, except those having a constant-air-volume-rate indoor blower: conduct the following steps only during the first test, the H1 or $H1_2$ test:

Step (1) Adjust the exhaust fan of the airflow measuring apparatus to achieve the certified heating full-load air volume rate.

Step (2) Measure the external static pressure.

Step (3) If this pressure is equal to or greater than the Table 4 to this appendix minimum external static pressure that applies given the heating-only heat pump's rated heating capacity, the pressure requirement is satisfied; proceed to step 7 of this section. If this pressure is not equal to or greater than the applicable Table 4 minimum external static pressure, proceed to step 4 of this section;

Step (4) Increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until either:

(i) The pressure is equal to the applicable Table 4 to this appendix minimum external static pressure; or

(ii) The measured air volume rate equals 90 percent or less of the heating full-load air volume rate, whichever occurs first;

Step (5) If the conditions of step 4 (i) of this section occur first, the pressure requirement is satisfied; proceed to step 7 of this section. If the conditions of step 4 (ii) of this section occur first, proceed to step 6 of this section;

Step (6) Make an incremental change to the setup of the indoor blower (*e.g.,* next highest fan motor pin setting, next highest fan motor speed) and repeat the evaluation process beginning at step 1 of this section. If the indoor blower setup cannot be further changed, increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until it equals the applicable Table 4 to this appendix minimum external static pressure; proceed to step 7 of this section;

Step (7) The airflow constraints have been satisfied. Use the measured air volume rate as the heating full-load air volume rate. Use the final indoor fan speed or control settings of the unit under test for all tests that use the heating full-load air volume rate. Adjust the fan of the airflow measurement apparatus if needed to obtain the same heating full-load air volume rate (in scfm) for all such tests, unless the system modulates indoor blower speed with outdoor dry bulb temperature—in this case, use an air volume rate that represents a normal installation and calculate the target minimum external

static pressure as described in section 3.1.4.2 of this appendix.

b. For ducted heating-only blower coil system heat pumps having a constant-air-volume-rate indoor blower. For all tests that specify the heating full-load air volume rate, obtain an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{var}, defined in section 3.1.4.1.1.b of this section, greater than 10 percent, while being as close to, but not less than, the applicable Table 4 minimum. Additional test steps as described in section 3.9.1.c of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For ducted heating-only coil-only system heat pumps in the H1 or $H1_2$ Test, (exclusively), the pressure drop across the indoor coil assembly must not exceed 0.30 inches of water. If this pressure drop is exceeded, reduce the air volume rate until the measured pressure drop equals the specified maximum. Use this reduced air volume rate for all tests that require the heating full-load air volume rate.

3.1.4.4.4 Non-Ducted Heat Pumps, Including Non-Ducted Heating-Only Heat Pumps

For non-ducted heat pumps, the heating full-load air volume rate is the air volume rate that results during each test when the unit operates at an external static pressure of zero inches of water.

3.1.4.5 Heating Minimum Air Volume Rate

3.1.4.5.1 Ducted Heat Pumps Where the Heating and Cooling Minimum Air Volume Rates are the Same

a. Use the cooling minimum air volume rate as the heating minimum air volume rate for:

(1) Ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, and that operates at the same airflow-control setting during both the A_1 and the $H1_1$ tests;

(2) Ducted blower coil system heat pumps with constant-air-flow indoor blowers installed that provide the same airflow for the A_1 and the $H1_1$ Tests; and

(3) Ducted coil-only system heat pumps.

b. For heat pumps that meet the above criteria ''1'' and ''3,'' no minimum requirements apply to the measured external or internal, respectively, static pressure. Use the final indoor blower control settings as determined when setting the cooling minimum air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling minimum air volume rate obtained in section 3.1.4.2 of this appendix. For heat pumps that meet the above criterion ''2,'' test at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{var}, defined in section 3.1.4.1.1.b, greater than 10 percent, while being as close to, but not less than, the same target minimum external static pressure as was specified for the A_1 cooling mode test. Additional test steps as described in section 3.9.1.c of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

3.1.4.5.2 Ducted Heat Pumps Where the Heating and Cooling Minimum Air Volume Rates Are Different Due to Indoor Blower Operation, *i.e.* Speed Adjustment by the System Controls

Identify the certified heating minimum air volume rate and certified instructions for setting fan speed or controls. If there is no certified heating minimum air volume rate, use the final indoor blower control settings as determined when setting the cooling minimum air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling minimum air volume obtained in section 3.1.4.2 of this appendix. Otherwise, calculate the target minimum external static pressure as described in section 3.1.4.2 of this appendix.

a. For ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, adjust for external static pressure as described in section 3.1.4.2.a of this appendix for cooling minimum air volume rate.

b. For ducted heat pumps tested with constant-air-volume indoor blowers installed, conduct all tests that specify the heating minimum air volume rate—(*i.e.*, the $H0_1$, $H1_1$, $H2_1$, and $H3_1$ Tests)—at an external static pressure that does not cause an automatic shutdown of the indoor blower while being as close to, but not less than the air volume rate variation Q_{var}, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.9.1.c of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For ducted two-capacity blower coil system northern heat pumps, use the appropriate approach of the above two cases.

d. For ducted two-capacity coil-only system heat pumps, use the cooling minimum air volume rate as the heating minimum air volume rate. For ducted two-capacity coil-only system northern heat pumps, use the cooling full-load air volume rate as the heating minimum air volume rate. For ducted two-capacity heating-only coil-only system heat pumps, the heating minimum air volume rate is the higher of the rate specified

by the manufacturer in the test setup instructions included with the unit or 75 percent of the heating full-load air volume rate. During the laboratory tests on a coil-only system, obtain the heating minimum air volume rate without regard to the pressure drop across the indoor coil assembly.

e. For non-ducted heat pumps, the heating minimum air volume rate is the air volume rate that results during each test when the unit operates at an external static pressure of zero inches of water and at the indoor blower setting used at low compressor capacity (two-capacity system) or minimum compressor speed (variable-speed system). For units having a single-speed compressor and a variable-speed, variable-air-volume-rate indoor blower, use the lowest fan setting allowed for heating.

f. For ducted systems with multiple indoor blowers within a single indoor section, obtain the heating minimum air volume rate using the same ''on'' indoor blowers as used for the cooling minimum air volume rate. Using the target external static pressure and the certified air volume rates, follow the procedures as described in section 3.1.4.5.2.a of this appendix if the indoor blowers are not constant-air-volume indoor blowers or as described in section 3.1.4.5.2.b of this appendix if the indoor blowers are constant-air-volume indoor blowers. The sum of the individual ''on'' indoor blowers' air volume rates is the heating full-load air volume rate for the system.

3.1.4.6 Heating Intermediate Air Volume Rate

Identify the certified heating intermediate air volume rate and certified instructions for setting fan speed or controls. If there is no certified heating intermediate air volume rate, use the final indoor blower control settings as determined when setting the heating full-load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full-load air volume obtained in section 3.1.4.2 of this appendix. Calculate the target minimum external static pressure as described in section 3.1.4.2 of this appendix.

a. For ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, adjust for external static pressure as described in section 3.1.4.2.a of this appendix for cooling minimum air volume rate.

b. For ducted heat pumps tested with constant-air-volume indoor blowers installed, conduct the $H2_V$ Test at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{Var}, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.9.1.c of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For non-ducted heat pumps, the heating intermediate air volume rate is the air volume rate that results when the heat pump operates at an external static pressure of zero inches of water and at the fan speed selected by the controls of the unit for the $H2_V$ Test conditions.

d. For ducted variable-speed compressor systems tested with a coil-only indoor unit, use the heating minimum air volume rate, which (as specified in section 3.1.4.5.1.a.(3) of this appendix) is equal to the cooling minimum air volume rate, without regard to the pressure drop across the indoor coil assembly.

3.1.4.7 Heating Nominal Air Volume Rate

The manufacturer must specify the heating nominal air volume rate and the instructions for setting fan speed or controls. Calculate target minimum external static pressure as described in section 3.1.4.2 of this appendix. Make adjustments as described in section 3.1.4.6 of this appendix for heating intermediate air volume rate so that the target minimum external static pressure is met or exceeded. For ducted variable-speed compressor systems tested with a coil-only indoor unit, use the heating full-load air volume rate as the heating nominal air volume rate.

3.1.5 Indoor Test Room Requirement When the Air Surrounding the Indoor Unit is Not Supplied From the Same Source as the Air Entering the Indoor Unit

If using a test set-up where air is ducted directly from the air reconditioning apparatus to the indoor coil inlet (see Figure 2, Loop Air-Enthalpy Test Method Arrangement, of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3)), maintain the dry bulb temperature within the test room within ±5.0 °F of the applicable sections 3.2 and 3.6 dry bulb temperature test condition for the air entering the indoor unit. Dew point must be within 2 °F of the required inlet conditions.

3.1.6 Air Volume Rate Calculations

For all steady-state tests and for frost accumulation ($H2$, $H2_1$, $H2_2$, $H2_V$) tests, calculate the air volume rate through the indoor coil as specified in sections 7.7.2.1 and 7.7.2.2 of ANSI/ASHRAE 37–2009. When using the outdoor air enthalpy method, follow sections 7.7.2.1 and 7.7.2.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) to calculate the air volume rate through the outdoor coil. To express air volume rates in terms of standard air, use:

Equation 3-1 $$\overline{\dot{V}_s} = \frac{\overline{\dot{V}_{mx}}}{0.075\,\frac{lbm_{da}}{ft^3} * v_n' * [1+W_n]} = \frac{\overline{\dot{V}_{mx}}}{0.075\,\frac{lbm_{da}}{ft^3} * v_n}$$

Where:

$\overline{\dot{V}}_s$ = air volume rate of standard (dry) air, $(ft^3/min)_{da}$

$\overline{\dot{V}}_{mx}$ = air volume rate of the air-water vapor mixture, $(ft^3/min)_{mx}$

v_n' = specific volume of air-water vapor mixture at the nozzle, ft^3 per lbm of the air-water vapor mixture

W_n = humidity ratio at the nozzle, lbm of water vapor per lbm of dry air

0.075 = the density associated with standard (dry) air, (lbm/ft^3)

v_n = specific volume of the dry air portion of the mixture evaluated at the dry-bulb temperature, vapor content, and barometric pressure existing at the nozzle, ft^3 per lbm of dry air.

NOTE: In the first printing of ANSI/ASHRAE 37–2009, the second IP equation for Q_{mi} should read,

$$Q_{mi} = 1097 C A_n \sqrt{P_V v_n'})$$

3.1.7 Test Sequence

Before making test measurements used to calculate performance, operate the equipment for the ''break-in'' period specified in the certification report, which may not exceed 20 hours. Each compressor of the unit must undergo this ''break-in'' period. When testing a ducted unit (except if a heating-only heat pump), conduct the A or A_2 Test first to establish the cooling full-load air volume rate. For ducted heat pumps where the heating and cooling full-load air volume rates are different, make the first heating mode test one that requires the heating full-load air volume rate. For ducted heating-only heat pumps, conduct the H1 or $H1_2$ Test first to establish the heating full-load air volume rate. When conducting a cyclic test, always conduct it immediately after the steady-state test that requires the same test conditions. For variable-speed systems, the first test using the cooling minimum air volume rate should precede the E_V Test, and the first test using the heating minimum air volume rate must precede the $H2_V$ Test. The test laboratory makes all other decisions on the test sequence.

3.1.8 Requirement for the Air Temperature Distribution Leaving the Indoor Coil

For at least the first cooling mode test and the first heating mode test, monitor the temperature distribution of the air leaving the indoor coil using the grid of individual sensors described in sections 2.5 and 2.5.4 of this appendix. For the 30-minute data collection interval used to determine capacity, the maximum spread among the outlet dry bulb temperatures from any data sampling must not exceed 1.5 °F. Install the mixing devices described in section 2.5.4.2 of this appendix to minimize the temperature spread.

3.1.9 Requirement for the Air Temperature Distribution Entering the Outdoor Coil

Monitor the Temperatures of the Air Entering the Outdoor Coil Using Air Sampling Devices and/or Temperature Sensor Grids, Maintaining the Required Tolerances, if Applicable, as Described in section 2.11 of this appendix

3.1.10 Control of Auxiliary Resistive Heating Elements

Except as noted, disable heat pump resistance elements used for heating indoor air at all times, including during defrost cycles and if they are normally regulated by a heat comfort controller. For heat pumps equipped with a heat comfort controller, enable the heat pump resistance elements only during the below-described, short test. For single-speed heat pumps covered under section 3.6.1 of this appendix, the short test follows the H1 or, if conducted, the H1C Test. For two-capacity heat pumps and heat pumps covered under section 3.6.2 of this appendix, the short test follows the $H1_2$ Test. Set the heat comfort controller to provide the maximum supply air temperature. With the heat pump operating and while maintaining the heating full-load air volume rate, measure the temperature of the air leaving the indoor-side beginning 5 minutes after activating the heat comfort controller. Sample the outlet dry-bulb temperature at regular intervals that span 5 minutes or less. Collect data for 10 minutes, obtaining at least 3 samples. Calculate the average outlet temperature over the 10-minute interval, T_{CC}.

3.2 Cooling Mode Tests for Different Types of Air Conditioners and Heat Pumps

3.2.1 Tests for a System Having a Single-Speed Compressor and Fixed Cooling Air Volume Rate

This set of tests is for single-speed-compressor units that do not have a cooling minimum air volume rate or a cooling intermediate air volume rate that is different than the cooling full load air volume rate. Conduct two steady-state wet coil tests, the A and B Tests. Use the two optional dry-coil tests, the steady-state C Test and the cyclic D Test, to determine the cooling mode cyclic degradation coefficient, C_D^c. If the two optional tests are conducted but yield a tested C_D^c that exceeds the default C_D^c or if the two optional tests are not conducted, assign C_D^c the default value of 0.25 (for outdoor units with no match) or 0.2 (for all other systems). Table 5 specifies test conditions for these four tests.

TABLE 5—COOLING MODE TEST CONDITIONS FOR UNITS HAVING A SINGLE-SPEED COMPRESSOR AND A FIXED COOLING AIR VOLUME RATE

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
A Test—required (steady, wet coil).	80	67	95	[1] 75	Cooling full-load [2].
B Test—required (steady, wet coil).	80	67	82	[1] 65	Cooling full-load [2].
C Test—optional (steady, dry coil).	80	([3])	82	.....	Cooling full-load [2].
D Test—optional (cyclic, dry coil).	80	([3])	82	.....	([4]).

[1] The specified test condition only applies if the unit rejects condensate to the outdoor coil.
[2] Defined in section 3.1.4.1 of this appendix.
[3] The entering air must have a low enough moisture content so no condensate forms on the indoor coil. (It is recommended that an indoor wet-bulb temperature of 57 °F or less be used.)
[4] Maintain the airflow nozzles static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the C Test.

3.2.2 Tests for a Unit Having a Single-Speed Compressor Where the Indoor Section Uses a Single Variable-Speed Variable-Air-Volume Rate Indoor Blower or Multiple Indoor Blowers

3.2.2.1 Indoor Blower Capacity Modulation That Correlates With the Outdoor Dry Bulb Temperature or Systems With a Single Indoor Coil but Multiple Indoor Blowers

Conduct four steady-state wet coil tests: The A_2, A_1, B_2, and B_1 tests. Use the two optional dry-coil tests, the steady-state C_1 test and the cyclic D_1 test, to determine the cooling mode cyclic degradation coefficient, C_D^c. If the two optional tests are conducted but yield a tested C_D^c that exceeds the default C_D^c or if the two optional tests are not conducted, assign C_D^c the default value of 0.2.

3.2.2.2 Indoor Blower Capacity Modulation Based on Adjusting the Sensible to Total(S/T) Cooling Capacity Ratio

The testing requirements are the same as specified in section 3.2.1 of this appendix and Table 5. Use a cooling full-load air volume rate that represents a normal installation. If performed, conduct the steady-state C Test and the cyclic D Test with the unit operating in the same S/T capacity control mode as used for the B Test.

TABLE 6—COOLING MODE TEST CONDITIONS FOR UNITS WITH A SINGLE-SPEED COMPRESSOR THAT MEET THE SECTION 3.2.2.1 INDOOR UNIT REQUIREMENTS

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
A_2 Test—required (steady, wet coil).	80	67	95	[1] 75	Cooling full-load [2].
A_1 Test—required (steady, wet coil).	80	67	95	[1] 75	Cooling minimum [3].
B_2 Test—required (steady, wet coil).	80	67	82	[1] 65	Cooling full-load [2].
B_1 Test—required (steady, wet coil).	80	67	82	[1] 65	Cooling minimum [3].

TABLE 6—COOLING MODE TEST CONDITIONS FOR UNITS WITH A SINGLE-SPEED COMPRESSOR THAT MEET THE SECTION 3.2.2.1 INDOOR UNIT REQUIREMENTS—Continued

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
C_1 Test[4]—optional (steady, dry coil).	80	([4])	82	.....	Cooling minimum[3].
D_1 Test[4]—optional (cyclic, dry coil).	80	([4])	82	.....	([5]).

[1] The specified test condition only applies if the unit rejects condensate to the outdoor coil.
[2] Defined in section 3.1.4.1 of this appendix.
[3] Defined in section 3.1.4.2 of this appendix.
[4] The entering air must have a low enough moisture content so no condensate forms on the indoor coil. (It is recommended that an indoor wet-bulb temperature of 57 °F or less be used.)
[5] Maintain the airflow nozzles static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the C_1 Test.

3.2.3 Tests for a Unit Having a Two-Capacity Compressor. (See Section 1.2 of This Appendix, Definitions)

a. Conduct four steady-state wet coil tests: the A_2, B_2, B_1, and F_1 Tests. Use the two optional dry-coil tests, the steady-state C_1 Test and the cyclic D_1 Test, to determine the cooling-mode cyclic-degradation coefficient, C_D^c. If the two optional tests are conducted but yield a tested C_D^c that exceeds the default C_D^c or if the two optional tests are not conducted, assign C_D^c the default value of 0.2. Table 7 specifies test conditions for these six tests.

b. For units having a variable-speed indoor blower that is modulated to adjust the sensible to total (S/T) cooling capacity ratio, use cooling full-load and cooling minimum air volume rates that represent a normal installation. Additionally, if conducting the dry-coil tests, operate the unit in the same S/T capacity control mode as used for the B_1 Test.

c. Test two-capacity, northern heat pumps (see section 1.2 of this appendix, Definitions) in the same way as a single speed heat pump with the unit operating exclusively at low compressor capacity (see section 3.2.1 of this appendix and Table 5).

d. If a two-capacity air conditioner or heat pump locks out low-capacity operation at higher outdoor temperatures, then use the two dry-coil tests, the steady-state C_2 Test and the cyclic D_2 Test, to determine the cooling-mode cyclic-degradation coefficient that only applies to on/off cycling from high capacity, $C_D^c(k=2)$. If the two optional tests are conducted but yield a tested $C_D^c(k = 2)$ that exceeds the default $C_D^c(k = 2)$ or if the two optional tests are not conducted, assign $C_D^c(k = 2)$ the default value. The default $C_D^c(k=2)$ is the same value as determined or assigned for the low-capacity cyclic-degradation coefficient, C_D^c [or equivalently, $C_D^c(k=1)$].

TABLE 7—COOLING MODE TEST CONDITIONS FOR UNITS HAVING A TWO-CAPACITY COMPRESSOR

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor capacity	Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
A_2 Test—required (steady, wet coil)	80	67	95	[1] 75	High	Cooling Full-Load.[2]
B_2 Test—required (steady, wet coil)	80	67	82	[1] 65	High	Cooling Full-Load.[2]
B_1 Test—required (steady, wet coil)	80	67	82	[1] 65	Low	Cooling Minimum.[3]
C_2 Test—optional (steady, dry-coil)	80	([4])	82	.....	High	Cooling Full-Load.[2]
D_2 Test—optional (cyclic, dry-coil)	80	([4])	82	.....	High	([5]).
C_1 Test—optional (steady, dry-coil)	80	([4])	82	.....	Low	Cooling Minimum.[3]
D_1 Test—optional (cyclic, dry-coil)	80	([4])	82	.....	Low	([6]).
F_1 Test—required (steady, wet coil)	80	67	67	[1] 53.5	Low	Cooling Minimum.[3]

[1] The specified test condition only applies if the unit rejects condensate to the outdoor coil.
[2] Defined in section 3.1.4.1 of this appendix.
[3] Defined in section 3.1.4.2 of this appendix.
[4] The entering air must have a low enough moisture content so no condensate forms on the indoor coil. DOE recommends using an indoor air wet-bulb temperature of 57 °F or less.
[5] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the C_2 Test.
[6] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the C_1 Test.

3.2.4 Tests for a Unit Having a Variable-Speed Compressor

a. Conduct five steady-state wet coil tests: the A_2, E_V, B_2, B_1, and F_1 Tests (the E_V test is not applicable for variable speed non-communicating coil-only air conditioners and heat pumps). Use the two optional dry-coil tests, the steady-state G_1 Test and the cyclic I_1 Test, to determine the cooling mode cyclic degradation coefficient, C_D^c. If the two optional tests are conducted and yield a tested C_D^c that exceeds the default C_D^c or if the two optional tests are not conducted, assign C_D^c the default value of 0.25. Table 8 specifies test conditions for these seven tests. The compressor shall operate at the same cooling full speed, measured by RPM or power input frequency (Hz), for both the A_2 and B_2 tests. The compressor shall operate at the same cooling minimum speed, measured by RPM or power input frequency (Hz), for the B_1, F_1, G_1, and I_1 tests. Determine the cooling intermediate compressor speed cited in Table 8 to this appendix, as required, using:

$$\text{Cooling intermediate speed} = \text{Cooling minimum speed} + \frac{\text{Cooling full speed} - \text{Cooling minimum speed}}{3}$$

Where a tolerance of plus 5 percent or the next higher inverter frequency step from that calculated is allowed.

b. For units that modulate the indoor blower speed to adjust the sensible to total (S/T) cooling capacity ratio, use cooling full-load, cooling intermediate, and cooling minimum air volume rates that represent a normal installation. Additionally, if conducting the dry-coil tests, operate the unit in the same S/T capacity control mode as used for the F_1 Test.

c. For multiple-split air conditioners and heat pumps (except where noted), the following procedures supersede the above requirements: For all Table 8 tests specified for a minimum compressor speed, turn off at least one indoor unit. The manufacturer shall designate the particular indoor unit(s) that is turned off. The manufacturer must also specify the compressor speed used for the Table 8 E_V Test, a cooling-mode intermediate compressor speed that falls within ¼ and ¾ of the difference between the full and minimum cooling-mode speeds. The manufacturer should prescribe an intermediate speed that is expected to yield the highest EER for the given E_V Test conditions and bracketed compressor speed range. The manufacturer can designate that one or more indoor units are turned off for the E_V Test.

d. For variable-speed non-communicating coil-only air conditioners and heat pumps, the manufacturer-provided equipment overrides for full and minimum compressor speed described in section 3.1.2 of this appendix shall be limited to two stages of digital on/off control.

TABLE 8—COOLING MODE TEST CONDITION FOR UNITS HAVING A VARIABLE-SPEED COMPRESSOR

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor speed	Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
A_2 Test—required (steady, wet coil).	80	67	95	[1]75	Cooling Full	Cooling Full-Load.[2]
B*2* Test—required (steady, wet coil).	80	67	82	[1]65	Cooling Full	Cooling Full-Load.[2]
E_V Test—required[7] (steady, wet coil).	80	67	87	[1]69	Cooling Intermediate.	Cooling Intermediate.[3]
B_1 Test—required (steady, wet coil).	80	67	82	[1]65	Cooling Minimum	Cooling Minimum.[4]
F_1 Test—required (steady, wet coil).	80	67	67	[1]53.5	Cooling Minimum	Cooling Minimum.[4]
G_1 Test[5]—optional (steady, dry-coil).	80	([6])	67	.....	Cooling Minimum	Cooling Minimum.[4]

TABLE 8—COOLING MODE TEST CONDITION FOR UNITS HAVING A VARIABLE-SPEED COMPRESSOR—Continued

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor speed	Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
I_1 Test[5]—optional (cyclic, dry-coil).	80	([6])	67	.....	Cooling Minimum	([6])

[1] The specified test condition only applies if the unit rejects condensate to the outdoor coil.
[2] Defined in section 3.1.4.1 of this appendix.
[3] Defined in section 3.1.4.3 of this appendix.
[4] Defined in section 3.1.4.2 of this appendix.
[5] The entering air must have a low enough moisture content so no condensate forms on the indoor coil. DOE recommends using an indoor air wet bulb temperature of 57 °F or less.
[6] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the G_1 Test.
[7] The E_V test is not applicable for variable-speed non-communicating coil-only air conditioners and heat pumps.

3.2.5 Cooling Mode Tests for Northern Heat Pumps With Triple-Capacity Compressors

Test triple-capacity, northern heat pumps for the cooling mode in the same way as specified in section 3.2.3 of this appendix for units having a two-capacity compressor.

3.2.6 Tests for an Air Conditioner or Heat Pump Having a Single Indoor Unit Having Multiple Indoor Blowers and Offering Two Stages of Compressor Modulation

Conduct the cooling mode tests specified in section 3.2.3 of this appendix.

3.3 Test Procedures for Steady-State Wet Coil Cooling Mode Tests (the A, A_2, A_1, B, B_2, B_1, E_V, and F_1 Tests)

a. For the pretest interval, operate the test room reconditioning apparatus and the unit to be tested until maintaining equilibrium conditions for at least 30 minutes at the specified section 3.2 test conditions. Use the exhaust fan of the airflow measuring apparatus and, if installed, the indoor blower of the test unit to obtain and then maintain the indoor air volume rate and/or external static pressure specified for the particular test. Continuously record (see section 1.2 of this appendix, Definitions):

(1) The dry-bulb temperature of the air entering the indoor coil,

(2) The water vapor content of the air entering the indoor coil,

(3) The dry-bulb temperature of the air entering the outdoor coil, and

(4) For the section 2.2.4 of this appendix cases where its control is required, the water vapor content of the air entering the outdoor coil.

Refer to section 3.11 of this appendix for additional requirements that depend on the selected secondary test method.

b. After satisfying the pretest equilibrium requirements, make the measurements specified in Table 3 of ANSI/ASHRAE 37–2009 for the indoor air enthalpy method and the user-selected secondary method. Make said Table 3 measurements at equal intervals that span 5 minutes or less. Continue data sampling until reaching a 30-minute period (*e.g.*, seven consecutive 5-minute samples) where the test tolerances specified in Table 9 are satisfied. For those continuously recorded parameters, use the entire data set from the 30-minute interval to evaluate Table 9 compliance. Determine the average electrical power consumption of the air conditioner or heat pump over the same 30-minute interval.

c. Calculate indoor-side total cooling capacity and sensible cooling capacity as specified in sections 7.3.3.1 and 7.3.3.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). To calculate capacity, use the averages of the measurements (*e.g.* inlet and outlet dry bulb and wet bulb temperatures measured at the psychrometers) that are continuously recorded for the same 30-minute interval used as described above to evaluate compliance with test tolerances. Do not adjust the parameters used in calculating capacity for the permitted variations in test conditions. Evaluate air enthalpies based on the measured barometric pressure. Use the values of the specific heat of air given in section 7.3.3.1 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) for calculation of the sensible cooling capacities. Assign the average total space cooling capacity, average sensible cooling capacity, and electrical power consumption over the 30-minute data collection interval to the variables $\dot{Q}_c^k(T)$, $\dot{Q}_{sc}^k(T)$ and $\dot{E}_c^k(T)$, respectively. For these three variables, replace the ''T'' with the nominal outdoor temperature at which the test was conducted. The superscript k is used only when testing multi-capacity units. Use the superscript k=2 to denote a test with the unit operating at high capacity or full speed, k=1 to denote low capacity or minimum speed, and k=v to denote the intermediate speed.

d. For mobile home and space-constrained ducted coil-only system tests,

(1) For two-stage or variable-speed systems, for all steady-state wet coil tests (*i.e.*,

the A_1, A_2, B_1, B_2, E_V, and F_1 tests), decrease by the quantity calculated in Equation 3.3–1 to this appendix and increase by the quantity calculated in Equation 3.3–2 to this appendix.

$$\text{Equation 3.3-1} \quad \frac{(\text{DFPC}_{MHSC} * 3.412)\ Btu/h}{1000\ scfm} * \dot{V}_S,$$

$$\text{Equation 3.3-2} \quad \frac{\text{DFPC}_{MHSC}\ W}{1000\ scfm} * \dot{V}_S;$$

Where:

$DFPC_{MHSC}$ is the default fan power coefficient (watts) for mobile-home and space-constrained systems,

$$\text{DFPC}_{MHSC} = 308 + \frac{(406 - 308) * (\%FLAVR - 75\%)}{100\% - 75\%}$$

And %FLAVR is the air volume rate used for the test, expressed as a percentage of the cooling full load air volume rate. For all tests specifying the full-load air volume rate (*e.g.*, the A_2 and B_2 tests), set %FLAVR to 100%. For tests that specify the cooling minimum air volume rate or cooling intermediate air volume rate (*i.e.*, the A_1, B_1, E_V, and F_1 tests) and for which the specified minimum or intermediate air volume rate is greater than or equal to 75 percent of the cooling full-load air volume rate and less than the cooling full-load air volume rate, set %FLAVR to the ratio of the specified air volume rate and the cooling full-load air volume rate, expressed as a percentage.

(2) For single-stage systems, for all steady-state wet coil tests (*i.e.*, the A and B tests), decrease $Q_c^k(T)$ by the quantity calculated in Equation 3.3–3 to this appendix and increase $\dot{E}_c^k(T)$ by the quantity calculated in Equation 3.3–4 to this appendix.

$$\text{Equation 3.3-3} \quad \frac{1385\ Btu/h}{1000\ scfm} * \dot{V}_S, \text{ and}$$

$$\text{Equation 3.3-4} \quad \frac{406\ W}{1000\ scfm} * \dot{V}_S$$

Where $\dot{V}_S$ is the average measured indoor air volume rate expressed in units of cubic feet per minute of standard air (scfm).

e. For non-mobile, non-space-constrained home ducted coil-only system tests,

(1) For two-stage or variable-speed systems, for all steady-state wet coil tests (*i.e.*, the A_1, A_2, B_1, B_2, E_V, and F_1 tests), decrease $Q_c^k(T)$ by the quantity calculated in Equation 3.3–5 to this appendix and increase $\dot{E}_c^k(T)$ by the quantity calculated in Equation 3.3–6 to this appendix.

$$\text{Equation 3.3-5} \quad \frac{(\text{DFPC}_C * 3.412)\ Btu/h}{1000\ scfm} * \dot{V}_S, \text{ and}$$

$$\text{Equation 3.3-6} \quad \frac{\text{DFPC}_C\ W}{1000\ scfm} * \dot{V}_S$$

Where:

DFPC_C is the default fan power coefficient (watts) for non-mobile-home and non-space-constrained systems,

$$\text{DFPC}_C = 335 + \frac{(441 - 335) * (\%FLAVR - 75\%)}{100\% - 75\%}$$

And %FLAVR is the air volume rate used for the test, expressed as a percentage of the cooling full load air volume rate. For all tests specifying the full-load air volume rate (*e.g.*, the A_2 and B_2 tests), set %FLAVR to 100%. For tests that specify the cooling minimum air volume rate or cooling intermediate air volume rate (*i.e.*, the A_1, B_1, E_V, and F_1 tests) and for which the specified minimum or intermediate air volume rate is greater than or equal to 75 percent of the cooling full-load air volume rate and less than the cooling full-load air volume rate, set %FLAVR to the ratio of the specified air volume rate and the cooling full-load air volume rate, expressed as a percentage.

(2) For single-stage systems, for all steady-state wet coil tests (*i.e.*, the A and B tests), decrease $\dot{Q}_c^k(T)$ by the quantity calculated in Equation 3.3–7 to this appendix and increase $\dot{E}_c^k(T)$ by the quantity calculated in Equation 3.3–8 to this appendix.

$$\text{Equation 3.3-7.} \quad \frac{1505\ Btu/h}{1000\ scfm} * \dot{V}_S, \text{ and}$$

$$\text{Equation 3.3-8.} \quad \frac{441\ W}{1000\ scfm} * \dot{V}_S$$

Where is the average measured indoor air volume rate expressed in units of cubic feet per minute of standard air (scfm).

TABLE 9—TEST OPERATING AND TEST CONDITION TOLERANCES FOR SECTION 3.3 STEADY-STATE WET COIL COOLING MODE TESTS AND SECTION 3.4 DRY COIL COOLING MODE TESTS

	Test operating tolerance [1]	Test condition tolerance [1]
Indoor dry-bulb, °F		
Entering temperature	2.0	0.5
Leaving temperature	2.0	
Indoor wet-bulb, °F		
Entering temperature	1.0	[2] 0.3
Leaving temperature	[2] 1.0	
Outdoor dry-bulb, °F		
Entering temperature	2.0	0.5
Leaving temperature	[3] 2.0	
Outdoor wet-bulb, °F		
Entering temperature	1.0	[4] 0.3
Leaving temperature	[3] 1.0	
External resistance to airflow, inches of water	0.05	[5] 0.02
Electrical voltage, % of reading	2.0	1.5
Nozzle pressure drop, % of reading	2.0	

[1] See section 1.2 of this appendix, Definitions.

[2] Only applies during wet coil tests; does not apply during steady-state, dry coil cooling mode tests.
[3] Only applies when using the outdoor air enthalpy method.
[4] Only applies during wet coil cooling mode tests where the unit rejects condensate to the outdoor coil.
[5] Only applies when testing non-ducted units.

f. For air conditioners and heat pumps having a constant-air-volume-rate indoor blower, the five additional steps listed below are required if the average of the measured external static pressures exceeds the applicable sections 3.1.4 minimum (or target) external static pressure (ΔP_{min}) by 0.03 inches of water or more.

(1) Measure the average power consumption of the indoor blower motor ($\dot{E}_{fan,1}$) and record the corresponding external static pressure (ΔP_1) during or immediately following the 30-minute interval used for determining capacity.

(2) After completing the 30-minute interval and while maintaining the same test conditions, adjust the exhaust fan of the airflow measuring apparatus until the external static pressure increases to approximately $\Delta P_1 + (\Delta P_1 - \Delta P_{min})$.

(3) After re-establishing steady readings of the fan motor power and external static pressure, determine average values for the indoor blower power ($\dot{E}_{fan,2}$) and the external static pressure (ΔP_2) by making measurements over a 5-minute interval.

(4) Approximate the average power consumption of the indoor blower motor at ΔP_{min} using linear extrapolation:

$$\dot{E}_{fan,\min} = \frac{\dot{E}_{fan,2} - \dot{E}_{fan,1}}{\Delta P_2 - \Delta P_1}(\Delta P_{\min} - \Delta P_1) + \dot{E}_{fan,1}$$

(5) Increase the total space cooling capacity, $\dot{Q}_c^k(T)$, by the quantity ($\dot{E}_{fan,1} - \dot{E}_{fan,min}$), when expressed on a Btu/h basis. Decrease the total electrical power, $\dot{E}_c^k(T)$, by the same fan power difference, now expressed in watts.

3.4 Test Procedures for the Steady-State Dry-Coil Cooling-Mode Tests (the C, C_1, C_2, and G_1 Tests)

a. Except for the modifications noted in this section, conduct the steady-state dry coil cooling mode tests as specified in section 3.3 of this appendix for wet coil tests. Prior to recording data during the steady-state dry coil test, operate the unit at least one hour after achieving dry coil conditions. Drain the drain pan and plug the drain opening. Thereafter, the drain pan should remain completely dry.

b. Denote the resulting total space cooling capacity and electrical power derived from the test as $\dot{Q}_{ss,dry}$ and $\dot{E}_{ss,dry}$. With regard to a section 3.3 deviation, do not adjust $\dot{Q}_{ss,dry}$ for duct losses (*i.e.*, do not apply section 7.3.3.3 of ANSI/ASHRAE 37–2009). In preparing for the section 3.5 cyclic tests of this appendix, record the average indoor-side air volume rate, $\bar{V}$, specific heat of the air, Cp,a (expressed on dry air basis), specific volume of the air at the nozzles, v'_n, humidity ratio at the nozzles, W_n, and either pressure difference or velocity pressure for the flow nozzles. For units having a variable-speed indoor blower (that provides either a constant or variable air volume rate) that will or may be tested during the cyclic dry coil cooling mode test with the indoor blower turned off (see section 3.5 of this appendix), include the electrical power used by the indoor blower motor among the recorded parameters from the 30-minute test.

c. If the temperature sensors used to provide the primary measurement of the indoor-side dry bulb temperature difference during the steady-state dry-coil test and the subsequent cyclic dry-coil test are different, include measurements of the latter sensors among the regularly sampled data. Beginning at the start of the 30-minute data collection period, measure and compute the indoor-side air dry-bulb temperature difference using both sets of instrumentation, ΔT (Set SS) and ΔT (Set CYC), for each equally spaced data sample. If using a consistent data sampling rate that is less than 1 minute, calculate and record minutely averages for the two temperature differences. If using a consistent sampling rate of one minute or more, calculate and record the two temperature differences from each data sample. After having recorded the seventh (i=7) set of temperature differences, calculate the following ratio using the first seven sets of values:

$$F_{CD} = \frac{1}{7}\sum_{i-6}^{i}\frac{\Delta T(Set\ SS)}{\Delta T(Set\ CYC)}$$

Each time a subsequent set of temperature differences is recorded (if sampling more frequently than every 5 minutes), calculate F_{CD} using the most recent seven sets of values. Continue these calculations until the 30-minute period is completed or until a value for F_{CD} is calculated that falls outside the allowable range of 0.94–1.06. If the latter occurs, immediately suspend the test and identify the cause for the disparity in the two temperature difference measurements. Recalibration of one or both sets of instrumentation may be required. If all the values for F_{CD} are within the allowable range, save the final value of the ratio from the 30-minute test as F_{CD}*. If the temperature sensors used to provide the primary measurement of the indoor-side dry bulb temperature difference during the steady-state dry-coil test and the subsequent cyclic dry-coil test are the same, set F_{CD}*= 1.

3.5 Test Procedures for the Cyclic Dry-Coil Cooling-Mode Tests (the D, D_1, D_2, and I_1 Tests)

After completing the steady-state dry-coil test, remove the outdoor air enthalpy method test apparatus, if connected, and begin manual OFF/ON cycling of the unit's compressor. The test set-up should otherwise be identical to the set-up used during the steady-state dry coil test. When testing heat pumps, leave the reversing valve during the compressor OFF cycles in the same position as used for the compressor ON cycles, unless automatically changed by the controls of the unit. For units having a variable-speed indoor blower, the manufacturer has the option of electing at the outset whether to conduct the cyclic test with the indoor blower enabled or disabled. Always revert to testing with the indoor blower disabled if cyclic testing with the fan enabled is unsuccessful.

a. For all cyclic tests, the measured capacity must be adjusted for the thermal mass stored in devices and connections located between measured points. Follow the procedure outlined in section 7.4.3.4.5 of ASHRAE 116–2010 (incorporated by reference, see §430.3) to ensure any required measurements are taken.

b. For units having a single-speed or two-capacity compressor, cycle the compressor OFF for 24 minutes and then ON for 6 minutes ($\Delta\tau_{cyc,dry}$ = 0.5 hours). For units having a variable-speed compressor, cycle the compressor OFF for 48 minutes and then ON for 12 minutes ($\Delta\tau_{cyc,dry}$ = 1.0 hours). Repeat the OFF/ON compressor cycling pattern until the test is completed. Allow the controls of the unit to regulate cycling of the outdoor fan. If an upturned duct is used, measure the dry-bulb temperature at the inlet of the device at least once every minute and ensure that its test operating tolerance is within 1.0 °F for each compressor OFF period.

c. Sections 3.5.1 and 3.5.2 of this appendix specify airflow requirements through the indoor coil of ducted and non-ducted indoor units, respectively. In all cases, use the exhaust fan of the airflow measuring apparatus (covered under section 2.6 of this appendix) along with the indoor blower of the unit, if installed and operating, to approximate a step response in the indoor coil airflow. Regulate the exhaust fan to quickly obtain and then maintain the flow nozzle static pressure difference or velocity pressure at the same value as was measured during the steady-state dry coil test. The pressure difference or velocity pressure should be within 2 percent of the value from the steady-state dry coil test within 15 seconds after airflow initiation. For units having a variable-speed indoor blower that ramps when cycling on and/or off, use the exhaust fan of the airflow measuring apparatus to impose a step response that begins at the initiation of ramp up and ends at the termination of ramp down.

d. For units having a variable-speed indoor blower, conduct the cyclic dry coil test using the pull-thru approach described below if any of the following occur when testing with the fan operating:

(1) The test unit automatically cycles off;

(2) Its blower motor reverses; or

(3) The unit operates for more than 30 seconds at an external static pressure that is 0.1 inches of water or more higher than the value measured during the prior steady-state test.

For the pull-thru approach, disable the indoor blower and use the exhaust fan of the airflow measuring apparatus to generate the specified flow nozzles static pressure difference or velocity pressure. If the exhaust fan cannot deliver the required pressure difference because of resistance created by the unpowered indoor blower, temporarily remove the indoor blower.

e. Conduct three complete compressor OFF/ON cycles with the test tolerances given in Table 10 satisfied. Calculate the degradation coefficient C_D for each complete cycle. If all three C_D values are within 0.02 of the average C_D then stability has been achieved, use the highest C_D value of these three. If

stability has not been achieved, conduct additional cycles, up to a maximum of eight cycles, until stability has been achieved between three consecutive cycles. Once stability has been achieved, use the highest C_D value of the three consecutive cycles that establish stability. If stability has not been achieved after eight cycles, use the highest C_D from cycle one through cycle eight, or the default C_D, whichever is lower.

f. With regard to the Table 10 parameters, continuously record the dry-bulb temperature of the air entering the indoor and outdoor coils during periods when air flows through the respective coils. Sample the water vapor content of the indoor coil inlet air at least every 2 minutes during periods when air flows through the coil. Record external static pressure and the air volume rate indicator (either nozzle pressure difference or velocity pressure) at least every minute during the interval that air flows through the indoor coil. (These regular measurements of the airflow rate indicator are in addition to the required measurement at 15 seconds after flow initiation.) Sample the electrical voltage at least every 2 minutes beginning 30 seconds after compressor start-up. Continue until the compressor, the outdoor fan, and the indoor blower (if it is installed and operating) cycle off.

g. For ducted units, continuously record the dry-bulb temperature of the air entering (as noted above) and leaving the indoor coil. Or if using a thermopile, continuously record the difference between these two temperatures during the interval that air flows through the indoor coil. For non-ducted units, make the same dry-bulb temperature measurements beginning when the compressor cycles on and ending when indoor coil airflow ceases.

h. Integrate the electrical power over complete cycles of length $\Delta\tau_{cyc,dry}$. For ducted blower coil systems tested with the unit's indoor blower operating for the cycling test, integrate electrical power from indoor blower OFF to indoor blower OFF. For all other ducted units and for non-ducted units, integrate electrical power from compressor OFF to compressor OFF. (Some cyclic tests will use the same data collection intervals to determine the electrical energy and the total space cooling. For other units, terminate data collection used to determine the electrical energy before terminating data collection used to determine total space cooling.)

TABLE 10—TEST OPERATING AND TEST CONDITION TOLERANCES FOR CYCLIC DRY COIL COOLING MODE TESTS

	Test operating tolerance [1]	Test condition tolerance [1]
Indoor entering dry-bulb temperature,[2] °F	2.0	0.5
Indoor entering wet-bulb temperature, °F		([3])
Outdoor entering dry-bulb temperature,[2] °F	2.0	0.5
External resistance to airflow,[2] inches of water	0.05	
Airflow nozzle pressure difference or velocity pressure,[2]% of reading	2.0	[4] 2.0
Electrical voltage,[5] % of reading	2.0	1.5

[1] See section 1.2 of this appendix, Definitions.

[2] Applies during the interval that air flows through the indoor (outdoor) coil except for the first 30 seconds after flow initiation. For units having a variable-speed indoor blower that ramps, the tolerances listed for the external resistance to airflow apply from 30 seconds after achieving full speed until ramp down begins.

[3] Shall at no time exceed a wet-bulb temperature that results in condensate forming on the indoor coil.

[4] The test condition must be the average nozzle pressure difference or velocity pressure measured during the steady-state dry coil test.

[5] Applies during the interval when at least one of the following—the compressor, the outdoor fan, or, if applicable, the indoor blower—are operating except for the first 30 seconds after compressor start-up.

If the Table 10 tolerances are satisfied over the complete cycle, record the measured electrical energy consumption as $e_{cyc,dry}$ and express it in units of watt-hours. Calculate the total space cooling delivered, $q_{cyc,dry}$, in units of Btu using,

$$q_{cyc,dry} = \frac{60*\overline{V}*C_{p,a}*\Gamma}{[v_n'*(1+W_n)]} = \frac{60*\overline{V}*C_{p,a}*\Gamma}{v_n} \quad \text{and} \quad \Gamma = F_{CD}^{*}\int_{\tau_1}^{\tau_2}[T_{a1}(\tau) - T_{a2}(\tau)]\delta\tau,\ hr*°\text{F}$$

Where,

$\overline{V}$, $C_{p,a}$, v_n' (or v_n), W_n, and F_{CD}* are the values recorded during the section 3.4 dry coil steady-state test and

$T_{a1}(\tau)$ = dry bulb temperature of the air entering the indoor coil at time τ, °F.

$T_{a2}(\tau)$ = dry bulb temperature of the air leaving the indoor coil at time τ, °F.

τ_1 = for ducted units, the elapsed time when airflow is initiated through the indoor coil; for non-ducted units, the elapsed time when the compressor is cycled on, hr.

τ_2 = the elapsed time when indoor coil airflow ceases, hr.

Adjust the total space cooling delivered, $q_{cyc,dry}$, according to calculation method outlined in section 7.4.3.4.5 of ASHRAE 116–2010 (incorporated by reference, see §430.3).

3.5.1 Procedures When Testing Ducted Systems

The automatic controls that are installed in the test unit must govern the OFF/ON cycling of the air moving equipment on the indoor side (*i.e.*, the exhaust fan of the airflow measuring apparatus and the indoor blower of the test unit). For ducted coil-only systems rated based on using a fan time-delay relay, control the indoor coil airflow according to the OFF delay listed by the manufacturer in the certification report. For ducted units having a variable-speed indoor blower that has been disabled (and possibly removed), start and stop the indoor airflow at the same instances as if the fan were enabled. For all other ducted coil-only systems, cycle the indoor coil airflow in unison with the cycling of the compressor. If air damper boxes are used, close them on the inlet and outlet side during the OFF period. Airflow through the indoor coil should stop within 3 seconds after the automatic controls of the test unit de-energize (or if the airflow system has been disabled (and possibly removed), within 3 seconds after the automatic controls of the test unit *would have* de-energized) the indoor blower.

a. For mobile home and space-constrained ducted coil-only systems,

(1) For two-stage or variable-speed systems, for all cyclic dry-coil tests (*i.e.*, the D_1, D_2, and I_1 tests) decrease $q_{cyc,dry}$ by the quantity calculated in Equation 3.5–2 to this appendix and increase $e_{cyc,dry}$ by the quantity calculated in Equation 3.5–3 to this appendix.

$$\text{Equation 3.5-2 } \frac{(\text{DFPC}_{MHSC} * 3.412) Btu/h}{1000\ scfm} * \dot{V}_S * [\tau_2 - \tau_1]$$

$$\text{Equation 3.5-3 } \frac{\text{DFPC}_{MHSC} W}{1000\ scfm} * \dot{V}_S * [\tau_2 - \tau_1]$$

Where:

$\dot{V}_S$ is the average indoor air volume rate from the section 3.4 dry coil steady-state test and is expressed in units of cubic feet per minute of standard air (scfm),

$DFPC_{MHSC}$ is the default fan power coefficient (watts) for mobile-home and space-constrained systems,

$$\text{DFPC}_{MHSC} = 308 + \frac{(406 - 308) * (\%FLAVR - 75\%)}{100\% - 75\%}$$

And %FLAVR is the air volume rate used for the test, expressed as a percentage of the cooling full load air volume rate. For all tests specifying the full-load air volume rate (*e.g.*, the D_2 test), set %FLAVR to 100%. For tests that specify the cooling minimum air volume rate or cooling intermediate air volume rate (*i.e.*, the D_1 and I_1 tests) and for which the specified minimum or intermediate air volume rate is greater than or equal to 75 percent of the cooling full-load air volume rate and less than the cooling full-load air volume rate, set %FLAVR to the ratio of the specified air volume rate and the cooling full-load air volume rate, expressed as a percentage.

(2) For single-stage systems, for all cyclic dry-coil tests (*i.e.*, the D test), decrease $q_{cyc,dry}$ by the quantity calculated in Equation 3.5–4 to this appendix and increase $e_{cyc,dry}$ by the quantity calculated in Equation 3.5–5 to this appendix.

$$\text{Equation 3.5-4 } \frac{1385\ Btu/h}{1000\ scfm} * \dot{V}_S * [\tau_2 - \tau_1]$$

$$\text{Equation 3.5-5 } \frac{406\,W}{1000\,scfm} * \dot{V}_S * [\tau_2 - \tau_1]$$

b. For ducted, non-mobile, non-space-constrained home coil-only units,

(1) For two-stage or variable-speed systems, for all cyclic dry-coil tests (*i.e.*, the D_1, D_2, and I_1 tests) decrease $q_{cyc,dry}$ by the quantity calculated in Equation 3.5–6 to this appendix and increase $e_{cyc,dry}$ by the quantity calculated in Equation 3.5–7 to this appendix.

$$\text{Equation 3.5-6. } \frac{(\text{DFPC}_C * 3.412)\,Btu/h}{1000\,scfm} * \dot{V}_S * [\tau_2 - \tau_1]$$

$$\text{Equation 3.5-7. } \frac{\text{DFPC}_C\,W}{1000\,scfm} * \dot{V}_S * [\tau_2 - \tau_1]$$

Where:

$\dot{V}_S$ is the average indoor air volume rate from the section 3.4 dry coil steady-state test and is expressed in units of cubic feet per minute of standard air (scfm),

DFPC_C is the default fan power coefficient (watts) for non-mobile-home and non-space-constrained systems,

$$\text{DFPC}_C = 335 + \frac{(441 - 335) * (\%FLAVR - 75\%)}{100\% - 75\%}$$

And %FLAVR is the air volume rate used for the test, expressed as a percentage of the cooling full load air volume rate. For all tests specifying the full-load air volume rate (*e.g.*, the D_2 test), set %FLAVR to 100%. For tests that specify the cooling minimum air volume rate or cooling intermediate air volume rate (*i.e.*, the D_1, and I_1 tests) and for which the specified minimum or intermediate air volume rate is greater than or equal to 75 percent of the cooling full-load air volume rate and less than the cooling full-load air volume rate, set %FLAVR to the ratio of the specified air volume rate and the cooling full-load air volume rate, expressed as a percentage.

(2) For single-stage systems, for all cyclic dry-coil tests (*i.e.*, the D test) decrease $q_{cyc,dry}$ by the quantity calculated in Equation 3.5–8 to this appendix and increase $e_{cyc,dry}$ by the quantity calculated in Equation 3.5–9 to this appendix.

$$\text{Equation 3.5-8. } \frac{1505\,Btu/h}{1000\,scfm} * \dot{V}_S * [\tau_2 - \tau_1]$$

$$\text{Equation 3.5-9. } \frac{441\,W}{1000\,scfm} * \dot{V}_S * [\tau_2 - \tau_1]$$

c. For units having a variable-speed indoor blower that is disabled during the cyclic test, decrease $q_{cyc,dry}$ and increase $e_{cyc,dry}$ based on: The product of $[\tau_2 - \tau_1]$ and the indoor blower power (in W) measured during or following the dry coil steady-state test; or,

d. The following algorithm if the indoor blower ramps its speed when cycling.

(1) Measure the electrical power consumed by the variable-speed indoor blower at a minimum of three operating conditions: at the speed/air volume rate/external static pressure that was measured during the steady-state test, at operating conditions associated with the midpoint of the ramp-up interval, and at conditions associated with the midpoint of the ramp-down interval. For these measurements, the tolerances on the airflow volume or the external static pressure are

the same as required for the section 3.4 steady-state test.

(2) For each case, determine the fan power from measurements made over a minimum of 5 minutes.

(3) Approximate the electrical energy consumption of the indoor blower if it had operated during the cyclic test using all three power measurements. Assume a linear profile during the ramp intervals. The manufacturer must provide the durations of the ramp-up and ramp-down intervals. If the test setup instructions included with the unit by the manufacturer specifies a ramp interval that exceeds 45 seconds, use a 45-second ramp interval nonetheless when estimating the fan energy.

3.5.2 Procedures When Testing Non-Ducted Indoor Units

Do not use airflow prevention devices when conducting cyclic tests on non-ducted indoor units. Until the last OFF/ON compressor cycle, airflow through the indoor coil must cycle off and on in unison with the compressor. For the last OFF/ON compressor cycle—the one used to determine $e_{cyc,dry}$ and $q_{cyc,dry}$—use the exhaust fan of the airflow measuring apparatus and the indoor blower of the test unit to have indoor airflow start 3 minutes prior to compressor cut-on and end three minutes after compressor cutoff. Subtract the electrical energy used by the indoor blower during the 3 minutes prior to compressor cut-on from the integrated electrical energy, $e_{cyc,dry}$. Add the electrical energy used by the indoor blower during the 3 minutes after compressor cutoff to the integrated cooling capacity, $q_{cyc,dry}$. For the case where the non-ducted indoor unit uses a variable-speed indoor blower which is disabled during the cyclic test, correct $e_{cyc,dry}$ and $q_{cyc,dry}$ using the same approach as prescribed in section 3.5.1 of this appendix for ducted units having a disabled variable-speed indoor blower.

3.5.3 Cooling-Mode Cyclic-Degradation Coefficient Calculation

Use the two dry-coil tests to determine the cooling-mode cyclic-degradation coefficient, C_D^c. Append ''(k=2)'' to the coefficient if it corresponds to a two-capacity unit cycling at high capacity. If the two optional tests are conducted but yield a tested C_D^c that exceeds the default C_D^c or if the two optional tests are not conducted, assign C_D^c the default value of 0.25 for variable-speed compressor systems and outdoor units with no match, and 0.20 for all other systems. The default value for two-capacity units cycling at high capacity, however, is the low-capacity coefficient, *i.e.*, $C_D^c(k=2) = C_D^c$. Evaluate C_D^c using the above results and those from the section 3.4 dry-coil steady-state test.

$$C_D^c = \frac{1 - \frac{EER_{cyc,dry}}{EER_{ss,dry}}}{1 - CLF}$$

Where:

$$EER_{cyc,dry} = \frac{q_{cyc,dry}}{e_{cyc,dry}}$$

the average energy efficiency ratio during the cyclic dry coil cooling mode test, Btu/W·h

$$EER_{ss,dry} = \frac{\dot{Q}_{ss,dry}}{\dot{E}_{ss,dry}}$$

the average energy efficiency ratio during the steady-state dry coil cooling mode test, Btu/W·h

$$CLF = \frac{q_{cyc,dry}}{Q_{ss,dry} * \Delta\tau_{cyc,dry}}$$

the cooling load factor dimensionless

Round the calculated value for C_D^c to the nearest 0.01. If C_D^c is negative, then set it equal to zero.

3.6 Heating Mode Tests for Different Types of Heat Pumps, Including Heating-Only Heat Pumps

3.6.1 Tests for a Heat Pump Having a Single-Speed Compressor and Fixed Heating Air Volume Rate

This set of tests is for single-speed-compressor heat pumps that do not have a heating minimum air volume rate or a heating intermediate air volume rate that is different than the heating full load air volume rate. Conducting a very low temperature test (H4) is optional. Conduct the optional high temperature cyclic (H1C) test to determine the heating mode cyclic-degradation coefficient, C_D^h. If this optional test is conducted but yields a tested C_D^h that exceeds the default C_D^h or if the optional test is not conducted, assign C_D^h the default value of 0.25. Test conditions for the five tests are specified in Table 11 of this section.

TABLE 11—HEATING MODE TEST CONDITIONS FOR UNITS HAVING A SINGLE-SPEED COMPRESSOR AND A FIXED-SPEED INDOOR BLOWER, A CONSTANT AIR VOLUME RATE INDOOR BLOWER, OR COIL-ONLY

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
H1 test (required, steady)	70	60(max)	47	43	Heating Full-Load.[1]
H1C test (optional, cyclic)	70	60(max)	47	43	([2])
H2 test (required)	70	60(max)	35	33	Heating Full-Load.[1]
H3 test (required, steady)	70	60(max)	17	15	Heating Full-Load.[1]
H4 test (optional, steady)	70	60(max)	5	4(max)	Heating Full-Load.[1]

[1] Defined in section 3.1.4.4 of this appendix.
[2] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during an ON period at the same pressure or velocity as measured during the H1 test.

3.6.2 Tests for a Heat Pump Having a Single-Speed Compressor and a Single Indoor Unit Having Either (1) a Variable-Speed, Variable-Air-Rate Indoor Blower Whose Capacity Modulation Correlates With Outdoor Dry Bulb Temperature or (2) Multiple Indoor Blowers

Conduct five tests: Two high temperature tests ($H1_2$ and $H1_1$), one frost accumulation test ($H2_2$), and two low temperature tests ($H3_2$ and $H3_1$). Conducting an additional frost accumulation test ($H2_1$) and a very low temperature test ($H4_2$) is optional. Conduct the optional high temperature cyclic ($H1C_1$) test to determine the heating mode cyclic-degradation coefficient, C_D^h. If this optional test is conducted but yields a tested C_D^h that exceeds the default C_D^h or if the optional test is not conducted, assign C_D^h the default value of 0.25. Test conditions for the seven tests are specified in Table 12. If the optional $H2_1$ test is not performed, use the following equations to approximate the capacity and electrical power of the heat pump at the $H2_1$ test conditions:

$$\dot{Q}_h^{k=1}(35) = QR_h^{k=2}(35) * \left\{\dot{Q}_h^{k=1}(17) + 0.6 * \left[\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(17)\right]\right\}$$

$$\dot{E}_h^{k=1}(35) = PR_h^{k=2}(35) * \left\{\dot{E}_h^{k=1}(17) + 0.6 * \left[\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(17)\right]\right\}$$

where,

$$\dot{Q}R_h^{k=2}(35) = \frac{\dot{Q}_h^{k=2}(35)}{\dot{Q}^{k=2}(17) + 0.6 * [\dot{Q}_h^{k=2}(47) - \dot{Q}_h^{k=2}(17)]}$$

$$PR_h^{k=2}(35) = \frac{\dot{E}_h^{k=2}(35)}{\dot{E}_h^{k=2}(17) + 0.6 * \left[\dot{E}_h^{k=2}(47) - \dot{E}_h^{k=2}(17)\right]}$$

The quantities $\dot{Q}_h{}^{k=2}(47)$, $\dot{E}_h{}^{k=2}(47)$, $\dot{Q}_h{}^{k=1}(47)$, and $\dot{E}_h{}^{k=1}(47)$ are determined from the $H1_2$ and $H1_1$ tests and evaluated as specified in section 3.7 of this appendix; the quantities $\dot{Q}_h{}^{k=2}(35)$ and $\dot{E}_h{}^{k=2}(35)$ are determined from the $H2_2$ test and evaluated as specified in section 3.9 of this appendix; and the quantities $\dot{Q}_h{}^{k=2}(17)$, $\dot{E}_h{}^{k=2}(17)$, $\dot{Q}_h{}^{k=1}(17)$, and $\dot{E}_h{}^{k=1}(17)$, are determined from the $H3_2$ and $H3_1$ tests and evaluated as specified in section 3.10 of this appendix.

TABLE 12—HEATING MODE TEST CONDITIONS FOR UNITS WITH A SINGLE-SPEED COMPRESSOR THAT MEET THE SECTION 3.6.2 INDOOR UNIT REQUIREMENTS

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
$H1_2$ test (required, steady)	70	60(max)	47	43	Heating Full-Load.[1]
$H1_1$ test (required, steady)	70	60(max)	47	43	Heating Minimum.[2]
$H1C_1$ test (optional, cyclic)	70	60(max)	47	43	[3]
$H2_2$ test (required)	70	60(max)	35	33	Heating Full-Load.[1]
$H2_1$ test (optional)	70	60(max)	35	33	Heating Minimum.[2]
$H3_2$ test (required, steady)	70	60(max)	17	15	Heating Full-Load.[1]
$H3_1$ test (required, steady)	70	60(max)	17	15	Heating Minimum.[2]
$H4_2$ test (optional, steady)	70	60(max)	5	4(max)	Heating Full-Load.[1]

[1] Defined in section 3.1.4.4 of this appendix.
[2] Defined in section 3.1.4.5 of this appendix.
[3] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during an ON period at the same pressure or velocity as measured during the $H1_1$ test.

3.6.3 Tests for a Heat Pump Having a Two-Capacity Compressor (see Section 1.2 of This Appendix, Definitions), Including Two-Capacity, Northern Heat Pumps (see Section 1.2 of This Appendix, Definitions)

a. Conduct one maximum temperature test ($H0_1$), two high temperature tests ($H1_2$ and $H1_1$), one frost accumulation test ($H2_2$), and one low temperature test ($H3_2$). Conducting a very low temperature test ($H4_2$) is optional. Conduct an additional frost accumulation test ($H2_1$) and low temperature test ($H3_1$) if both of the following conditions exist:

(1) Knowledge of the heat pump's capacity and electrical power at low compressor capacity for outdoor temperatures of 37 °F and less is needed to complete the section 4.2.3 of this appendix seasonal performance calculations; and

(2) The heat pump's controls allow low-capacity operation at outdoor temperatures of 37 °F and less.

If the two conditions in a.(1) and a.(2) of this section are met, an alternative to conducting the $H2_1$ frost accumulation is to use the following equations to approximate the capacity and electrical power:

$$\dot{Q}_h^{k=1}(35) = 0.90 * \left\{\dot{Q}_h^{k=1}(17) + 0.6 * \left[\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(17)\right]\right\}$$

$$\dot{E}_h^{k=1}(35) = 0.985 * \left\{\dot{E}_h^{k=1}(17) + 0.6 * \left[\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(17)\right]\right\}$$

Determine the quantities $\dot{Q}_h^{k=1}$ (47) and $\dot{E}_h^{k=1}$ (47) from the $H1_1$ test and evaluate them according to section 3.7 of this appendix. Determine the quantities $\dot{Q}_h^{k=1}$ (17) and $\dot{E}_h^{k=1}$ (17) from the $H3_1$ test and evaluate them according to section 3.10 of this appendix.

b. Conduct the optional high temperature cyclic test ($H1C_1$) to determine the heating mode cyclic-degradation coefficient, C_D^h. If this optional test is conducted but yields a tested C_D^h that exceeds the default C_D^h or if the optional test is not conducted, assign C_D^h the default value of 0.25. If a two-capacity heat pump locks out low capacity operation at lower outdoor temperatures, conduct the high temperature cyclic test ($H1C_2$) to determine the high-capacity heating mode cyclic-degradation coefficient, C_D^h (k=2). If this optional test at high capacity is conducted but yields a tested C_D^h (k = 2) that exceeds the default C_D^h (k = 2) or if the optional test is not conducted, assign C_D^h the default value. The default C_D^h (k=2) is the same value as determined or assigned for the low-capacity cyclic-degradation coefficient, C_D^h [or equivalently, C_D^h (k=1)]. Table 13 specifies test conditions for these nine tests.

TABLE 13—HEATING MODE TEST CONDITIONS FOR UNITS HAVING A TWO-CAPACITY COMPRESSOR

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor capacity	Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
$H0_1$ test (required, steady) ...	70	60(max)	62	56.5	Low	Heating Minimum.[1]
$H1_2$ test (required, steady) ...	70	60(max)	47	43	High	Heating Full-Load.[2]
$H1C_2$ test (optional,[7] cyclic)	70	60(max)	47	43	High	([3])
$H1_1$ test (required, steady) ...	70	60(max)	47	43	Low	Heating Minimum.[1]
$H1C_1$ test (optional, cyclic) ..	70	60(max)	47	43	Low	([4])
$H2_2$ test (required)	70	60(max)	35	33	High	Heating Full-Load.[2]
$H2_1$ test[5 6] (required)	70	60(max)	35	33	Low	Heating Minimum.[1]
$H3_2$ test (required, steady) ...	70	60(max)	17	15	High	Heating Full-Load.[2]
$H3_1$ test[5] (required, steady)	70	60(max)	17	15	Low	Heating Minimum.[1]
$H4_2$ test (optional, steady) ...	70	60(max)	5	4(max)	High	Heating Full-Load.[2]

[1] Defined in section 3.1.4.5 of this appendix.
[2] Defined in section 3.1.4.4 of this appendix.
[3] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during an ON period at the same pressure or velocity as measured during the $H1_2$ test.
[4] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during an ON period at the same pressure or velocity as measured during the $H1_1$ test.
[5] Required only if the heat pump's performance when operating at low compressor capacity and outdoor temperatures less than 37 °F is needed to complete HSPF2 calculations in section 4.2.3 of this appendix.
[6] If note #5 to this table applies, the equations for $Q_h^{k=1}$ (35) and $E_h^{k=1}$ (17) in section 3.6.3 of this appendix may be used in lieu of conducting the $H2_1$ test.
[7] Required only if the heat pump locks out low-capacity operation at lower outdoor temperatures.

3.6.4 Tests for a Heat Pump Having a Variable-Speed Compressor

3.6.4.1 Variable-Speed Compressor Other Than Non-Communicating Coil-Only Heat Pumps

a. Conduct one maximum temperature test ($H0_1$), two high temperature tests ($H1_N$ and $H1_1$), one frost accumulation test ($H2_V$), and one low temperature test ($H3_2$). Conducting one or more of the following tests is optional: an additional high temperature test ($H1_2$), an additional frost accumulation test ($H2_2$), and a very low temperature test ($H4_2$). Conduct the optional high temperature cyclic ($H1C_1$) test to determine the heating mode cyclic-degradation coefficient, C_D^h. If this optional test is conducted and yields a tested C_D^h that exceeds the default C_D^h or if the optional test is not conducted, assign C_D^h the default value of 0.25. Test conditions for the nine tests are specified in Table 14A to this appendix. The compressor shall operate for the $H1_2$, $H2_2$ and $H3_2$ Tests at the same heating full speed, measured by RPM or power input frequency (Hz), as the maximum speed at which the system controls would operate the compressor in normal operation in 17 °F ambient temperature. The compressor shall operate for the $H1_N$ test at the maximum speed at which the system controls would operate the compressor in normal operation in 47 °F ambient temperature. Additionally, for a cooling/heating heat pump, the compressor shall operate for the $H1_N$ test at a speed, measured by RPM or power input frequency (Hz), no lower than the speed used in the A_2 test if the tested $H1_N$ heating capacity is less than the tested A_2 cooling capacity. The compressor shall operate at the same heating minimum speed, measured by RPM or power input frequency (Hz), for the $H0_1$, $H1C_1$, and $H1_1$ Tests. Determine the heating intermediate compressor speed cited in Table 14A using the heating mode full and minimum compressors speeds and:

$$\text{Heating intermediate speed} = \text{Heating minimum speed} + \frac{\text{Heating full speed} - \text{Heating minimum speed}}{3}$$

Where a tolerance of plus 5 percent or the next higher inverter frequency step from that calculated is allowed.

b. If one of the high temperature tests ($H1_2$ or $H1_N$) is conducted using the same compressor speed (RPM or power input frequency) as the $H3_2$ test, set the 47 °F capacity and power input values used for calculation of HSPF2 equal to the measured values for that test:

$\dot{Q}^{k=2}{}_{hcalc}(47) = \dot{Q}^{k=2}{}_{h}(47)$; $\dot{E}^{k=2}{}_{hcalc}(47) = \dot{E}^{k=2}{}_{h}(47)$

Where:

$\dot{Q}^{k=2}{}_{hcalc}(47)$ and $\dot{E}^{k=2}{}_{hcalc}(47)$ are the capacity and power input, respectively, representing full-speed operation at 47 °F for the HSPF2 calculations,

$\dot{Q}^{k=2}{}_{h}(47)$ is the capacity measured in the high temperature test ($H1_2$ or $H1_N$) that used the same compressor speed as the $H3_2$ test, and

$\dot{E}^{k=2}{}_{h}(47)$ is the power input measured in the high temperature test ($H1_2$ or $H1_N$) which used the same compressor speed as the $H3_2$ test.

Evaluate the quantities $\dot{Q}^{hk=2}(47)$ and $\dot{E}_h{}^{k=2}(47)$ according to section 3.7 of this appendix.

Otherwise (if no high temperature test is conducted using the same speed (RPM or power input frequency) as the $H3_2$ test), calculate the 47 °F capacity and power input values used for calculation of HSPF2 as follows:

$\dot{Q}^{k=2}{}_{hcalc}(47) = \dot{Q}^{k=2}{}_{h}(17) * (1 + 30\ °F * CSF)$;

$\dot{E}^{k=2}{}_{hcalc}(47) = \dot{E}^{k=2}{}_{h}(17) * (1 + 30\ °F * PSF)$;

Where:

$\dot{Q}^{k=2}{}_{hcalc}(47)$ and $\dot{E}^{k=2}{}_{hcalc}(47)$ are the capacity and power input, respectively, representing full-speed operation at 47 °F for the HSPF2 calculations,

$\dot{Q}^{k=2}{}_{h}(17)$ is the capacity measured in the $H3_2$ test,

$\dot{E}^{k=2}{}_{h}(17)$ is the power input measured in the $H3_2$ test,

CSF is the capacity slope factor, equal to 0.0204/ °F for split systems and 0.0262/ °F for single-package systems, and

PSF is the Power Slope Factor, equal to 0.00455/ °F.

c. If the $H2_2$ test is not done, use the following equations to approximate the capacity and electrical power at the $H2_2$ test conditions:

$\dot{Q}^{k=2}{}_{h}(35) = 0.90*\{\dot{Q}^{k=2}{}_{h}(17) + 0.6*[\dot{Q}^{k=2}{}_{hcalc}(47) - \dot{Q}^{k=2}{}_{h}(17)]\}$

$\dot{E}^{k=2}{}_{h}(35) = 0.985*\{\dot{E}^{k=2}{}_{h}(17) + 0.6*[\dot{E}^{k=2}{}_{hcalc}(47) - \dot{E}^{k=2}{}_{h}(17)]\}$

Where:

$\dot{Q}^{k=2}{}_{hcalc}(47)$ and $\dot{E}^{k=2}{}_{hcalc}(47)$ are the capacity and power input, respectively, representing full-speed operation at 47 °F for the HSPF2 calculations, calculated as described in paragraph b. of this section, and

$\dot{Q}^{k=2}{}_{h}(17)$ and $\dot{E}^{k=2}{}_{h}(17)$ are the capacity and power input measured in the $H3_2$ test.

d. Determine the quantities $\dot{Q}_h{}^{k=2}(17)$ and $\dot{E}_h{}^{k=2}(17)$ from the $H3_2$ test, determine the quantities $\dot{Q}_h{}^{k=2}(5)$ and $\dot{E}_h{}^{k=2}(5)$ from the $H4_2$ test, and evaluate all four according to section 3.10 of this appendix.

e. For multiple-split heat pumps (only), the following procedures supersede the above requirements. For all Table 14A of this appendix tests specified for a minimum compressor speed, turn off at least one indoor unit. The manufacturer shall designate the particular indoor unit(s) to be turned off. The manufacturer must also specify the compressor speed used for the Table 14A $H2_V$ test, a heating mode intermediate compressor speed that falls within ¼ and ¾ of the difference between the full and minimum heating mode speeds. The manufacturer should prescribe an intermediate speed that is expected to yield the highest COP for the given $H2_V$ test conditions and bracketed compressor speed range. The manufacturer can designate that one or more specific indoor units are turned off for the $H2_V$ test.

TABLE 14A—HEATING MODE TEST CONDITIONS FOR UNITS HAVING A VARIABLE-SPEED COMPRESSOR OTHER THAN VARIABLE-SPEED NON-COMMUNICATING COIL-ONLY HEAT PUMPS

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor speed	Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
$H0_1$ test (required, steady).	70	60(max)	62	56.5	Heating Minimum.	Heating Minimum.[1]
$H1_2$ test (optional, steady).	70	60(max)	47	43	Heating Full[4] ...	Heating Full-Load.[3]
$H1_1$ test (required, steady).	70	60(max)	47	43	Heating Minimum.	Heating Minimum.[1]
$H1_N$ test (required, steady).	70	60(max)	47	43	Heating Full[5] ...	Heating Nominal.[7]
$H1C_1$ test (optional, cyclic).	70	60(max)	47	43	Heating Minimum.	([2])
$H2_2$ test (optional).	70	60(max)	35	33	Heating Full[4] ...	Heating Full-Load.[3]
$H2_V$ test (required).	70	60(max)	35	33	Heating Intermediate.	Heating Intermediate.[6]
$H3_2$ test (required, steady).	70	60(max)	17	15	Heating Full[4] ...	Heating Full-Load.[3]
$H4_2$ test (optional, steady).	70	60(max)	5	4(max) ...	Heating Full[8] ...	Heating Full-Load.[3]

[1] Defined in section 3.1.4.5 of this appendix.
[2] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during an ON period at the same pressure or velocity as measured during the $H1_1$ test.
[3] Defined in section 3.1.4.4 of this appendix.
[4] Maximum speed that the system controls would operate the compressor in normal operation in 17 °F ambient temperature. The $H1_2$ test is not needed if the $H1_N$ test uses this same compressor speed.
[5] Maximum speed that the system controls would operate the compressor in normal operation in 47 °F ambient temperature.
[6] Defined in section 3.1.4.6 of this appendix.
[7] Defined in section 3.1.4.7 of this appendix.
[8] Maximum speed that the system controls would operate the compressor in normal operation at 5 °F ambient temperature.

3.6.4.2 Variable-Speed Compressor With Non-Communicating Coil-Only Heat Pumps

a. Conduct one maximum temperature test ($H0_1$), two high temperature tests ($H1_N$ and $H1_1$), two frost accumulation test ($H2_2$ and $H2_1$), and two low temperature tests ($H3_2$ and $H3_1$). Conducting one or both of the following tests is optional: an additional high temperature test ($H1_2$) and a very low temperature test ($H4_2$). Conduct the optional high temperature cyclic ($H1C_1$) test to determine the heating mode cyclic-degradation coefficient, C_D^h. If this optional test is conducted and yields a tested C_D^h that exceeds the default C_D^h or if the optional test is not conducted, assign C_D^h the default value of 0.25. Test conditions for the ten tests are specified in Table 14B to this appendix. The compressor shall operate for the $H1_2$ and $H3_2$ tests at the same heating full speed, measured by RPM or power input frequency (Hz), as the maximum speed at which the system controls would operate the compressor in normal operation in 17 °F ambient temperature. The compressor shall operate for the $H1_N$ test at the maximum speed at which the system controls would operate the compressor in normal operation in 47 °F ambient temperature. Additionally, for a cooling/heating heat pump, the compressor shall operate for the $H1_N$ test at a speed, measured by RPM or power input frequency (Hz), no lower than the speed used in the A_2 test if the tested $H1_N$ heating capacity is less than the tested A_2 cooling capacity. The compressor shall operate at the same heating minimum speed, measured by RPM or power input frequency (Hz), for the $H0_1$, $H1C_1$, and $H1_1$ tests.

b. If one of the high temperature tests ($H1_2$ or $H1_N$) is conducted using the same compressor speed (RPM or power input frequency) as the $H3_2$ test, set the 47 °F capacity and power input values used for calculation of HSPF2 equal to the measured values for that test:

$$\dot{Q}^{k=2hcalc}(47) = \dot{Q}^{k=2h}(47) = \dot{E}^{k=2hcalc}(47) = \dot{E}^{k=2h}(47)$$

Where:

$\dot{Q}^{k=2hcalc}(47)$ and $\dot{E}^{k=2hcalc}(47)$ are the capacity and power input, respectively, representing full-speed operation at 47 °F for the HSPF2 calculations,

$\dot{Q}^{k=2}{}_h(47)$ is the capacity measured in the high temperature test ($H1_2$ or $H1_N$) which used the same compressor speed as the $H3_2$ test, and

$\dot{E}^{k=2}{}_h(47)$ is the power input measured in the high temperature test ($H1_2$ or $H1_N$) which used the same compressor speed as the $H3_2$ test.

Evaluate the quantities $\dot{Q}^{h=2}(47)$ and $\dot{E}^{k=2}(47)$ according to section 3.7 of this appendix.

Otherwise (if no high temperature test is conducted using the same speed (RPM or power input frequency) as the $H3_2$ test), calculate the 47 °F capacity and power input values used for calculation of HSPF2 as follows:

$\dot{Q}^{k=2hcalc}(47) = \dot{Q}^{k=2h}(17) * (1 + 30\ °F\ CSF)$; and

$\dot{E}^{k=2hcalc}(47) = \dot{E}^{k=2h}(17) * (1 + 30\ °F\ PSF)$; and

Where:

$\dot{Q}^{k=2hcalc}$ and $\dot{E}^{k=2hcalc}(47)$ are the capacity and power input, respectively, representing full-speed operation at 47 °F for the HSPF2 calculations,

$\dot{Q}^{k=2h}$ is the capacity measured in the $H3_2$ test,

$\dot{E}^{k=2h}(47)$ is the power input measured in the $H3_2$ test,

CSF is the capacity slope factor, equal to 0.0204/ °F for split systems, and

PSF is the Power Slope Factor, equal to 0.00455/ °F.

c. Determine the quantities $\dot{Q}^{k=2}{}_h(17)$ and $\dot{E}^{k=2}{}_h(5)$ from the $H3_2$ test, determine the quantities $\dot{Q}^{k=2}{}_h(5)$ and $\dot{E}^{k=2}{}_h(5)$ from the $H4_2$ test, and evaluate all four according to section 3.10 of this appendix.

TABLE 14B—HEATING MODE TEST CONDITIONS FOR VARIABLE-SPEED NON-COMMUNICATING COIL-ONLY HEAT PUMPS

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor speed	Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
$H0_1$ test (required, steady).	70	60 (max)	62	56.5	Heating Minimum.	Heating Minimum.[1]
$H1_2$ test (optional, steady).	70	60 (max)	47	43	Heating Full[4] ...	Heating Full-Load.[3]
$H1_1$ test (required, steady).	70	60 (max)	47	43	Heating Minimum.	Heating Minimum.[1]
$H1_N$ test (required, steady).	70	60 (max)	47	43	Heating Full[5] ...	Heating Full-Load.[3]
$H1C_1$ test (optional, cyclic).	70	60 (max)	47	43	Heating Minimum.	([2])
$H2_2$ test (required).	70	60 (max)	35	33	Heating Full[6] ...	Heating Full-Load.[3]
$H2_1$ test (required).	70	60 (max)	35	33	Heating Minimum[7].	Heating Minimum.[1]
$H3_2$ test (required, steady).	70	60 (max)	17	15	Heating Full[4] ...	Heating Full-Load.[3]
$H3_1$ test (required, steady).	70	60 (max)	17	15	Heating Minimum[8].	Heating Minimum.[1]
$H4_2$ test (optional, steady).	70	60 (max)	5	4 (max) ..	Heating Full[9] ...	Heating Full-Load.[3]

[1] Defined in section 3.1.4.5 of this appendix.

[2] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during an ON period at the same pressure or velocity as measured during the $H1_1$ test.

[3] Defined in section 3.1.4.4 of this appendix.

[4] Maximum speed that the system controls would operate the compressor in normal operation in 17 °F ambient temperature. The $H1_2$ test is not needed if the $H1_N$ test uses this same compressor speed.

[5] Maximum speed that the system controls would operate the compressor in normal operation in 47 °F ambient temperature.

[6] Maximum speed that the system controls would operate the compressor in normal operation in 35 °F ambient temperature.

[7] Minimum speed that the system controls would operate the compressor in normal operation in 35 °F ambient temperature.

[8] Minimum speed that the system controls would operate the compressor in normal operation in 17 °F ambient temperature.

[9] Maximum speed that the system controls would operate the compressor in normal operation in 5 °F ambient temperature.

3.6.5 Additional Test for a Heat Pump Having a Heat Comfort Controller

Test any heat pump that has a heat comfort controller (see section 1.2 of this appendix, Definitions) according to section 3.6.1, 3.6.2, or 3.6.3, whichever applies, with the heat comfort controller disabled. Additionally, conduct the abbreviated test described in section 3.1.9 of this appendix with the heat comfort controller active to determine the system's maximum supply air temperature. (NOTE: heat pumps having a variable-speed compressor and a heat comfort controller are not covered in the test procedure at this time.)

3.6.6 Heating Mode Tests for Northern Heat Pumps with Triple-Capacity Compressors

Test triple-capacity, northern heat pumps for the heating mode as follows:

a. Conduct one maximum temperature test ($H0_1$), two high temperature tests ($H1_2$ and $H1_1$), one frost accumulation test ($H2_2$), two low temperature tests ($H3_2$, $H3_3$), and one very low temperature test ($H4_3$). Conduct an additional frost accumulation test ($H2_1$) and low temperature test ($H3_1$) if both of the following conditions exist: (1) Knowledge of the heat pump's capacity and electrical power at low compressor capacity for outdoor temperatures of 37 °F and less is needed to complete the section 4.2.6 seasonal performance calculations; and (2) the heat pump's controls allow low capacity operation at outdoor temperatures of 37 °F and less. If the above two conditions are met, an alternative to conducting the $H2_1$ frost accumulation test to determine $\dot{Q}_h^{k=1}(35)$ and $E_h^{k=1}(35)$ is to use the following equations to approximate this capacity and electrical power:

$$\dot{Q}_h^{k=1}(35) = 0.90 * \left\{\dot{Q}_h^{k=1}(17) + 0.6 * \left[\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(17)\right]\right\}$$

$$\dot{E}_h^{k=1}(35) = 0.985 * \left\{\dot{E}_h^{k=1}(17) + 0.6 * \left[\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(17)\right]\right\}$$

In evaluating the above equations, determine the quantities $Q_h^{k=1}(47)$ from the $H1_1$ test and evaluate them according to section 3.7 of this appendix. Determine the quantities $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ from the $H3_1$ test and evaluate them according to section 3.10 of this appendix. Use the paired values of $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ derived from conducting the $H2_1$ frost accumulation test and evaluated as specified in section 3.9.1 of this appendix or use the paired values calculated using the above default equations, whichever contribute to a higher Region IV HSPF2 based on the DHRmin.

b. Conducting a frost accumulation test ($H2_3$) with the heat pump operating at its booster capacity is optional. If this optional test is not conducted, determine $\dot{Q}_h^{k=3}(35)$ and $\dot{E}_h^{k=3}(35)$ using the following equations to approximate this capacity and electrical power:

$$\dot{Q}_h^{k=3}(35) = QR_h^{k=2}(35) * \left\{\dot{Q}_h^{k=3}(17) + 1.20 * \left[\dot{Q}_h^{k=3}(17) - \dot{Q}_h^{k=3}(5)\right]\right\}$$

$$\dot{E}_h^{k=3}(35) = PR_h^{k=2}(35) * \left\{\dot{E}_h^{k=3}(17) + 1.20 * \left[\dot{E}_h^{k=3}(17) - \dot{E}_h^{k=3}(5)\right]\right\}$$

Where:

$$QR_h^{k=2}(35) = \frac{\dot{Q}_h^{k=2}(35)}{\dot{Q}_h^{k=2}(17) + 0.6 * \left[\dot{Q}_h^{k=2}(47) - \dot{Q}_h^{k=2}(17)\right]}$$

$$PR_h^{k=2}(35) = \frac{\dot{E}_h^{k=2}(35)}{\dot{E}_h^{k=2}(17) + 0.6 * \left[\dot{E}_h^{k=2}(47) - \dot{E}_h^{k=2}(17)\right]}$$

Determine the quantities $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the $H1_2$ test and evaluate them according to section 3.7 of this appendix. Determine the quantities $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the $H2_2$ test and evaluate them according to section 3.9.1 of this appendix. Determine the quantities $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test, determine the quantities $\dot{Q}_h^{k=3}(17)$ and $\dot{E}_h^{k=3}(17)$ from the $H3_3$ test, and determine the quantities $\dot{Q}_h^{k=3}(5)$ and $\dot{E}_h^{k=3}(5)$ from the $H4_3$ test. Evaluate all six quantities according to section 3.10 of this appendix. Use the paired values of $\dot{Q}_h^{k=3}(35)$ and $\dot{E}_h^{k=3}(35)$ derived from conducting the $H2_3$ frost accumulation test and calculated as specified in section 3.9.1 of this appendix or use the paired values calculated using the above default equations, whichever contribute to a higher Region IV HSPF2 based on the DHRmin.

c. Conduct the optional high temperature cyclic test ($H1C_1$) to determine the heating mode cyclic-degradation coefficient, C_D^h. A default value for C_D^h of 0.25 may be used in lieu of conducting the cyclic. If a triple-capacity heat pump locks out low capacity operation at lower outdoor temperatures, conduct the high temperature cyclic test ($H1C_2$) to determine the high capacity heating mode cyclic-degradation coefficient, C_D^h (k=2). The default C_D^h (k=2) is the same value as determined or assigned for the low-capacity cyclic-degradation coefficient, C_D^h [or equivalently, C_D^h (k=1)]. Finally, if a triple-capacity heat pump locks out both low and high capacity operation at the lowest outdoor temperatures, conduct the low temperature cyclic test ($H3C_3$) to determine the booster-capacity heating mode cyclic-degradation coefficient, C_D^h (k=3). The default C_D^h (k=3) is the same value as determined or assigned for the high capacity cyclic-degradation coefficient, C_D^h [or equivalently, C_D^h (k=2)]. Table 15 specifies test conditions for all 13 tests.

TABLE 15—HEATING MODE TEST CONDITIONS FOR UNITS WITH A TRIPLE-CAPACITY COMPRESSOR

Test description	Air entering indoor unit (°F)		Air entering outdoor unit (°F)		Compressor capacity	Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
$H0_1$ Test (required, steady).	70	60 (max)	62	56.5	Low	Heating Minimum.[1]
$H1_2$ (required, steady).	70	60 (max)	47	43	High	Heating Full-Load.[2]
$H1C_2$ Test (optional,[8] cyclic.	70	60 (max)	47	43	High	([3])
$H1_1$ Test (required, steady).	70	60 (max)	47	43	Low	Heating Minimum.[1]
$H1C_1$ Test (optional, cyclic).	70	60 (max)	47	43	Low	([4])
$H2_3$ Test (optional, steady).	70	60 (max)	35	33	Booster	Heating Full-Load.[2]
$H2_2$ Test (required).	70	60 (max)	35	33	High	Heating Full-Load.[2]
$H2_1$ Test (required.	70	60 (max)	35	33	Low	Heating Minimum.[1]
$H3_3$ Test (required, steady).	70	60 (max)	17	15	Booster	Heating Full-Load.[2]
$H3C_3$ Test[5 6] (optional, cyclic).	70	60 (max)	17	15	Booster	([7])

TABLE 15—HEATING MODE TEST CONDITIONS FOR UNITS WITH A TRIPLE-CAPACITY COMPRESSOR—Continued

Test description	Air entering indoor unit (°F)		Air entering outdoor unit (°F)		Compressor capacity	Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
$H3_2$ Test (required, steady).	70	60 (max)	17	15	High	Heating Full-Load.[2]
$H3_1$ Test[5] (required, steady).	70	60 (max)	17	15	Low	Heating Minimum.[1]
$H4_3$ Test (required, steady).	70	60 (max)	5	4 (max) ..	Booster	Heating Full-Load.[2]

[1] Defined in section 3.1.4.5 of this appendix.
[2] Defined in section 3.1.4.4 of this appendix.
[3] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the $H1_2$ test.
[4] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the $H1_1$ test.
[5] Required only if the heat pump's performance when operating at low compressor capacity and outdoor temperatures less than 37 °F is needed to complete the HSPF2 calculations in section 4.2.6 of this appendix.
[6] If note #5 to this table applies, the equations for $\dot{Q}_k = 1/h$ (35) and $\dot{E}_k = 1/h$ (17) in section 3.6.6 of this appendix may be used in lieu of conducting the $H2_1$ test.
[7] Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the $H3_3$ test.
[8] Required only if the heat pump locks out low-capacity operation at lower outdoor temperatures

3.6.7 Tests for a Heat Pump Having a Single Indoor Unit Having Multiple Indoor Blowers and Offering Two Stages of Compressor Modulation. Conduct the Heating Mode Tests Specified in Section 3.6.3 of this Appendix

3.7 Test Procedures for Steady-State Maximum Temperature and High Temperature Heating Mode Tests (the $H0_1$, $H1$, $H1_2$, $H1_1$, and $H1_N$ tests)

a. For the pretest interval, operate the test room reconditioning apparatus and the heat pump until equilibrium conditions are maintained for at least 30 minutes at the specified section 3.6 test conditions. Use the exhaust fan of the airflow measuring apparatus and, if installed, the indoor blower of the heat pump to obtain and then maintain the indoor air volume rate and/or the external static pressure specified for the particular test. Continuously record the dry-bulb temperature of the air entering the indoor coil, and the dry-bulb temperature and water vapor content of the air entering the outdoor coil. Refer to section 3.11 of this appendix for additional requirements that depend on the selected secondary test method. After satisfying the pretest equilibrium requirements, make the measurements specified in Table 3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) for the indoor air enthalpy method and the user-selected secondary method. Make said Table 3 measurements at equal intervals that span 5 minutes or less. Continue data sampling until a 30-minute period (*e.g.*, seven consecutive 5-minute samples) is reached where the test tolerances specified in Table 16 are satisfied. For those continuously recorded parameters, use the entire data set for the 30-minute interval when evaluating Table 16 compliance. Determine the average electrical power consumption of the heat pump over the same 30-minute interval.

TABLE 16—TEST OPERATING AND TEST CONDITION TOLERANCES FOR SECTION 3.7 AND SECTION 3.10 STEADY-STATE HEATING MODE TESTS

	Test operating tolerance [1]	Test condition tolerance [1]
Indoor dry-bulb, °F:		
Entering temperature	2.0	0.5
Leaving temperature	2.0	
Indoor wet-bulb, °F:		
Entering temperature	1.0	
Leaving temperature	1.0	
Outdoor dry-bulb, °F:		
Entering temperature	2.0	0.5
Leaving temperature	[2]2.0	

TABLE 16—TEST OPERATING AND TEST CONDITION TOLERANCES FOR SECTION 3.7 AND SECTION 3.10 STEADY-STATE HEATING MODE TESTS—Continued

	Test operating tolerance [1]	Test condition tolerance [1]
Outdoor wet-bulb, °F:		
Entering temperature	1.0	0.3
Leaving temperature	[2] 1.0	
External resistance to airflow, inches of water	0.05	[3] 0.02
Electrical voltage, % of reading	2.0	1.5
Nozzle pressure drop, % of reading	2.0	

[1] See section 1.2 of this appendix, Definitions.
[2] Only applies when the Outdoor Air Enthalpy Method is used.
[3] Only applies when testing non-ducted units.

b. Calculate indoor-side total heating capacity as specified in sections 7.3.4.1 and 7.3.4.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). To calculate capacity, use the averages of the measurements (*e.g.* inlet and outlet dry bulb temperatures measured at the psychrometers) that are continuously recorded for the same 30-minute interval used as described above to evaluate compliance with test tolerances. Do not adjust the parameters used in calculating capacity for the permitted variations in test conditions. Assign the average space heating capacity and electrical power over the 30-minute data collection interval to the variables $\dot{Q}_h^k$ and $\dot{E}_h^k(T)$ respectively. The ''T'' and superscripted ''k'' are the same as described in section 3.3 of this appendix. Additionally, for the heating mode, use the superscript to denote results from the optional $H1_N$ test, if conducted.

c. For mobile home and space-constrained ducted coil-only system tests,

(1) For two-stage or variable-speed systems, for all steady-state maximum temperature and high temperature tests (*i.e.*, the $H0_1$, $H1_1$, $H1_2$, and $H1_N$ tests), increase $Q_c^k(T)$ by the quantity calculated in Equation 3.7–1 to this appendix and increase $\dot{E}_c^k(T)$ by the quantity calculated in Equation 3.7–2 to this appendix.

$$\text{Equation 3.7-1} \quad \frac{(\text{DFPC}_{MHSC} * 3.412)\ Btu/h}{1000\ scfm} * \dot{V}_S$$

$$\text{Equation 3.7-2} \quad \frac{\text{DFPC}_{MHSC}\ W}{1000\ scfm} * \dot{V}_S,$$

Where:

DFPC_{MHSC} is the default fan power coefficient (watts) for mobile-home and space-constrained systems,

$$\text{DFPC}_{MHSC} = 308 + \frac{(406 - 308) * (\%FLAVR - 75\%)}{100\% - 75\%}$$

And %FLAVR is the air volume rate used for the test, expressed as a percentage of the cooling full load air volume rate. For all tests specifying the full-load air volume rate (*e.g.*, the $H1_2$ and $H1_N$ tests), set %FLAVR to 100%. For tests that specify the heating minimum air volume rate or heating intermediate air volume rate (*i.e.*, the $H0_1$ and $H1_1$ tests) and for which the specified minimum or intermediate air volume rate is greater than or equal to 75 percent of the cooling full-load air volume rate and less than the cooling full-load air volume rate, set %FLAVR to the ratio of the specified air volume rate and the cooling full-load air volume rate, expressed as a percentage.

(2) For single-stage systems, for all steady-state maximum temperature and high temperature tests (*i.e.*, the H1 test), increase $Q_c^k(T)$ by the quantity calculated in Equation 3.7–3 to this appendix and increase $E_c^k(T)$

by the quantity calculated in Equation 3.7–4 to this appendix.

$$\text{Equation 3.7-3} \quad \frac{1385\ Btu/h}{1000\ scfm} * \dot{V}_S$$

$$\text{Equation 3.7-4} \quad \frac{406\ W}{1000\ scfm} * \dot{V}_S.$$

Where $\dot{V}_S$ is the average measured indoor air volume rate expressed in units of cubic feet per minute of standard air (scfm).

d. For non-mobile, non-space-constrained home ducted coil-only system tests,

(1) For two-stage or variable-speed systems, for all steady-state maximum temperature and high temperature tests (*i.e.*, the $H0_1$, $H1_1$, $H1_2$, and $H1_N$ tests), increase $Q_c^k(T)$ by the quantity calculated in Equation 3.7–5 to this appendix and increase $E_c^k(T)$ by the quantity calculated in Equation 3.7–6 to this appendix.

$$\text{Equation 3.7-5} \quad \frac{(\text{DFPC}_C{*}3.412)\ Btu/h}{1000\ scfm} * \dot{V}_S$$

$$\text{Equation 3.7-6} \quad \frac{\text{DFPC}_C\ W}{1000\ scfm} * \dot{V}_S,$$

Where:

DFPC_C is the default fan power coefficient (watts) for non-mobile-home and non-space-constrained systems,

$$\text{DFPC}_C = 335 + \frac{(441 - 335) * (\%FLAVR - 75\%)}{100\% - 75\%}$$

And %FLAVR is the air volume rate used for the test, expressed as a percentage of the cooling full load air volume rate. For all tests specifying the full-load air volume rate (*e.g.*, the $H1_2$ and $H1_N$ tests), set %FLAVR to 100%. For tests that specify the heating minimum air volume rate or heating intermediate air volume rate (*i.e.*, the $H0_1$ and $H1_1$ tests) and for which the specified minimum or intermediate air volume rate is greater than or equal to 75 percent of the cooling full-load air volume rate and less than the cooling full-load air volume rate, set %FLAVR to the ratio of the specified air volume rate and the cooling full-load air volume rate, expressed as a percentage.

(2) For single-stage systems, for all steady-state maximum temperature and high temperature tests (*i.e.*, the H1 test), increase $Q_c^k(\text{T})$ by the quantity calculated in Equation 3.7–7 to this appendix and increase $E_c^k(T)$ by the quantity calculated in Equation 3.7–8 to this appendix.

$$\text{Equation 3.7-7} \quad \frac{1505\ Btu/h}{1000\ scfm} * \dot{V}_S$$

$$\text{Equation 3.7-8} \quad \frac{441\ W}{1000\ scfm} * \dot{V}_S.$$

Where $\dot{V}_S$ is the average measured indoor air volume rate expressed in units of cubic feet per minute of standard air (scfm).

e. If conducting the cyclic heating mode test, which is described in section 3.8 of this appendix, record the average indoor-side air volume rate, $\bar{V}$, specific heat of the air, $C_{p,a}$ (expressed on dry air basis), specific volume of the air at the nozzles, v_n' (or v_n), humidity ratio at the nozzles, W_n, and either pressure difference or velocity pressure for the flow nozzles. If either or both of the below criteria apply, determine the average, steady-state, electrical power consumption of the indoor blower motor ($\dot{E}_{fan,1}$):

(1) The section 3.8 cyclic test will be conducted and the heat pump has a variable-speed indoor blower that is expected to be disabled during the cyclic test; or

(2) The heat pump has a (variable-speed) constant-air volume-rate indoor blower and during the steady-state test the average external static pressure (ΔP_1) exceeds the applicable section 3.1.4.4 minimum (or targeted) external static pressure (ΔP_{min}) by 0.03 inches of water or more.

Determine $\dot{E}_{fan,1}$ by making measurements during the 30-minute data collection interval, or immediately following the test and prior to changing the test conditions. When the above ''2'' criteria applies, conduct the following four steps after determining $\dot{E}_{fan,1}$ (which corresponds to ΔP_1):

(i) While maintaining the same test conditions, adjust the exhaust fan of the airflow measuring apparatus until the external static pressure increases to approximately $\Delta P_1 + (\Delta P_1 - \Delta P_{min})$.

(ii) After re-establishing steady readings for fan motor power and external static pressure, determine average values for the indoor blower power ($\dot{E}_{fan,2}$) and the external static pressure (ΔP_2) by making measurements over a 5-minute interval.

(iii) Approximate the average power consumption of the indoor blower motor if the 30-minute test had been conducted at ΔP_{min} using linear extrapolation:

$$\dot{E}_{fan,\min} = \frac{\dot{E}_{fan,2} - \dot{E}_{fan,1}}{\Delta P_2 - \Delta P_1}(\Delta P_{\min} - \Delta P_1) + \dot{E}_{fan,1}$$

(iv) Decrease the total space heating capacity, $\dot{Q}_h^k(T)$, by the quantity ($\dot{E}_{fan,1} - \dot{E}_{fan,min}$), when expressed on a Btu/h basis. Decrease the total electrical power, $\dot{E}_h^k(T)$ by the same fan power difference, now expressed in watts.

f. If the temperature sensors used to provide the primary measurement of the indoor-side dry bulb temperature difference during the steady-state dry-coil test and the subsequent cyclic dry-coil test are different, include measurements of the latter sensors among the regularly sampled data. Beginning at the start of the 30-minute data collection period, measure and compute the indoor-side air dry-bulb temperature difference using both sets of instrumentation, ΔT (Set SS) and ΔT (Set CYC), for each equally spaced data sample. If using a consistent data sampling rate that is less than 1 minute, calculate and record minutely averages for the two temperature differences. If using a consistent sampling rate of one minute or more, calculate and record the two temperature differences from each data sample. After having recorded the seventh (i=7) set of temperature differences, calculate the following ratio using the first seven sets of values:

$$F_{CD} = \frac{1}{7}\sum_{i-6}^{i}\frac{\Delta T(Set\ SS)}{\Delta T(Set\ CYC)}$$

Each time a subsequent set of temperature differences is recorded (if sampling more frequently than every 5 minutes), calculate F_{CD} using the most recent seven sets of values. Continue these calculations until the 30-minute period is completed or until a value for F_{CD} is calculated that falls outside the allowable range of 0.94–1.06. If the latter occurs, immediately suspend the test and identify the cause for the disparity in the two temperature difference measurements. Recalibration of one or both sets of instrumentation may be required. If all the values for F_{CD} are within the allowable range, save the final value of the ratio from the 30-minute test as F_{CD}*. If the temperature sensors used

to provide the primary measurement of the indoor-side dry bulb temperature difference during the steady-state dry-coil test and the subsequent cyclic dry-coil test are the same, set F_{CD}*= 1.

3.8 Test Procedures for the Cyclic Heating Mode Tests (the $H0C_1$, $H1C$, $H1C_1$ and $H1C_2$ Tests).

a. Except as noted below, conduct the cyclic heating mode test as specified in section 3.5 of this appendix. As adapted to the heating mode, replace section 3.5 references to ''the steady-state dry coil test'' with ''the heating mode steady-state test conducted at the same test conditions as the cyclic heating mode test.'' Use the test tolerances in Table 17 rather than Table 10. Record the outdoor coil entering wet-bulb temperature according to the requirements given in section 3.5 of this appendix for the outdoor coil entering dry-bulb temperature. Drop the subscript ''dry'' used in variables cited in section 3.5 of this appendix when referring to quantities from the cyclic heating mode test. If available, use electric resistance heaters (see section 2.1 of this appendix) to minimize the variation in the inlet air temperature. Determine the total space heating delivered during the cyclic heating test, q_{cyc}, as specified in section 3.5 of this appendix except for making the following changes:

(1) When evaluating Equation 3.5–1, use the values of $\bar{V}$, $C_{p,a}$,v_n', (or v_n), and W_n that were recorded during the section 3.7 steady-state test conducted at the same test conditions.

(2) Calculate

$$\Gamma \text{ using, } \Gamma = F_{CD}^{*} \int_{\tau_1}^{\tau_2} [T_{a1}(\tau) - T_{a2}(\tau)]\delta\tau, \ \ hr \times {}^{\circ}F,$$

where F_{CD}* is the value recorded during the section 3.7 steady-state test conducted at the same test condition.

b. For ducted coil-only system heat pumps (excluding the special case where a variable-speed fan is temporarily removed),

(1) For mobile home and space-constrained ducted coil-only systems,

(i) For two-stage or variable-speed systems, for all cyclic heating tests (*i.e.*, the $H1C_1$ and $H1C_2$ tests), increase q_{cyc} by the amount calculated using Equation 3.5–2 to this appendix. Additionally, increase e_{cyc} by the amount calculated using Equation 3.5–3 to this appendix.

(ii) For single-stage systems, for all cyclic heating tests (*i.e.*, the H1C and $H1C_1$ tests), increase q_{cyc} by the amount calculated using Equation 3.5–4 to this appendix. Additionally, increase e_{cyc} by the amount calculated using Equation 3.5–5 to this appendix.

(2) For non-mobile home and non-space-constrained ducted coil-only systems,

(i) For two-stage or variable-speed systems, for all cyclic heating tests (*i.e.*, the $H1C_1$ and $H1C_2$ tests), increase q_{cyc} by the amount calculated using Equation 3.5–6 to this appendix. Additionally, increase e_{cyc} by the amount calculated using Equation 3.5–7 to this appendix.

(ii) For single-stage systems, for all cyclic heating tests (*i.e.*, the H1C and $H1C_1$ tests), increase q_{cyc} by the amount calculated using Equation 3.5–8 to this appendix. Additionally, increase e_{cyc} by the amount calculated using Equation 3.5–9 to this appendix.

In making these calculations, use the average indoor air volume rate (V_s) determined from the section 3.7 of this appendix steady-state heating mode test conducted at the same test conditions.

c. For non-ducted heat pumps, subtract the electrical energy used by the indoor blower during the 3 minutes after compressor cutoff from the non-ducted heat pump's integrated heating capacity, $q_{cyc.}$

d. If a heat pump defrost cycle is manually or automatically initiated immediately prior to or during the OFF/ON cycling, operate the heat pump continuously until 10 minutes after defrost termination. After that, begin cycling the heat pump immediately or delay until the specified test conditions have been re-established. Pay attention to preventing defrosts after beginning the cycling process. For heat pumps that cycle off the indoor blower during a defrost cycle, make no effort here to restrict the air movement through the indoor coil while the fan is off. Resume the OFF/ON cycling while conducting a minimum of two complete compressor OFF/ON cycles before determining q_{cyc} and $e_{cyc.}$

3.8.1 Heating Mode Cyclic-Degradation Coefficient Calculation

Use the results from the required cyclic test and the required steady-state test that were conducted at the same test conditions to determine the heating mode cyclic-degradation coefficient C_D^h. Add ''(k=2)'' to the coefficient if it corresponds to a two-capacity unit cycling at high capacity. For the below calculation of the heating mode cyclic degradation coefficient, do not include the duct loss correction from section 7.3.3.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3) in determining $\dot{Q}_h^k(T_{cyc})$ (or q_{cyc}). If the optional cyclic test is conducted but yields a tested C_D^h that exceeds

the default C_D^h or if the optional test is not conducted, assign C_D^h the default value of 0.25. The default value for two-capacity units cycling at high capacity, however, is the low-capacity coefficient, *i.e.*, C_D^h (k=2) = C_D^h. The tested C_D^h is calculated as follows:

$$C_D^h = \frac{1 - \frac{COP_{cyc}}{COP_{ss}(T_{cyc})}}{1 - HLF}$$

Where:

$$COP_{cyc} = \frac{q_{cyc}}{3.413 \frac{Btu/h}{W} * e_{cyc}}$$

the average coefficient of performance during the cyclic heating mode test, dimensionless.

$$COP_{ss}(T_{cyc}) = \frac{\dot{Q}_h^k(T_{cyc})}{3.413 \frac{Btu/h}{W} * \dot{E}_h^k(T_{cyc})}$$

the average coefficient of performance during the steady-state heating mode test conducted at the same test conditions—*i.e.*, same outdoor dry bulb temperature, T_{cyc}, and speed/capacity, k, if applicable—as specified for the cyclic heating mode test, dimensionless.

$$HLF = \frac{q_{cyc}}{\dot{Q}_h^k(T_{cyc}) * \Delta\tau_{cyc}}$$

the heating load factor, dimensionless.

T_{cyc} = the nominal outdoor temperature at which the cyclic heating mode test is conducted, 62 or 47 °F.

$\Delta\tau_{cyc}$ = the duration of the OFF/ON intervals; 0.5 hours when testing a heat pump having a single-speed or two-capacity compressor and 1.0 hour when testing a heat pump having a variable-speed compressor.

Round the calculated value for C_D^h to the nearest 0.01. If C_D^h is negative, then set it equal to zero.

TABLE 17—TEST OPERATING AND TEST CONDITION TOLERANCES FOR CYCLIC HEATING MODE TESTS

	Test operating tolerance [1]	Test condition tolerance [1]
Indoor entering dry-bulb temperature,[2] °F	2.0	0.5
Indoor entering wet-bulb temperature,[2] °F	1.0	
Outdoor entering dry-bulb temperature,[2] °F	2.0	0.5
Outdoor entering wet-bulb temperature,[2] °F	2.0	1.0
External resistance to air-flow,[2] inches of water	0.05	
Airflow nozzle pressure difference or velocity pressure,[2]% of reading	2.0	[3] 2.0

TABLE 17—TEST OPERATING AND TEST CONDITION TOLERANCES FOR CYCLIC HEATING MODE TESTS—Continued

	Test operating tolerance [1]	Test condition tolerance [1]
Electrical voltage,[4]% of reading	2.0	1.5

[1] See section 1.2 of this appendix, Definitions.
[2] Applies during the interval that air flows through the indoor (outdoor) coil except for the first 30 seconds after flow initiation. For units having a variable-speed indoor blower that ramps, the tolerances listed for the external resistance to airflow shall apply from 30 seconds after achieving full speed until ramp down begins.
[3] The test condition must be the average nozzle pressure difference or velocity pressure measured during the steady-state test conducted at the same test conditions.
[4] Applies during the interval that at least one of the following—the compressor, the outdoor fan, or, if applicable, the indoor blower—are operating, except for the first 30 seconds after compressor start-up.

3.9 Test Procedures for Frost Accumulation Heating Mode Tests (the H2, $H2_2$, $H2_V$, and $H2_1$ Tests).

a. Confirm that the defrost controls of the heat pump are set as specified in section 2.2.1 of this appendix. Operate the test room reconditioning apparatus and the heat pump for at least 30 minutes at the specified section 3.6 test conditions before starting the ''preliminary'' test period. The preliminary test period must immediately precede the ''official'' test period, which is the heating and defrost interval over which data are collected for evaluating average space heating capacity and average electrical power consumption.

b. For heat pumps containing defrost controls which are likely to cause defrosts at intervals less than one hour, the preliminary test period starts at the termination of an automatic defrost cycle and ends at the termination of the next occurring automatic defrost cycle. For heat pumps containing defrost controls which are likely to cause defrosts at intervals exceeding one hour, the preliminary test period must consist of a heating interval lasting at least one hour followed by a defrost cycle that is either manually or automatically initiated. In all cases, the heat pump's own controls must govern when a defrost cycle terminates.

c. The official test period begins when the preliminary test period ends, at defrost termination. The official test period ends at the termination of the next occurring automatic defrost cycle. When testing a heat pump that uses a time-adaptive defrost control system (see section 1.2 of this appendix, Definitions), however, manually initiate the defrost cycle that ends the official test period at the instant indicated by instructions provided by the manufacturer. If the heat pump has not undergone a defrost after 6 hours, immediately conclude the test and use the results from the full 6-hour period to calculate the average space heating capacity and average electrical power consumption.

For heat pumps that turn the indoor blower off during the defrost cycle, take steps to cease forced airflow through the indoor coil and block the outlet duct whenever the heat pump's controls cycle off the indoor blower. If it is installed, use the outlet damper box described in section 2.5.4.1 of this appendix to affect the blocked outlet duct.

d. Defrost termination occurs when the controls of the heat pump actuate the first change in converting from defrost operation to normal heating operation. Defrost initiation occurs when the controls of the heat pump first alter its normal heating operation in order to eliminate possible accumulations of frost on the outdoor coil.

e. To constitute a valid frost accumulation test, satisfy the test tolerances specified in Table 18 during both the preliminary and official test periods. As noted in Table 18, test operating tolerances are specified for two sub-intervals:

(1) When heating, except for the first 10 minutes after the termination of a defrost cycle (sub-interval H, as described in Table 18) and

(2) When defrosting, plus these same first 10 minutes after defrost termination (sub-interval D, as described in Table 18). Evaluate compliance with Table 18 test condition tolerances and the majority of the test operating tolerances using the averages from measurements recorded only during sub-interval H. Continuously record the dry bulb temperature of the air entering the indoor coil, and the dry bulb temperature and water vapor content of the air entering the outdoor coil. Sample the remaining parameters listed in Table 18 at equal intervals that span 5 minutes or less.

f. For the official test period, collect and use the following data to calculate average space heating capacity and electrical power. During heating and defrosting intervals when the controls of the heat pump have the indoor blower on, continuously record the dry-bulb temperature of the air entering (as noted above) and leaving the indoor coil. If using a thermopile, continuously record the difference between the leaving and entering dry-bulb temperatures during the interval(s) that air flows through the indoor coil. For coil-only system heat pumps, determine the corresponding cumulative time (in hours) of

indoor coil airflow, $\Delta\tau_a$. Sample measurements used in calculating the air volume rate (refer to sections 7.7.2.1 and 7.7.2.2 of ANSI/ASHRAE 37–2009) at equal intervals that span 10 minutes or less. (NOTE: In the first printing of ANSI/ASHRAE 37–2009, the second IP equation for Q_{mi} should read:) Record the electrical energy consumed, expressed in watt-hours, from defrost termination to defrost termination, $e_{DEF}{}^k(35)$, as well as the corresponding elapsed time in hours, $\Delta\tau_{FR}$.

TABLE 18—TEST OPERATING AND TEST CONDITION TOLERANCES FOR FROST ACCUMULATION HEATING MODE TESTS

	Test operating tolerance [1]		Test condition tolerance [1]
	Sub-interval H [2]	Sub-interval D [3]	Sub-interval H [2]
Indoor entering dry-bulb temperature, °F	2.0	[4] 4.0	0.5
Indoor entering wet-bulb temperature, °F	1.0		
Outdoor entering dry-bulb temperature, °F	2.0	10.0	1.0
Outdoor entering wet-bulb temperature, °F	1.5		0.5
External resistance to airflow, inches of water	0.05		[5] 0.02
Electrical voltage, % of reading	2.0		1.5

[1] See section 1.2 of this appendix, Definitions.
[2] Applies when the heat pump is in the heating mode, except for the first 10 minutes after termination of a defrost cycle.
[3] Applies during a defrost cycle and during the first 10 minutes after the termination of a defrost cycle when the heat pump is operating in the heating mode.
[4] For heat pumps that turn off the indoor blower during the defrost cycle, the noted tolerance only applies during the 10 minute interval that follows defrost termination.
[5] Only applies when testing non-ducted heat pumps.

3.9.1 Average Space Heating Capacity and Electrical Power Calculations

a. Evaluate average space heating capacity, $\dot{Q}_h{}^k(35)$, when expressed in units of Btu per hour, using:

$$\dot{Q}_h^k(35) = \frac{60 * \bar{\dot{V}} * C_{p,a} * \Gamma}{\Delta\tau_{FR}[\nu_n' * (1 + W_n)]} = \frac{60 * \bar{\dot{V}} * C_{p,a} * \Gamma}{\Delta\tau_{FR}\nu_n}$$

where,

$\bar{\dot{V}}$ = the average indoor air volume rate measured during sub-interval H, cfm.

$C_{p,a} = 0.24 + 0.444 \cdot W_n$, the constant pressure specific heat of the air-water vapor mixture that flows through the indoor coil and is expressed on a dry air basis, Btu/$lbm_{da} \cdot °F$.

v_n' = specific volume of the air-water vapor mixture at the nozzle, ft^3/lbm_{mx}.

W_n = humidity ratio of the air-water vapor mixture at the nozzle, lbm of water vapor per lbm of dry air.

$\Delta\tau_{FR} = \tau_2 - \tau_1$, the elapsed time from defrost termination to defrost termination, hr.

$$\Gamma = \int_{\tau_1}^{\tau_2}[T_{a2}(\tau) - T_{a1}(\tau)]d\tau,\ hr * °F$$

$T_{a1}(\tau)$ = dry bulb temperature of the air entering the indoor coil at elapsed time τ, °F; only recorded when indoor coil airflow occurs; assigned the value of zero during periods (if any) where the indoor blower cycles off.

$T_{a2}(\tau)$ = dry bulb temperature of the air leaving the indoor coil at elapsed time τ, °F; only recorded when indoor coil airflow occurs; assigned the value of zero during periods (if any) where the indoor blower cycles off.

τ_1 = the elapsed time when the defrost termination occurs that begins the official test period, hr.

τ_2 = the elapsed time when the next automatically occurring defrost termination

occurs, thus ending the official test period, hr.

v_n = specific volume of the dry air portion of the mixture evaluated at the dry-bulb temperature, vapor content, and barometric pressure existing at the nozzle, ft^3 per lbm of dry air.

To account for the effect of duct losses between the outlet of the indoor unit and the section 2.5.4 dry-bulb temperature grid, adjust $\dot{Q}_h{}^k(35)$ in accordance with section 7.3.4.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3).

b. Evaluate average electrical power, $\dot{E}_h{}^k(35) = \frac{e_{def}(35)}{\Delta_{\tau_{FR}}}$, when expressed in units of watts, using:

(1) For mobile home and space-constrained ducted coil-only system tests,

(i) For two-stage or variable-speed systems, for all frost accumulation tests (*i.e.*, the $H2_1$, $H2_2$, and $H2_V$ tests), increase $Q_h{}^k(35)$ by the quantity calculated in Equation 3.9.1–1 to this appendix and increase $E_h{}^k$ (35) by the quantity calculated in Equation 3.9.1–2 to this appendix.

$$\text{Equation 3.9.1-1} \quad \frac{(\text{DFPC}_{MHSC} * 3.412)\, Btu/h}{1000\, scfm} * \dot{V}_S$$

$$\text{Equation 3.9.1-2} \quad \frac{\text{DFPC}_{MHSC}\, W}{1000\, scfm} * \dot{V}_S,$$

Where:

$DFPC_{MHSC}$ is the default fan power coefficient (watts) for mobile-home and space-constrained systems,

$$\text{DFPC}_{MHSC} = 308 + \frac{(406 - 308) * (\%FLAVR - 75\%)}{100\% - 75\%}$$

And %FLAVR is the air volume rate used for the test, expressed as a percentage of the cooling full load air volume rate. For all tests specifying the full-load air volume rate (*e.g.*, the $H2_2$ test), set %FLAVR to 100%. For tests that specify the heating minimum air volume rate or heating intermediate air volume rate (*i.e.*, the $H2_1$ and $H2_v$ tests) and for which the specified minimum or intermediate air volume rate is greater than or equal to 75 percent of the cooling full-load air volume rate and less than the cooling full-load air volume rate, set %FLAVR to the ratio of the specified air volume rate and the cooling full-load air volume rate, expressed as a percentage.

(ii) For single-stage systems, for all frost accumulation tests (*i.e.*, the H2 test), increase $Q_h{}^k(35)$ by the quantity calculated in Equation 3.9.1–3 to this appendix and increase $Q_h{}^k(35)$ by the quantity calculated in Equation 3.9.1–4 to this appendix.

$$\text{Equation 3.9.1-3} \quad \frac{1385 Btu/h}{1000\, scfm} * \dot{V}_S$$

$$\text{Equation 3.9.1-4} \quad \frac{406\,W}{1000\,scfm} * \dot{V}_S.$$

Where V_s is the average measured indoor air volume rate expressed in units of cubic feet per minute of standard air (scfm).

(2) For non-mobile home and non-space-constrained ducted coil-only systems,

(i) For two-stage or variable-speed systems, for all frost accumulation tests (*i.e.*, the $H2_1$, $H2_2$, and $H2_V$ tests), increase $Q_h^k(35)$ by the quantity calculated in Equation 3.9.1–5 to this appendix and increase $E_h^k(35)$ by the quantity calculated in Equation 3.9.1–6 to this appendix.

$$\text{Equation 3.9.1-5} \quad \frac{(\text{DFPC}_C * 3.412)\,Btu/h}{1000\,scfm} * \dot{V}_S$$

$$\text{Equation 3.9.1-6} \quad \frac{\text{DFPC}_C\,W}{1000\,scfm} * \dot{V}_S,$$

Where:

$DFPC_C$ is the default fan power coefficient (watts) for non-mobile-home and non-space-constrained systems,

$$\text{DFPC}_C = 335 + \frac{(441 - 335) * (\%FLAVR - 75\%)}{100\% - 75\%}$$

And %FLAVR is the air volume rate used for the test, expressed as a percentage of the cooling full load air volume rate. For all tests specifying the full-load air volume rate (*e.g.*, the $H2_2$ test), set %FLAVR to 100%. For tests that specify the heating minimum air volume rate or heating intermediate air volume rate (*i.e.*, the $H2_1$ and $H2_V$ tests) and for which the specified minimum or intermediate air volume rate is greater than or equal to 75 percent of the cooling full-load air volume rate and less than the cooling full-load air volume rate, set %FLAVR to the ratio of the specified air volume rate and the cooling full-load air volume rate, expressed as a percentage.

(ii) For single-stage systems, for all frost accumulation tests (*i.e.*, the H2 test), increase $Q_h^k(35)$ by the quantity calculated in Equation 3.9.1–7 to this appendix and increase $E_h^k(35)$ by the quantity calculated in Equation 3.9.1–8 to this appendix.

$$\text{Equation 3.9.1-7} \quad \frac{1505\,Btu/h}{1000\,scfm} * \dot{V}_S, \text{ and}$$

$$\text{Equation 3.9.1-8} \quad \frac{441\,W}{1000\,scfm} * \dot{V}_S.$$

Where V_s is the average measured indoor air volume rate expressed in units of cubic feet per minute of standard air (scfm).

c. For heat pumps having a constant-air-volume-rate indoor blower, the five additional steps listed below are required if the average of the external static pressures measured during sub-interval H exceeds the applicable section 3.1.4.4, 3.1.4.5, or 3.1.4.6 minimum (or targeted) external static pressure (ΔP_{min}) by 0.03 inches of water or more:

(1) Measure the average power consumption of the indoor blower motor ($\dot{E}_{fan,1}$) and record the corresponding external static pressure (ΔP_1) during or immediately following the frost accumulation heating mode

test. Make the measurement at a time when the heat pump is heating, except for the first 10 minutes after the termination of a defrost cycle.

(2) After the frost accumulation heating mode test is completed and while maintaining the same test conditions, adjust the exhaust fan of the airflow measuring apparatus until the external static pressure increases to approximately $\Delta P_1 + (\Delta P_1 - \Delta P_{min})$.

(3) After re-establishing steady readings for the fan motor power and external static pressure, determine average values for the indoor blower power ($\dot{E}_{fan,2}$) and the external static pressure (ΔP_2) by making measurements over a 5-minute interval.

(4) Approximate the average power consumption of the indoor blower motor had the frost accumulation heating mode test been conducted at ΔP_{min} using linear extrapolation:

$$\dot{E}_{fan,\min} = \frac{\dot{E}_{fan,2} - \dot{E}_{fan,1}}{\Delta P_2 - \Delta P_1}(\Delta P_{\min} - \Delta P_1) + \dot{E}_{fan,1}$$

(5) Decrease the total heating capacity, $\dot{Q}_h^k(35)$, by the quantity $[(\dot{E}_{fan,1} - \dot{E}_{fan,min}) \cdot (\Delta\tau_a/\Delta\tau_{FR}]$, when expressed on a Btu/h basis. Decrease the total electrical power, $E_h^k(35)$, by the same quantity, now expressed in watts.

3.9.2 Demand Defrost Credit

a. Assign the demand defrost credit, F_{def}, that is used in section 4.2 of this appendix to the value of 1 in all cases except for heat pumps having a demand-defrost control system (see section 1.2 of this appendix, Definitions). For such qualifying heat pumps, evaluate F_{def} using,

$$F_{def} = 1 + 0.03 * \left[1 - \frac{\Delta\tau_{def} - 1.5}{\Delta\tau_{\max} - 1.5}\right]$$

where:

$\Delta\tau_{def}$ = the time between defrost terminations (in hours) or 1.5, whichever is greater. Assign a value of 6 to $\Delta\tau_{def}$ if this limit is reached during a frost accumulation test and the heat pump has not completed a defrost cycle.

$\Delta\tau_{max}$ = maximum time between defrosts as allowed by the controls (in hours) or 12, whichever is less, as provided in the certification report.

b. For two-capacity heat pumps and for section 3.6.2 units, evaluate the above equation using the $\Delta\tau_{def}$ that applies based on the frost accumulation test conducted at high capacity and/or at the heating full-load air volume rate. For variable-speed heat pumps, evaluate $\Delta\tau_{def}$ based on the required frost accumulation test conducted at the intermediate compressor speed.

3.10 Test Procedures for Steady-State Low Temperature and Very Low Temperature Heating Mode Tests (the H3, $H3_2$, $H3_1$, $H3_3$, H4, $H4_2$, and $H4_3$ Tests)

Except for the modifications noted in this section, conduct the low temperature and very low temperature heating mode tests using the same approach as specified in section 3.7 of this appendix for the maximum and high temperature tests. After satisfying the section 3.7 requirements for the pretest interval but before beginning to collect data to determine the capacity and power input, conduct a defrost cycle. This defrost cycle may be manually or automatically initiated. Terminate the defrost sequence using the heat pump's defrost controls. Begin the 30-minute data collection interval described in section 3.7 of this appendix, from which the capacity and power input are determined, no sooner than 10 minutes after defrost termination. Defrosts should be prevented over the 30-minute data collection interval.

3.11 Additional Requirements for the Secondary Test Methods

3.11.1 If Using the Outdoor Air Enthalpy Method as the Secondary Test Method.

a. For all cooling mode and heating mode tests, first conduct a test without the outdoor air-side test apparatus described in section 2.10.1 of this appendix connected to the outdoor unit (''free outdoor air'' test).

b. For the first section 3.2 steady-state cooling mode test and the first section 3.6 steady-state heating mode test, conduct a

second test in which the outdoor-side apparatus is connected (''ducted outdoor air'' test). No other cooling mode or heating mode tests require the ducted outdoor air test so long as the unit operates the outdoor fan during all cooling mode steady-state tests at the same speed and all heating mode steady-state tests at the same speed. If using more than one outdoor fan speed for the cooling mode steady-state tests, however, conduct the ducted outdoor air test for each cooling mode test where a different fan speed is first used. This same requirement applies for the heating mode tests.

3.11.1.1 Free Outdoor Air Test

a. For the free outdoor air test, connect the indoor air-side test apparatus to the indoor coil; do not connect the outdoor air-side test apparatus. Allow the test room reconditioning apparatus and the unit being tested to operate for at least one hour. After attaining equilibrium conditions, measure the following quantities at equal intervals that span 5 minutes or less:

(1) The section 2.10.1 evaporator and condenser temperatures or pressures;

(2) Parameters required according to the Indoor Air Enthalpy Method.

Continue these measurements until a 30-minute period (*e.g.*, seven consecutive 5-minute samples) is obtained where the Table 9 or Table 16, whichever applies, test tolerances are satisfied.

b. For cases where a ducted outdoor air test is not required per section 3.11.1.b of this appendix, the free outdoor air test constitutes the ''official'' test for which validity is not based on comparison with a secondary test.

c. For cases where a ducted outdoor air test is required per section 3.11.1.b of this appendix, the following conditions must be met for the free outdoor air test to constitute a valid ''official'' test:

(1) The energy balance specified in section 3.1.1 of this appendix is achieved for the ducted outdoor air test (*i.e.*, compare the capacities determined using the indoor air enthalpy method and the outdoor air enthalpy method).

(2) The capacities determined using the indoor air enthalpy method from the ducted outdoor air and free outdoor air tests must agree within 2 percent.

3.11.1.2 Ducted Outdoor Air Test

a. The test conditions and tolerances for the ducted outdoor air test are the same as specified for the official test, where the official test is the free outdoor air test described in section 3.11.1.1 of this appendix.

b. After collecting 30 minutes of steady-state data during the free outdoor air test, connect the outdoor air-side test apparatus to the unit for the ducted outdoor air test. Adjust the exhaust fan of the outdoor airflow measuring apparatus until averages for the evaporator and condenser temperatures, or the saturated temperatures corresponding to the measured pressures, agree within ±0.5 °F of the averages achieved during the free outdoor air test. Collect 30 minutes of steady-state data after re-establishing equilibrium conditions.

c. During the ducted outdoor air test, at intervals of 5 minutes or less, measure the parameters required according to the indoor air enthalpy method and the outdoor air enthalpy method for the prescribed 30 minutes.

d. For cooling mode ducted outdoor air tests, calculate capacity based on outdoor air-enthalpy measurements as specified in sections 7.3.3.2 and 7.3.3.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3). For heating mode ducted tests, calculate heating capacity based on outdoor air-enthalpy measurements as specified in sections 7.3.4.2 and 7.3.3.4.3 of the same ANSI/ASHRAE Standard. Adjust the outdoor-side capacity according to section 7.3.3.4 of ANSI/ASHRAE 37–2009 to account for line losses when testing split systems. As described in section 8.6.2 of ANSI/ASHRAE 37–2009, use the outdoor air volume rate as measured during the ducted outdoor air tests to calculate capacity for checking the agreement with the capacity calculated using the indoor air enthalpy method.

3.11.2 If Using the Compressor Calibration Method as the Secondary Test Method

a. Conduct separate calibration tests using a calorimeter to determine the refrigerant flow rate. Or for cases where the superheat of the refrigerant leaving the evaporator is less than 5 °F, use the calorimeter to measure total capacity rather than refrigerant flow rate. Conduct these calibration tests at the same test conditions as specified for the tests in this appendix. Operate the unit for at least one hour or until obtaining equilibrium conditions before collecting data that will be used in determining the average refrigerant flow rate or total capacity. Sample the data at equal intervals that span 5 minutes or less. Determine average flow rate or average capacity from data sampled over a 30-minute period where the Table 9 (cooling) or the Table 16 (heating) tolerances are satisfied. Otherwise, conduct the calibration tests according to sections 5, 6, 7, and 8 of ASHRAE 23.1–2010 (incorporated by reference, see §430.3); sections 5, 6, 7, 8, 9, and 11 of ASHRAE 41.9–2011 (incorporated by reference, see §430.3); and section 7.4 of ANSI/ASHRAE 37–2009 (incorporated by reference, see §430.3).

b. Calculate space cooling and space heating capacities using the compressor calibration method measurements as specified in section 7.4.5 and 7.4.6 respectively, of ANSI/ASHRAE 37–2009.

3.11.3 If Using the Refrigerant-Enthalpy Method as the Secondary Test Method

Conduct this secondary method according to section 7.5 of ANSI/ASHRAE 37–2009. Calculate space cooling and heating capacities using the refrigerant-enthalpy method measurements as specified in sections 7.5.4 and 7.5.5, respectively, of the same ANSI/ASHRAE Standard.

3.12 Rounding of Space Conditioning Capacities for Reporting Purposes

a. When reporting rated capacities, round them off as specified in §430.23 (for a single unit) and in 10 CFR 429.16 (for a sample).

b. For the capacities used to perform the calculations in section 4 of this appendix, however, round only to the nearest integer.

3.13 Laboratory Testing To Determine Off Mode Average Power Ratings

Voltage tolerances: As a percentage of reading, test operating tolerance must be 2.0 percent and test condition tolerance must be 1.5 percent (see section 1.2 of this appendix for definitions of these tolerances).

Conduct one of the following tests: If the central air conditioner or heat pump lacks a compressor crankcase heater, perform the test in section 3.13.1 of this appendix; if the central air conditioner or heat pump has a compressor crankcase heater that lacks controls and is not self-regulating, perform the test in section 3.13.1 of this appendix; if the central air conditioner or heat pump has a crankcase heater with a fixed power input controlled with a thermostat that measures ambient temperature and whose sensing element temperature is not affected by the heater, perform the test in section 3.13.1 of this appendix; if the central air conditioner or heat pump has a compressor crankcase heater equipped with self-regulating control or with controls for which the sensing element temperature is affected by the heater, perform the test in section 3.13.2 of this appendix.

3.13.1 This Test Determines the Off Mode Average Power Rating for Central Air Conditioners and Heat Pumps That Lack a Compressor Crankcase Heater, or Have a Compressor Crankcase Heating System That Can Be Tested Without Control of Ambient Temperature During the Test. This Test Has No Ambient Condition Requirements

a. Test Sample Set-up and Power Measurement: For coil-only systems, provide a furnace or modular blower that is compatible with the system to serve as an interface with the thermostat (if used for the test) and to provide low-voltage control circuit power. Make all control circuit connections between the furnace (or modular blower) and the outdoor unit as specified by the manufacturer's installation instructions. Measure power supplied to both the furnace (or modular blower) and power supplied to the outdoor unit. Alternatively, provide a compatible transformer to supply low-voltage control circuit power, as described in section 2.2.d of this appendix. Measure transformer power, either supplied to the primary winding or supplied by the secondary winding of the transformer, and power supplied to the outdoor unit. For blower coil and single-package systems, make all control circuit connections between components as specified by the manufacturer's installation instructions, and provide power and measure power supplied to all system components.

b. Configure Controls: Configure the controls of the central air conditioner or heat pump so that it operates as if connected to a building thermostat that is set to the OFF position. Use a compatible building thermostat if necessary to achieve this configuration. For a thermostat-controlled crankcase heater with a fixed power input, bypass the crankcase heater thermostat if necessary to energize the heater.

c. Measure $P2_x$: If the unit has a crankcase heater time delay, make sure that time-delay function is disabled or wait until delay time has passed. Determine the average power from non-zero value data measured over a 5-minute interval of the non-operating central air conditioner or heat pump and designate the average power as $P2_x$, the heating season total off mode power.

d. Measure P_x for coil-only split systems and for blower coil split systems for which a furnace or a modular blower is the designated air mover: Disconnect all low-voltage wiring for the *outdoor* components and *outdoor* controls from the low-voltage transformer. Determine the average power from non-zero value data measured over a 5-minute interval of the power supplied to the (remaining) low-voltage components of the central air conditioner or heat pump, or low-voltage power, P_x. This power measurement does not include line power supplied to the outdoor unit. It is the line power supplied to the air mover, or, if a compatible transformer is used instead of an air mover, it is the line power supplied to the transformer primary coil. If a compatible transformer is used instead of an air mover and power output of the low-voltage secondary circuit is measured, P_x is zero.

e. Calculate *P2:* Set the number of compressors equal to the unit's number of single-stage compressors plus 1.75 times the unit's number of compressors that are not single-stage.

For single-package systems and blower coil split systems for which the designated air mover is not a furnace or modular blower, divide the heating season total off mode power ($P2_x$) by the number of compressors to

calculate *P2*, the heating season per-compressor off mode power. Round *P2* to the nearest watt. The expression for calculating *P2* is as follows:

$$P2 = \frac{P2_x}{number\ of\ compressors}.$$

For coil-only split systems and blower coil split systems for which a furnace or a modular blower is the designated air mover, subtract the low-voltage power (P_x) from the heating season total off mode power (P_x) and divide by the number of compressors to calculate *P2*, the heating season per-compressor off mode power. Round *P2* to the nearest watt. The expression for calculating *P2* is as follows:

$$P2 = \frac{P2_x - P_x}{number\ of\ compressors}.$$

f. Shoulder-season per-compressor off mode power, P1: If the system does not have a crankcase heater, has a crankcase heater without controls that is not self-regulating, or has a value for the crankcase heater turn-on temperature (as certified to DOE) that is higher than 71 °F, P1 is equal to P2.

Otherwise, de-energize the crankcase heater (by removing the thermostat bypass or otherwise disconnecting only the power supply to the crankcase heater) and repeat the measurement as described in section 3.13.1.c of this appendix. Designate the measured average power as $P1_x$, the shoulder season total off mode power.

Determine the number of compressors as described in section 3.13.1.e of this appendix.

For single-package systems and blower coil systems for which the designated air mover is not a furnace or modular blower, divide the shoulder season total off mode power ($P1_x$) by the number of compressors to calculate *P1*, the shoulder season per-compressor off mode power. Round *P1* to the nearest watt. The expression for calculating *P1* is as follows:

$$P1 = \frac{P1_x}{number\ of\ compressors}.$$

For coil-only split systems and blower coil split systems for which a furnace or a modular blower is the designated air mover, subtract the low-voltage power (P_x) from the shoulder season total off mode power ($P1_x$) and divide by the number of compressors to calculate *P1*, the shoulder season per-compressor off mode power. Round *P1* to the nearest watt. The expression for calculating *P1* is as follows:

$$P1 = \frac{P1_x - P_x}{number\ of\ compressors}.$$

3.13.2 This Test Determines the Off Mode Average Power Rating for Central Air Conditioners and Heat Pumps for Which Ambient Temperature Can Affect the Measurement of Crankcase Heater Power

a. Test Sample Set-up and Power Measurement: set up the test and measurement as described in section 3.13.1.a of this appendix.

b. Configure Controls: Position a temperature sensor to measure the outdoor dry-bulb temperature in the air between 2 and 6 inches from the crankcase heater control temperature sensor or, if no such temperature sensor exists, position it in the air between 2 and 6 inches from the crankcase heater. Utilize the temperature measurements from this sensor for this portion of the test procedure. Configure the controls of the central air conditioner or heat pump so that it operates as if connected to a building thermostat that is set to the OFF position.

Use a compatible building thermostat if necessary to achieve this configuration.

Conduct the test after completion of the B, B_1, or B_2 test. Alternatively, start the test when the outdoor dry-bulb temperature is at 82 °F and the temperature of the compressor shell (or temperature of each compressor's shell if there is more than one compressor) is at least 81 °F. Then adjust the outdoor temperature and achieve an outdoor dry-bulb temperature of 72 °F. If the unit's compressor has no sound blanket, wait at least 4 hours after the outdoor temperature reaches 72 °F. Otherwise, wait at least 8 hours after the outdoor temperature reaches 72 °F. Maintain this temperature within ±2 °F while the compressor temperature equilibrates and while making the power measurement, as described in section 3.13.2.c of this appendix.

c. Measure $P1_x$: If the unit has a crankcase heater time delay, make sure that time-delay function is disabled or wait until delay time has passed. Determine the average power from non-zero value data measured over a 5-minute interval of the non-operating central air conditioner or heat pump and designate the average power as $P1_x$, the shoulder season total off mode power. For units with crankcase heaters which operate during this part of the test and whose controls cycle or vary crankcase heater power over time, the test period shall consist of three complete crankcase heater cycles or 18 hours, whichever comes first. Designate the average power over the test period as $P1_x$, the shoulder season total off mode power.

d. Reduce outdoor temperature: Approach the target outdoor dry-bulb temperature by adjusting the outdoor temperature. This target temperature is five degrees Fahrenheit less than the temperature certified by the manufacturer as the temperature at which the crankcase heater turns on. If the unit's compressor has no sound blanket, wait at least 4 hours after the outdoor temperature reaches the target temperature. Otherwise, wait at least 8 hours after the outdoor temperature reaches the target temperature. Maintain the target temperature within ±2 °F while the compressor temperature equilibrates and while making the power measurement, as described in section 3.13.2.e of this appendix.

e. Measure $P2_x$: If the unit has a crankcase heater time delay, make sure that time-delay function is disabled or wait until delay time has passed. Determine the average non-zero power of the non-operating central air conditioner or heat pump over a 5-minute interval and designate it as $P2_x$, the heating season total off mode power. For units with crankcase heaters whose controls cycle or vary crankcase heater power over time, the test period shall consist of three complete crankcase heater cycles or 18 hours, whichever comes first. Designate the average power over the test period as $P2_x$, the heating season total off mode power.

f. Measure P_x for coil-only split systems and for blower coil split systems for which a furnace or modular blower is the designated air mover: Disconnect all low-voltage wiring for the *outdoor* components and *outdoor* controls from the low-voltage transformer. Determine the average power from non-zero value data measured over a 5-minute interval of the power supplied to the (remaining) low-voltage components of the central air conditioner or heat pump, or low-voltage power, P_x. This power measurement does not include line power supplied to the outdoor unit. It is the line power supplied to the air mover, or, if a compatible transformer is used instead of an air mover, it is the line power supplied to the transformer primary coil. If a compatible transformer is used instead of an air mover and power output of the low-voltage secondary circuit is measured, P_x is zero.

g. Calculate *P1:*

Set the number of compressors equal to the unit's number of single-stage compressors plus 1.75 times the unit's number of compressors that are not single-stage.

For single-package systems and blower coil split systems for which the air mover is not a furnace or modular blower, divide the shoulder season total off mode power ($P1_x$) by the number of compressors to calculate *P1*, the shoulder season per-compressor off mode power. Round to the nearest watt. The expression for calculating *P1* is as follows:

$$P1 = \frac{P1_x}{number\ of\ compressors}.$$

For coil-only split systems and blower coil split systems for which a furnace or a modular blower is the designated air mover, subtract the low-voltage power (P_x) from the shoulder season total off mode power ($P1_x$) and divide by the number of compressors to calculate *P1*, the shoulder season per-compressor off mode power. Round to the nearest watt. The expression for calculating *P1* is as follows:

$$P1 = \frac{P1_x - P_x}{number\ of\ compressors}.$$

h. Calculate *P2:*

Determine the number of compressors as described in section 3.13.2.g of this appendix.

For, single-package systems and blower coil split systems for which the air mover is not a furnace, divide the heating season total off mode power ($P2_x$) by the number of compressors to calculate *P2*, the heating season per-compressor off mode power. Round to the nearest watt. The expression for calculating *P2* is as follows:

$$P2 = \frac{P2_x}{number\ of\ compressors}.$$

For coil-only split systems and blower coil split systems for which a furnace or a modular blower is the designated air mover, subtract the low-voltage power (P_x) from the heating season total off mode power ($P2_x$) and divide by the number of compressors to calculate *P2*, the heating season per-compressor off mode power. Round to the nearest watt. The expression for calculating *P2* is as follows:

$$P2 = \frac{P2_x - P_x}{number\ of\ compressors}.$$

4 Calculations of Seasonal Performance Descriptors

4.1 Seasonal Energy Efficiency Ratio (SEER2) Calculations

Calculate SEER2 as follows: For equipment covered under sections 4.1.2, 4.1.3, and 4.1.4 of this appendix, evaluate the seasonal energy efficiency ratio,

$$\text{Equation 4.1-1 } SEER2 = \frac{\sum_{j=1}^{8} q_c(T_j)}{\sum_{j=1}^{8} e_c(T_j)} = \frac{\sum_{j=1}^{8} \frac{q_c(T_j)}{N}}{\sum_{j=1}^{8} \frac{e_c(T_j)}{N}}$$

where,

$\frac{q_c(T_j)}{N}$ = the ratio of the total space cooling provided during periods of the space cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season (N), Btu/h.

$\frac{e_c(T_j)}{N}$ = the electrical energy consumed by the test unit during periods of the space cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season (N), W.

T_j = the outdoor bin temperature, °F. Outdoor temperatures are grouped or ''binned.'' Use bins of 5 °F with the 8 cooling season bin temperatures being 67, 72, 77, 82, 87, 92, 97, and 102 °F.

j = the bin number. For cooling season calculations, j ranges from 1 to 8.

Additionally, for sections 4.1.2, 4.1.3, and 4.1.4 of this appendix, use a building cooling load, $BL(T_j)$. When referenced, evaluate $BL(T_j)$ for cooling using,

$$\text{Equation 4.1-2 } BL(T_j) = \frac{(T_j - 65)}{95 - 65} * \frac{\dot{Q}_c^{k=2}(95)}{1.1} * V$$

where:

$\dot{Q}_c^{k=2}(95)$ = the space cooling capacity determined from the A_2 test and calculated as specified in section 3.3 of this appendix, Btu/h.

1.1 = sizing factor, dimensionless.

The temperatures 95 °F and 65 °F in the building load equation represent the selected outdoor design temperature and the zero-load base temperature, respectively.

V is a factor equal to 0.93 for variable-speed heat pumps and otherwise equal to 1.0.

4.1.1 SEER2 Calculations for a Blower Coil System Having a Single-Speed Compressor and Either a Fixed-Speed Indoor Blower or a Constant-Air-Volume-Rate Indoor Blower, or a Single-Speed Coil-Only System Air Conditioner or Heat Pump

a. Evaluate the seasonal energy efficiency ratio, expressed in units of Btu/watt-hour, using:

$SEER2 = PLF(0.5) * EER_B$

where:

$EER_B = \frac{\dot{Q}_c(82)}{\dot{E}_c(82)}$ = the energy efficiency ratio determined from the B test described in sections 3.2.1, 3.1.4.1, and 3.3 of this appendix, Btu/h per watt.

$PLF(0.5) = 1 - 0.5 \cdot C_D^c$, the part-load performance factor evaluated at a cooling load factor of 0.5, dimensionless.

b. Refer to section 3.3 of this appendix regarding the definition and calculation of $\dot{Q}_c(82)$ and $\dot{E}_c(82)$. Evaluate the cooling mode cyclic degradation factor C_D^c as specified in section 3.5.3 of this appendix.

4.1.2 SEER2 Calculations for an Air Conditioner or Heat Pump Having a Single-Speed Compressor and a Variable-Speed Variable-Air-Volume-Rate Indoor Blower

4.1.2.1 Units Covered by Section 3.2.2.1 of This Appendix Where Indoor Blower Capacity Modulation Correlates With the Outdoor Dry Bulb Temperature

The manufacturer must provide information on how the indoor air volume rate or the indoor blower speed varies over the outdoor temperature range of 67 °F to 102 °F. Calculate SEER2 using Equation 4.1–1. Evaluate the quantity $q_c(T_j)/N$ in Equation 4.1–1 using,

Equation 4.1.2-1 $$\frac{q_c(T_j)}{N} = X(T_j) * \dot{Q}_c(T_j) * \frac{n_j}{N}$$

where:

$$X(T_j) = \left\{ \begin{matrix} BL(T_j)/\dot{Q}_c(T_j) \\ or \\ 1 \end{matrix} \right\}$$ whichever is less; the cooling mode load factor for temperature bin j, dimensionless.

$\dot{Q}_c(T_j)$ = the space cooling capacity of the test unit when operating at outdoor temperature, T_j, Btu/h.

n_j/N = fractional bin hours for the cooling season; the ratio of the number of hours during the cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season, dimensionless.

a. For the space cooling season, assign n_j/N as specified in Table 19. Use Equation 4.1–2 to calculate the building load, $BL(T_j)$. Evaluate $\dot{Q}_c(T_j)$ using,

Equation 4.1.2-2 $$\dot{Q}_c(T_j) = \dot{Q}_c^{k=1}(T_j) + \frac{\dot{Q}_c^{k=2}(T_j) - \dot{Q}_c^{k=1}(T_j)}{FP_c^{k=2} - FP_c^{k=1}} * \left[FP_c(T_j) - FP_c^{k=1}\right]$$

where:

$$\dot{Q}_c^{k=1}(T_j) = \dot{Q}_c^{k=1}(82) + \frac{\dot{Q}_c^{k=1}(95) - \dot{Q}_c^{k=1}(82)}{95 - 82} * (T_j - 82)$$

the space cooling capacity of the test unit at outdoor temperature T_j if operated at the cooling minimum air volume rate, Btu/h.

$$\dot{Q}_c^{k=2}(T_j) = \dot{Q}_c^{k=2}(82) + \frac{\dot{Q}_c^{k=2}(95) - \dot{Q}_c^{k=2}(82)}{95 - 82} * (T_j - 82)$$

the space cooling capacity of the test unit at outdoor temperature T_j if operated at the Cooling full-load air volume rate, Btu/h.

b. For units where indoor blower speed is the primary control variable, $FP_c^{k=1}$ denotes the fan speed used during the required A_1 and B_1 tests (see section 3.2.2.1 of this appendix), $FP_c^{k=2}$ denotes the fan speed used during the required A_2 and B_2 tests, and $FP_c(T_j)$ denotes the fan speed used by the unit when the outdoor temperature equals T_j. For units where indoor air volume rate is the primary control variable, the three FP_c's are similarly defined only now being expressed in terms of air volume rates rather than fan speeds. Refer to sections 3.2.2.1, 3.1.4 to 3.1.4.2, and 3.3 of this appendix regarding the definitions and calculations of $\dot{Q}_c^{k=1}(82)$, $\dot{Q}_c^{k=1}(95)$, $\dot{Q}_c^{k=2}(82)$, and $\dot{Q}_c^{k=2}(95)$.

Calculate $e_c(T_j)/N$ in Equation 4.1–1 using, Equation 4.1.2–3

$$\frac{e_c(T_j)}{N} = \frac{X(T_j) * \dot{E}_c(T_j)}{PLF_j} * \frac{n_j}{N}$$

where:

$PLF_j = 1 - C_D^c \cdot [1 - X(T_j)]$, the part load factor, dimensionless.

$\dot{E}_c(T_j)$ = the electrical power consumption of the test unit when operating at outdoor temperature T_j, W.

c. The quantities $X(T_j)$ and n_j/N are the same quantities as used in Equation 4.1.2–1. Evaluate the cooling mode cyclic degradation factor C_D^c as specified in section 3.5.3 of this appendix.

d. Evaluate $\dot{E}_c(T_j)$ using,

$$\dot{E}_c(T_j) = \dot{E}_c^{k=1}(T_j) + \frac{\dot{E}_c^{k=2}(T_j) - \dot{E}_c^{k=1}(T_j)}{\mathrm{FP}_c^{k=2} - \mathrm{FP}_c^{k=1}} * \left[\mathrm{FP}_c(T_j) - \mathrm{FP}_c^{k=1}\right]$$

where:

$$\dot{E}_c^{k=1}(T_j) = \dot{E}_c^{k=1}(82) + \frac{\dot{E}_c^{k=1}(95) - \dot{E}_c^{k=1}(82)}{95 - 82} * (T_j - 82)$$

the electrical power consumption of the test unit at outdoor temperature T_j if operated at the cooling minimum air volume rate, W.

$\dot{E}_c^{k=2}(T_j) = \dot{E}_c^{k=2}(82) + \frac{\dot{E}_c^{k=2}(95) - \dot{E}_c^{k=2}(82)}{95-82} * (T_j - 82)$ the electrical power consumption of the test unit at outdoor temperature T_j if operated at the cooling full-load air volume rate, W.

e. The parameters $FP_c^{k=1}$, and $FP_c^{k=2}$, and $FP_c(T_j)$ are the same quantities that are used when evaluating Equation 4.1.2–2. Refer to sections 3.2.2.1, 3.1.4 to 3.1.4.2, and 3.3 of this

appendix regarding the definitions and calculations of $\dot{E}_c^{k=1}(82)$, $\dot{E}_c^{k=1}(95)$, $\dot{E}_c^{k=2}(82)$, and $\dot{E}_c^{k=2}(95)$.

4.1.2.2 Units Covered by Section 3.2.2.2 of This Appendix Where Indoor Blower Capacity Modulation is Used to Adjust the Sensible to Total Cooling Capacity Ratio

Calculate SEER2 as specified in section 4.1.1 of this appendix.

4.1.3 SEER2 Calculations for an Air Conditioner or Heat Pump Having a Two-Capacity Compressor

Calculate SEER2 using Equation 4.1–1. Evaluate the space cooling capacity, $\dot{Q}_c^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=1}(T_j)$, of the test unit when operating at low compressor capacity and outdoor temperature T_j using,

$$\text{Equation 4.1.3-1} \quad \dot{Q}_c^{k=1}(T_j) = \dot{Q}_c^{k=1}(67) + \frac{\dot{Q}_c^{k=1}(82) - \dot{Q}_c^{k=1}(67)}{82-67} * (T_j - 67)$$

$$\text{Equation 4.1.3-2} \quad \dot{E}_c^{k=1}(T_j) = \dot{E}_c^{k=1}(67) + \frac{\dot{E}_c^{k=1}(82) - \dot{E}_c^{k=1}(67)}{82-67} * (T_j - 67)$$

where $\dot{Q}_c^{k=1}(82)$ and $\dot{E}_c^{k=1}(82)$ are determined from the B_1 test, $\dot{Q}_c^{k=1}(67)$ and $\dot{E}_c^{k=1}(67)$ are determined from the F_1 test, and all four quantities are calculated as specified in section 3.3 of this appendix. Evaluate the space cooling capacity, $\dot{Q}_c^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=2}(T_j)$, of the test unit when operating at high compressor capacity and outdoor temperature T_j using,

$$\text{Equation 4.1.3-3} \quad \dot{Q}_c^{k=2}(T_j) = \dot{Q}_c^{k=2}(82) + \frac{\dot{Q}_c^{k=2}(95) - \dot{Q}_c^{k=2}(82)}{95-82} * (T_j - 82)$$

$$\text{Equation 4.1.3-4} \quad \dot{E}_c^{k=2}(T_j) = \dot{E}_c^{k=2}(82) + \frac{\dot{E}_c^{k=2}(95) - \dot{E}_c^{k=2}(82)}{95-82} * (T_j - 82)$$

where $\dot{Q}_c^{k=2}(95)$ and $\dot{E}_c^{k=2}(95)$ are determined from the A_2 test, $\dot{Q}_c^{k=2}(82)$, and $\dot{E}_c^{k=2}(82)$, are determined from the B_2 test, and all are calculated as specified in section 3.3 of this appendix.

The calculation of Equation 4.1–1 quantities $q_c(T_j)/N$ and $e_c(T_j)/N$ differs depending on whether the test unit would operate at low capacity (section 4.1.3.1 of this appendix), cycle between low and high capacity (section 4.1.3.2 of this appendix), or operate at high capacity (sections 4.1.3.3 and 4.1.3.4 of this appendix) in responding to the building load. For units that lock out low capacity operation at higher outdoor temperatures, the outdoor temperature at which the unit locks out must be that specified by the manufacturer in the certification report so that the appropriate equations are used. Use Equation 4.1–2 to calculate the building load, $BL(T_j)$, for each temperature bin.

4.1.3.1 Steady-state Space Cooling Capacity at Low Compressor Capacity Is Greater Than or Equal to the Building Cooling Load at Temperature T_j, $\dot{Q}_c^{k=1}(T_j) \geq BL(T_j)$

$$\frac{q_c(T_j)}{N} = X^{k=1}(T_j) * \dot{Q}_c^{k=1}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \frac{X^{k=1}(T_j) * \dot{E}_c^{k=1}(T_j)}{PLF_j} * \frac{n_j}{N}$$

Where:

$X^{k=1}(T_j) = BL(T_j)/\dot{Q}_c^{k=1}(T_j)$, the cooling mode low capacity load factor for temperature bin j, dimensionless.

$PLF_j = 1 - C_D^c \cdot [1 - X^{k=1}(T_j)]$, the part load factor, dimensionless.

n_j/N = fractional bin hours for the cooling season; the ratio of the number of hours during the cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season, dimensionless.

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19. Use Equations 4.1.3–1 and 4.1.3–2, respectively, to evaluate $\dot{Q}_c^{k=1}(T_j)$ and $\dot{E}_c^{k=1}(T_j)$. Evaluate the cooling mode cyclic degradation factor C_D^c as specified in section 3.5.3 of this appendix.

TABLE 19—DISTRIBUTION OF FRACTIONAL HOURS WITHIN COOLING SEASON TEMPERATURE BINS

Bin number, j	Bin temperature range °F	Representative temperature for bin °F	Fraction of total temperature bin hours, n_j/N
1	65–69	67	0.214
2	70–74	72	0.231
3	75–79	77	0.216

TABLE 19—DISTRIBUTION OF FRACTIONAL HOURS WITHIN COOLING SEASON TEMPERATURE BINS—Continued

Bin number, j	Bin temperature range °F	Representative temperature for bin °F	Fraction of total temperature bin hours, n_j/N
4	80–84	82	0.161
5	85–89	87	0.104
6	90–94	92	0.052
7	95–99	97	0.018
8	100–104	102	0.004

4.1.3.2 Unit Alternates Between High (k=2) and Low (k=1) Compressor Capacity to Satisfy the Building Cooling Load at Temperature T_j, $\dot{Q}_c^{k=1}(T_j) < BL(T_j) < \dot{Q}_c^{k=2}(T_j)$

$$\frac{q_c(T_j)}{N} = [X^{k=1}(T_j) * \dot{Q}_c^{k=1}(T_j) + X^{k=2}(T_j) * \dot{Q}_c^{k=2}(T_j)] * \frac{n_j}{N}$$

$$\frac{e_c(T_j)}{N} = [X^{k=1}(T_j) * \dot{E}_c^{k=1}(T_j) + X^{k=2}(T_j) * \dot{E}_c^{k=2}(T_j)] * \frac{n_j}{N}$$

Where:

$X^{k=1}(T_j) = \frac{\dot{Q}_c^{k=2}(T_j) - BL(T_j)}{\dot{Q}_c^{k=2}(T_j) - \dot{Q}_c^{k=1}(T_j)}$ the cooling mode, low capacity load factor for temperature bin j, dimensionless.

$X^{k=2}(T_j) = 1 - X^{k=1}(T_j)$, the cooling mode, high capacity load factor for temperature bin j, dimensionless.

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19. Use Equations 4.1.3–1 and 4.1.3–2, respectively, to evaluate $\dot{Q}_c^{k=1}(T_j)$ and $\dot{E}_c^{k=1}(T_j)$. Use Equations 4.1.3–3 and 4.1.3–4, respectively, to evaluate $\dot{Q}_c^{k=2}(T_j)$ and $\dot{E}_c^{k=2}(T_j)$.

4.1.3.3 Unit Only Operates at High (k=2) Compressor Capacity at Temperature T_j and Its Capacity Is Greater Than the Building Cooling Load, $BL(T_j) < \dot{Q}_c^{k=2}(T_j)$. This section applies to units that lock out low compressor capacity operation at higher outdoor temperatures.

$$\frac{q_c(T_j)}{N} = X^{k=2}(T_j) * \dot{Q}_c^{k=2}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \frac{X^{k=2}(T_j) * \dot{E}_c^{k=2}(T_j)}{PLF_j} * \frac{n_j}{N}$$

Where,

$X^{k=2}(T_j) = BL(T_j)/\dot{Q}_c^{k=2}(T_j)$, the cooling mode high capacity load factor for temperature bin j, dimensionless.

$PLF_j = 1 - C_D{}^c(k = 2) * [1 - X^{k=2}(T_j)]$, the part load factor, dimensionless.

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19. Use Equations 4.1.3–3 and 4.1.3–4, respectively, to evaluate $\dot{Q}_c^{k=2}(T_j)$ and $\dot{E}_c^{k=2}(T_j)$. If the C_2 and D_2 tests described in section 3.2.3 and Table 7 of this appendix are not conducted, set $C_D{}^c$

(k=2) equal to the default value specified in section 3.5.3 of this appendix.

4.1.3.4 Unit Must Operate Continuously at High (k=2) Compressor Capacity at Temperature T_j, $BL(T_j) \geq \dot{Q}_c^{k=2}(T_j)$

$$\frac{q_c(T_j)}{N} = \dot{Q}_c^{k=2}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \dot{E}_c^{k=2}(T_j) * \frac{n_j}{N}$$

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19. Use Equations 4.1.3–3 and 4.1.3–4, respectively, to evaluate $\dot{Q}_c^{k=2}(T_j)$ and $\dot{E}_c^{k=2}(T_j)$.

4.1.4 SEER2 Calculations for an Air Conditioner or Heat Pump Having a Variable-Speed Compressor

Calculate SEER2 using Equation 4.1–1 to this appendix. Evaluate the space cooling capacity, $Q_c^{k=1}(T_j)$, and electrical power consumption, $E_c^{k=1}(T_j)$, of the test unit when operating at minimum compressor speed and outdoor temperature T_j. Use:

Equation 4.1.4-1 $$\dot{Q}_c^{k=1}(T_j) = \dot{Q}_c^{k=1}(67) + \frac{\dot{Q}_c^{k=1}(82) - \dot{Q}_c^{k=1}(67)}{82-67} * (T_j - 67)$$

Equation 4.1.4-2 $$\dot{E}_c^{k=1}(T_j) = \dot{E}_c^{k=1}(67) + \frac{\dot{E}_c^{k=1}(82) - \dot{E}_c^{k=1}(67)}{82-67} * (T_j - 67)$$

Where $\dot{Q}_c^{k=1}(82)$ and $\dot{E}_c^{k=1}(82)$ are determined from the B_1 test, $\dot{Q}_c^{k=1}(67)$ and $E_c^{k=1}(67)$ are determined from the F_1 test, and all four quantities are calculated as specified in section 3.3 of this appendix. Evaluate the space cooling capacity, $\dot{Q}_c^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=2}(T_j)$, of the test unit when operating at full compressor speed and outdoor temperature T_j. Use Equations 4.1.3–3 and 4.1.3–4 to this appendix, respectively, where $\dot{Q}_c^{k=2}(95)$ and $\dot{E}_c^{k=2}(95)$ are determined from the A_2 test, $\dot{Q}_c^{k=2}(82)$ and $\dot{E}_c^{k=2}(82)$ are determined from the B_2 test, and all four quantities are calculated as specified in section 3.3 of this appendix. For units other than variable-speed non-communicating coil-only air-conditioners or heat pumps, calculate the space cooling capacity, $\dot{Q}_c^{k=v}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=v}(T_j)$, of the test unit when operating at outdoor temperature T_j and the intermediate compressor speed used during the section 3.2.4 (and Table 8) E_v test of this appendix using:

Equation 4.1.4-3 $$\dot{Q}_c^{k=v}(T_j) = \dot{Q}_c^{k=v}(87) + M_Q * (T_j - 87)$$

Equation 4.1.4-4 $$\dot{E}_c^{k=v}(T_j) = \dot{E}_h^{k=v}(87) + M_E * (T_j - 87)$$

Where $\dot{Q}_c^{k=v}(87)$ are determined from the E_v test and calculated as specified in section 3.3 of this appendix. Approximate the slopes of the k=v intermediate speed cooling capacity and electrical power input curves, M_Q and M_E, as follows:

$$M_Q = \left[\frac{\dot{Q}_c^{k=1}(82) - \dot{Q}_c^{k=1}(67)}{82-67} * (1 - N_Q)\right] + \left[N_Q * \frac{\dot{Q}_c^{k=2}(95) - \dot{Q}_c^{k=2}(82)}{95-82}\right]$$

$$M_E = \left[\frac{\dot{E}_c^{k=1}(82) - \dot{E}_c^{k=1}(67)}{82-67} * (1 - N_E)\right] + \left[N_E * \frac{\dot{E}_c^{k=2}(95) - \dot{E}_c^{k=2}(82)}{95-82}\right]$$

Where:

$$N_Q = \frac{\dot{Q}_c^{k=v}(87) - \dot{Q}_c^{k=1}(87)}{\dot{Q}_c^{k=2}(87) - \dot{Q}_c^{k=1}(87)} \text{ and } N_E = \frac{\dot{E}_c^{k=v}(87) - \dot{E}_c^{k=1}(87)}{\dot{E}_c^{k=2}(87) - \dot{E}_c^{k=1}(87)}$$

Use Equations 4.1.4–1 and 4.1.4–2 to this appendix, respectively, to calculate $\dot{Q}_c^{k=1}(87)$ and $\dot{E}_c^{k=1}(87)$.

4.1.4.1 Steady-state space cooling capacity when operating at minimum compressor speed is greater than or equal to the building cooling load at temperature T_j, $\dot{Q}_c^{k=l}(T_j) \geq BL(T_j)$.

$$\frac{q_c(T_j)}{N} = X^{k=1}(T_j) * \dot{Q}_c^{k=1}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \frac{X^{k=1}(T_j) * \dot{E}_c^{k=1}(T_j)}{PLF_j} * \frac{n_j}{N}$$

Where:

$X^{k=l}(T_j) = BL(T_j)/\dot{Q}_c^{k=l}(T_j)$, the cooling mode minimum speed load factor for temperature bin j, dimensionless.

$PLF_j = 1 - C_D^c \cdot [1 - X^{k=l}(T_j)]$, the part load factor, dimensionless.

n_j/N = fractional bin hours for the cooling season; the ratio of the number of hours during the cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season, dimensionless.

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19. Use Equations 4.1.3–1 and 4.1.3–2, respectively, to evaluate $\dot{Q}_c^{k=1}(T_j)$ and $\dot{E}_c^{k=1}(T_j)$. Evaluate the cooling mode cyclic degradation factor C_D^c as specified in section 3.5.3 of this appendix.

4.1.4.2 Unit operates at an intermediate compressor speed (k=i) in order to match the building cooling load at temperature T_j, $\dot{Q}_c^{k=l}(T_j) < BL(T_j) < \dot{Q}_c^{k=2}(T_j)$.

$$\frac{q_c(T_j)}{N} = \dot{Q}_c^{k=i}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \dot{E}_c^{k=i}(T_j) * \frac{n_j}{N}$$

Where:

$\dot{Q}_c^{k=i}(T_j) = BL(T_j)$, the space cooling capacity delivered by the unit in matching the building load at temperature T_j, Btu/h. The matching occurs with the unit operating at compressor speed k = i.

$\dot{E}_c^{k=i}(T_j) = \frac{\dot{Q}_c^{k=i}(T_j)}{EER^{k=i}(T_j)}$ the electrical power input required by the test unit when operating at a compressor speed of k = i and temperature T_j, W.

$EER^{k=i}(T_j)$ = the steady-state energy efficiency ratio of the test unit when operating at a compressor speed of k = i and temperature T_j, Btu/h per W.

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19 of this section. For each temperature bin where the unit operates at an intermediate compressor speed, determine the energy efficiency ratio $EER^{k=i}(T_j)$ using the following equations,

For each temperature bin where $\dot{Q}_c^{k=1}(T_j) < BL(T_j) < \dot{Q}_c^{k=v}(T_j)$,

$$EER^{k=i}(T_j) = EER^{k=1}(T_j) + \frac{EER^{k=v}(T_j) - EER^{k=1}(T_j)}{Q^{k=v}(T_j) - Q^{k=1}(T_j)} * (BL(T_j) - Q^{k=1}(T_j))$$

For each temperature bin where $\dot{Q}_c^{k=v}(T_j) \leq BL(T_j) < \dot{Q}_c^{k=2}(T_j)$,

$$EER^{k=i}(T_j) = EER^{k=v}(T_j) + \frac{EER^{k=2}(T_j) - EER^{k=v}(T_j)}{Q^{k=2}(T_j) - Q^{k=v}(T_j)} * (BL(T_j) - Q^{k=v}(T_j))$$

Where:

$EER^{k=1}(T_j)$ is the steady-state energy efficiency ratio of the test unit when operating at minimum compressor speed and temperature Tj, Btu/h per W, calculated using capacity $\dot{Q}_c^{k=1}(T_j)$ calculated using Equation 4.1.4–1 and electrical power consumption $\dot{E}_c^{k=1}(T_j)$ calculated using Equation 4.1.4–2;

$EER^{k=v}(T_j)$ is the steady-state energy efficiency ratio of the test unit when operating at intermediate compressor speed and temperature Tj, Btu/h per W, calculated using capacity $\dot{Q}_c^{k=v}(T_j)$ calculated using Equation 4.1.4–3 and electrical power consumption $\dot{E}_c^{k=v}(T_j)$ calculated using Equation 4.1.4–4;

$EER^{k=2}(T_j)$ is the steady-state energy efficiency ratio of the test unit when operating at full compressor speed and temperature Tj, Btu/h per W, calculated using capacity $\dot{Q}_c^{k=2}(T_j)$ and electrical power consumption $\dot{E}_c^{k=2}(T_j)$, both calculated as described in section 4.1.4; and

$BL(T_j)$ is the building cooling load at temperature T_j, Btu/h.

4.1.4.2.1 Units That Are Not Variable-Speed Non-Communicating Coil-Only Air Conditioners or Heat Pumps

If the unit operates at an intermediate compressor speed (k=i) in order to match the building cooling load at temperature T_j, $\dot{Q}_c^{k=1}(T_j) < BL(T_j) < \dot{Q}_c^{k=2}(T_j)$.

$$\frac{q_c(T_j)}{N} = \dot{Q}_c^{k=i}(T_j) * \frac{n_j}{N} \quad \frac{e_c(T_j)}{N} = \dot{E}_c^{k=i}(T_j) * \frac{n_j}{N}$$

Where:

$\dot{Q}_c^{k=i}(T_j) = BL(T_j)$, the space cooling capacity delivered by the unit in matching the building load at temperature T_j, in Btu/h. The matching occurs with the unit operating at compressor speed k = i.

$\dot{E}_c^{k=i}(T_j) = \frac{\dot{Q}_c^{k=i}(T_j)}{EER^{k=i}(T_j)}$ the electrical power input required by the test unit when operating at a compressor speed of k = i and temperature T_j, in W.

$EER^{k=i}(T_j)$ = the steady-state energy efficiency ratio of the test unit when operating at a compressor speed of k = i and temperature T_j, Btu/h per W.

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19 of this section. For each temperature bin where the unit operates at an intermediate compressor speed, determine the energy efficiency ratio $EER^{k=i}(T_j)$ using the following equations:

For each temperature bin where $\dot{Q}_c^{k=1}(T_j) < BL(T_j) < \dot{Q}_c^{k=v}(T_j)$,

$$EER^{k=i}(T_j) = EER^{k=1}(T_j) + \frac{EER^{k=v}(T_j) - EER^{k=1}(T_j)}{Q^{k=v}(T_j) - Q^{k=1}(T_j)} * (BL(T_j) - Q^{k=1}(T_j))$$

For each temperature bin where $\dot{Q}_c^{k=v}(T_j) < BL(T_j) < \dot{Q}_c^{k=2}(T_j)$,

$$EER^{k=i}(T_j) = EER^{k=v}(T_j) + \frac{EER^{k=2}(T_j) - EER^{k=v}(T_j)}{Q^{k=2}(T_j) - Q^{k=v}(T_j)} * (BL(T_j) - Q^{k=v}(T_j))$$

Where:

$EER^{k=1}(T_j)$ is the steady-state energy efficiency ratio of the test unit when operating at minimum compressor speed and temperature Tj, in Btu/h per W, calculated using capacity $\dot{Q}_c^{k=1}(T_j)$ calculated using Equation 4.1.4–1 to this appendix and electrical power consumption $\dot{E}_c^{k=1}(T_j)$ calculated using Equation 4.1.4–2 to this appendix;

$EER^{k=v}(T_j)$ is the steady-state energy efficiency ratio of the test unit when operating at intermediate compressor speed and temperature Tj, in Btu/h per W, calculated using capacity $\dot{Q}_c^{k=v}(T_j)$ calculated using Equation 4.1.4–3 to this appendix and electrical power consumption $\dot{E}_c^{k=v}(T_j)$ calculated using Equation 4.1.4–4 to this appendix;

$EER^{k=2}(T_j)$ is the steady-state energy efficiency ratio of the test unit when operating at full compressor speed and temperature Tj, Btu/h per W, calculated using capacity $\dot{Q}_c^{k=2}(T_j)$ and electrical power consumption $\dot{E}_c^{k=2}(T_j)$, both calculated as described in section 4.1.4 of this appendix; and

$BL(T_j)$ is the building cooling load at temperature T_j, Btu/h.

4.1.4.2.2 Variable-Speed Non-Communicating Coil-Only Air Conditioners or Heat Pumps

If the unit alternates between high (k=2) and low (k=1) compressor capacity to satisfy the building cooling load at temperature T_j, $\dot{Q}_c^{k=1}(T_j) < BL(T_j) < \dot{Q}_c^{k=2}(T_j)$.

$$\frac{q_c(T_j)}{N} = [X^{k=1}(T_j) * \dot{Q}_c^{k=1}(T_j) + X^{k=2}(T_j) * \dot{Q}_c^{k=2}(T_j)] * \frac{n_j}{N}$$

$$\frac{e_c(T_j)}{N} = [X^{k=1}(T_j) * \dot{E}_c^{k=1}(T_j) + X^{k=2}(T_j) * \dot{E}_c^{k=2}(T_j)] * \frac{n_j}{N}$$

Where:

$X^{k=1}(T_j) = \frac{\dot{Q}_c^{k=2}(T_j) - BL(T_j)}{\dot{Q}_c^{k=2}(T_j) - \dot{Q}_c^{k=1}(T_j)}$ the cooling mode, low capacity load factor for

the cooling mode, low capacity load factor for temperature bin j (dimensionless); and $X^{k=2}(T_j) = 1 - X^{k=1}(T_j)$, the cooling mode, high capacity load factor for temperature bin j (demensionless).

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 19 to this appendix. Obtain $\dot{Q}_c^{k=1}(T_j)$, $\dot{E}_c^{k=1}(T_j)$, $\dot{Q}_c^{k=2}(T_j)$, and $\dot{E}_c^{k=2}(T_j)$ as described in section 4.1.4 of this appendix.

4.1.4.3 Unit must operate continuously at full (k=2) compressor speed at temperature Tj, $BL(T_j) \geq \dot{Q}_c^{k=2}(T_j)$. Evaluate the Equation 4.1–1 quantities

$$\frac{q_c(T_j)}{N} \text{ and } \frac{e_c(T_j)}{N}$$

as specified in section 4.1.3.4 of this appendix with the understanding that $\dot{Q}_c^{k=2}(T_j)$ and $\dot{E}_c^{k=2}(T_j)$ correspond to full compressor speed operation and are derived from the results of the tests specified in section 3.2.4 of this appendix.

4.1.5 SEER2 Calculations for an Air Conditioner or Heat Pump Having a Single Indoor Unit With Multiple Indoor Blowers

Calculate SEER2 using Eq. 4.1–1, where $q_c(Tj)/N$ and $e_c(Tj)/N$ are evaluated as specified in the applicable subsection.

4.1.5.1 For Multiple Indoor Blower Systems That Are Connected to a Single, Single-Speed Outdoor Unit

a. Calculate the space cooling capacity, $\dot{Q}_c^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=1}(T_j)$, of the test unit when operating at the cooling minimum air volume rate and outdoor temperature T_j using the equations given in section 4.1.2.1 of this appendix. Calculate the space cooling capacity, $\dot{Q}_c^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=2}(T_j)$, of the test unit when operating at the cooling full-load air volume rate and outdoor temperature T_j using the equations given in section 4.1.2.1 of this appendix. In evaluating the section 4.1.2.1 equations, determine the quantities $\dot{Q}_c^{k=1}(82)$ and $\dot{E}_c^{k=1}(82)$ from the B1 test, $\dot{Q}_c^{k=1}(95)$ and $\dot{E}_c^{k=1}(95)$ from the A1 test, $\dot{Q}_c^{k=2}(82)$ and $\dot{E}_c^{k=2}(82)$ from the B2 test, and $\dot{Q}_c^{k=2}(95)$ and $\dot{E}_c^{k=2}(95)$ from the A_2 test. Evaluate all eight quantities as specified in section 3.3. Refer to section 3.2.2.1 and Table 6 for additional information on the four referenced laboratory tests.

b. Determine the cooling mode cyclic degradation coefficient, C_D^c, as per sections 3.2.2.1 and 3.5 to 3.5.3 of this appendix. Assign this same value to $C_D^c(K=2)$.

c. Except for using the above values of $\dot{Q}_c^{k=1}(T_j)$, $\dot{E}_c^{k=1}(T_j)$, $\dot{E}_c^{k=2}(T_j)$, $\dot{Q}_c^{k=2}(T_j)$, C_D^c, and C_D^c (K=2), calculate the quantities $q_c(T_j)/N$ and $e_c(T_j)/N$ as specified in section 4.1.3.1 of this appendix for cases where $\dot{Q}_c^{k=1}(T_j) \geq BL(T_j)$. For all other outdoor bin temperatures, T_j, calculate $q_c(Tj)/N$ and $e_c(Tj)/N$ as specified in section 4.1.3.3 of this appendix if $\dot{Q}_c^{k=2}(T_j) > BL(T_j)$ or as specified in section 4.1.3.4 of this appendix if $\dot{Q}_c^{k=2}(T_j) \leq BL(T_j)$.

4.1.5.2 For Multiple Indoor Blower Systems That Are Connected to Either a Lone Outdoor Unit Having a Two-Capacity Compressor or Two Separate But Identical Model Single-Speed Outdoor Units. Calculate the Quantities $q_c(Tj)/N$ and $e_c(Tj)/N$ as Specified in Section 4.1.3 of This Appendix

4.2 Heating Seasonal Performance Factor 2 (HSPF2) Calculations

Unless an approved alternative efficiency determination method is used, as set forth in 10 CFR 429.70(e). Calculate HSPF2 as follows: Six generalized climatic regions are depicted in Figure 1 and otherwise defined in Table 20. For each of these regions and for each applicable standardized design heating requirement, evaluate the heating seasonal performance factor using,

Equation 4.2-1

$$HSPF2 = \frac{\sum_j^J n_{j*BL(T_j)}}{\sum_j^J e_h(T_j) + \sum_j^J RH(T_j)} * F_{def} = \frac{\sum_j^J \left[\frac{n_j}{N} * BL(T_j)\right]}{\sum_j^J \frac{e_h(T_j)}{N} + \sum_j^J \frac{RH(T_j)}{N}} * F_{def}$$

Where:

$e_h(T_j)/N$ = The ratio of the electrical energy consumed by the heat pump during periods of the heating season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the heating season (N), W. For heat pumps having a heat comfort controller, this ratio may also

include electrical energy used by resistive elements to maintain a minimum air delivery temperature (see 4.2.5).

$RH(T_j)/N$ = The ratio of the electrical energy used for resistive space heating during periods when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the heating season (N), W. Except as noted in section 4.2.5 of this appendix, resistive space heating is modeled as being used to meet that portion of the building load that the heat pump does not meet because of insufficient capacity or because the heat pump automatically turns off at the lowest outdoor temperatures. For heat pumps having a heat comfort controller, all or part of the electrical energy used by resistive heaters at a particular bin temperature may be reflected in $e_h(T_j)/N$ (see section 4.2.5 of this appendix).

T_j = the outdoor bin temperature, °F. Outdoor temperatures are ''binned'' such that calculations are only performed based one temperature within the bin. Bins of 5 °F are used.

n_j/N = Fractional bin hours for the heating season; the ratio of the number of hours during the heating season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the heating season, dimensionless. Obtain n_j/N values from Table 20.

j = the bin number, dimensionless.

J = for each generalized climatic region, the total number of temperature bins, dimensionless. Referring to Table 20, J is the highest bin number (j) having a nonzero entry for the fractional bin hours for the generalized climatic region of interest.

F_{def} = the demand defrost credit described in section 3.9.2 of this appendix, dimensionless.

$BL(T_j)$ = the building space conditioning load corresponding to an outdoor temperature of T_j; the heating season building load also depends on the generalized climatic region's outdoor design temperature and the design heating requirement, Btu/h.

TABLE 20—GENERALIZED CLIMATIC REGION INFORMATION

Region Number	I	II	III	IV	V	*VI
Heating Load Hours, HLH	493	857	1247	1701	2202	1842
Outdoor Design Temperature, T_{OD}	37	27	17	5	−10	30
Heating Load Line Equation Slope Factor, C	1.10	1.06	1.30	1.15	1.16	1.11
Variable-speed Slope Factor, C_{VS}	1.03	0.99	1.21	1.07	1.08	1.03
Zero-Load Temperature, T_{zl}	58	57	56	55	55	57
j T_j (°F)	Fractional Bin Hours, n_j/N					
1 62	0	0	0	0	0	0
2 57	.239	0	0	0	0	0
3 52	.194	.163	.138	.103	.086	.215
4 47	.129	.143	.137	.093	.076	.204
5 42	.081	.112	.135	.100	.078	.141
6 37	.041	.088	.118	.109	.087	.076
7 32	.019	.056	.092	.126	.102	.034
8 27	.005	.024	.047	.087	.094	.008
9 22	.001	.008	.021	.055	.074	.003
10 17	0	.002	.009	.036	.055	0
11 12	0	0	.005	.026	.047	0
12 7	0	0	.002	.013	.038	0
13 2	0	0	.001	.006	.029	0
14 −3	0	0	0	.002	.018	0
15 −8	0	0	0	.001	.010	0
16 −13	0	0	0	0	.005	0
17 −18	0	0	0	0	.002	0
18 −23	0	0	0	0	.001	0

*Pacific Coast Region.

Evaluate the building heating load using:

$$\text{Equation 4.2-2} \quad BL(T_j) = \frac{T_{zl} - T_j}{T_{zl} - 5°\text{F}} * C * \dot{Q}_c(95°\text{F})$$

Where:

T_j = the outdoor bin temperature, °F;

T_{zl} = the zero-load temperature, °F, which varies by climate region according to Table 20 to this appendix;

C = slope (adjustment) factor, which varies by climate region according to Table 20 to this appendix. When calculating building load for a variable-speed compressor system, substitute C_{VS} for C;

$Q_c(95\ °F)$ = the cooling capacity at 95 °F determined from the A or A_2 test, Btu/h. For heating-only heat pump units, replace $Q_c(95\ °F)$ in Equation 4.2–2 with $Q_h(47\ °F)$;

$Q_h(47\ °F)$ = the heating capacity at 47 °F determined from the H1 test for units having a single-speed compressor, $H1_2$ for units having a two-capacity compressor, and $H1_N$ test for units having a variable-speed compressor, Btu/h.

a. For all heat pumps, HSPF2 accounts for the heating delivered and the energy consumed by auxiliary resistive elements when operating below the balance point. This condition occurs when the building load exceeds the space heating capacity of the heat pump condenser. For HSPF2 calculations for all heat pumps, see either section 4.2.1, 4.2.2, 4.2.3, or 4.2.4 of this appendix, whichever applies.

b. For heat pumps with heat comfort controllers (see section 1.2 of this appendix, Definitions), HSPF2 also accounts for resistive heating contributed when operating above the heat-pump-plus-comfort-controller balance point as a result of maintaining a minimum supply temperature. For heat pumps having a heat comfort controller, see section 4.2.5 of this appendix for the additional steps required for calculating the HSPF2.

4.2.1 Additional Steps for Calculating the HSPF2 of a Blower Coil System Heat Pump Having a Single-Speed Compressor and Either a Fixed-Speed Indoor Blower or a Constant-Air-Volume-Rate Indoor Blower, or a Single-Speed Coil-Only System Heat Pump

Equation 4.2.1-1

$$\frac{e_h(T_j)}{N} = \frac{X(T_j) * \dot{E}_h(T_j) * \delta(T_j)}{PLF_j} * \frac{n_j}{N}$$

Equation 4.2.1-2

$$\frac{RH(T_j)}{N} = \frac{BL(T_j) - [X(T_j) * \dot{Q}_h(T_j) * \delta(T_j)]}{3.413 \frac{Btu/h}{W}} * \frac{n_j}{N}$$

Where:

$$X(T_j) = \begin{Bmatrix} BL(T_j)/\dot{Q}_h(T_j) \\ or \\ 1 \end{Bmatrix}$$

whichever is less; the heating mode load factor for temperature bin j, dimensionless.

$\dot{Q}_h(T_j)$ = the space heating capacity of the heat pump when operating at outdoor temperature T_j, Btu/h.

$\dot{E}_h(T_j)$ = the electrical power consumption of the heat pump when operating at outdoor temperature T_j, W.

$\delta(T_j)$ = the heat pump low temperature cut-out factor, dimensionless.

$PLF_j = 1 - \dot{C}_D{}^h \cdot [1 - X(T_j)]$ the part load factor, dimensionless.

Use Equation 4.2–2 to determine $BL(T_j)$. Obtain fractional bin hours for the heating season, n_j/N, from Table 20. Evaluate the heating mode cyclic degradation factor $C_D{}^h$ as specified in section 3.8.1 of this appendix.

Determine the low temperature cut-out factor using

Equation 4.2.1-3 $$\delta(T_j) = \begin{cases} 0, if\ T_j \le T_{off}\ or\ \frac{\dot{Q}_h(T_j)}{3.413*\dot{E}_h(T_j)} < 1 \\ 1/2\,, if\ T_{off} < T_j \le T_{on}\ and\ \frac{\dot{Q}_h(T_j)}{3.413*\dot{E}_h(T_j)} \ge 1 \\ 1, if\ T_j > T_{on}\ and\ \frac{\dot{Q}_h(T_j)}{3.413*\dot{E}_h(T_j)} \ge 1 \end{cases}$$

Where:

T_{off} = the outdoor temperature when the compressor is automatically shut off, °F. (If no such temperature exists, T_j is always greater than T_{off} and T_{on}).

T_{on} = the outdoor temperature when the compressor is automatically turned back on, if applicable, following an automatic shut-off, °F.

If the H4 test is not conducted, calculate $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using

Equation 4.2.1-4 $$\dot{Q}_h(T_j) = \begin{cases} \dot{Q}_h(17) + \frac{[\dot{Q}_h(47) - \dot{Q}_h(17)]*(T_j - 17)}{47-17},\ if\ T_j \ge 45\ °\text{F}\ or\ T_j \le 17\ °\text{F} \\ \dot{Q}_h(17) + \frac{[\dot{Q}_h(35) - \dot{Q}_h(17)]*(T_j - 17)}{35-17},\ if\ 17\ °\text{F} < T_j < 45\ °\text{F} \end{cases}$$

Equation 4.2.1-5

$$\dot{E}_h(T_j) = \begin{cases} \dot{E}_h(17) + \frac{\left[\dot{E}_h(47) - \dot{E}_h(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j \ge 45\ °\text{F}\ or\ T_j \le 17\ °\text{F} \\ \dot{E}_h(17) + \frac{\left[\dot{E}_h(35) - \dot{E}_h(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} < T_j < 45\ °\text{F} \end{cases}$$

where $\dot{Q}_h(47)$ and $\dot{E}_h(47)$ are determined from the H1 test and calculated as specified in section 3.7 of this appendix; $\dot{Q}_h(35)$ and $\dot{E}_h(35)$ are determined from the H2 test and calculated as specified in section 3.9.1 of this appendix; and $\dot{Q}_h(17)$ and $\dot{E}_h(17)$ are determined from the H3 test and calculated as specified in section 3.10 of this appendix.

If the H4 test is conducted, calculate $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using

Equation 4.2.1-6

$$\dot{Q}_h\,(T_j) = \begin{cases} \dot{Q}_h(17) + \frac{\left[\dot{Q}_h(47) - \dot{Q}_h(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j \ge 45\ °\text{F} \\ \dot{Q}_h(17) + \frac{\left[\dot{Q}_h(35) - \dot{Q}_h(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} \le T_j < 45\ °\text{F} \\ \dot{Q}_h(5) + \frac{\left[\dot{Q}_h(17) - \dot{Q}_h(5)\right] * (T_j - 5)}{17 - 5}, & if\ T_j < 17\ °\text{F} \end{cases}$$

Equation 4.2.1-7

$$\dot{E}_h(T_j) = \begin{cases} \dot{E}_h(17) + \dfrac{\left[\dot{E}_h(47) - \dot{E}_h(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j \geq 45\ °\text{F} \\ \dot{E}_h(17) + \dfrac{\left[\dot{E}_h(35) - \dot{E}_h(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} \leq T_j < 45\ °\text{F} \\ \dot{E}_h(5) + \dfrac{\left[\dot{E}_h(17) - \dot{E}_h(5)\right] * (T_j - 5)}{17 - 5}, & if\ T_j < 17\ °\text{F} \end{cases}$$

where $\dot{Q}_h(47)$ and $\dot{E}_h(47)$ are determined from the H1 test and calculated as specified in section 3.7 of this appendix; $\dot{Q}_h(35)$ and $\dot{E}_h(35)$ are determined from the H2 test and calculated as specified in section 3.9.1 of this appendix; $\dot{Q}_h(17)$ and $\dot{E}_h(17)$ are determined from the H3 test and calculated as specified in section 3.10 of this appendix; $\dot{Q}_h(5)$ and $\dot{E}_h(5)$ are determined from the H4 test and calculated as specified in section 3.10 of this appendix.

4.2.2 Additional Steps for Calculating the HSPF2 of a Heat Pump Having a Single-Speed Compressor and a Variable-Speed, Variable-Air-Volume-Rate Indoor Blower

The manufacturer must provide information about how the indoor air volume rate or the indoor blower speed varies over the outdoor temperature range of 65 °F to −23 °F. Calculate the quantities

$$\frac{e_h(T_j)}{N} \text{ and } \frac{RH(T_j)}{N}$$

in Equation 4.2–1 as specified in section 4.2.1 of this appendix with the exception of replacing references to the H1C test and section 3.6.1 of this appendix with the $H1C_1$ test and section 3.6.2 of this appendix. In addition, evaluate the space heating capacity and electrical power consumption of the heat pump $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using

Equation 4.2.2-1 $$\dot{Q}_h(T_j) = \dot{Q}_h^{k=1}(T_j) + \frac{\dot{Q}_h^{k=2}(T_j) - \dot{Q}_h^{k=1}(T_j)}{\text{FP}_h^{k=2} - \text{FP}_h^{k=1}} * \left[\text{FP}_h(T_j) - \text{FP}_h^{k=1}\right]$$

Equation 4.2.2-2 $$\dot{E}_h(T_j) = \dot{E}_h^{k=1}(T_j) + \frac{\dot{E}_h^{k=2}(T_j) - \dot{E}_h^{k=1}(T_j)}{\text{FP}_h^{k=2} - \text{FP}_h^{k=1}} * \left[\text{FP}_h(T_j) - \text{FP}_h^{k=1}\right]$$

where the space heating capacity and electrical power consumption at low capacity (k=1) at outdoor temperature Tj are determined using

Equation 4.2.2-3 $$\dot{Q}_h^k(T_j) = \begin{cases} \dot{Q}_h^k(17) + \dfrac{\left[\dot{Q}_h^k(47) - \dot{Q}_h^k(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j \geq 45\ °\text{F}\ or\ T_j \leq 17\ °\text{F} \\ \dot{Q}_h^k(17) + \dfrac{\left[\dot{Q}_h^k(35) - \dot{Q}_h^k(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} < T_j < 45\ °\text{F} \end{cases}$$

Equation 4.2.2-4

$$\dot{E}_h^k(T_j) = \begin{cases} \dot{E}_h^k(17) + \dfrac{\left[\dot{E}_h^k(47) - \dot{E}_h^k(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j \geq 45\ °\text{F}\ or\ T_j \leq 17\ °\text{F} \\ \dot{E}_h^k(17) + \dfrac{\left[\dot{E}_h^k(35) - \dot{E}_h^k(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} < T_j < 45\ °\text{F} \end{cases}$$

If the $H4_2$ test is not conducted, calculate the space heating capacity and electrical power consumption at high capacity (k=2) at outdoor temperature Tj using Equations 4.2.2–3 and 4.2.2–4 for k=2.

If the $H4_2$ test is conducted, calculate the space heating capacity and electrical power consumption at high capacity (k=2) at outdoor temperature Tj using Equations 4.2.2–5 and 4.2.2–6.

Equation 4.2.2-5

$$\dot{Q}_h^{k=2}(T_j) = \begin{cases} \dot{Q}_h^{k=2}(17) + \dfrac{\left[\dot{Q}_h^{k=2}(47) - \dot{Q}_h^{k=2}(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j \geq 45\ °\text{F} \\ \dot{Q}_h^{k=2}(17) + \dfrac{\left[\dot{Q}_h^{k=2}(35) - \dot{Q}_h^{k=2}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} \leq T_j < 45\ °\text{F} \\ \dot{Q}_h^{k=2}(5) + \dfrac{\left[\dot{Q}_h^{k=2}(17) - \dot{Q}_h^{k=2}(5)\right] * (T_j - 5)}{17 - 5}, & if\ T_j < 17\ °\text{F} \end{cases}$$

Equation 4.2.2-6

$$\dot{E}_h^{k=2}(T_j) = \begin{cases} \dot{E}_h^{k=2}(17) + \dfrac{\left[\dot{E}_h^{k=2}(47) - \dot{E}_h^{k=2}(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j \geq 45\ °\text{F} \\ \dot{E}_h^{k=2}(17) + \dfrac{\left[\dot{E}_h^{k=2}(35) - \dot{E}_h^{k=2}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} \leq T_j < 45\ °\text{F} \\ \dot{E}_h^{k=2}(5) + \dfrac{\left[\dot{E}_h^{k=2}(17) - \dot{E}_h^{k=2}(5)\right] * (T_j - 5)}{17 - 5}, & if\ T_j < 17\ °\text{F} \end{cases}$$

For units where indoor blower speed is the primary control variable, $FP_h^{k=1}$ denotes the fan speed used during the required $H1_1$ and $H3_1$ tests (see Table 12), $FP_h^{k=2}$ denotes the fan speed used during the required $H1_2$, $H2_2$, and $H3_2$ tests, and $FP_h(T_j)$ denotes the fan speed used by the unit when the outdoor temperature equals T_j. For units where indoor air volume rate is the primary control variable, the three FP_h's are similarly defined only now being expressed in terms of air volume rates rather than fan speeds. Determine $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the $H1_1$ test, and $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the $H1_2$ test. Calculate all four quantities as specified in section 3.7 of this appendix. Determine $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ as specified in section 3.6.2 of this appendix; determine $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ and from the $H2_2$ test and the calculation specified in section 3.9 of this appendix. Determine $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17$ from the $H3_1$ test, and $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test. Calculate all four quantities as specified in section 3.10 of this appendix. Determine $\dot{Q}_h^{k=2}(5)$ and $\dot{E}_h^{k=2}(5)$ from the $H4_2$ test and the calculation specified in section 3.10 of this appendix.

4.2.3 Additional Steps for Calculating the HSPF2 of a Heat Pump Having a Two-Capacity Compressor

The calculation of the Equation 4.2–1 to this appendix quantities differ depending upon whether the heat pump would operate at low capacity (section 4.2.3.1 of this appendix), cycle between low and high capacity (section 4.2.3.2 of this appendix), or operate at high capacity (sections 4.2.3.3 and 4.2.3.4 of this appendix) in responding to the building

load. For heat pumps that lock out low capacity operation at low outdoor temperatures, the outdoor temperature at which the unit locks out must be that specified by the manufacturer in the certification report so that the appropriate equations can be selected.

a. Evaluate the space heating capacity and electrical power consumption of the heat pump when operating at low compressor capacity and outdoor temperature T_j using

$$\dot{Q}_h^{k=1}(T_j) = \begin{cases} \dot{Q}_h^{k=1}(47) + \dfrac{\left[\dot{Q}_h^{k=1}(62) - \dot{Q}_h^{k=1}(47)\right] * (T_j - 47)}{62 - 47}, & if\ T_j \geq 40\ °\text{F} \\ \dot{Q}_h^{k=1}(17) + \dfrac{\left[\dot{Q}_h^{k=1}(35) - \dot{Q}_h^{k=1}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} \leq T_j < 40\ °\text{F} \\ \dot{Q}_h^{k=1}(17) + \dfrac{\left[\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j < 17\ °\text{F} \end{cases}$$

$$\dot{E}_h^{k=1}(T_j) = \begin{cases} \dot{E}_h^{k=1}(47) + \dfrac{\left[\dot{E}_h^{k=1}(62) - \dot{E}_h^{k=1}(47)\right] * (T_j - 47)}{62 - 47}, & if\ T_j \geq 40\ °\text{F} \\ \dot{E}_h^{k=1}(17) + \dfrac{\left[\dot{E}_h^{k=1}(35) - \dot{E}_h^{k=1}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} \leq T_j < 40\ °\text{F} \\ \dot{E}_h^{k=1}(17) + \dfrac{\left[\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j < 17\ °\text{F} \end{cases}$$

b. If the $H4_2$ test is not conducted, evaluate the space heating capacity and electrical power consumption ($\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$) of the heat pump when operating at high compressor capacity and outdoor temperature Tj by solving Equations 4.2.2–3 and 4.2.2–4, respectively, for k=2. If the $H4_2$ test is conducted, evaluate the space heating capacity and electrical power consumption ($\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$) of the heat pump when operating at high compressor capacity and outdoor temperature Tj using Equations 4.2.2–5 and 4.2.2–6, respectively.

Determine $\dot{Q}_h^{k=1}(62)$ and $\dot{E}_h^{k=1}(62)$ from the $H0_1$ test, $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the $H1_1$ test, and $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the $H1_2$ test. Calculate all six quantities as specified in section 3.7 of this appendix. Determine $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the $H2_2$ test and, if required as described in section 3.6.3 of this appendix, determine $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ from the $H2_1$ test. Calculate the required 35 °F quantities as specified in section 3.9 in this appendix. Determine $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test and, if required as described in section 3.6.3 of this appendix, determine $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ from the $H3_1$ test. Calculate the required 17 °F quantities as specified in section 3.10 of this appendix. Determine $\dot{Q}_h^{k=2}(5)$ and $\dot{E}_h^{k=2}(5)$ from the $H4_2$ test and the calculation specified in section 3.10 of this appendix.

4.2.3.1 Steady-State Space Heating Capacity When Operating at Low Compressor Capacity Is Greater Than or Equal to the Building Heating Load at Temperature T_j, $\dot{Q}_h^{k=1}(T_j) \geq BL(T_j)$

$$\text{Equation 4.2.3-1} \quad \frac{e_h(T_j)}{N} = \frac{X^{k=1}(T_j) * \dot{E}_h^{k=1}(T_j) * \delta(T_j)}{PLF_j} * \frac{n_j}{N}$$

$$\text{Equation 4.2.3-2} \quad \frac{RH(T_j)}{N} = \frac{BL(T_j) * [1 - \delta(T_j)]}{3.413 \frac{Btu/h}{W}} * \frac{n_j}{N}$$

Where:

$X^{k=1}(T_j) = BL(T_j)/\dot{Q}_h^{k=1}(T_j)$, the heating mode low capacity load factor for temperature bin *j*, dimensionless.

$PLF_j = 1 - C_D^h \cdot [\,1 - X^{k=1}(T_j)\,]$, the part load factor, dimensionless.

$\delta(T_j)$ = the low temperature cutoff factor, dimensionless.

Evaluate the heating mode cyclic degradation factor C_{D^h} as specified in section 3.8.1 of this appendix.

Determine the low temperature cut-out factor using

$$\text{Equation 4.2.3-3} \quad \delta(T_j) = \begin{cases} 0, \ if \ T_j \leq T_{off} \\ 1/2, \ if \ T_{off} < T_j \leq T_{on} \\ 1, \ if \ T_j > T_{on} \end{cases}$$

where T_{off} and T_{on} are defined in section 4.2.1 of this appendix. Use the calculations given in section 4.2.3.3 of this appendix, and not the above, if:

a. The heat pump locks out low capacity operation at low outdoor temperatures and

b. T_j is below this lockout threshold temperature.

4.2.3.2 Heat Pump Alternates Between High (k=2) and Low (k=1) Compressor Capacity To Satisfy the Building Heating Load at a Temperature T_j, $\dot{Q}_h^{k=1}(T_j)$ $BL(T_j)$ $\dot{Q}_h^{k=2}(T_j)$

Calculate $\frac{RH(T_j)}{N}$ using Equation 4.2.3-2. Evaluate $\frac{e_h(T_j)}{N}$ using

$$\frac{e_h(T_j)}{N} = [X^{k=1}(T_j) * \dot{E}_h^{k=1}(T_j) + X^{k=2}(T_j) * \dot{E}_h^{k=2}(T_j)] * \delta(T_j) * \frac{n_j}{N}$$

where:

$$X^{k=1}(T_j) = \frac{\dot{Q}_h^{k=2}(T_j) - BL(T_j)}{\dot{Q}_h^{k=2}(T_j) - \dot{Q}_h^{k=1}(T_j)}$$

$X^{k=2}(T_j) = 1 - X^{k=1}(T_j)$ the heating mode, high capacity load factor for temperature bin $_j$, dimensionless.

Determine the low temperature cut-out factor, $\delta'(T_j)$, using Equation 4.2.3–3.

4.2.3.3 Heat Pump Only Operates at High (k=2) Compressor Capacity at Temperature T_j and its Capacity Is Greater Than the Building Heating Load, $BL(T_j) < \dot{Q}_h^{k=2}(T_j)$. This Section Applies to Units That Lock Out Low Compressor Capacity Operation at Low Outdoor Temperatures

Calculate $\frac{RH(T_j)}{N}$ using Equation 4.2.3-2. Evaluate $\frac{e_h(T_j)}{N}$ using

$$\frac{e_h(T_j)}{N} = \frac{X^{k=2}(T_j) * \dot{E}_h^{k=2}(T_j) * \delta(T_j)}{PLF_j} * \frac{n_j}{N}$$

where:

$X^{k=2}(T_j) = BL(T_j)/\dot{Q}_h^{k=2}(T_j)$. $PLF_j = 1 - C^h{}_D(k = 2) * [1 - X^{k=2}(T_j)]$

If the $H1C_2$ test described in section 3.6.3 and Table 13 of this appendix is not conducted, set C_D^h (k=2) equal to the default value specified in section 3.8.1 of this appendix.

Determine the low temperature cut-out factor, $\delta(T_j)$, using Equation 4.2.3–3.

4.2.3.4 Heat Pump Must Operate Continuously at High (k=2) Compressor Capacity at Temperature T_j, $BL(T_j) \geq \dot{Q}_h^{k=2}(T_j)$

$$\frac{e_h(T_j)}{N} = \dot{E}_h^{k=2}(T_j) * \delta'(T_j) * \frac{n_j}{N}$$

$$\frac{RH(T_j)}{N} = \frac{BL(T_j) - \left[\dot{Q}_h^{k=2}(T_j) * \delta'(T_j)\right]}{3.413\frac{Btu}{Wh}} * \frac{n_j}{N}$$

Where:

$$\delta'(T_j) = \begin{cases} 0, & if\ T_j \leq T_{off}\ or\ \dfrac{\dot{Q}_h^{k=2}(T_j)}{3.413 * \dot{E}_h^{k=2}(T_j)} < 1 \\ \dfrac{1}{2}, & if\ T_{off} < T_j \leq T_{on}\ and\ \dfrac{\dot{Q}_h^{k=2}(T_j)}{3.413 * \dot{E}_h^{k=2}(T_j)} \geq 1 \\ 1, & if\ T_j > T_{on}\ and\ \dfrac{\dot{Q}_h^{k=2}(T_j)}{3.413 * \dot{E}_h^{k=2}(T_j)} \geq 1 \end{cases}$$

4.2.4 Additional Steps for Calculating the HSPF2 of a Heat Pump Having a Variable-Speed Compressor. Calculate HSPF2 Using Equation 4.2–1

The calculation of Equation 4.2-1 quantities $\frac{RH(T_j)}{N}$ and $\frac{e_h(T_j)}{N}$ differs depending upon whether the heat pump would operate at minimum speed (section 4.2.4.1 of this appendix), operate at an intermediate speed (section 4.2.4.2 of this appendix), or operate at full speed (section 4.2.4.3 of this appendix) in responding to the building load.

a. Minimum Compressor Speed. For units other than variable-speed non-communicating coil-only heat pumps, evaluate the space heating capacity, $\dot{Q}_h^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=1}(T_j)$, of the heat pump when operating at minimum compressor speed and outdoor temperature T_j using:

Equation 4.2.4-1

$$\dot{Q}_h^{k=1}(T_j) = \dot{Q}_h^{k=1}(47) + \frac{\dot{Q}_h^{k=1}(62) - \dot{Q}_h^{k=1}(47)}{62-47} * (T_j - 47); \text{ and}$$

Equation 4.2.4-2

$$\dot{E}_h^{k=1}(T_j) = \dot{E}_h^{k=1}(47) + \frac{\dot{E}_h^{k=1}(62) - \dot{E}_h^{k=1}(47)}{62 - 47} * (T_j - 47)$$

Where $Q_h^{k=1}(62)$ and $E_h^{k=1}(62)$ are determined from the $H0_1$ test, $Q_h^{k=1}(47)$ and $E_h^{k=1}(47)$ are determined from the $H1_1$ test, and all four quantities are calculated as specified in section 3.7 of this appendix.

For variable-speed non-communicating coil-only heat pumps, when T_j is greater than or equal to 47 °F, evaluate the space heating capacity, $\dot{Q}_h^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=1}(T_j)$, of the heat pump when operating at minimum compressor speed as described in Equations 4.2.4–1 and 4.2.4–2 to this appendix, respectively. When T_j is less than 47 °F, evaluate the space heating capacity, $\dot{Q}_h^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=1}(T_j)$ using:

Equation 4.2.4-3

$$\dot{Q}_h^{k=1}(T_j) = \begin{cases} \dot{Q}_h^{k=1}(35) + \dfrac{\left[\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(35)\right] * (T_j - 35)}{47 - 35}, & if\ 35\ °\text{F} \le T_j < 47\ °\text{F} \\ \dot{Q}_h^{k=1}(17) + \dfrac{\left[\dot{Q}_h^{k=1}(35) - \dot{Q}_h^{k=1}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} \le T_j < 35\ °\text{F} \\ \dot{Q}_h^{k=2}(T_j) * \left(\dot{Q}_h^{k=1}(17) / \dot{Q}_h^{k=2}(17)\right), & if\ T_j < 17\ °\text{F} \end{cases}$$

And

Equation 4.2.4-4

$$\dot{E}_h^{k=1}(T_j) = \begin{cases} \dot{E}_h^{k=1}(35) + \dfrac{\left[\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(35)\right] * (T_j - 35)}{47 - 35}, & if\ 35\ °\text{F} \le T_j < 47\ °\text{F} \\ \dot{E}_h^{k=1}(17) + \dfrac{\left[\dot{E}_h^{k=1}(35) - \dot{E}_h^{k=1}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} \le T_j < 35\ °\text{F} \\ \dot{E}_h^{k=2}(T_j) * \left(\dot{E}_h^{k=1}(17) / \dot{E}_h^{k=2}(17)\right), & if\ T_j < 17\ °\text{F} \end{cases}$$

Where $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ are determined from the $H1_1$ test, and both quantities are calculated as specified in section 3.7 of this appendix; $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ are determined from the $H2_1$ test, and are calculated as specified in section 3.9 of this appendix; $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ are determined from the $H3_1$ test, and are calculated as specified in section 3.10 of this appendix; and $\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$ are calculated as described in section 4.2.4.c or 4.2.4.d of this appendix, as appropriate.

b. Minimum Compressor Speed for Minimum-speed-limiting Variable-speed Heat Pumps. For units other than variable-speed non-communicating coil-only heat pumps, evaluate the space heating capacity, $\dot{Q}_h^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=1}(T_j)$, of the heat pump when operating at minimum compressor speed and outdoor temperature T_j using:

Equation 4.2.4-5

$$\dot{Q}_h^{k=1}(T_j) = \begin{cases} \dot{Q}_h^{k=1}(47) + \dfrac{\left[\dot{Q}_h^{k=1}(62) - \dot{Q}_h^{k=1}(47)\right] * (T_j - 47)}{62 - 47}, & if\ T_j \geq 47\ °\text{F} \\ \dot{Q}_h^{k=v}(35) + \dfrac{\left[\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=v}(35)\right] * (T_j - 35)}{47 - 35}, & if\ 35\ °\text{F} \leq T_j < 47\ °\text{F} \\ \dot{Q}_h^{k=v}(T_j), & if\ T_j < 35\ °\text{F} \end{cases}$$

And

Equation 4.2.4-6

$$\dot{E}_h^{k=1}(T_j) = \begin{cases} \dot{E}_h^{k=1}(47) + \dfrac{\left[\dot{E}_h^{k=1}(62) - \dot{E}_h^{k=1}(47)\right] * (T_j - 47)}{62 - 47}, & if\ T_j \geq 47\ °\text{F} \\ \dot{E}_h^{k=v}(35) + \dfrac{\left[\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=v}(35)\right] * (T_j - 35)}{47 - 35}, & if\ 35\ °\text{F} \leq T_j < 47\ °\text{F} \\ \dot{E}_h^{k=v}(T_j), & if\ T_j < 35\ °\text{F} \end{cases}$$

Where $\dot{Q}_h^{k=1}(62)$ and $\dot{E}_h^{k=1}(62)$ are determined from the $H0_1$ test, $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ are determined from the $H1_1$ test, and all four quantities are calculated as specified in section 3.7 of this appendix; $\dot{Q}_h^{k=v}(35)$ and $\dot{E}_h^{k=v}(35)$ are determined from the $H2_v$ test and are calculated as specified in section 3.9 of this appendix; and $\dot{Q}_h^{k=v}(T_j)$ and $\dot{E}_h^{k=v}(T_j)$ are calculated using Equations 4.2.4–7 and 4.2.4–8 to this appendix, respectively.

For variable-speed non-communicating coil-only heat pumps, evaluate the space heating capacity, $\dot{Q}_h^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=1}(T_j)$, of the heat pump as described in section 4.2.4.a of this appendix, using Equations 4.2.4–1, 4.2.4–2, 4.2.4–3, and 4.2.4–4 to this appendix, as appropriate.

c. Full Compressor Speed for Heat Pumps for which the $H4_2$ test is not conducted. Evaluate the space heating capacity, $\dot{Q}_h^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=2}(T_j)$, of the heat pump when operating at full compressor speed and outdoor temperature T_j using:

$$\dot{Q}_h^{k=2}(T_j) =$$

$$\begin{cases} \left\{\dot{Q}_h^{k=2}(17) + \dfrac{\left[\dot{Q}_{hcalc}^{k=2}(47) - \dot{Q}_h^{k=2}(17)\right] * (T_j - 17)}{47 - 17}\right\} * \left(\dfrac{\dot{Q}_h^{k=N}(47)}{\dot{Q}_{hcalc}^{k=2}(47)}\right), & if\ T_j \geq 45\ °\text{F} \\ \dot{Q}_h^{k=2}(17) + \dfrac{\left[\dot{Q}_h^{k=2}(35) - \dot{Q}_h^{k=2}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} \leq T_j < 45\ °\text{F} \\ \dot{Q}_h^{k=2}(17) + \dfrac{\left[\dot{Q}_{hcalc}^{k=2}(47) - \dot{Q}_h^{k=2}(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j < 17\ °\text{F} \end{cases}$$

And

$$\dot{E}_h^{k=2}(T_j) =$$

$$\begin{cases} \left\{\dot{E}_h^{k=2}(17) + \dfrac{\left[\dot{E}_{hcalc}^{k=2}(47) - \dot{E}_h^{k=2}(17)\right] * (T_j - 17)}{47 - 17}\right\} * \left(\dfrac{\dot{E}_h^{k=N}(47)}{\dot{E}_{hcalc}^{k=2}(47)}\right), & if\ T_j \geq 45\ °\text{F} \\ \dot{E}_h^{k=2}(17) + \dfrac{\left[\dot{E}_h^{k=2}(35) - \dot{E}_h^{k=2}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} \leq T_j < 45\ °\text{F} \\ \dot{E}_h^{k=2}(17) + \dfrac{\left[\dot{E}_{hcalc}^{k=2}(47) - \dot{E}_h^{k=2}(17)\right] * (T_j - 17)}{47 - 17}, & if\ T_j < 17\ °\text{F} \end{cases}$$

Determine $\dot{Q}_h^{k=N}(47)$ and $\dot{E}_h^{k=N}(47)$ from the $H1_N$ test and the calculations specified in section 3.7 of this appendix. See section 3.6.4.b of this appendix regarding determination of the capacity $\dot{Q}_{hcalc}^{k=2}(47)$ and power input $\dot{E}_{hcacl}^{k=2}(47)$ used in the HSPF2 calculations to represent the $H1_2$ Test. Determine $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the $H2_2$ test and the calculations specified in section 3.9 of this appendix or, if the $H2_2$ test is not conducted, by conducting the calculations specified in section 3.6.4 of this appendix. Determine $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test and the methods specified in section 3.10 of this appendix.

d. Full Compressor Speed for Heat Pumps for which the $H4_2$ test is Conducted. For T_j above 17 °F, evaluate the space heating capacity, $\dot{Q}_h^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=2}(T_j)$, of the heat pump when operating at full compressor speed as described above for heat pumps for which the $H4_2$ is not conducted. For T_j between 5 °F and 17 °F, evaluate the space heating capacity, $\dot{Q}_h^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=2}(T_j)$, of the heat pump when operating at full compressor speed using the following equations:

$$\dot{Q}_h^{k=2}(T_j) = \dot{Q}_h^{k=2}(5) + \frac{\dot{Q}_h^{k=2}(17) - \dot{Q}_h^{k=2}(5)}{17 - 5} * (T_j - 5)$$

$$\dot{E}_h^{k=2}(T_j) = \dot{E}_h^{k=2}(5) + \frac{\dot{E}_h^{k=2}(17) - \dot{E}_h^{k=2}(5)}{17 - 5} * (T_j - 5)$$

Determine $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test, and $\dot{Q}_h^{k=2}(5)$ and $\dot{E}_h^{k=2}(5)$ from the $H4_2$ test, using the methods specified in section 3.10 of this appendix for all four values. For T_j below 5 °F, evaluate the space heating capacity, $\dot{Q}_h^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=2}(T_j)$, of the heat pump when operating at full compressor speed using the following equations:

$$\dot{Q}_h^{k=2}(T_j) = \dot{Q}_h^{k=2}(5) - \frac{\dot{Q}_{hcalc}^{k=2}(47) - \dot{Q}_h^{k=2}(17)}{47 - 17} * (5 - T_j)$$

$$\dot{E}_h^{k=2}(T_j) = \dot{E}_h^{k=2}(5) - \frac{\dot{E}_{hcalc}^{k=2}(47) - \dot{E}_h^{k=2}(17)}{47 - 17} * (5 - T_j)$$

Determine $\dot{Q}_{hcalc}^{k=2}(47)$ and $\dot{E}_{hcalc}^{k=2}(47)$ as described in section 3.6.4.b of this appendix. Determine $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test, using the methods specified in section 3.10 of this appendix.

e. Intermediate Compressor Speed. For units other than variable-speed noncommunicating coil-only heat pumps, calculate the space heating capacity, $\dot{Q}_h^{k=v}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=v}(T_j)$, of the heat pump when operating at outdoor temperature T_j and the intermediate compressor speed used during the $H2_V$ test in section 3.6.4 of this appendix using:

Equation 4.2.4-7 $\dot{Q}_h^{k=v}(T_j) = \dot{Q}_h^{k=v}(35) + M_Q * (T_j - 35)$, and

Equation 4.2.4-8 $\dot{E}_h^{k=v}(T_j) = \dot{E}_h^{k=v}(35) + M_E * (T_j - 35)$

Where $\dot{Q}_h^{k=v}(35)$ and $\dot{E}_h^{k=v}(35)$ are determined from the $H2_V$ test and calculated as specified in section 3.9 of this appendix. Approximate the slopes of the k=v intermediate speed heating capacity and electrical power input curves, M_Q and M_E, as follows:

$$M_Q = \left[\frac{\dot{Q}_h^{k=1}(62) - \dot{Q}_h^{k=1}(47)}{62-47} * (1 - N_Q)\right] + \left[N_Q * \frac{\dot{Q}_h^{k=2}(35) - \dot{Q}_h^{k=2}(17)}{35-17}\right]$$

$$M_E = \left[\frac{\dot{E}_h^{k=1}(62) - \dot{E}_h^{k=1}(47)}{62-47} * (1 - N_E)\right] + \left[N_E * \frac{\dot{E}_h^{k=2}(35) - \dot{E}_h^{k=2}(17)}{35-17}\right]$$

Where:

$$N_Q = \frac{\dot{Q}_h^{k=v}(35) - \dot{Q}_h^{k=1}(35)}{\dot{Q}_h^{k=2}(35) - \dot{Q}_h^{k=1}(35)} \text{ and } N_E = \frac{\dot{E}_h^{k=v}(35) - \dot{E}_h^{k=1}(35)}{\dot{E}_h^{k=2}(35) - \dot{E}_h^{k=1}(35)}$$

Use Equations 4.2.4–1 and 4.2.4–2 to this appendix, respectively, to calculate $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$, whether or not the heat pump is a minimum-speed-limiting variable-speed heat pump.

For variable-speed non-communicating coil-only heat pumps, there is no intermediate speed.

4.2.4.1 Steady-State Space Heating Capacity When Operating at Minimum Compressor Speed is Greater Than or Equal to the Building Heating Load at Temperature T_j, $\dot{Q}_h^{k=1}(T_j \geq BL(T_j)$.

Evaluate the Equation 4.2–1 to this appendix quantities:

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

As specified in section 4.2.3.1 of this appendix. Except now use Equations 4.2.4–1 and 4.2.4–2 (for heat pumps that are not minimum-speed-limiting and are not variable-speed non-communicating coil-only heat pumps), Equations 4.2.4–1, 4.2.4–2, 4.2.4–3, and 4.2.4–4 as appropriate (for variable-speed non-communicating coil-only heat pumps), or Equations 4.2.4–5 and 4.2.4.-6 (for minimum-speed-limiting variable-speed heat pumps that are not variable-speed non-communicating coil-only heat pumps) to this appendix to evaluate $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$, respectively, and replace section 4.2.3.1 references to ''low capacity'' and section 3.6.3 of this appendix with ''minimum speed'' and section 3.6.4 of this appendix.

4.2.4.2 Heat Pump Operates at an Intermediate Compressor Speed (k = i) or, for a Variable-Speed Non-Communicating Coil-Only Heat Pump, Cycles Between High and Low Speeds, in Order to Match the Building Heating Load at a Temperature T_j, $\dot{Q}_h^{k=1}(T_j) < \dot{Q}BL(T_j) < \dot{Q}_h^{k=2}(T_j)$.

For units that are not variable-speed non-communicating coil-only heat pumps, calculate:

$\frac{RH(T_j)}{N}$ using Equation 4.2.3-2 while evaluating $\frac{e_h(T_j)}{N}$ using,

$$\frac{e_h(T_j)}{N} = \dot{E}_h^{k=i}(T_j) * \delta(T_j) * \frac{n_j}{N}$$

Where:

$$\dot{E}_h^{k=i}(T_j) = \frac{\dot{Q}_h^{k=i}(T_j)}{3.413\frac{Btu/h}{W} * COP^{k=i}(T_j)}$$

And $\delta(T_j)$ is evaluated using Equation 4.2.3–3, while:

$\dot{Q}_h^{k=i}(T_j) = BL(T_j)$, the space heating capacity delivered by the unit in matching the building load at temperature (T_j), in Btu/h. The matching occurs with the heat pump operating at compressor speed k=i, and

$COP^{k=i}(T_j)$ = the steady-state coefficient of performance of the heat pump when operating at compressor speed k=i and temperature T_j (dimensionless). For each temperature bin where the heat pump operates at an intermediate compressor speed, determine $COP^{k=i}(T_j)$ using the following equations,

For each temperature bin where $\dot{Q}_h^{k=1}(T_j) < BL(T_j) < \dot{Q}_h^{k=v}(T_j)$,

$$COP_h^{k=i}(T_j) = COP_h^{k=1}(T_j) + \frac{COP_h^{k=v}(T_j) - COP_h^{k=1}(T_j)}{Q_h^{k=v}(T_j) - Q_h^{k=1}(T_j)} * (BL(T_j) - Q_h^{k=1}(T_j))$$

For each temperature bin where $\dot{Q}_h^{k=v}(T_j) \leq BL(T_j) < \dot{Q}_h^{k=2}(T_j)$,

$$COP_h^{k=i}(T_j) = COP_h^{k=v}(T_j) + \frac{COP_h^{k=2}(T_j) - COP_h^{k=v}(T_j)}{Q_h^{k=2}(T_j) - Q_h^{k=v}(T_j)} * (BL(T_j) - Q_h^{k=v}(T_j))$$

Where:

$COP_h^{k=1}(T_j)$ is the steady-state coefficient of performance of the heat pump when operating at minimum compressor speed and temperature Tj, dimensionless, calculated using capacity $\dot{Q}_h^{k=1}(T_j)$ calculated using Equation 4.2.4–1 or 4.2.4–3 to this appendix and electrical power consumption $\dot{E}_h^{k=1}(T_j)$ calculated using Equation 4.2.4–2 or 4.2.4–4 to this appendix;

$COP_h^{k=v}(T_j)$ is the steady-state coefficient of performance of the heat pump when operating at intermediate compressor speed and temperature Tj, dimensionless, calculated using capacity $\dot{Q}_h^{k=v}(T_j)$ calculated using Equation 4.2.4–7 to this appendix and electrical power consumption $\dot{E}_h^{k=v}(T_j)$ calculated using Equation 4.2.4–8 to this appendix;

$COP_h^{k=2}(T_j)$ is the steady-state coefficient of performance of the heat pump when operating at full compressor speed and temperature Tj (dimensionless), calculated using capacity $\dot{Q}_h^{k=2}(T_j)$ and electrical power consumption $\dot{E}_h^{k=2}(T_j)$, both calculated as described in section 4.2.4 of this appendix; and

$BL(T_j)$ is the building heating load at temperature T_j, in Btu/h.

For variable-speed non-communicating heat pumps, calculate $\frac{RH(T_j)}{N}$ and $\frac{e_h(T_j)}{N}$ as described in section 4.2.3.2 of this appendix with the understanding that $\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$ correspond to full compressor speed operation, $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$ correspond to minimum compressor speed operation, and all four quantities are derived from the results of the specified section 3.6.4 tests of this appendix.

4.2.4.3 Heat Pump Must Operate Continuously at Full (k=2) Compressor Speed at Temperature T_j, $BL(T_j) \geq \dot{Q}_h^{k=2}(T_j)$. Evaluate the Equation 4.2–1 Quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.4 of this appendix with the understanding that $\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$ correspond to full compressor speed operation and are derived from the results of the specified section 3.6.4 tests of this appendix.

4.2.5 Heat Pumps Having a Heat Comfort Controller

Heat pumps having heat comfort controllers, when set to maintain a typical minimum air delivery temperature, will cause the heat pump condenser to operate less because of a greater contribution from the resistive elements. With a conventional heat pump, resistive heating is only initiated if the heat pump condenser cannot meet the building load (*i.e.*, is delayed until a second stage call from the indoor thermostat). With a heat comfort controller, resistive heating can occur even though the heat pump condenser has adequate capacity to meet the building load (*i.e.*, both on during a first stage call from the indoor thermostat). As a result, the outdoor temperature where the heat pump compressor no longer cycles (*i.e.*, starts to run continuously), will be lower than if the heat pump did not have the heat comfort controller.

4.2.5.1 Blower Coil System Heat Pump Having a Heat Comfort Controller: Additional Steps for Calculating the HSPF2 of a Heat Pump Having a Single-Speed Compressor and Either a Fixed-Speed Indoor Blower or a Constant-Air-Volume-Rate Indoor Blower Installed, or a Single-Speed Coil-Only System Heat Pump

Calculate the space heating capacity and electrical power of the heat pump without the heat comfort controller being active as specified in section 4.2.1 of this appendix (Equations 4.2.1–4 and 4.2.1–5) for each outdoor bin temperature, T_j, that is listed in Table 20. Denote these capacities and electrical powers by using the subscript ''hp'' instead of ''h.'' Calculate the mass flow rate (expressed in pounds-mass of dry air per hour) and the specific heat of the indoor air (expressed in $Btu/lbm_{da} \cdot °F$) from the results of the H1 test using:

$$\dot{m}_{da} = \overline{\dot{V}_s} * 0.075 \frac{lbm_{da}}{ft^3} * \frac{60_{min}}{hr} = \frac{\overline{\dot{V}}_{mx}}{v'_n * [1 + W_n]} * \frac{60_{min}}{hr} = \frac{\overline{\dot{V}}_{mx}}{v_n} * \frac{60_{min}}{hr}$$

$$C_{p,da} = 0.24 + 0.444 * W_n$$

where $\overline{\dot{V}}_s$, $\overline{\dot{V}}_{mx}$, v'_n (or v_n), and W_n are defined following Equation 3–1. For each outdoor bin temperature listed in Table 20, calculate the nominal temperature of the air leaving the heat pump condenser coil using,

$$T_0(T_j) = 70°\text{F} + \frac{\dot{Q}_{hp}(T_j)}{\dot{m}_{da} * C_{p,da}}$$

Evaluate $e_h(T_j/N)$, $RH(T_j)/N$, $X(T_j)$, PLF_j, and $\delta(T_j)$ as specified in section 4.2.1 of this appendix. For each bin calculation, use the space heating capacity and electrical power from Case 1 or Case 2, whichever applies.

Case 1. For outdoor bin temperatures where $T_o(T_j)$ is equal to or greater than T_{CC} (the maximum supply temperature determined according to section 3.1.10 of this appendix), determine $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ as specified in section 4.2.1 of this appendix (*i.e.*, $\dot{Q}_h(T_j) = \dot{Q}_{hp}(T_j)$ and $\dot{E}_h(T_j) = \dot{E}_{hp}(T_j)$).

NOTE: Even though $T_o(T_j) \geq T_{cc}$, resistive heating may be required; evaluate Equation 4.2.1–2 for all bins.

Case 2. For outdoor bin temperatures where $T_o(T_j) < T_{CC}$, determine $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using,

$$\dot{Q}_h(T_j) = \dot{Q}_{hp}(T_j) + \dot{Q}_{CC}(T_j) \qquad \dot{E}_h(T_j) = \dot{E}_{hp}(T_j) + \dot{E}_{CC}(T_j)$$

where,

$$\dot{Q}_{CC}(T_j) = \dot{m}_{da} * C_{p,da} * [T_{CC} - T_0(T_j)] \qquad \dot{E}_{CC}(T_j) = \frac{\dot{Q}_{CC}(T_j)}{3.413 \frac{Btu/h}{W}}$$

NOTE: Even though $T_o(T_j) < T_{cc}$, additional resistive heating may be required; evaluate Equation 4.2.1–2 for all bins.

4.2.5.2 Heat Pump Having a Heat Comfort Controller: Additional Steps for Calculating the HSPF2 of a Heat Pump Having a Single-Speed Compressor and a Variable-Speed, Variable-Air-Volume-Rate Indoor Blower

Calculate the space heating capacity and electrical power of the heat pump without the heat comfort controller being active as specified in section 4.2.2 of this appendix (Equations 4.2.2–1 and 4.2.2–2) for each outdoor bin temperature, T_j, that is listed in Table 20. Denote these capacities and electrical powers by using the subscript ''hp'' instead of ''h.'' Calculate the mass flow rate (expressed in pounds-mass of dry air per hour) and the specific heat of the indoor air (expressed in $Btu/lbm_{da} \cdot °F$) from the results of the $H1_2$ test using:

$$\dot{m}_{da} = \overline{\dot{V}_s} * 0.075 \frac{lbm_{da}}{ft^3} * \frac{60_{min}}{hr} = \frac{\overline{\dot{V}}_{mx}}{v'_n * [1 + W_n]} * \frac{60_{min}}{hr} = \frac{\overline{\dot{V}}_{mx}}{v_n} * \frac{60_{min}}{hr}$$

$$C_{p,da} = 0.24 + 0.444 * W_n$$

where $\overline{\dot{V}}_S$, $\overline{\dot{V}}_{mx}$, v'_n (or v_n), and W_n are defined following Equation 3–1. For each outdoor bin temperature listed in Table 20, calculate the nominal temperature of the air leaving the heat pump condenser coil using,

$$T_0(T_j) = 70°\text{F} + \frac{\dot{Q}_{hp}(T_j)}{\dot{m}_{da} * C_{p,da}}$$

Evaluate $e_h(T_j)/N$, $RH(T_j)/N$, $X(T_j)$, PLF_j, and $\delta(T_j)$ as specified in section 4.2.1 of this appendix with the exception of replacing references to the H1C test and section 3.6.1 of this appendix with the $H1C_1$ test and section 3.6.2 of this appendix. For each bin calculation, use the space heating capacity and electrical power from Case 1 or Case 2, whichever applies.

Case 1. For outdoor bin temperatures where $T_o(T_j)$ is equal to or greater than T_{CC} (the maximum supply temperature determined according to section 3.1.10 of this appendix), determine $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ as specified in section 4.2.2 of this appendix (*i.e.* $\dot{Q}_h(T_j) = \dot{Q}_{hp}(T_j)$ and $\dot{E}_h(T_j) = \dot{E}_{hp}(T_j)$). Note: Even though $T_o(T_j) \geq T_{CC}$, resistive heating may be required; evaluate Equation 4.2.1–2 for all bins.

Case 2. For outdoor bin temperatures where $T_o(T_j) < T_{CC}$, determine $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using,

$$\dot{Q}_h(T_j) = \dot{Q}_{hp}(T_j) + \dot{Q}_{CC}(T_j) \qquad \dot{E}_h(T_j) = \dot{E}_{hp}(T_j) + \dot{E}_{CC}(T_j)$$

where,

$$\dot{Q}_{CC}(T_j) = \dot{m}_{da} * C_{p,da} * [T_{CC} - T_0(T_j)] \qquad \dot{E}_{CC}(T_j) = \frac{\dot{Q}_{CC}(T_j)}{3.413 \frac{Btu/h}{W}}$$

NOTE: Even though $T_o(T_j) < T_{cc}$, additional resistive heating may be required; evaluate Equation 4.2.1–2 for all bins.

4.2.5.3 Heat Pumps Having a Heat Comfort Controller: Additional Steps for Calculating the HSPF2 of a Heat Pump Having a Two-Capacity Compressor

Calculate the space heating capacity and electrical power of the heat pump without the heat comfort controller being active as specified in section 4.2.3 of this appendix for both high and low capacity and at each outdoor bin temperature, T_j, that is listed in Table 20. Denote these capacities and electrical powers by using the subscript ''hp'' instead of ''h.'' For the low capacity case, calculate the mass flow rate (expressed in pounds-mass of dry air per hour) and the specific heat of the indoor air (expressed in $Btu/lbm_{da} \cdot °F$) from the results of the $H1_1$ test using:

$$\dot{m}_{da}^{k=1} = \overline{\dot{V}_s} * 0.075 \frac{lbm_{da}}{ft^3} * \frac{60_{min}}{hr} = \frac{\overline{\dot{V}}_{mx}}{v_n' * [1 + W_n]} * \frac{60_{min}}{hr} = \frac{\overline{\dot{V}}_{mx}}{v_n} * \frac{60_{min}}{hr}$$

$$C_{p,da}^{k=1} = 0.24 + 0.444 * W_n$$

where $\overline{\dot{V}}_s$, $\overline{\dot{V}}_{mx}$, v'_n (or v_n), and W_n are defined following Equation 3–1. For each outdoor bin temperature listed in Table 20, calculate the nominal temperature of the air leaving the heat pump condenser coil when operating at low capacity using,

$$T_0^{k=1}(T_j) = 70°\text{F} + \frac{\dot{Q}_{hp}^{k=1}(T_j)}{\dot{m}_{da}^{k=1} * C_{p,da}^{k=1}}$$

Repeat the above calculations to determine the mass flow rate ($\dot{m}_{da}^{k=2}$) and the specific heat of the indoor air ($C_{p,da}^{k=2}$) when operating at high capacity by using the results of the $H1_2$ test. For each outdoor bin temperature listed in Table 20, calculate the nominal temperature of the air leaving the heat pump condenser coil when operating at high capacity using,

$$T_0^{k=2}(T_j) = 70°\text{F} + \frac{\dot{Q}_{hp}^{k=2}(T_j)}{\dot{m}_{da}^{k=2} * C_{p,da}^{k=2}}$$

Evaluate $e_h(T_j)/N$, $RH(T_j)/N$, $X^{k=1}(T_j)$, and/or $X^{k=2}(T_j)$, PLF_j, and $\delta'(T_j)$ or $\delta''(T_j)$ as specified in section 4.2.3.1. 4.2.3.2, 4.2.3.3, or 4.2.3.4 of this appendix, whichever applies, for each temperature bin. To evaluate these quantities, use the low-capacity space heating capacity and the low-capacity electrical power from Case 1 or Case 2, whichever applies; use the high-capacity space heating capacity and the high-capacity electrical power from Case 3 or Case 4, whichever applies.

Case 1. For outdoor bin temperatures where $T_o^{k=1}(T_j)$ is equal to or greater than T_{CC} (the maximum supply temperature determined according to section 3.1.10 of this appendix), determine $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$ as specified in section 4.2.3 of this appendix (*i.e.*, $\dot{Q}_h^{k=1}(T_j) = \dot{Q}_{hp}^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j) = \dot{E}_{hp}^{k=1}(T_j)$).

NOTE: Even though $T_o^{k=1}(T_j) \geq T_{CC}$, resistive heating may be required; evaluate $RH(T_j)/N$ for all bins.

Case 2. For outdoor bin temperatures where $T_o^{k=1}(T_j) < T_{CC}$, determine $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$ using,

$$\dot{Q}_h^{k=1}(T_j) = \dot{Q}_{hp}^{k=1}(T_j) + \dot{Q}_{CC}^{k=1}(T_j) \quad \dot{E}_h^{k=1}(T_j) = \dot{E}_{hp}^{k=1}(T_j) + \dot{E}_{CC}^{k=1}(T_j)$$

where,

$$\dot{Q}_{CC}^{k=1}(T_j) = \dot{m}_{da}^{k=1} * C_{p,da}^{k=1} * [T_{CC} - T_0^{k=1}(T_j)] \qquad \dot{E}_{CC}^{k=1}(T_j) = \frac{\dot{Q}_{CC}^{k=1}(T_j)}{3.413 \frac{Btu/h}{W}}$$

NOTE: Even though $T_o^{k=1}(T_j) \geq T_{cc}$, additional resistive heating may be required; evaluate $RH(T_j)/N$ for all bins.

Case 3. For outdoor bin temperatures where $T_o^{k=2}(T_j)$ is equal to or greater than T_{CC}, determine $\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$ as specified in section 4.2.3 of this appendix (*i.e.*, $\dot{Q}_h^{k=2}(T_j) = \dot{Q}_{hp}^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j) = \dot{E}_{hp}^{k=2}(T_j)$).

NOTE: Even though $T_o^{k=2}(T_j) < T_{CC}$, resistive heating may be required; evaluate $RH(T_j)/N$ for all bins.

Case 4. For outdoor bin temperatures where $T_o^{k=2}(T_j) < T_{CC}$, determine $\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$ using,

$$\dot{Q}_h^{k=2}(T_j) = \dot{Q}_{hp}^{k=2}(T_j) + \dot{Q}_{CC}^{k=2}(T_j)\ \dot{E}_h^{k=2}(T_j) = \dot{E}_{hp}^{k=2}(T_j) + \dot{E}_{CC}^{k=2}(T_j)$$

where,

$$\dot{Q}_{CC}^{k=2}(T_j) = \dot{m}_{da}^{k=2} * C_{p,da}^{k=2} * [T_{CC} - T_0^{k=2}(T_j)] \qquad \dot{E}_{CC}^{k=2}(T_j) = \frac{\dot{Q}_{CC}^{k=2}(T_j)}{3.413\frac{Btu/h}{W}}$$

NOTE: Even though $T_o^{k=2}(T_j)$ T_{cc}, additional resistive heating may be required; evaluate $RH(T_j)/N$ for all bins.

4.2.5.4 Heat Pumps Having a Heat Comfort Controller: Additional Steps for Calculating the HSPF2 of a Heat Pump Having a Variable-Speed Compressor [Reserved]

4.2.6 Additional Steps for Calculating the HSPF2 of a Heat Pump Having a Triple-Capacity Compressor

The only triple-capacity heat pumps covered are triple-capacity, northern heat pumps. For such heat pumps, the calculation of the Eq. 4.2–1 quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

differ depending on whether the heat pump would cycle on and off at low capacity (section 4.2.6.1 of this appendix), cycle on and off at high capacity (section 4.2.6.2 of this appendix), cycle on and off at booster capacity (section 4.2.6.3 of this appendix), cycle between low and high capacity (section 4.2.6.4 of this appendix), cycle between high and booster capacity (section 4.2.6.5 of this appendix), operate continuously at low capacity (section 4.2.6.6 of this appendix), operate continuously at high capacity (section 4.2.6.7 of this appendix), operate continuously at booster capacity (section 4.2.6.8 of this appendix), or heat solely using resistive heating (also section 4.2.6.8 of this appendix) in responding to the building load. As applicable, the manufacturer must supply information regarding the outdoor temperature range at which each stage of compressor capacity is active. As an informative example, data may be submitted in this manner: At the low (k=1) compressor capacity, the outdoor temperature range of operation is 40 °F ≤ T ≤ 65 °F; At the high (k=2) compressor capacity, the outdoor temperature range of operation is 20 °F ≤ T ≤ 50 °F; At the booster (k=3) compressor capacity, the outdoor temperature range of operation is −20 °F ≤ T ≤ 30 °F.

a. Evaluate the space heating capacity and electrical power consumption of the heat pump when operating at low compressor capacity and outdoor temperature T_j using the equations given in section 4.2.3 of this appendix for $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$) In evaluating the section 4.2.3 equations, Determine $\dot{Q}_h^{k=1}(62)$ and $\dot{E}_h^{k=1}(62)$ from the $H0_1$ test, $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the $H1_1$ test, and $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the $H1_2$ test. Calculate all four quantities as specified in section 3.7 of this appendix.

If, in accordance with section 3.6.6 of this appendix, the $H3_1$ test is conducted, calculate $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ as specified in section 3.10 of this appendix and determine $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ as specified in section 3.6.6 of this appendix.

b. Evaluate the space heating capacity and electrical power consumption ($\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$) of the heat pump when operating at high compressor capacity and outdoor temperature Tj by solving Equations 4.2.2–3 and 4.2.2–4, respectively, for k=2. Determine $\dot{Q}_h^{k=1}(62)$ and $\dot{E}_h^{k=1}(62)$ from the $H0_1$ test, $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the $H1_1$ test, and $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the $H1_2$ test, evaluated as specified in section 3.7 of this appendix. Determine the equation input for $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the $H2_2$ test evaluated as specified in section 3.9.1 of this appendix. Also, determine $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test, evaluated as specified in section 3.10 of this appendix.

c. Evaluate the space heating capacity and electrical power consumption of the heat pump when operating at booster compressor capacity and outdoor temperature T_j using

$$\dot{Q}_h^{k=3}(T_j) = \begin{cases} \dot{Q}_h^{k=3}(17) + \dfrac{\left[\dot{Q}_h^{k=3}(35) - \dot{Q}_h^{k=3}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} < T_j \leq 45\ °\text{F} \\ \dot{Q}_h^{k=3}(5) + \dfrac{\left[\dot{Q}_h^{k=3}(17) - \dot{Q}_h^{k=3}(5)\right] * (T_j - 5)}{17 - 5}, & if\ T_j \leq 17\ °\text{F} \end{cases}$$

$$\dot{E}_h^{k=3}(T_j) = \begin{cases} \dot{E}_h^{k=3}(17) + \dfrac{\left[\dot{E}_h^{k=3}(35) - \dot{E}_h^{k=3}(17)\right] * (T_j - 17)}{35 - 17}, & if\ 17\ °\text{F} < T_j \leq 45\ °\text{F} \\ \dot{E}_h^{k=3}(5) + \dfrac{\left[\dot{E}_h^{k=3}(17) - \dot{E}_h^{k=3}(5)\right] * (T_j - 5)}{17 - 5}, & if\ T_j \leq 17\ °\text{F} \end{cases}$$

Determine $\dot{Q}_h^{k=3}(17)$ and $\dot{E}_h^{k=3}(17)$ from the $H3_3$ test and determine $\dot{Q}_h^{k=3}(5)$ and $\dot{E}_h^{k=3}(5)$ from the $H4_3$ test. Calculate all four quantities as specified in section 3.10 of this appendix. Determine the equation input for $\dot{Q}_h^{k=3}(35)$ and $\dot{E}_h^{k=3}(35)$ as specified in section 3.6.6 of this appendix.

4.2.6.1 Steady-State Space Heating Capacity When Operating at Low Compressor Capacity Is Greater Than or Equal to the Building Heating Load at Temperature T_j, $\dot{Q}_h^{k=1}(T_j) \geq BL(T_j)$., and the Heat Pump Permits Low Compressor Capacity at T_j. Evaluate the Quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

using Eqs. 4.2.3–1 and 4.2.3–2, respectively. Determine the equation inputs $X^{k=1}(T_j)$, PLF_j, and $\delta'(T_j)$ as specified in section 4.2.3.1. In calculating the part load factor, PLF_j, use the low-capacity cyclic-degradation coefficient $C_D{}^h$, [or equivalently, $C_D{}^h(k=1)$] determined in accordance with section 3.6.6 of this appendix.

4.2.6.2 Heat Pump Only Operates at High (k=2) Compressor Capacity at Temperature T_j and Its Capacity Is Greater Than or Equal to the Building Heating Load, $BL(T_j) \leq \dot{Q}_h^{k=2}(T_j)$

Evaluate the quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.3 of this appendix. Determine the equation inputs $X^{k=2}(T_j)$, PLF_j, and $\delta'(T_j)$ as specified in section 4.2.3.3 of this appendix. In calculating the part load factor, PLF_j, use the high-capacity cyclic-degradation coefficient, $C_D{}^h(k=2)$ determined in accordance with section 3.6.6 of this appendix.

4.2.6.3 Heat Pump Only Operates at Booster (k=3) Compressor Capacity at Temperature T_j and its Capacity Is Greater Than or Equal to the Building Heating Load, $BL(T_j) \leq \dot{Q}_h^{k=3}(T_j)$

Calculate $\frac{RH(T_j)}{N}$ and using Eq. 4.2.3-2. Evaluate $\frac{e_h(T_j)}{N}$ using

$$\frac{e_h(T_j)}{N} = \frac{X^{k=3}(T_j) * \dot{E}_h^{k=3}(T_j) * \delta'(T_j)}{PLF_j} * \frac{n_j}{N}$$

where

$$X^{k=3}(T_j) = BL(T_j)/\dot{Q}_h^{k=3}(T_j) \text{ and } PLF_j = 1 - C_D^h(k=3) * [1 - X^{k=3}(T_j)$$

Determine the low temperature cut-out factor, $\delta'(T_j)$, using Eq. 4.2.3–3. Use the booster-capacity cyclic-degradation coefficient, $C_D{}^h(k=3)$ determined in accordance with section 3.6.6 of this appendix.

4.2.6.4 Heat Pump Alternates Between High (k=2) and Low (k=1) Compressor Capacity To Satisfy the Building Heating Load at a Temperature T_j, $\dot{Q}_h^{k=1}(T_j) < BL(T_j) < \dot{Q}_h^{k=2}(T_j)$

Evaluate the quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.2 of this appendix. Determine the equation inputs $X^{k=1}(T_j)$, $X^{k=2}(T_j)$, and $\delta'(T_j)$ as specified in section 4.2.3.2 of this appendix.

4.2.6.5 Heat Pump Alternates Between High (k=2) and Booster (k=3) Compressor Capacity To Satisfy the Building Heating Load at a Temperature T_j, $\dot{Q}_h^{k=2}(T_j) < BL(T_j) < \dot{Q}_h^{k=3}(T_j)$

Calculate $\frac{RH(T_j)}{N}$ and using Eq. 4.2.3-2. Evaluate $\frac{e_h(T_j)}{N}$ using

$$\frac{e_h(T_j)}{N} = [X^{k=2}(T_j) * \dot{E}_h^{k=2}(T_j) + X^{k=3}(T_j) * \dot{E}_h^{k=3}(T_j)] * \delta'(T_j) * \frac{n_j}{N}$$

where:

$$X^{k=2}(T_j) = \frac{\dot{Q}_h^{k=3}(T_j) - BL(T_j)}{\dot{Q}_h^{k=3}(T_j) - \dot{Q}_h^{k=2}(T_j)}$$

and $X^{k=3}(T_j) = 1 - X^{k=2}(T_j)$ = the heating mode, booster capacity load factor for temperature bin j, dimensionless. Determine the low temperature cut-out factor, $\delta'(T_j)$, using Eq. 4.2.3–3.

4.2.6.6 Heat Pump Only Operates at Low (k=1) Capacity at Temperature T_j and Its Capacity Is Less Than the Building Heating Load, $BL(T_j) > \dot{Q}_h^{k=1}(T_j)$

$$\frac{e_h(T_j)}{N} = \dot{E}_h^{k=1}(T_j) * \delta'(T_j) * \frac{n_j}{N} \quad \text{and} \frac{RH(T_j)}{N} = \frac{BL(T_j) - [\dot{Q}_h^{k=1}(T_j) * \delta'(T_j)]}{3.413\frac{Btu/h}{W}} * \frac{n_j}{N}$$

where the low temperature cut-out factor, $\delta'(T_j)$, is calculated using Eq. 4.2.3–3.

4.2.6.7 Heat Pump Only Operates at High (k=2) Capacity at Temperature T_j and Its Capacity Is Less Than the Building Heating Load, $BL(T_j) > \dot{Q}_h^{k=2}(T_j)$

Evaluate the quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.4 of this appendix. Calculate $\delta''(T_j)$ using the equation given in section 4.2.3.4 of this appendix.

4.2.6.8 Heat Pump Only Operates at Booster (k=3) Capacity at Temperature T_j and Its Capacity Is Less Than the Building Heating Load, $BL(T_j) > \dot{Q}_h^{k=3}(T_j)$ or the System Converts To Using Only Resistive Heating

$$\frac{e_h(T_j)}{N} = \dot{E}_h^{k=3}(T_j) * \delta'(T_j) * \frac{n_j}{N} \quad \text{and} \quad \frac{RH(T_j)}{N} = \frac{BL(T_j) - [\dot{Q}_h^{k=3}(T_j) * \delta'(T_j)]}{3.413\frac{Btu/h}{W}} * \frac{n_j}{N}$$

where $\delta''(T_j)$ is calculated as specified in section 4.2.3.4 of this appendix if the heat pump is operating at its booster compressor capacity. If the heat pump system converts to using only resistive heating at outdoor temperature T_j, set $\delta'(T_j)$ equal to zero.

4.2.7 Additional Steps for Calculating the HSPF2 of a Heat Pump Having a Single Indoor Unit With Multiple Indoor Blowers. The Calculation of the Eq. 4.2–1 Quantities $e_h(T_j)/N$ and $RH(T_j)/N$ Are Evaluated as Specified in the Applicable Subsection

4.2.7.1 For Multiple Indoor Blower Heat Pumps That Are Connected to a Singular, Single-Speed Outdoor Unit

a. Calculate the space heating capacity, $\dot{Q}_h^{k=1}$ (Tj), and electrical power consumption, $\dot{E}_h^{k=1}$ (Tj), of the heat pump when operating at the heating minimum air volume rate and outdoor temperature T_j using Eqs. 4.2.2–3 and 4.2.2–4, respectively. Use these same equations to calculate the space heating capacity, $\dot{Q}_h^{k=2}$ (Tj) and electrical power consumption, $\dot{E}_h^{k=2}$ (Tj), of the test unit when operating at the heating full-load air volume rate and outdoor temperature T_j. In evaluating Eqs. 4.2.2–3 and 4.2.2– 4, determine the quantities $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the $H1_1$ test; determine $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the $H1_2$ test. Evaluate all four quantities according to section 3.7 of this appendix. Determine the quantities $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ as specified in section 3.6.2 of this appendix. Determine $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the $H2_2$ frost accumulation test as calculated according to section 3.9.1 of this appendix. Determine the quantities $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ from the $H3_1$ test, and $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the $H3_2$ test. Evaluate all four quantities according to section 3.10 of this appendix. Refer to section 3.6.2 and Table 12 of this appendix for additional information on the referenced laboratory tests.

b. Determine the heating mode cyclic degradation coefficient, C_D^h, as per sections 3.6.2 and 3.8 to 3.8.1 of this appendix. Assign this same value to $C_D^h(k = 2)$.

c. Except for using the above values of $\dot{Q}_h^{k=1}(Tj)$, $\dot{E}_h^{k=1}(Tj)$, $\dot{Q}_h^{k=2}(Tj)$, $\dot{E}_h^{k=2}(Tj)$, C_D^h, and $C_D^h(k = 2)$, calculate the quantities $e_h(T_j)/N$ as specified in section 4.2.3.1 of this appendix for cases where $\dot{Q}_h^{k=1}(Tj) \geq BL(T_j)$. For all other outdoor bin temperatures, T_j, calculate $e_h(Tj)/N$ and $RH_h(Tj)/N$ as specified in section 4.2.3.3 of this appendix if $\dot{Q}_h^{k=2}(Tj) > BL(Tj)$ or as specified in section 4.2.3.4 of this appendix if $\dot{Q}_h^{k=2}(Tj) \leq BL(T_j)$.

4.2.7.2 For Multiple Indoor Blower Heat Pumps Connected to Either a Single Outdoor Unit With a Two-Capacity Compressor or to Two Separate but Identical Model Single-Speed Outdoor Units. Calculate the Quantities $e_h(T_j)/N$ and $RH(T_j)/N$ as Specified in Section 4.2.3 of This Appendix

4.3 Calculations of Off-Mode Power Consumption

For central air conditioners and heat pumps with a cooling capacity of: Less than 36,000 Btu/h, determine the off mode represented value, $P_{W,OFF}$, with the following equation:

$$P_{W,OFF} = \frac{P1 + P2}{2};$$

greater than or equal to 36,000 Btu/h, calculate the capacity scaling factor according to:

$$F_{scale} = \frac{\dot{Q}_C(95)}{36{,}000},$$

where, $\dot{Q}_C(95)$ is the total cooling capacity at the A or A_2 test condition, and determine the off mode represented value, $P_{W,OFF}$, with the following equation:

$$P_{W,OFF} = \frac{P1 + P2}{2 \times F_{scale}};$$

4.4 Rounding of SEER2 and HSPF2 for Reporting Purposes

After calculating SEER2 according to section 4.1 of this appendix and HSPF2 according to section 4.2 of this appendix round the values off as specified per §430.23(m) of title 10 of the Code of Federal Regulations.




Figure 1—Climatic Regions I through VI for the United States

TABLE 21—REPRESENTATIVE COOLING AND HEATING LOAD HOURS FOR EACH GENERALIZED CLIMATIC REGION

Climatic region	Cooling load hours CLH_R	Heating load hours HLH_R
I	2,400	493
II	1,800	857
III	1,200	1,247
IV	800	1,701
Rating Values	1,000	1,572
V	400	2,202
VI	200	1,842

4.5 Calculations of the SHR, Which Should Be Computed for Different Equipment Configurations and Test Conditions Specified in Table 22.

TABLE 22—APPLICABLE TEST CONDITIONS FOR CALCULATION OF THE SENSIBLE HEAT RATIO

Equipment configuration	Reference table number of Appendix M	SHR computation with results from	Computed values
Units Having a Single-Speed Compressor and a Fixed-Speed Indoor Blower, a Constant Air Volume Rate Indoor Blower, or Single-Speed Coil-Only.	4	B Test	SHR(B).
Units Having a Single-Speed Compressor That Meet the section 3.2.2.1 Indoor Unit Requirements.	5	B2 and B1 Tests	SHR(B1), SHR(B2).
Units Having a Two-Capacity Compressor	6	B2 and B1 Tests	SHR(B1), SHR(B2).
Units Having a Variable-Speed Compressor	7	B2 and B1 Tests	SHR(B1), SHR(B2).

The SHR is defined and calculated as follows:

$$SHR = \frac{Sensible\ Cooling\ Capacity}{Total\ Cooling\ Capacity}$$

$$= \frac{\dot{Q}_{sc}^{k}(T)}{\dot{Q}_{c}^{k}(T)}$$

Where both the total and sensible cooling capacities are determined from the same cooling mode test and calculated from data collected over the same 30-minute data collection interval.

4.6 Calculations of the Energy Efficiency Ratio (EER)

Calculate the energy efficiency ratio using,

$$EER = \frac{Total\ Cooling\ Capacity}{Total\ Electrical\ Power\ Consumption}$$

$$= \frac{\dot{Q}_{c}^{k}(T)}{\dot{E}_{c}^{k}(T)}$$

where $\dot{Q}_{c}^{k}(T)$ and $\dot{E}_{c}^{k}(T)$ are the space cooling capacity and electrical power consumption determined from the 30-minute data collection interval of the same steady-state wet coil cooling mode test and calculated as specified in section 3.3 of this appendix. Add the letter identification for each steady-state test as a subscript (*e.g.*, EER_{A_2}) to differentiate among the resulting EER values. The represented value of EER is determined from the A or A_2 test, whichever is applicable. The represented value of EER determined in accordance with this appendix is called EER2.

[82 FR 1533, Jan. 5, 2017, as amended at 86 FR 68394, Dec. 2, 2021; 87 FR 64588, Oct. 25, 2022; 87 FR 66935, Nov. 7, 2022]

APPENDIX N TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CONSUMER FURNACES OTHER THAN BOILERS

0. Incorporation by Reference

DOE incorporated by reference in §430.3, the entire standards for ASTM D2156R13 and IEC 62301. DOE also incorporated selected provisions of ASHRAE 103–1993.

1. *Scope.* The scope of this appendix is as specified in section 2 of ASHRAE 103–1993 as it pertains to furnaces other than low pressure steam or hot water boilers or to electric boilers. Low pressure steam or hot water boilers and electric boilers are addressed in appendix EE of this subpart.

2. *Definitions.* Definitions include those specified in section 3 of ASHRAE 103–1993 and the following additional and modified definitions.

Active mode means the condition in which the furnace is connected to the power source, and at least one of the burner, electric resistance elements, or any electrical auxiliaries such as blowers, are activated.

Control means a device used to regulate the operation of a piece of equipment and the supply of fuel, electricity, air, or water.

Draft inducer means a fan incorporated in the furnace that either draws or forces air into the combustion chamber.

Gas valve means an automatic or semi-automatic device consisting essentially of a valve and operator that controls the gas supply to the burner(s) during normal operation of an appliance. The operator may be actuated by application of gas pressure on a flexible diaphragm, by electrical means, by mechanical means or by other means.

Installation and operation (I&O) manual means instructions for installing, commissioning, and operating the furnace, which are supplied with the product when shipped by the manufacturer.

Isolated combustion system means a system where a unit is installed within the structure, but isolated from the heated space. A portion of the jacket heat from the unit is lost, and air for ventilation, combustion and draft control comes from outside the heated space.

Multi-position furnace means a furnace that can be installed in more than one airflow configuration (*i.e.*, upflow or horizontal; downflow or horizontal; upflow or downflow; and upflow, or downflow, or horizontal).

Off mode means a mode in which the furnace is connected to a mains power source and is not providing any active mode or standby mode function, and where the mode may persist for an indefinite time. The existence of an off switch in off position (a disconnected circuit) is included within the classification of off mode.

Off switch means the switch on the furnace that, when activated, results in a measurable change in energy consumption between the standby and off modes.

Oil control valve means an automatically or manually operated device consisting of an oil valve for controlling the fuel supply to a burner to regulate burner input.

Standby mode means any mode in which the furnace is connected to a mains power source and offers one or more of the following space heating functions that may persist:

(a) Activation of other modes (including activation or deactivation of active mode) by remote switch (including thermostat or remote control), internal or external sensors, and/or timer; and

(b) Continuous functions, including information or status displays or sensor-based functions.

Thermal stack damper means a type of stack damper that relies exclusively upon the changes in temperature in the stack gases to open or close the damper.

3. *Classifications.* Classifications are as specified in section 4 of ASHRAE 103–1993 for furnaces.

4. *Requirements.* Requirements are as specified in section 5 of ASHRAE 103–1993 for furnaces.

5. *Instruments.* Instruments must be as specified in section 6 of ASHRAE 103–1993.

6. *Apparatus.* The apparatus used in conjunction with the furnace during the testing must be as specified in section 7 of ASHRAE 103–1993 (except for the excluded sub-sections as enumerated at §430.3(g)(15)); and as specified in sections 6.1 through 6.5 of this appendix.

6.1 *General.*

(a) Install the furnace in the test room in accordance with the I&O manual, as defined in section 2.6 of this appendix, except that if provisions within this appendix are specified, then the provisions herein drafted and prescribed by DOE govern. If the I&O manual and any additional provisions of this appendix are not sufficient for testing a furnace, the manufacturer must request a waiver from the test procedure pursuant to §430.27.

(b) If the I&O manual indicates the unit should not be installed with a return duct, then the return (inlet) duct specified in section 7.2.1 of ASHRAE 103–1993 is not required.

(c) Test multi-position furnaces in the least efficient configuration. Testing of multi-position furnaces in other configurations is permitted if energy use or efficiency is represented pursuant to the requirements in 10 CFR part 429.

(d) The apparatuses described in section 6 of this appendix are used in conjunction with

the furnace during testing. Each piece of apparatus shall conform to material and construction specifications listed in this appendix and in ASHRAE 103–1993, and the reference standards cited in this appendix and in ASHRAE 103–1993.

(e) Test rooms containing equipment must have suitable facilities for providing the utilities (including but not limited to environmental controls, applicable measurement equipment, and any other technology or tools) necessary for performance of the test and must be able to maintain conditions within the limits specified in section 6 of this appendix.

6.2 *Forced-air central furnaces (direct vent and direct exhaust).*

(a) Units not equipped with a draft hood or draft diverter must be provided with the minimum-length vent configuration recommended in the I&O manual or a 5-ft flue pipe if there is no recommendation provided in the I&O manual (*see* Figure 4 of ASHRAE 103–1993). For a direct exhaust system, insulate the minimum-length vent configuration or the 5-ft flue pipe with insulation having an R-value not less than 7 and an outer layer of aluminum foil. For a direct vent system, *see* section 7.5 of ASHRAE 103–1993 for insulation requirements.

(b) For units with power burners, cover the flue collection box with insulation having an R-value of not less than 7 and an outer layer of aluminum foil before the cool-down and heat-up tests described in sections 9.5 and 9.6 of ASHRAE 103–1993, respectively. However, do not apply the insulation for the jacket loss test (if conducted) described in section 8.6 of ASHRAE 103–1993 or the steady-state test described in section 9.1 of ASHRAE 103–1993.

(c) For power-vented units, insulate the shroud surrounding the blower impeller with insulation having an R-value of not less than 7 and an outer layer of aluminum foil before the cool-down and heat-up tests described in sections 9.5 and 9.6, respectively, of ASHRAE 103–1993. However, do not apply the insulation for the jacket loss test (if conducted) described in section 8.6 of ASHRAE 103–1993 or the steady-state test described in section 9.1 of ASHRAE 103–1993. Do not insulate the blower motor or block the airflow openings that facilitate the cooling of the combustion blower motor or bearings.

6.3 *Downflow furnaces.* Install an internal section of vent pipe the same size as the flue collar for connecting the flue collar to the top of the unit, if not supplied by the manufacturer. However, do not insulate the internal vent pipe during the jacket loss test (if conducted) described in section 8.6 of ASHRAE 103–1993 or the steady-state test described in section 9.1 of ASHRAE 103–1993. Do not insulate the internal vent pipe before the cool-down and heat-up tests described in sections 9.5 and 9.6, respectively, of ASHRAE 103–1993. If the vent pipe is surrounded by a metal jacket, do not insulate the metal jacket. Install a 5-ft test stack of the same cross-sectional area or perimeter as the vent pipe above the top of the furnace. Tape or seal around the junction connecting the vent pipe and the 5-ft test stack. Insulate the 5-ft test stack with insulation having an R-value not less than 7 and an outer layer of aluminum foil. (*See* Figure 3–E of ASHRAE 103–1993.)

6.4 *Units with draft hoods or draft diverters.* Install the stack damper in accordance with the I&O manual. Install 5 feet of stack above the damper.

(a) For units with an integral draft diverter, cover the 5-ft stack with insulation having an R-value of not less than 7 and an outer layer of aluminum foil.

(b) For units with draft hoods, insulate the flue pipe between the outlet of the furnace and the draft hood with insulation having an R-value of not less than 7 and an outer layer of aluminum foil.

(c) For units with integral draft diverters that are mounted in an exposed position (not inside the overall unit cabinet), cover the diverter boxes (excluding any openings through which draft relief air flows) before the beginning of any test (including jacket loss test) with insulation having an R-value of not less than 7 and an outer layer of aluminum foil.

(d) For units equipped with integral draft diverters that are enclosed within the overall unit cabinet, insulate the draft diverter box with insulation as described in section 6.4.c before the cool-down and heat-up tests described in sections 9.5 and 9.6, respectively, of ASHRAE 103–1993. However, do not apply the insulation for the jacket loss test (if conducted) described in section 8.6 of ASHRAE 103–1993 or the steady-state test described in section 9.1 of ASHRAE 103–1993.

6.5 *Condensate collection.* Attach condensate drain lines to the unit as specified in the I&O manual. Maintain a continuous downward slope of drain lines from the unit. Additional precautions (such as eliminating any line configuration or position that would otherwise restrict or block the flow of condensate or checking to ensure a proper connection with condensate drain spout that allows for unobstructed flow) must be taken to facilitate uninterrupted flow of condensate during the test. Collection containers must be glass or polished stainless steel to facilitate removal of interior deposits. The collection container must have a vent opening to the atmosphere.

7. *Testing conditions.* The testing conditions must be as specified in section 8 of ASHRAE 103–1993 (except for the excluded sub-sections as enumerated at §430.3(g)(15)); and as specified in sections 7.1 to 7.9 of this appendix, respectively.

7.1 *Fuel supply, gas.* In conducting the tests specified herein, gases with characteristics as shown in Table 1 of ASHRAE 103–1993 shall be used. Maintain the gas supply, ahead of all controls for a furnace, at a test pressure between the normal and increased values shown in Table 1 of ASHRAE 103–1993. Maintain the regulator outlet pressure at a level approximating that recommended in the I&O manual, as defined in section 2.6 of this appendix, or, in the absence of such recommendation, to the nominal regulator settings used when the product is shipped by the manufacturer. Use a gas having a specific gravity as shown in Table 1 of ASHRAE 103–1993 and with a higher heating value within ±5% of the higher heating value shown in Table 1 of ASHRAE 103–1993. Determine the actual higher heating value in Btu per standard cubic foot for the gas to be used in the test within an error no greater than 1%.

7.2 *Gas burner.* Adjust the burners of gas-fired furnaces to their maximum Btu input ratings at the normal test pressure specified by section 7.1 of this appendix. Correct the burner input rate to reflect gas characteristics at a temperature of 60 °F and atmospheric pressure of 30 in of Hg and adjust down to within ±2 percent of the hourly Btu nameplate input rating specified by the manufacturer as measured during the steady-state performance test in section 8 of this appendix. Set the primary air shutters in accordance with the I&O manual to give a good flame at this condition. If, however, the setting results in the deposit of carbon on the burners during any test specified herein, the tester shall adjust the shutters and burners until no more carbon is deposited and shall perform the tests again with the new settings (*see* Figure 9 of ASHRAE 103–1993). After the steady-state performance test has been started, do not make additional adjustments to the burners during the required series of performance tests specified in section 9 of ASHRAE 103–1993. If a vent-limiting means is provided on a gas pressure regulator, keep it in place during all tests.

7.3 *Modulating gas burner adjustment at reduced input rate.* For gas-fired furnaces equipped with modulating-type controls, adjust the controls to operate the unit at the nameplate minimum input rate. If the modulating control is of a non-automatic type, adjust the control to the setting recommended in the I&O manual. In the absence of such recommendation, the midpoint setting of the non-automatic control shall be used as the setting for determining the reduced fuel input rate. Start the furnace by turning the safety control valve to the ''ON'' position.

7.4 *Oil burner.* Adjust the burners of oil-fired furnaces to give a CO_2 reading specified in the I&O manual and an hourly Btu input during the steady-state performance test described in section 8 of this appendix. Ensure the hourly BTU input is within ±2% of the normal hourly Btu input rating as specified in the I&O manual. Smoke in the flue may not exceed a No. 1 smoke during the steady-state performance test as measured by the procedure in ASTM D2156R13). Maintain the average draft over the fire and in the flue during the steady-state performance test at the value specified in the I&O manual. Do not allow draft fluctuations exceeding 0.005 in. water. Do not make additional adjustments to the burner during the required series of performance tests. The instruments and measuring apparatus for this test are described in section 6 of this appendix and shown in Figure 8 of ASHRAE 103–1993.

7.5 *Temperature Rise Targets.* Adjust air throughputs to achieve a temperature rise that is the higher of a and b, below, unless c applies. A tolerance of ±2 °F is permitted.

(a) 15 °F less than the nameplate maximum temperature rise or

(b) 15 °F higher than the minimum temperature rise specified in the I&O manual.

(c) A furnace with a non-adjustable air temperature rise range and an automatically controlled airflow that does not permit a temperature rise range of 30 °F or more must be tested at the midpoint of the rise range.

7.6 *Temperature Rise Adjustments.* Establish the temperature rise specified in section 7.5 of this appendix by adjusting the circulating airflow. This adjustment must be accomplished by symmetrically restricting the outlet air duct and varying blower speed selection to obtain the desired temperature rise and minimum external static pressure, as specified in Table 4 of ASHRAE 103–1993. If the required temperature rise cannot be obtained at the minimum specified external static pressure by adjusting blower speed selection and duct outlet restriction, then the following applies.

(a) If the resultant temperature rise is less than the required temperature rise, vary the blower speed by gradually adjusting the blower voltage so as to maintain the minimum external static pressure listed in Table 4 of ASHRAE 103–1993. The airflow restrictions shall then remain unchanged. If static pressure must be varied to prevent unstable blower operation, then increase the static pressure until blower operation is stabilized, except that the static pressure must not exceed the maximum external static pressure as specified by the manufacturer in the I&O manual.

(b) If the resultant temperature rise is greater than the required temperature rise, then the unit can be tested at a higher temperature rise value, but one not greater than nameplate maximum temperature rise. In order not to exceed the maximum temperature rise, the speed of a direct-driven blower may be increased by increasing the circulating air blower motor voltage.

7.7 *Measurement of jacket surface temperature.* Divide the jacket of the furnace into 6-inch squares when practical, and otherwise into 36-square-inch regions comprising 4-inch by 9-inch or 3-inch by 12-inch sections, and determine the surface temperature at the center of each square or section with a surface thermocouple. Record the surface temperature of the 36-square-inch areas in groups where the temperature differential of the 36-square-inch areas is less than 10 °F for temperature up to 100 °F above room temperature, and less than 20 °F for temperatures more than 100 °F above room temperature. For forced-air central furnaces, the circulating air blower compartment is considered as part of the duct system, and no surface temperature measurement of the blower compartment needs to be recorded for the purpose of this test. For downflow furnaces, measure all cabinet surface temperatures of the heat exchanger and combustion section, including the bottom around the outlet duct and the burner door, using the 36-square-inch thermocouple grid. The cabinet surface temperatures around the blower section do not need to be measured (*See* Figure 3–E of ASHRAE 103–1993).

7.8 *Installation of vent system.* Keep the vent or air intake system supplied by the manufacturer in place during all tests. Test units intended for installation with a variety of vent pipe lengths with the minimum vent length as specified in the I&O manual, or a 5-ft. flue pipe if there are no recommendations in the I&O manual. Do not connect a furnace employing a direct vent system to a chimney or induced-draft source. Vent combustion products solely by using the venting incorporated in the furnace and the vent or air intake system supplied by the manufacturer. For units that are not designed to significantly preheat the incoming air, see section 7.4 of this appendix and Figure 4a or 4b of ASHRAE 103–1993. For units that do significantly preheat the incoming air, see Figure 4c or 4d of ASHRAE 103–1993.

7.9 *Additional optional method of testing for determining D_P and D_F for furnaces.* On units whose design is such that there is no measurable airflow through the combustion chamber and heat exchanger when the burner(s) is (are) off as determined by the optional test procedure in section 7.9.1 of this appendix, D_F and D_P may be set equal to 0.05.

7.9.1 *Optional test method for indicating the absence of flow through the heat exchanger.* Manufacturers may use the following test protocol to determine whether air flows through the combustion chamber and heat exchanger when the burner(s) is (are) off. The minimum default draft factor may be used only for units determined pursuant to this protocol to have no airflow through the combustion chamber and heat exchanger.

7.9.1.1 *Test apparatus.* Use a smoke stick that produces smoke that is easily visible and has a density less than or approximately equal to air. Use a smoke stick that produces smoke that is non-toxic to the test personnel and produces gas that is unreactive with the environment in the test chamber.

7.9.1.2 *Test conditions.* Minimize all air currents and drafts in the test chamber, including turning off ventilation if the test chamber is mechanically ventilated. Wait at least two minutes following the termination of the furnace on-cycle before beginning the optional test method for indicating the absence of flow through the heat exchanger.

7.9.1.3 *Location of the test apparatus.* After all air currents and drafts in the test chamber have been eliminated or minimized, position the smoke stick based on the following equipment configuration:

(a) For horizontal combustion air intakes, approximately 4 inches from the vertical plane at the termination of the intake vent and 4 inches below the bottom edge of the combustion air intake; or

(b) for vertical combustion air intakes, approximately 4 inches horizontal from vent perimeter at the termination of the intake vent and 4 inches down (parallel to the vertical axis of the vent).

7.9.1.4 *Duration of test.* Establish the presence of smoke from the smoke stick and then monitor the direction of the smoke flow for no less than 30 seconds.

7.9.1.5 *Test results.* During visual assessment, determine whether there is any draw of smoke into the combustion air intake vent.

(a) If absolutely no smoke is drawn into the combustion air intake, the furnace meets the requirements to allow use of the minimum default draft factor pursuant to section 7.9 of this appendix.

(b) If there is any smoke drawn into the intake, proceed with the methods of testing as prescribed in section 8.8 of ASHRAE 103–1993.

8. *Test procedure.* Conduct testing and measurements as specified in section 9 of ASHRAE 103–1993 (except for the excluded sub-sections as enumerated at §430.3(g)(15)); and as specified in sections 8.1 through 8.10 of this appendix. Section 8.4 of this appendix may be used in lieu of section 9.2 of ASHRAE 103–1993.

8.1 *Fuel input.* For gas units, measure and record the steady-state gas input rate in Btu/hr, including pilot gas, corrected to standard conditions of 60 °F and 30 in. Hg. Use measured values of gas temperature and pressure at the meter and barometric pressure to correct the metered gas flow rate to the above standard conditions. For oil units, measure and record the steady-state fuel input rate.

8.2 *Electrical input.* During the steady-state test, perform a single measurement of all of the electrical power involved in burner operation (PE), including energizing the ignition system, controls, gas valve or oil control valve, and draft inducer, if applicable.

During the steady-state test, perform a single measurement of the electrical power to the circulating air blower (BE).

8.3 *Input to interrupted ignition device.* For burners equipped with an interrupted ignition device, record the nameplate electric power used by the ignition device, PE_{IG}, or record that PE_{IG} = 0.4 kW if no nameplate power input is provided. Record the nameplate ignition device on-time interval, t_{IG}, or, if the nameplate does not provide the ignition device on-time interval, measure the on-time interval with a stopwatch at the beginning of the test, starting when the burner is turned on. Set t_{IG} = 0 and PE_{IG} = 0 if the device on-time interval is less than or equal to 5 seconds after the burner is on.

8.4 *Optional test procedures for condensing furnaces, measurement of condensate during the establishment of steady-state conditions.* For units with step-modulating or two-stage controls, conduct the test at both the maximum and reduced inputs. In lieu of collecting the condensate immediately after the steady state conditions have been reached as required by section 9.2 of ASHRAE 103–1993, condensate may be collected during the establishment of steady state conditions as defined by section 9.1.2.1 of ASHRAE 103–1993. Perform condensate collection for at least 30 minutes. Measure condensate mass immediately at the end of the collection period to prevent evaporation loss from the sample. Record fuel input for the 30-minute condensate collection test period. Observe and record fuel higher heating value (HHV), temperature, and pressures necessary for determining fuel energy input ($Q_{C,SS}$). Measure the fuel quantity and HHV with errors no greater than 1%. The humidity for the room air shall at no time exceed 80%. Determine the mass of condensate for the establishment of steady state conditions ($M_{C,SS}$) in pounds by subtracting the tare container weight from the total container and condensate weight measured at the end of the 30-minute condensate collection test period.

8.5 *Cool-down test for gas- and oil-fueled gravity and forced-air central furnaces without stack dampers.* Turn off the main burner after completing steady-state testing, and measure the flue gas temperature by means of the thermocouple grid described in section 7.6 of ASHRAE 103–1993 at 1.5 minutes ($T_{F,OFF}(t_3)$) and 9 minutes ($T_{F,OFF}(t_4)$) after shutting off the burner. When taking these temperature readings, the integral draft diverter must remain blocked and insulated, and the stack restriction must remain in place. On atmospheric systems with an integral draft diverter or draft hood and equipped with either an electromechanical inlet damper or an electromechanical flue damper that closes within 10 seconds after the burner shuts off to restrict the flow through the heat exchanger in the off-cycle, bypass or adjust the control for the electromechanical damper so that the damper remains open during the cool-down test.

For furnaces that employ post-purge, measure the length of the post-purge period with a stopwatch. Record the time from burner ''OFF'' to combustion blower ''OFF'' (electrically de-energized) as t_P. If the measured t_P is less than or equal to 30 seconds, set t_P at 0 and conduct the cool-down test as if there is no post-purge. If t_P is prescribed by the I&O manual or measured to be greater than 180 seconds, stop the combustion blower at 180 seconds and use that value for t_P. Measure the flue gas temperature by means of the thermocouple grid described in section 7.6 of ASHRAE 103–1993 at the end of the post-purge period, $t_P(T_{F,OFF}(t_P))$, and at the time (1.5 + t_P) minutes ($T_{F,OFF}(t_3)$) and (9.0 + t_P) minutes ($T_{F,OFF}(t_4)$) after the main burner shuts off.

8.6 *Cool-down test for gas- and oil-fueled gravity and forced-air central furnaces without stack dampers and with adjustable fan control.* For a furnace with adjustable fan control, measure the time delay between burner shutdown and blower shutdown, t^+. This time delay, t^+, will be 3.0 minutes for non-condensing furnaces or 1.5 minutes for condensing furnaces or until the supply air temperature drops to a value of 40 °F above the inlet air temperature, whichever results in the longest fan on-time. For a furnace without adjustable fan control or with the type of adjustable fan control whose range of adjustment does not allow for the time delay, t^+, specified above, bypass the fan control and manually control the fan to allow for the appropriate delay time as specified in section 9.5.1.2 of ASHRAE 103–1993. For a furnace that employs a single motor to drive both the power burner and the indoor air circulating blower, the power burner and indoor air circulating blower must be stopped at the same time.

8.7 [Reserved]

8.8 *Calculation options.* The rate of the flue gas mass flow through the furnace and the factors D_P, D_F, and D_S are calculated by the equations in sections 11.6.1, 11.6.2, 11.6.3, 11.6.4, 11.7.1, and 11.7.2 of ASHRAE 103–1993. On units whose design is such that there is no measurable airflow through the combustion chamber and heat exchanger when the burner(s) is (are) off (as determined by the optional test procedure in section 7.9 of this appendix), D_F and D_P may be set equal to 0.05.

8.9 *Optional test procedures for condensing furnaces that have no off-period flue losses.* For units that have applied the test method in section 7.9 of this appendix to determine that no measurable airflow exists through the combustion chamber and heat exchanger during the burner off-period and having post-purge periods of less than 5 seconds, the cool-down and heat-up tests specified in sections 9.5 and 9.6 of ASHRAE 103–1993 may be omitted. In lieu of conducting the cool-down and

heat-up tests, the tester may use the losses determined during the steady-state test described in section 9.1 of ASHRAE 103–1993 when calculating heating seasonal efficiency, $Effy_{HS}$.

8.10 *Measurement of electrical standby and off mode power.*

8.10.1 *Standby power measurement.* With all electrical auxiliaries of the furnace not activated, measure the standby power ($P_{W,SB}$) in accordance with the procedures in IEC 62301, except that section 8.5, *Room Ambient Temperature,* of ASHRAE 103–1993 and the voltage provision of section 8.2.1.4, *Electrical Supply,* of ASHRAE 103–1993 shall apply in lieu of the corresponding provisions of IEC 62301 at section 4.2, *Test room,* and the voltage specification of section 4.3, *Power supply.* Frequency shall be 60Hz. Clarifying further, IEC 62301 section 4.4, *Power measurement instruments,* and Section 5, *Measurements,* apply in lieu of ASHRAE 103–1993 section 6.10, *Energy Flow Rate.* Measure the wattage so that all possible standby mode wattage for the entire appliance is recorded, not just the standby mode wattage of a single auxiliary. Round the recorded standby power ($P_{W,SB}$) to the second decimal place, except for loads greater than or equal to 10W, which must be recorded to at least three significant figures.

8.10.2 *Off mode power measurement.* If the unit is equipped with an off switch or there is an expected difference between off mode power and standby mode power, measure off mode power ($P_{W,OFF}$) in accordance with the standby power procedures in IEC 62301, except that section 8.5, *Room Ambient Temperature,* of ASHRAE 103–1993 and the voltage provision of section 8.2.1.4, *Electrical Supply,* of ASHRAE 103–1993 shall apply in lieu of the corresponding provisions of IEC 62301 at section 4.2, *Test room,* and the voltage specification of section 4.3, *Power supply.* Frequency shall be 60Hz. Clarifying further, IEC 62301 section 4.4, *Power measurement instruments,* and section 5, *Measurements,* apply for this measurement in lieu of ASHRAE 103–1993 section 6.10, *Energy Flow Rate.* Measure the wattage so that all possible off mode wattage for the entire appliance is recorded, not just the off mode wattage of a single auxiliary. If there is no expected difference in off mode power and standby mode power, let $P_{W,OFF} = P_{W,SB}$, in which case no separate measurement of off mode power is necessary. Round the recorded off mode power ($P_{W,OFF}$) to the second decimal place, except for loads greater than or equal to 10W, in which case round the recorded value to at least three significant figures.

9. *Nomenclature.* Nomenclature includes the nomenclature specified in section 10 of ASHRAE 103–1993 and the following additional variables:

Eff_{motor} = Efficiency of power burner motor

PE_{IG} = Electrical power to the interrupted ignition device, kW

$R_{T,a} = R_{T,F}$ if flue gas is measured

$= R_{T,S}$ if stack gas is measured

$R_{T,F}$ = Ratio of combustion air mass flow rate to stoichiometric air mass flow rate

$R_{T,S}$ = Ratio of the sum of combustion air and relief air mass flow rate to stoichiometric air mass flow rate

t_{IG} = Electrical interrupted ignition device on-time, min.

$T_{a,SS,X} = T_{F,SS,X}$ if flue gas temperature is measured, °F

$= T_{S,SS,X}$ if stack gas temperature is measured, °F

y_{IG} = Ratio of electrical interrupted ignition device on-time to average burner on-time

y_P = Ratio of power burner combustion blower on-time to average burner on-time

E_{SO} = Average annual electric standby mode and off mode energy consumption, in kilowatt-hours

$P_{W,OFF}$ = Furnace off mode power, in watts

$P_{W,SB}$ = Furnace standby mode power, in watts

10. *Calculation of derived results from test measurements.* Perform calculations as specified in section 11 of ASHRAE 103–1993 (except for the excluded sub-sections as enumerated at §430.3(g)(15)); and as specified in sections 10.1 through 10.11 and Figure 1 of this appendix.

10.1 *Annual fuel utilization efficiency.* The annual fuel utilization efficiency (AFUE) is as defined in sections 11.2.12 (non-condensing systems), 11.3.12 (condensing systems), 11.4.12 (non-condensing modulating systems) and 11.5.12 (condensing modulating systems) of ASHRAE 103–1993, except for the definition for the term $Effy_{HS}$ in the defining equation for AFUE. $Effy_{HS}$ is defined as:

$Effy_{HS}$ = heating seasonal efficiency as defined in sections 11.2.11 (non-condensing systems), 11.3.11 (condensing systems), 11.4.11 (non-condensing modulating systems) and 11.5.11 (condensing modulating systems) of ASHRAE 103–1993, except that for condensing modulating systems sections 11.5.11.1 and 11.5.11.2 are replaced by sections 10.2 and 10.3 of this appendix. $Effy_{HS}$ is based on the assumptions that all weatherized warm air furnaces are located outdoors and that non-weatherized warm air furnaces are installed as isolated combustion systems.

10.2 *Part-load efficiency at reduced fuel input rate.* If the option in section 8.9 of this appendix is not employed, calculate the part-load efficiency at the reduced fuel input rate, $Effy_{U,R}$, for condensing furnaces equipped with either step-modulating or two-stage controls, expressed as a percent and defined as:

$$Effy_{U,H} = 100 - L_{L,A} + L_G - L_C - C_J L_J - \left[\frac{t_{ON}}{t_{ON} + \left(\frac{Q_P}{Q_{IN}}\right) t_{OFF}}\right](L_{S,ON} + L_{S,OFF} + L_{I,ON} + L_{I,OFF})$$

If the option in section 8.9 of this appendix is employed, calculate $\underline{Effy}_{U,R}$ as follows:

$$Effy_{U,H} = 100 - L_{L,A} + L_G - L_C - C_J L_J - \left[\frac{t_{ON}}{t_{ON} + \left(\frac{Q_P}{Q_{IN}}\right) t_{OFF}}\right](C_S)(L_{S,SS})$$

Where:

$L_{L,A}$ = value as defined in section 11.2.7 of ASHRAE 103–1993,

L_G = value as defined in section 11.3.11.1 of ASHRAE 103–1993, at reduced input rate,

L_C = value as defined in section 11.3.11.2 of ASHRAE 103–1993 at reduced input rate,

L_J = value as defined in section 11.4.8.1.1 of ASHRAE 103–1993 at maximum input rate,

t_{ON} = value as defined in section 11.4.9.11 of ASHRAE 103–1993,

Q_P = pilot fuel input rate determined in accordance with section 9.2 of ASHRAE 103–1993 in Btu/h,

Q_{IN} = value as defined in section 11.4.8.1.1 of ASHRAE 103–1993,

t_{OFF} = value as defined in section 11.4.9.12 of ASHRAE 103–1993 at reduced input rate,

$L_{S,ON}$ = value as defined in section 11.4.10.5 of ASHRAE 103–1993 at reduced input rate,

$L_{S,OFF}$ = value as defined in section 11.4.10.6 of ASHRAE 103–1993 at reduced input rate,

$L_{I,ON}$ = value as defined in section 11.4.10.7 of ASHRAE 103–1993 at reduced input rate,

$L_{I,OFF}$ = value as defined in section 11.4.10.8 of ASHRAE 103–1993 at reduced input rate,

C_J = jacket loss factor and equal to:

= 0.0 for furnaces intended to be installed indoors

= 1.7 for furnaces intended to be installed as isolated combustion systems

= 3.3 for furnaces intended to be installed outdoors

$L_{S,SS}$ = value as defined in section 11.4.6 of ASHRAE 103–1993 at reduced input rate,

C_S = value as defined in section 11.3.10.1 of ASHRAE 103–1993 at reduced input rate.

10.3 *Part-Load Efficiency at Maximum Fuel Input Rate.* If the option in section 8.9 of this appendix is not employed, calculate the part-load efficiency at maximum fuel input rate, $Effy_{U,H}$, for condensing furnaces equipped with two-stage controls, expressed as a percent and defined as:

$$Effy_{U,R} = 100 - L_{L,A} + L_G - L_C - C_J L_J - \left[\frac{t_{ON}}{t_{ON} + \left(\frac{Q_P}{Q_{IN}}\right) t_{OFF}}\right](L_{S,ON} + L_{S,OFF} + L_{I,ON} + L_{I,OFF})$$

If the option in section 8.9 of this appendix is employed, calculate $Effy_{U,H}$ as follows:

$$Effy_{U,R} = 100 - L_{L,A} + L_G - L_C - C_J L_J - \left[\frac{t_{ON}}{t_{ON} + \left(\frac{Q_P}{Q_{IN}}\right) t_{OFF}}\right](C_S)(L_{S,SS})$$

Where:

$L_{L,A}$ = value as defined in section 11.2.7 of ASHRAE 103–1993,

L_G = value as defined in section 11.3.11.1 of ASHRAE 103–1993 at maximum input rate,

L_C = value as defined in section 11.3.11.2 of ASHRAE 103–1993 at maximum input rate,

L_J = value as defined in section 11.4.8.1.1 of ASHRAE 103–1993 at maximum input rate,

t_{ON} = value as defined in section 11.4.9.11 of ASHRAE 103–1993,

Q_P = pilot fuel input rate determined in accordance with section 9.2 of ASHRAE 103–1993 in Btu/h,

Q_{IN} = value as defined in section 11.4.8.1.1 of ASHRAE 103–1993,

t_{OFF} = value as defined in section 11.4.9.12 of ASHRAE 103–1993 at maximum input rate,

$L_{S,ON}$ = value as defined in section 11.4.10.5 of ASHRAE 103–1993 at maximum input rate,

$L_{S,OFF}$ = value as defined in section 11.4.10.6 of ASHRAE 103–1993 at maximum input rate,

$L_{I,ON}$ = value as defined in section 11.4.10.7 of ASHRAE 103–1993 at maximum input rate,

$L_{I,OFF}$ = value as defined in section 11.4.10.8 of ASHRAE 103–1993 at maximum input rate,

C_J = value as defined in section 10.2 of this appendix,

$L_{S,SS}$ = value as defined in section 11.4.6 of ASHRAE 103–1993 at maximum input rate,

C_S = value as defined in section 11.4.10.1 of ASHRAE 103–1993 at maximum input rate.

10.4 *National average burner operating hours, average annual fuel energy consumption, and average annual auxiliary electrical energy consumption for gas or oil furnaces.*

10.4.1 *National average number of burner operating hours.* For furnaces equipped with single-stage controls, the national average number of burner operating hours is defined as:

$BOH_{SS} = 2{,}080\ (0.77)\ (A)\ DHR - 2{,}080\ (B)$

Where:

2,080 = national average heating load hours

0.77 = adjustment factor to adjust the calculated design heating requirement and heating load hours to the actual heating load experienced by the heating system

A = 100,000/[341,200 (y_P PE + y_{IG} PE_{IG} + y BE) + (Q_{IN} − Q_P) $Effy_{HS}$], for forced draft unit, indoors

= 100,000/[341,200 (y_P PE Eff_{motor} + y_{IG} PE_{IG} + y BE) + (Q_{IN} − Q_P) $Effy_{HS}$], for forced draft unit, isolated combustion system,

= 100,000/[341,200 (y_P PE (1 − Eff_{motor}) + y_{IG} PE_{IG} + y BE) + (Q_{IN} − Q_P) $Effy_{HS}$], for induced draft unit, indoors, and

= 100,000/[341,200 (y_{IG} PE_{IG} + y BE) + (Q_{IN} − Q_P) $Effy_{HS}$], for induced draft unit, isolated combustion system.

DHR = typical design heating requirements as listed in Table 8 (in kBtu/h) of ASHRAE 103–1993, using the proper value of Q_{OUT} defined in section 11.2.8.1 of ASHRAE 103–1993.

$B = 2\ Q_P\ (Effy_{HS})\ (A)/100{,}000$

Where:

Eff_{motor} = nameplate power burner motor efficiency provided by the manufacturer,

= 0.50, an assumed default power burner efficiency if not provided by the manufacturer.

100,000 = factor that accounts for percent and kBtu

y_P = ratio of induced or forced draft blower on-time to average burner on-time, as follows:

1 for units without post-purge;

1 + (t_P/3.87) for single stage furnaces with post purge; or

1 + (t_P/10) for two-stage and step modulating furnaces with post purge.

PE = all electrical power related to burner operation at full load steady-state operation, including electrical ignition device if energized, controls, gas valve or oil control valve, and draft inducer, as determined in section 8.2 of this appendix.

y_{IG} = ratio of burner interrupted ignition device on-time to average burner on-time, as follows:

0 for burners not equipped with interrupted ignition device;

(t_{IG}/3.87) for single-stage furnaces; or

(t_{IG}/10) for two-stage and step modulating furnaces;

PE_{IG} = electrical input rate to the interrupted ignition device on burner (if employed), as defined in section 8.3 of this appendix

y = ratio of blower on-time to average burner on-time, as follows:

1 for furnaces without fan delay;

1 + ($t^+ - t^-$)/3.87 for single-stage furnaces with fan delay; or

1 + ($t^+ - t^-$)/10 for two-stage and step modulating furnaces with fan delay.

BE = circulating air fan electrical energy input rate at full-load steady-state operation as defined in section 8.2 of this appendix.

t_P = post-purge time as defined in section 8.5 of this appendix

= 0 if t_P is equal to or less than 30 seconds

t_{IG} = on-time of the burner interrupted ignition device, as defined in section 8.3 of this appendix

Q_{IN} = as defined in section 11.2.8.1 of ASHRAE 103–1993

Q_P = as defined in section 11.2.11 of ASHRAE 103–1993

$Effy_{HS}$ = as defined in section 11.2.11 (non-condensing systems) or section 11.3.11.3 (condensing systems) of ASHRAE 103–1993, percent, and calculated on the basis of:

isolated combustion system installation, for non-weatherized warm air furnaces; or outdoor installation, for furnaces that are weatherized.

2 = ratio of the average length of the heating season in hours to the average heating load hours

t^+ = delay time between burner shutoff and the blower shutoff measured as defined in section 9.5.1.2 of ASHRAE 103–1993

t^- = as defined in section 9.6.1 of ASHRAE 103–1993

10.4.1.1 For furnaces equipped with two stage or step modulating controls the average annual energy used during the heating season, E_M, is defined as:

$E_M = (Q_{IN} - Q_P)\ BOH_{SS} + (8{,}760 - 4{,}600)\ Q_P$

Where:

Q_{IN} = as defined in section 11.4.8.1.1 of ASHRAE 103–1993

Q_P = as defined in section 11.4.12 of ASHRAE 103–1993

BOH_{SS} = as defined in section 10.4.1 of this appendix, in which the weighted $Effy_{HS}$ as defined in section 11.4.11.3 or 11.5.11.3 of ASHRAE 103–1993 is used for calculating the values of A and B, the term DHR is based on the value of Q_{OUT} defined in section 11.4.8.1.1 or 11.5.8.1.1 of ASHRAE 103–1993, and the term ($y_P PE + y_{IG} PE_{IG} + yBE$) in the factor A is increased by the factor R, which is defined as:

R = 2.3 for two stage controls

= 2.3 for step modulating controls when the ratio of minimum-to-maximum output is greater than or equal to 0.5

= 3.0 for step modulating controls when the ratio of minimum-to-maximum output is less than 0.5

A = $100{,}000/[341{,}200\ (y_P\ PE + y_{IG}\ PE_{IG} + y\ BE)\ R + (Q_{IN} - Q_P)\ Effy_{HS}]$, for forced draft unit, indoors

= $100{,}000/[341{,}200\ (y_P\ PE\ Eff_{motor} + y_{IG}\ PE_{IG} + y\ BE)\ R + (Q_{IN} - Q_P)\ Effy_{HS}]$, for forced draft unit, isolated combustion system,

= $100{,}000/[341{,}200\ (y_P\ PE\ (1 - Eff_{motor}) + y_{IG}\ PE_{IG} + y\ BE)\ R + (Q_{IN} - Q_P)\ Effy_{HS}]$, for induced draft unit, indoors, and

= $100{,}000/[341{,}200\ (y_{IG}\ PE_{IG} + y\ BE)\ R + (Q_{IN} - Q_P)\ Effy_{HS}]$, for induced draft unit, isolated combustion system.

Where:

Eff_{motor} = nameplate power burner motor efficiency provided by the manufacturer,

= 0.50, an assumed default power burner efficiency if not provided by the manufacturer.

$Effy_{HS}$ = as defined in section 11.4.11.3 or 11.5.11.3 of ASHRAE 103–1993, and calculated on the basis of:

isolated combustion system installation, for non-weatherized warm air furnaces; or outdoor installation, for furnaces that are weatherized.

8,760 = total number of hours per year

4,600 = as defined in section 11.4.12 of ASHRAE 103–1993

10.4.1.2 For furnaces equipped with two-stage or step-modulating controls, the national average number of burner operating hours at the reduced operating mode (BOH_R) is defined as:

$BOH_R = X_R\ E_M/Q_{IN,R}$

Where:

X_R = as defined in section 11.4.8.7 of ASHRAE 103–1993

E_M = as defined in section 10.4.1.1 of this appendix

$Q_{IN,R}$ = as defined in section 11.4.8.1.2 of ASHRAE 103–1993

10.4.1.3 For furnaces equipped with two-stage controls, the national average number of burner operating hours at the maximum operating mode (BOH_H) is defined as:

$BOH_H = X_H\ E_M/Q_{IN}$

Where:

X_H = as defined in section 11.4.8.6 of ASHRAE 103–1993

E_M = as defined in section 10.4.1.1 of this appendix

Q_{IN} = as defined in section 11.4.8.1.1 of ASHRAE 103–1993

10.4.1.4 For furnaces equipped with step-modulating controls, the national average number of burner operating hours at the modulating operating mode (BOH_M) is defined as:

$BOH_M = X_H\ E_M/Q_{IN,M}$

Where:

X_H = as defined in section 11.4.8.6 of ASHRAE 103–1993

E_M = as defined in section 10.4.1.1 of this appendix

$Q_{IN,M} = Q_{OUT,M}/(Effy_{SS,M}/100)$

$Q_{OUT,M}$ = as defined in section 11.4.8.10 or 11.5.8.10 of ASHRAE 103–1993, as appropriate

$Effy_{SS,M}$ = as defined in section 11.4.8.8 or 11.5.8.8 of ASHRAE 103–1993, as appropriate, in percent

100 = factor that accounts for percent

10.4.2 *Average annual fuel energy consumption for gas or oil fueled furnaces.* For furnaces equipped with single-stage controls, the average annual fuel energy consumption (E_F) is expressed in Btu per year and defined as:

$E_F = BOH_{SS} (Q_{IN} - Q_P) + 8{,}760\ Q_P$

Where:

BOH_{SS} = as defined in section 10.4.1 of this appendix
Q_{IN} = as defined in section 11.2.8.1 of ASHRAE 103–1993
Q_P = as defined in section 11.2.11 of ASHRAE 103–1993
8,760 = as defined in section 10.4.1.1 of this appendix

10.4.2.1 For furnaces equipped with either two-stage or step modulating controls, E_F is defined as:

$E_F = E_M + 4{,}600\ Q_P$

Where:

E_M = as defined in section 10.4.1.1 of this appendix
4,600 = as defined in section 11.4.12 of ASHRAE 103–1993
Q_P = as defined in section 11.2.11 of ASHRAE 103–1993

10.4.2.2 [Reserved]

10.4.3 *Average annual auxiliary electrical energy consumption for gas or oil-fueled furnaces.* For furnaces equipped with single-stage controls, the average annual auxiliary electrical consumption (E_{AE}) is expressed in kilowatt-hours and defined as:

$E_{AE} = BOH_{SS} (y_P\ PE + y_{IG}\ PE_{IG} + yBE) + E_{SO}$

Where:

BOH_{SS} = as defined in section 10.4.1 of this appendix
y_P = as defined in section 10.4.1 of this appendix
PE = as defined in section 10.4.1 of this appendix
y_{IG} = as defined in section 10.4.1 of this appendix
PE_{IG} = as defined in section 10.4.1 of this appendix
y = as defined in section 10.4.1 of this appendix
BE = as defined in section 10.4.1 of this appendix
E_{SO} = as defined in section 10.11 of this appendix

10.4.3.1 For furnaces equipped with two-stage controls, E_{AE} is defined as:

$E_{AE} = BOH_R (y_P\ PE_R + y_{IG}\ PE_{IG} + yBE_R) + BOH_H (y_P\ PE_H + y_{IG}\ PE_{IG} + y\ BE_H) + E_{SO}$

Where:

BOH_R = as defined in section 10.4.1.2 of this appendix
y_P = as defined in section 10.4.1 of this appendix
PE_R = as defined in section 8.2 of this appendix and measured at the reduced fuel input rate
y_{IG} = as defined in section 10.4.1 of this appendix
PE_{IG} = as defined in section 10.4.1 of this appendix
y = as defined in section 10.4.1 of this appendix
BE_R = as defined in section 8.2 of this appendix and measured at the reduced fuel input rate
BOH_H = as defined in section 10.4.1.3 of this appendix
PE_H = as defined in section 8.2 of this appendix and measured at the maximum fuel input rate
BE_H = as defined in section 8.2 of this appendix and measured at the maximum fuel input rate
E_{SO} = as defined in section 10.11 of this appendix

10.4.3.2 For furnaces equipped with step-modulating controls, E_{AE} is defined as:

$E_{AE} = BOH_R (y_P\ PE_R + y_{IG}\ PE_{IG} + y\ BE_R) + BOH_M (y_P\ PE_H + y_{IG}\ PE_{IG} + y\ BE_H) + E_{SO}$

Where:

BOH_R = as defined in section 10.4.1.2 of this appendix
y_P = as defined in section 10.4.1 of this appendix
PE_R = as defined in section 8.2 of this appendix and measured at the reduced fuel input rate
y_{IG} = as defined in section 10.4.1 of this appendix
PE_{IG} = as defined in section 10.4.1 of this appendix
y = as defined in section 10.4.1 of this appendix
BE_R = as defined in section 8.2 of this appendix and measured at the reduced fuel input rate
BOH_M = as defined in 10.4.1.4 of this appendix
PE_H = as defined in section 8.2 of this appendix and measured at the maximum fuel input rate
BE_H = as defined in section 8.2 of this appendix and measured at the maximum fuel input rate
E_{SO} = as defined in section 10.11 of this appendix

10.5 *Average annual electric energy consumption for electric furnaces.* For electric furnaces, the average annual electrical energy consumption (E_E) is expressed in kilowatt-hours and defined as:

$E_E = 100\ (2{,}080)\ (0.77)\ DHR/(3.412\ AFUE) + E_{SO}$

Where:

100 = to express a percent as a decimal
2,080 = as defined in section 10.4.1 of this appendix
0.77 = as defined in section 10.4.1 of this appendix
DHR = as defined in section 10.4.1 of this appendix
3.412 = conversion factor from watt-hours to Btu
AFUE = as defined in section 11.1 of ASHRAE 103–1993, in percent, and calculated on the basis of:
isolated combustion system installation, for non-weatherized warm air furnaces; or
outdoor installation, for furnaces that are weatherized.
E_{SO} = as defined in section 10.11 of this appendix.

10.6 *Energy factor.*

10.6.1 *Energy factor for gas or oil furnaces.* Calculate the energy factor, EF, for gas or oil furnaces defined as, in percent:

$EF = (E_F - 4{,}600\ (Q_P))(Effy_{HS})/(E_F + 3{,}412\ (E_{AE}))$

Where:

E_F = average annual fuel consumption as defined in section 10.4.2 of this appendix
4,600 = as defined in section 11.4.12 of ASHRAE 103–1993
Q_P = pilot fuel input rate determined in accordance with section 9.2 of ASHRAE 103–1993 in Btu/h
$Effy_{HS}$ = annual fuel utilization efficiency as defined in sections 11.2.11, 11.3.11, 11.4.11 or 11.5.11 of ASHRAE 103–1993, in percent, and calculated on the basis of:
isolated combustion system installation, for non-weatherized warm air furnaces; or
outdoor installation, for furnaces that are weatherized.
3,412 = conversion factor from kW to Btu/h
E_{AE} = as defined in section 10.4.3 of this appendix

10.6.2 *Energy factor for electric furnaces.* The energy factor, EF, for electric furnaces is defined as:

EF = AFUE

Where:

AFUE = annual fuel utilization efficiency as defined in section 10.4.3 of this appendix, in percent

10.7 *Average annual energy consumption for furnaces located in a different geographic region of the United States and in buildings with different design heating requirements.*

10.7.1 *Average annual fuel energy consumption for gas or oil-fueled furnaces located in a different geographic region of the United States and in buildings with different design heating requirements.* For gas or oil-fueled furnaces, the average annual fuel energy consumption for a specific geographic region and a specific typical design heating requirement (E_{FR}) is expressed in Btu per year and defined as:

$E_{FR} = (E_F - 8{,}760\ Q_P)\ (HLH/2{,}080) + 8{,}760\ Q_P$

Where:

E_F = as defined in section 10.4.2 of this appendix
8,760 = as defined in section 10.4.1.1 of this appendix
Q_P = as defined in section 11.2.11 of ASHRAE 103–1993
HLH = heating load hours for a specific geographic region determined from the heating load hour map in Figure 1 of this appendix
2,080 = as defined in section 10.4.1 of this appendix

10.7.2 *Average annual auxiliary electrical energy consumption for gas or oil-fueled furnaces located in a different geographic region of the United States and in buildings with different design heating requirements.* For gas or oil-fueled furnaces, the average annual auxiliary electrical energy consumption for a specific geographic region and a specific typical design heating requirement (E_{AER}) is expressed in kilowatt-hours and defined as:

$E_{AER} = (E_{AE} - E_{SO})\ (HLH/2080) + E_{SOR}$

Where:

E_{AE} = as defined in section 10.4.3 of this appendix
E_{SO} = as defined in section 10.11 of this appendix
HLH = as defined in section 10.7.1 of this appendix
2,080 = as defined in section 10.4.1 of this appendix
E_{SOR} = as defined in section 10.7.3 of this appendix.

10.7.3 *Average annual electric energy consumption for electric furnaces located in a different geographic region of the United States and in buildings with different design heating requirements.* For electric furnaces, the average annual electric energy consumption for a specific geographic region and a specific typical design heating requirement (E_{ER}) is expressed in kilowatt-hours and defined as:

$E_{ER} = 100\ (0.77)\ DHR\ HLH/(3.412\ AFUE) + E_{SOR}$

Where:

100 = as defined in section 10.4.3 of this appendix

0.77 = as defined in section 10.4.1 of this appendix

DHR = as defined in section 10.4.1 of this appendix

HLH = as defined in section 10.7.1 of this appendix

3.412 = as defined in section 10.4.3 of this appendix

AFUE = as defined in section 10.4.3 of this appendix

E_{SOR} = E_{SO} as defined in section 10.11 of this appendix, except that in the equation for E_{SO}, the term BOH is multiplied by the expression (HLH/2080) to get the appropriate regional accounting of standby mode and off mode loss.

10.8 *Annual energy consumption for mobile home furnaces*

10.8.1 *National average number of burner operating hours for mobile home furnaces (BOH_{SS}).* BOH_{SS} is the same as in section 10.4.1 of this appendix, except that the value of $Effy_{HS}$ in the calculation of the burner operating hours, BOH_{SS}, is calculated on the basis of a direct vent unit with system number 9 or 10.

10.8.2 *Average annual fuel energy for mobile home furnaces (E_F).* E_F is same as in section 10.4.2 of this appendix except that the burner operating hours, BOH_{SS}, is calculated as specified in section 10.8.1 of this appendix.

10.8.3 *Average annual auxiliary electrical energy consumption for mobile home furnaces (E_{AE}).* E_{AE} is the same as in section 10.4.3 of this appendix, except that the burner operating hours, BOH_{SS}, is calculated as specified in section 10.8.1 of this appendix.

10.9 *Calculation of sales weighted average annual energy consumption for mobile home furnaces.* To reflect the distribution of mobile homes to geographical regions with average HLH_{MHF} values different from 2,080, adjust the annual fossil fuel and auxiliary electrical energy consumption values for mobile home furnaces using the following adjustment calculations.

10.9.1 For mobile home furnaces, the sales weighted average annual fossil fuel energy consumption is expressed in Btu per year and defined as:

$$E_{F,MHF} = (E_F - 8{,}760\ Q_P)\ HLH_{MHF}/2{,}080 + 8{,}760\ Q_P$$

Where:

E_F = as defined in section 10.8.2 of this appendix

8,760 = as defined in section 10.4.1.1 of this appendix

Q_P = as defined in section 10.2 of this appendix

HLH_{MHF} = 1880, sales weighted average heating load hours for mobile home furnaces

2,080 = as defined in section 10.4.1 of this appendix

10.9.2 For mobile home furnaces, the sales-weighted-average annual auxiliary electrical energy consumption is expressed in kilowatt-hours and defined as:

$$E_{AE,MHF} = E_{AE}\ HLH_{MHF}/2{,}080$$

Where:

E_{AE} = as defined in section 10.8.3 of this appendix

HLH_{MHF} = as defined in section 10.9.1 of this appendix

2,080 = as defined in section 10.4.1 of this appendix

10.10 [Reserved]

10.11 *Average annual electrical standby mode and off mode energy consumption.* Calculate the annual electrical standby mode and off mode energy consumption (E_{SO}) in kilowatt-hours, defined as:

$$E_{SO} = (P_{W,SB}\ (4160 - BOH) + 4600\ P_{W,OFF})\ K$$

Where:

$P_{W,SB}$ = furnace standby mode power, in watts, as measured in section 8.10.1 of this appendix

4,160 = average heating season hours per year

BOH = total burner operating hours as calculated in section 10.4 of this appendix for gas or oil-fueled furnaces. Where for gas or oil-fueled furnaces equipped with single-stage controls, BOH = BOH_{SS}; for gas or oil-fueled furnaces equipped with two-stage controls, BOH = (BOH_R + BOH_H); and for gas or oil-fueled furnaces equipped with step-modulating controls, BOH = (BOH_R + BOH_M). For electric furnaces, BOH = $100(2080)(0.77)DHR/(E_{in}\ 3.412(AFUE))$

4,600 = as defined in section 11.4.12 of ASHRAE 103–1993

$P_{W,OFF}$ = furnace off mode power, in watts, as measured in section 8.10.2 of this appendix

K = 0.001 kWh/Wh, conversion factor from watt-hours to kilowatt-hours

Where:

100 = to express a percent as a decimal

2,080 = as defined in section 10.4.1 of this appendix

0.77 = as defined in section 10.4.1 of this appendix

DHR = as defined in section 10.4.1 of this appendix

E_{in} = steady-state electric rated power, in kilowatts, from section 9.3 of ASHRAE 103–1993

3.412 = as defined in section 10.4.3 of this appendix

AFUE = as defined in section 11.1 of ASHRAE 103–1993 in percent




FIGURE 1- HEATING LOAD HOURS (HLH) FOR THE UNITED STATES

[88 FR 15538, Mar. 13, 2023]

APPENDIX O TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF VENTED HOME HEATING EQUIPMENT

NOTE: Prior to November 16, 2022, representations with respect to the energy use or efficiency of vented home heating equipment, including compliance certifications, must be based on testing conducted in accordance with either this appendix as it now appears or appendix O as it appeared at 10 CFR part 430, subpart B revised as of January 1, 2021.

On and after November 16, 2022, representations with respect to energy use or efficiency of vented home heating equipment, including compliance certifications, must be based on testing conducted in accordance with this appendix.

0.0 Incorporation by Reference.

DOE incorporated by reference in §430.3: ANSI Z21.86–2016; ASHRAE 103–2017; ASTM D2156–09 (R2018); IEC 62301; UL 729–2016; UL 730–2016; and UL 896–2016 in their entirety. However, only enumerated provisions of ANSI Z21.86–2016; ASHRAE 103–2017, UL 729–2016, UL 730–2016, and UL 896–2016 are applicable to this appendix, as follows:

0.1 ANSI Z21.86–2016

(i) Section 5.2—Test gases

(ii) Section 9.1.3

(iii) Section 11.1.3

(iv) Section 11.7—Temperature at discharge air opening and surface temperatures

0.2 ASHRAE 103–2017

(i) Section 6—INSTRUMENTS

(ii) Section 8.2.2.3.1—Oil Supply

(iii) Section 8.6—Jacket Loss Measurement

(iv) Section 8.8.3—Additional Optional Method of Testing for Determining DP and DF for Furnaces and Boilers

(v) Section 9.10—Optional Test Procedures for Condensing Furnaces and Boilers that Have no OFF-Period Flue Losses

0.3 UL 729–2016

(i) Section 38.1—Enclosure

(ii) Section 38.2—Chimney connector

0.4 UL 730–2016

(i) Section 36.1—Enclosure

(ii) Section 36.2—Chimney connector

(iii) Sections 37.5.8 through 37.5.180.5 UL 896–2016

(i) Section 37.1.2

(ii) Section 37.1.3

1.0 Definitions

1.1 ''Active mode'' means the condition during the heating season in which the vented heater is connected to the power source, and either the burner or any electrical auxiliary is activated.

1.2 ''Air shutter'' means an adjustable device for varying the size of the primary air inlet(s) to the combustion chamber power burner.

1.3 ''Air tube'' means a tube which carries combustion air from the burner fan to the burner nozzle for combustion.

1.4 ''Barometic draft regulator or barometric damper'' means a mechanical device designed to maintain a constant draft in a vented heater.

1.5 ''Condensing vented heater'' means a vented heater that, during the laboratory tests prescribed in this appendix, condenses part of the water vapor in the flue gases.

1.6 ''Draft hood'' means an external device which performs the same function as an integral draft diverter, as defined in section 1.17 of this appendix.

1.7 ''Electro-mechanical stack damper'' means a type of stack damper which is operated by electrical and/or mechanical means.

1.8 ''Excess air'' means air which passes through the combustion chamber and the vented heater flues in excess of that which is theoretically required for complete combustion.

1.9 ''Flue'' means a conduit between the flue outlet of a vented heater and the integral draft diverter, draft hood, barometric damper or vent terminal through which the flue gases pass prior to the point of draft relief.

1.10 ''Flue damper'' means a device installed between the furnace and the integral draft diverter, draft hood, barometric draft regulator, or vent terminal which is not equipped with a draft control device, designed to open the venting system when the appliance is in operation and to close the venting system when the appliance is in a standby condition.

1.11 ''Flue gases'' means reaction products resulting from the combustion of a fuel with the oxygen of the air, including the inerts and any excess air.

1.12 ''Flue losses'' means the sum of sensible and latent heat losses above room temperature of the flue gases leaving a vented heater.

1.13 ''Flue outlet'' means the opening provided in a vented heater for the exhaust of the flue gases from the combustion chamber.

1.14 ''Heat input'' (Q_{in}) means the rate of energy supplied in a fuel to a vented heater operating under steady-state conditions, expressed in Btu's per hour. It includes any input energy to the pilot light and is obtained by multiplying the measured rate of fuel consumption by the measured higher heating value of the fuel.

1.15 ''Heating capacity'' (Q_{out}) means the rate of useful heat output from a vented heater, operating under steady-state conditions, expressed in Btu's per hour. For room and wall heaters, it is obtained by multiplying the ''heat input'' (Q_{in}) by the steady-state efficiency (η_{ss}) divided by 100. For floor furnaces, it is obtained by multiplying (A) the ''heat input'' (Q_{in}) by (B) the steady-state efficiency divided by 100, minus the quantity (2.8) (L_j) divided by 100, where L_j is the jacket loss as determined in section 3.2 of this appendix.

1.16 ''Higher heating value'' (HHV) means the heat produced per unit of fuel when complete combustion takes place at constant pressure and the products of combustion are cooled to the initial temperature of the fuel and air and when the water vapor formed during combustion is condensed. The higher heating value is usually expressed in Btu's per pound, Btu's per cubic foot for gaseous fuel, or Btu's per gallon for liquid fuel.

1.17 ''IEC 62301 (Second Edition)'' means the test standard published by the International Electrotechnical Commission, titled ''Household electrical appliances—Measurement of standby power,'' Publication 62301 Edition 2.0 2011–01 (incorporated by reference; see §430.3).

1.18 ''Induced draft'' means a method of drawing air into the combustion chamber by mechanical means.

1.19 ''Infiltration parameter'' means that portion of unconditioned outside air drawn into the heated space as a consequence of loss of conditioned air through the exhaust system of a vented heater.

1.20 ''Integral draft diverter'' means a device which is an integral part of a vented heater, designed to: (1) Provide for the exhaust of the products of combustion in the event of no draft, back draft, or stoppage beyond the draft diverter, (2) prevent a back draft from entering the vented heater, and (3) neutralize the stack action of the chimney or gas vent upon the operation of the vented heater.

1.21 ''Manually controlled vented heaters'' means either gas or oil fueled vented heaters equipped without thermostats.

1.22 ''Modulating control'' means either a step-modulating or two-stage control.

1.23 ''Off mode'' means the condition during the non-heating season in which the vented heater is connected to the power source, and neither the burner nor any electrical auxiliary is activated.

1.24 ''Power burner'' means a vented heater burner which supplies air for combustion at a pressure exceeding atmospheric pressure, or a burner which depends on the draft induced by a fan incorporated in the furnace for proper operation.

1.25 ''Reduced heat input rate'' means the factory adjusted lowest reduced heat input rate for vented home heating equipment equipped with either two stage thermostats or step-modulating thermostats.

1.26 ''Seasonal off switch'' means the control device, such as a lever or toggle, on the vented heater that affects a difference in off mode energy consumption as compared to standby mode consumption.

1.27 ''Single-stage thermostat'' means a thermostat that cycles a burner at the maximum heat input rate and off.

1.28 ''Stack'' means the portion of the exhaust system downstream of the integral draft diverter, draft hood or barometric draft regulator.

1.29 ''Stack damper'' means a device installed downstream of the integral draft diverter, draft hood, or barometric draft regulator, designed to open the venting system when the appliance is in operation and to close off the venting system when the appliance is in the standby condition.

1.30 ''Stack gases'' means the flue gases combined with dilution air that enters at the integral draft diverter, draft hood or barometric draft regulator.

1.31 ''Standby mode'' means the condition during the heating season in which the vented heater is connected to the power source, and neither the burner nor any electrical auxiliary is activated.

1.32 ''Steady-state conditions for vented home heating equipment'' means equilibrium conditions as indicated by temperature variations of not more than 5 °F (2.8C) in the flue gas temperature for units equipped with draft hoods, barometric draft regulators or direct vent systems, in three successive readings taken 15 minutes apart or not more than 3 °F (1.7C) in the stack gas temperature for units equipped with integral draft diverters in three successive readings taken 15 minutes apart.

1.33 ''Step-modulating control'' means a control that either cycles off and on at the low input if the heating load is light, or gradually, increases the heat input to meet any higher heating load that cannot be met with the low firing rate.

1.34 ''Thermal stack damper'' means a type of stack damper which is dependent for operation exclusively upon the direct conversion of thermal energy of the stack gases into movement of the damper plate.

1.35 ''Two stage control'' means a control that either cycles a burner at the reduced heat input rate and off or cycles a burner at the maximum heat input rate and off.

1.36 ''Vaporizing-type oil burner'' means a device with an oil vaporizing bowl or other receptacle designed to operate by vaporizing liquid fuel oil by the heat of combustion and mixing the vaporized fuel with air.

1.37 ''Vent/air intake terminal'' means a device which is located on the outside of a building and is connected to a vented heater by a system of conduits. It is composed of an air intake terminal through which the air for combustion is taken from the outside atmosphere and a vent terminal from which flue gases are discharged.

1.38 ''Vent limiter'' means a device which limits the flow of air from the atmospheric diaphragm chamber of a gas pressure regulator to the atmosphere. A vent limiter may be a limiting orifice or other limiting device.

1.39 ''Vent pipe'' means the passages and conduits in a direct vent system through which gases pass from the combustion chamber to the outdoor air.

2.0 Testing conditions.

2.1 Installation of test unit.

2.1.1 Vented wall furnaces (including direct vent systems). Install non-direct vent gas fueled vented wall furnaces as specified in Section 11.1.3 of ANSI Z21.86–2016. Install direct vent gas fueled vented wall furnaces as specified in Section 9.1.3 of ANSI Z21.86–2016. Install oil-fueled vented wall furnaces as specified in Section 36.1 of UL 730–2016.

2.1.2 Vented floor furnaces. Install vented floor furnaces for test as specified in Section 38.1 of UL 729–2016.

2.1.3 Vented room heaters. Install vented room heaters for test in accordance with the manufacturer's installation and operations (I&O) manual provided with the unit.

2.2 Flue and stack requirements.

2.2.1 Gas fueled vented home heating equipment employing integral draft diverters and draft hoods (excluding direct vent systems). Attach to, and vertically above the outlet of gas-fueled vented home heating equipment employing draft diverters or draft hoods with vertically discharging outlets, a five (5) foot long test stack having a cross-sectional area the same size as the draft diverter outlet.

Attach to the outlet of vented heaters having a horizontally discharging draft diverter or draft hood outlet a 90-degree elbow, and a five (5) foot long vertical test stack. A horizontal section of pipe may be used on the floor furnace between the diverter and the elbow, if necessary, to clear any framing used in the installation. Use the minimum length of pipe possible for this section. Use stack, elbow, and horizontal section with

same cross-sectional area as the diverter outlet.

2.2 Oil-fueled vented home heating equipment (excluding direct vent systems). Use flue connections for oil-fueled vented floor furnaces as specified in Section 38.2 of UL 729–2016, Section 36.2 of UL 730–2016 for oil-fueled vented wall furnaces, and Sections 37.1.2 and 37.1.3 of UL 896–2016 for oil-fueled vented room heaters.

2.2.3 Direct vent systems. Have the exhaust/air intake system supplied by the manufacturer in place during all tests. Test units intended for installation with a variety of vent pipe lengths with the minimum length recommended by the manufacturer in the I&O manual. Do not connect a heater employing a direct vent system to a chimney or induced draft source. Vent the gas solely on the provision for venting incorporated in the heater and the vent/air intake system supplied with it.

2.2.4 Condensing vented heater, additional flue requirements. The flue pipe installation must not allow condensate formed in the flue pipe to flow back into the unit. An initial downward slope from the unit's exit, an offset with a drip leg, annular collection rings, or drain holes must be included in the flue pipe installation without disturbing normal flue gas flow. Flue gases should not flow out of the drain with the condensate. For condensing vented heaters that do not include means for collection of condensate, a means to collect condensate must be supplied by the test lab for the purposes of testing.

2.3 Fuel supply.

2.3.1 Natural gas. For a gas-fueled vented heater, maintain the gas supply to the unit under test at an inlet test pressure immediately ahead of all controls at 7 to 10 inches water column. If the heater is equipped with a gas pressure regulator, maintain the regulator outlet pressure within the greater of ±0.2 inches water column, or ±10 percent, of the manufacturer-specified manifold pressure on the nameplate of the unit or in the I&O manual. Use natural gas having a specific gravity between 0.57 and 0.70 and a higher heating value within ±5 percent of 1,025 Btu per standard cubic foot. Determine the actual higher heating value in Btu per standard cubic foot for the natural gas to be used in the test with an error no greater than one percent. If the burner cannot be adjusted to obtain a heat input rate of within ±2 percent of the hourly Btu rating specified by the manufacturer on the nameplate of the unit or in the I&O manual, as required by section 2.4.1 of this appendix, maintain the gas supply to the unit under test at an inlet test pressure immediately ahead of all controls at any value within the range specified on the nameplate of the unit or in the I&O manual that results in a heat input rate of within ±2 percent of the hourly Btu rating specified by the manufacturer on the nameplate of the unit or in the I&O manual.

2.3.2 Propane gas. For a propane-gas-fueled vented heater, maintain the gas supply to the unit under test at an inlet pressure of 11 to 13 inches water column. If the heater is equipped with a gas pressure regulator, maintain the regulator outlet pressure within the greater of ±0.2 inches water column, or ±10 percent, of the manufacturer's specified manifold pressure on the nameplate of the unit or in the I&O manual. Use propane having a specific gravity between 1.522 and 1.574 and a higher heating value within ±5 percent of 2,500 Btu per standard cubic foot. Determine the actual higher heating value in Btu per standard cubic foot for the propane to be used in the test. If the burner cannot be adjusted to obtain a heat input rate of within ±2 percent of the hourly Btu rating specified by the manufacturer on the nameplate of the unit or in the I&O manual, as required by section 2.4.1 of this appendix, maintain the gas supply to the unit under test at an inlet test pressure immediately ahead of all controls at any value within the range specified on the nameplate of the unit or in the I&O manual that results in a heat input rate of within ±2 percent of the hourly Btu rating specified by the manufacturer on the nameplate of the unit or in the I&O manual.

2.3.3 Other test gas. For vented heaters fueled by other test gases, use test gases with characteristics as described in Table 3 of Section 5.2 of ANSI Z21.86–2016. Use gases with a measured higher heating value within ±5 percent of the values specified in Table 3 of Section 5.2 of ANSI Z21.86–2016. Determine the actual higher heating value of the gas used in the test with an error no greater than one percent.

2.3.4 Oil supply. For an oil-fueled vented heater, use No. 1 fuel oil (kerosene) for vaporizing-type burners and either No. 1 or No. 2 fuel oil, as specified by the manufacturer in the I&O manual provided with the unit, for mechanical atomizing type burners. Use test fuel conforming to the specifications given in Tables 2 and 3 of Section 8.2.2.3.1 of ASHRAE 103–2017. Measure the higher heating value of the test fuel within ±1 percent.

2.3.5 Electrical supply. For auxiliary electric components of a vented heater, maintain the electrical supply to the test unit within ±1 percent of the nameplate voltage for the entire test cycle. If a voltage range is used for nameplate voltage, maintain the electrical supply within ±1 percent of the midpoint of the nameplate voltage range.

2.4 Burner adjustments.

2.4.1 Gas burner adjustments. Adjust the burners of gas-fueled vented heaters to their maximum Btu ratings at the test pressure specified in section 2.3 of this appendix. Correct the burner volumetric flow rate to 60 °F (15.6 °C) and 30 inches of mercury barometric pressure, set the fuel flow rate to obtain a

heat rate of within ±2 percent of the hourly Btu rating specified by the manufacturer on the nameplate of the unit or in the I&O manual, as measured after 15 minutes of operation, starting with all parts of the vented heater at room temperature. Set the primary air shutters in accordance with the manufacturer's recommendations on the nameplate of the unit or in the I&O manual to give a good flame at this adjustment. Do not allow the deposit of carbon during any test specified herein. If a vent limiting means is provided on a gas pressure regulator, have it in place during all tests.

For gas-fueled heaters with modulating controls, adjust the controls to operate the heater at the maximum fuel input rate. Set the thermostat control to the maximum setting. Start the heater by turning the safety control valve to the ''on'' position. In order to prevent modulation of the burner at maximum input, place the thermostat sensing element in a temperature control bath which is held at a temperature below the maximum set point temperature of the control.

For gas-fueled heaters with modulating controls, adjust the controls to operate the heater at the reduced fuel input rate. Set the thermostat control to the minimum setting. Start the heater by turning the safety control valve to the ''on'' position. If ambient test room temperature is above the lowest control set point temperature, initiate burner operation by placing the thermostat sensing element in a temperature control bath that is held at a temperature below the minimum set point temperature of the control.

2.4.2 Oil burner adjustments. Adjust the burners of oil-fueled vented heaters to give the CO_2 reading recommended by the manufacturer and an hourly Btu input, during the steady-state performance test described below, which is within ±2 percent of the heater manufacturer's specified hourly Btu input rating on the nameplate of the unit or in the I&O manual. On units employing a power burner, do not allow smoke in the flue to exceed a No. 1 smoke during the steady-state performance test as measured by the procedure in ASTM D2156–09 (R2018). If, on units employing a power burner, the smoke in the flue exceeds a No. 1 smoke during the steady-state test, readjust the burner to give a lower smoke reading, and, if necessary, a lower CO_2 reading, and start all tests over. Maintain the average draft over the fire and in the flue during the steady-state performance test at that recommended by the manufacturer within ±0.005 inches of water gauge. Do not make additional adjustments to the burner during the required series of performance tests. The instruments and measuring apparatus for this test are described in Section 6 and shown in Figure 8 of ASHRAE 103–2017. Calibrate instruments for measuring oil pressure so that the error is no greater than ±0.5 psi.

2.5 Circulating air adjustments.

2.5.1 Forced-air vented wall furnaces (including direct vent systems). During testing, maintain the air flow through the heater as specified by the manufacturer in the I&O manual provided with the unit and operate the vented heater with the outlet air temperature between 80 °F and 130 °F above room temperature. If adjustable air discharge registers are provided, adjust them so as to provide the maximum possible air restriction. Measure air discharge temperature as specified in Section 11.7.2 of ANSI Z21.86–2016.

2.5.2 Fan-type vented room heaters and floor furnaces. During tests on fan-type furnaces and heaters, adjust the air flow through the heater as specified by the manufacturer. If adjustable air discharge registers are provided, adjust them to provide the maximum possible air restriction.

2.6 Location of temperature measuring instrumentation.

2.6.1 Gas-fueled vented home heating equipment (including direct vent systems). Install thermocouples for measuring the heated air temperature as described in Section 11.7.5 of ANSI Z21.86–2016. Establish the temperature of the inlet air by means of a single No. 24 AWG bead-type thermocouple located in the center of the plane of each inlet air opening. Use bead-type thermocouples having wire size not greater than No. 24 American Wire Gauge (AWG). If a thermocouple has a direct line of sight with the fire, install a radiation shield, meeting the material and minimum thickness requirements from Section 8.14.1 of ANSI Z21.86–2016, on the fire side of the thermocouple only, and position the shield so that it does not touch the thermocouple junction.

2.6.1.1 Integral draft diverter. For units employing an integral draft diverter, install nine thermocouples, wired in parallel, in a horizontal plane in the five-foot test stack located one foot from the test stack inlet. Equalize the length of all thermocouple leads before paralleling. Locate one thermocouple in the center of the stack. Locate eight thermocouples along imaginary lines intersecting at right angles in this horizontal plane at points one third and two thirds of the distance between the center of the stack and the stack wall.

For units with a stack diameter 2 inches or less, five thermocouples may be installed instead of nine. Locate one thermocouple in the center of the stack. Locate four thermocouples along imaginary lines intersecting at right angles in this horizontal plane at points halfway between the center of the stack and the stack wall.

2.6.1.2 Direct vent system. For units which employ a direct vent system, locate at least one thermocouple at the center of each flue way exiting the heat exchanger. Provide radiation shields if the thermocouples are exposed to burner radiation.

2.6.1.3 Draft hood or direct vent system which does not intentionally preheat incoming air. For units which employ a draft hood or units which employ a direct vent system which does not intentionally preheat the incoming combustion air, such as a non-concentric direct vent system, install nine thermocouples, wired in parallel, in a horizontal plane located within 12 inches (304.8 mm) of the heater outlet and upstream of the draft hood on units so equipped. Locate one thermocouple in the center of the pipe and eight thermocouples along imaginary lines intersecting at right angles in this horizontal plane at points one third and two thirds of the distance between the center of the pipe and the pipe wall.

For units with a flue pipe diameter of 2 inches or less, five thermocouples may be installed instead of nine. Locate one thermocouple in the center of the pipe and four thermocouples along imaginary lines intersecting at right angles in this horizontal plane at points halfway between the center of the pipe and the pipe wall.

2.6.1.4 Direct vent system which intentionally preheat incoming air. For units which employ direct vent systems that intentionally preheat the incoming combustion air, such as a concentric direct vent system, install nine thermocouples, wired in parallel, in a plane parallel to and located within 6 inches (152.4 mm) of the vent/air intake terminal. Equalize the length of all thermocouple leads before paralleling. Locate one thermocouple in the center of the flue pipe and eight thermocouples along imaginary lines intersecting at right angles in this plane at points one third and two thirds of the distance between the center of the flue pipe and the pipe wall.

For units with a flue pipe diameter of 2 inches or less, five thermocouples may be installed instead of nine. Locate one thermocouple in the center of the flue pipe and four thermocouples along imaginary lines intersecting at right angles in this plane at points halfway between the center of the flue pipe and the pipe wall.

2.6.2 Oil-fueled vented home heating equipment (including direct vent systems).

Install thermocouples for measuring the heated air temperature as described in Sections 37.5.8 through 37.5.18 of UL 730–2016. Establish the temperature of the inlet air by means of a single No. 24 AWG bead-type thermocouple located in the center of the plane of each inlet air opening. Use bead-type thermocouples having a wire size not greater than No. 24 AWG. If there is a thermocouple that has a direct line of sight with the fire, install a radiation shield, meeting the material and minimum thickness requirements from Section 8.14.1 of ANSI Z21.86–2016, on the fire side of the thermocouple only, and position the shield so that it does not touch the thermocouple junction.

Install nine thermocouples, wired in parallel and having equal length leads, in a plane perpendicular to the axis of the flue pipe. Locate this plane at the position shown in Figure 36.4 of UL 730–2016, or Figure 38.1 and 38.2 of UL 729–2016 for a single thermocouple, except that on direct vent systems which intentionally preheat the incoming combustion air, locate this plane within 6 inches (152.5 mm) of the outlet of the vent/air intake terminal. Locate one thermocouple in the center of the flue pipe and eight thermocouples along imaginary lines intersecting at right angles in this plane at points one third and two thirds of the distance between the center of the pipe and pipe wall.

For units with a flue pipe diameter of 2 inches or less, five thermocouples may be installed instead of nine. Wire the thermocouples in parallel with equal length leads, in a plane perpendicular to the axis of the flue pipe. Locate this plane at the position shown in Figure 36.4 of UL 730–2016, or Figure 38.1 and 38.2 of UL 729–2016 for a single thermocouple, except that on direct vent systems which intentionally preheat the incoming combustion air, locate this plane within 6 inches (152.5 mm) of the outlet of the vent/air intake terminal. Locate one thermocouple in the center of the flue pipe and four thermocouples along imaginary lines intersecting at right angles in this plane at points halfway between the center of the pipe and pipe wall.

2.7 Combustion measurement instrumentation. Analyze the samples of stack and flue gases for vented heaters to determine the concentration by volume of carbon dioxide present in the dry gas with instrumentation which will result in a reading having an accuracy of ±0.1 percentage point.

2.8 Energy flow instrumentation. Install one or more instruments, which measure the rate of gas flow or fuel oil supplied to the vented heater, and if appropriate, the electrical energy with an error no greater than one percent.

2.9 Room ambient temperature. The room ambient temperature shall be the arithmetic average temperature of the test area, determined by measurement with four No. 24 AWG bead-type thermocouples with junctions shielded against radiation using shielding meeting the material and minimum thickness requirements from Section 8.14.1 of ANSI Z21.86–2016, located approximately at 90-degree positions on a circle circumscribing the heater or heater enclosure under test, in a horizontal plane approximately at the vertical midpoint of the appliance or test enclosure, and with the junctions approximately 24 inches from sides of the heater or test enclosure and located so as not to be affected by other than room air.

The value T_{RA} is the room ambient temperature measured at the last of the three successive readings taken 15 minutes apart

described in section 3.1.1 or 3.1.2 of this appendix as applicable. During the time period required to perform all the testing and measurement procedures specified in section 3.0 of this appendix, maintain the room ambient temperature within ±5 °F (±2.8 °C) of the value T_{RA}. At no time during these tests shall the room ambient temperature exceed 100 °F (37.8 °C) or fall below 65 °F (18.3 °C).

Locate a thermocouple at each elevation of draft relief inlet opening and combustion air inlet opening at a distance of approximately 24 inches from the inlet openings. The temperature of the air for combustion and the air for draft relief shall not differ more than ±5 °F from the room ambient temperature as measured above at any point in time. This requirement for combustion air inlet temperature does not need to be met once the burner is shut off during the testing described in sections 3.3 and 3.6 of this appendix.

2.10 Equipment used to measure mass flow rate in flue and stack. The tracer gas chosen for this task should have a density which is less than or approximately equal to the density of air. Use a gas unreactive with the environment to be encountered. Using instrumentation of either the batch or continuous type, measure the concentration of tracer gas with an error no greater than 2 percent of the value of the concentration measured.

2.11 Equipment with multiple control modes.

2.11.1 For equipment that has both manual and automatic thermostat control modes, test the unit according to the procedure for its automatic control mode, *i.e.*, single-stage, two-stage, or step-modulating.

2.11.2 For equipment that has multiple automatic thermostat control modes, test in the default mode (or similarly named mode identified for normal operation) as defined by the manufacturer in its I&O manual. If a default mode is not defined in the I&O manual, test in the mode in which the equipment operates as shipped from the manufacturer.

3.0 Testing and measurements.

3.1 *Steady-state testing.*

3.1.1 *Gas fueled vented home heating equipment (including direct vent systems).* Set up the vented heater as specified in sections 2.1, 2.2, and 2.3 of this appendix. The draft diverter shall be in the normal open condition and the stack shall not be insulated. (Insulation of the stack is no longer required for the vented heater test.) Begin the steady-state performance test by operating the burner and the circulating air blower, on units so equipped, with the adjustments specified by sections 2.4.1 and 2.5 of this appendix, until steady-state conditions are attained as indicated by three successive readings taken 15 minutes apart with a temperature variation of not more than ±3 °F (1.7 C) in the stack gas temperature for vented heaters equipped with draft diverters or ±5 °F (2.8 C) in the flue gas temperature for vented heaters equipped with either draft hoods or direct vent systems. The measurements described in this section are to coincide with the last of these 15 minute readings.

On units employing draft diverters, measure the room temperature (T_{RA}) as described in section 2.9 of this appendix and measure the steady-state stack gas temperature ($T_{S,SS}$) using the nine thermocouples located in the 5 foot test stack as specified in section 2.6.1 of this appendix. Secure a sample of the stack gases in the plane where $T_{S,SS}$ is measured or within 3.5 feet downstream of this plane. Determine the concentration by volume of carbon dioxide (X_{CO2S}) present in the dry stack gas. If the location of the gas sampling differs from the temperature measurement plane, there shall be no air leaks through the stack between these two locations.

On units employing draft hoods or direct vent systems, measure the room temperature (T_{RA}) as described in section 2.9 of this appendix and measure the steady-state flue gas temperature ($T_{F,SS}$), using the nine thermocouples located in the flue pipe as described in section 2.6.1 of this appendix. Secure a sample of the flue gas in the plane of temperature measurement and determine the concentration by volume of CO_2 (X_{CO2F}) present in dry flue gas. In addition, for units employing draft hoods, secure a sample of the stack gas in a horizontal plane in the five foot test stack located one foot from the test stack inlet; and determine the concentration by volume of CO_2 (X_{CO2S}) present in dry stack gas.

Determine the steady-state heat input rate (Qin) including pilot gas by multiplying the measured higher heating value of the test gas by the steady-state gas input rate corrected to standard conditions of 60 °F and 30 inches of mercury. Use measured values of gas temperature and pressure at the meter and the barometric pressure to correct the metered gas flow rate to standard conditions.

After the above test measurements have been completed on units employing draft diverters, secure a sample of the flue gases at the exit of the heat exchanger(s) and determine the concentration of CO_2 (X_{CO2F}) present. In obtaining this sample of flue gas, move the sampling probe around or use a sample probe with multiple sampling ports in order to assure that an average value is obtained for the CO_2 concentration. For units with multiple heat exchanger outlets, measure the CO_2 concentration in a sample from each outlet to obtain the average CO_2 concentration for the unit. A manifold (parallel connected sampling tubes) may be used to obtain this sample.

For heaters with single-stage thermostat control (wall mounted electric thermostats), determine the steady-state efficiency at the

maximum fuel input rate as specified in section 2.4 of this appendix.

For gas fueled vented heaters equipped with either two stage control or step-modulating control, determine the steady-state efficiency at the maximum fuel input rate and at the reduced fuel input rate, as specified in section 2.4.1 of this appendix.

For manually controlled gas fueled vented heaters with various input rates, determine the steady-state efficiency at a fuel input rate that is within ±5 percent of 50 percent of the maximum rated fuel input rate as indicated on the nameplate of the unit or in the manufacturer's installation and operation manual shipped with the unit. If the heater is designed to use a control that precludes operation at other than maximum rated fuel input rate (single firing rate) determine the steady state efficiency at the maximum rated fuel input rate only.

3.1.2 Oil-fueled vented home heating equipment (including direct vent systems). Set up and adjust the vented heater as specified in sections 2.1, 2.2, and 2.3.4 of this appendix. Begin the steady-state performance test by operating the burner and the circulating air blower, on units so equipped, with the adjustments specified by sections 2.4.2 and 2.5 of this appendix, until steady-state conditions are attained as indicated by a temperature variation of not more than ±5 °F (2.8 °C) in the flue gas temperature in three successive readings taken 15 minutes apart. The measurements described in this section are to coincide with the last of these 15 minutes readings.

For units equipped with power burners, do not allow smoke in the flue to exceed a No. 1 smoke during the steady-state performance test as measured by the procedure described in ASTM D2156–09 (R2018). Maintain the average draft over the fire and in the breeching during the steady-state performance test at that recommended by the manufacturer ±0.005 inches of water gauge.

Measure the room temperature (T_{RA}) as described in section 2.9 of this appendix. Measure the steady-state flue gas temperature ($T_{F,SS}$) using nine thermocouples (or five, as applicable) located in the flue pipe as described in section 2.6.2 of this appendix. From the plane where $T_{F,SS}$ was measured, collect a sample of the flue gas and determine the concentration by volume of CO_2 (X_{CO2F}) present in dry flue gas. Measure and record the steady-state heat input rate (Q_{in}).

For manually controlled oil fueled vented heaters, determine the steady-state efficiency at a fuel input rate that is within ±5 percent of 50 percent of the maximum fuel input rate; or, if the design of the heater is such that the fuel input rate cannot be set to ±5 percent of 50 percent of the maximum rated fuel input rate, determine the steady-state efficiency at the minimum rated fuel input rate as measured in section 3.1.2 of this appendix for manually controlled oil fueled vented heaters.

3.1.3 *Auxiliary Electric Power Measurement.* Allow the auxiliary electrical system of a gas or oil vented heater to operate for at least five minutes before recording the maximum auxiliary electric power measurement from the wattmeter. Record the maximum electric power (P_E) expressed in kilowatts. For vented heaters with modulating controls, the recorded (P_E) shall be maximum measured electric power multiplied by the following factor (R). For two stage controls, R = 1.3. For step modulating controls, R = 1.4 when the ratio of minimum-to-maximum fuel input is greater than or equal to 0.7, R = 1.7 when the ratio of minimum-to-maximum fuel input is less than 0.7 and greater than or equal to 0.5, and R = 2.2 when the ratio of minimum-to-maximum fuel input is less than 0.5.

3.2 Jacket loss measurement. Conduct a jacket loss test for vented floor furnaces. Measure the jacket loss (L_j) in accordance with ASHRAE 103–2017 Section 8.6, applying the provisions for furnaces and not the provisions for boilers.

3.3 *Measurement of the off-cycle losses for vented heaters equipped with thermal stack dampers.* Unless specified otherwise, the thermal stack damper should be at the draft diverter exit collar. Attach a five foot length of bare stack to the outlet of the damper. Install thermocouples as specified in section 2.6.1 of this appendix.

For vented heaters equipped with single-stage thermostats, measure the off-cycle losses at the maximum fuel input rate. For vented heaters equipped with two stage thermostats, measure the off-cycle losses at the maximum fuel input rate and at the reduced fuel input rate. For vented heaters equipped with step-modulating thermostats, measure the off-cycle losses at the reduced fuel input rate.

Allow the vented heater to heat up to a steady-state condition. Feed a tracer gas at a constant metered rate into the stack directly above and within one foot above the stack damper. Record tracer gas flow rate and temperature. Measure the tracer gas concentration in the stack at several locations in a horizontal plane through a cross-section of the stack at a point sufficiently above the stack damper to ensure that the tracer gas is well mixed in the stack.

Continuously measure the tracer gas concentration and temperature during a 10-minute cool-down period. Shut the burner off and immediately begin measuring tracer gas concentration in the stack, stack temperature, room temperature, and barometric pressure. Record these values as the midpoint of each one-minute interval between burner shut-down and ten minutes after burner shut-down. Meter response time and

sampling delay time shall be considered in timing these measurements.

3.4 *Measurement of the effectiveness of electro-mechanical stack dampers.* For vented heaters equipped with electro-mechanical stack dampers, measure the cross sectional area of the stack (A_s), the net area of the damper plate (A_o), and the angle that the damper plate makes when closed with a plane perpendicular to the axis of the stack (Ω). The net area of the damper plate means the area of the damper plate minus the area of any holes through the damper plate.

3.5 *Pilot light measurement.*

3.5.1 Measure the energy input rate to the pilot light (Q_P) with an error no greater than 3 percent for vented heaters so equipped.

3.5.2 For manually controlled heaters where the pilot light is designed to be turned off by the user when the heater is not in use, that is, turning the control to the OFF position will shut off the gas supply to the burner(s) and to the pilot light, the measurement of Q_P is not needed. This provision applies only if an instruction to turn off the unit is provided on the heater near the gas control valve (e.g. by label) by the manufacturer.

3.6 *Optional procedure for determining* $D_{p'}$ $D_{F'}$ and D_s *for systems for all types of vented heaters.* For all types of vented heaters, $D_{p'}$ $D_{F'}$ and D_S can be measured by the following optional cool down test.

Conduct a cool down test by letting the unit heat up until steady-state conditions are reached, as indicated by temperature variation of not more than 5 °F (2.8 °C) in the flue gas temperature in three successive readings taken 15 minutes apart, and then shutting the unit off with the stack or flue damper controls by-passed or adjusted so that the stack or flue damper remains open during the resulting cool down period. If a draft was maintained on oil fueled units in the flue pipe during the steady-state performance test described in section 3.1 of this appendix, maintain the same draft (within a range of − .001 to + .005 inches of water gauge of the average steady-state draft) during this cool down period.

Measure the flue gas mass flow rate ($m_{F,OFF}$) during the cool down test described above at a specific off-period flue gas temperature and corrected to obtain its value at the steady-state flue gas temperature ($T_{F,SS}$), using the procedure described below.

Within one minute after the unit is shut off to start the cool down test for determining D_F, begin feeding a tracer gas into the combustion chamber at a constant flow rate of V_T, and at a point which will allow for the best possible mixing with the air flowing through the chamber. (On units equipped with an oil fired power burner, the best location for injecting this tracer gas appears to be through a hole drilled in the air tube.) Periodically measure the value of V_T with an instantaneously reading flow meter having an accuracy of ±3 percent of the quantity measured. Maintain V_T at less than 1 percent of the air flow rate through the furnace. If a combustible tracer gas is used, there should be a delay period between the time the burner gas is shut off and the time the tracer gas is first injected to prevent ignition of the tracer gas.

Between 5 and 6 minutes after the unit is shut off to start the cool down test, measure at the exit of the heat exchanger the average flue gas temperature, $T^*_{F,Off}$. At the same instant the flue gas temperature is measured, also measure the percent volumetric concentration of tracer gas C_T in the flue gas in the same plane where $T^*_{F,Off}$ is determined. Obtain the concentration of tracer gas using an instrument which will result in an accuracy of ±2 percent in the value of C_T measured. If use of a continuous reading type instrument results in a delay time between drawing of a sample and its analysis, this delay should be taken into account so that the temperature measurement and the measurement of tracer gas concentration coincide. In addition, determine the temperature of the tracer gas entering the flow meter (T_T) and the barometric pressure (P_B).

The rate of the flue gas mass flow through the vented heater and the factors D_P, D_F, and D_S are calculated by the equations in sections 4.5.1 through 4.5.3 of this appendix.

3.6.1 *Procedure for determining* ($D_{F \text{ and }} D_P$) *of vented home heating equipment with no measurable airflow.* On units whose design is such that there is no measurable airflow through the combustion chamber and heat exchanger when the burner(s) is off (as determined by the test procedure in section 3.6.2 of this appendix), D_F and D_P may be set equal to 0.05.

3.6.2 *Test Method to Determine Whether the Use of the Default Draft Factors* ($D_{F \text{ and }} D_P$) *of 0.05 is Allowed.* Manufacturers may use the following test protocol to determine whether air flows through the combustion chamber and heat exchanger when the burner(s) is off using a smoke stick device. The default draft factor of 0.05 (as allowed per section 3.6.1 of this appendix) may be used only for units determined pursuant to this protocol to have no air flow through the combustion chamber and heat exchanger.

3.6.2.1 *Test Conditions.* Wait for two minutes following the termination of the vented heater's on-cycle.

3.6.2.2 *Location of Test Apparatus*

3.6.2.2.1 After all air currents and drafts in the test chamber have been minimized, position the operable smoke stick/pencil as specified, based on the following equipment configuration: for horizontal combustion air intakes, approximately 4 inches from the vertical plane at the termination of the intake vent and 4 inches below the bottom edge of the combustion air intake, or for

vertical combustion air intakes, approximately 4 inches horizontal from vent perimeter at the termination of the intake vent and 4 inches down (parallel to the vertical axis of the vent). In the instance where the boiler combustion air intake is closer than 4 inches to the floor, place the smoke device directly on the floor without impeding the flow of smoke.

3.6.2.2.2 Monitor the presence and the direction of the smoke flow.

3.6.2.3 *Duration of Test.* Continue monitoring the release of smoke for no less than 30 seconds.

3.6.2.4 *Test Results*

3.6.2.4.1 During visual assessment, determine whether there is any draw of smoke into the combustion air intake.

3.6.2.4.2 If absolutely no smoke is drawn into the combustion air intake, the vented heater meets the requirements to allow use of the default draft factor of 0.05.

3.6.2.4.3 If there is any smoke drawn into the intake, use of default draft factor of 0.05 is prohibited. Proceed with the methods of testing as prescribed in section 3.6 of this appendix, or select the appropriate default draft factor from Table 1.

3.7 *Measurement of electrical standby mode and off mode power.*

3.7.1 *Standby power measurements.* With all electrical auxiliaries of the vented heater not activated, measure the standby power ($P_{W,SB}$) in accordance with the procedures in IEC 62301 (Second Edition) (incorporated by reference, see §430.3), except that section 2.9, *Room ambient temperature,* and the voltage provision of section 2.3.5, *Electrical supply,* of this appendix shall apply in lieu of the IEC 62301 (Second Edition) corresponding sections 4.2, *Test room,* and 4.3, *Power supply.* Clarifying further, the IEC 62301 (Second Edition) sections 4.4, *Power measuring instruments,* and section 5, *Measurements,* shall apply in lieu of section 2.8, *Energy flow instrumentation,* of this appendix. Measure the wattage so that all possible standby mode wattage for the entire appliance is recorded, not just the standby mode wattage of a single auxiliary. The recorded standby power ($P_{W,SB}$) shall be rounded to the second decimal place, and for loads greater than or equal to 10W, at least three significant figures shall be reported.

3.7.2 *Off mode power measurement.* If the unit is equipped with a seasonal off switch or there is an expected difference between off mode power and standby mode power, measure off mode power ($P_{W,OFF}$) in accordance with the standby power procedures in IEC 62301 (Second Edition) (incorporated by reference, see §430.3), except that section 2.9, *Room ambient temperature,* and the voltage provision of section 2.3.5, *Electrical supply,* of this appendix shall apply in lieu of the IEC 62301 (Second Edition) corresponding sections 4.2, *Test room,* and 4.3, *Power supply.* Clarifying further, the IEC 62301 (Second Edition) sections 4.4, *Power measuring instruments,* and section 5, *Measurements,* shall apply in lieu of section 2.8, *Energy flow instrumentation,* of this appendix. Measure the wattage so that all possible off mode wattage for the entire appliance is recorded, not just the off mode wattage of a single auxiliary. If there is no expected difference in off mode power and standby mode power, let $P_{W,OFF} = P_{W,SB}$, in which case no separate measurement of off mode power is necessary. The recorded off mode power ($P_{W,OFF}$) shall be rounded to the second decimal place, and for loads greater than or equal to 10W, at least three significant figures shall be reported.

3.8 *Condensing vented heaters—measurement of condensate under steady-state and cyclic conditions.* Attach condensate drain lines to the vented heater as specified in the manufacturer's I&O manual provided with the unit. The test unit shall be level prior to all testing. A continuous downward slope of drain lines from the unit shall be maintained. The drain lines must facilitate uninterrupted flow of condensate during the test. The condensate collection container must be glass or polished stainless steel to facilitate removal of interior deposits. The collection container shall have a vent opening to the atmosphere, be dried prior to each use, and be at room ambient temperature. The humidity of the room air shall at no time exceed 80 percent relative humidity. For condensing units not designed for collecting and draining condensate, drain lines must be provided during testing that meet the criteria set forth in this section 3.8. Units employing manual controls and units not tested under the optional tracer gas procedures of sections 3.3 and 3.6 of this appendix shall only conduct the steady-state condensate collection test.

3.8.1 *Steady-state condensate collection test.* Begin steady-state condensate collection concurrently with or immediately after completion of the steady-state testing of section 3.1 of this appendix. The steady-state condensate collection period shall be 30 minutes. Condensate mass shall be measured immediately at the end of the collection period to minimize evaporation loss from the sample. Record fuel input during the 30-minute condensate collection steady-state test period. Measure and record fuel higher heating value (HHV), temperature, and pressures necessary for determining fuel energy input ($Q_{c,ss}$). The fuel quantity and HHV shall be measured with errors no greater than ±1 percent. Determine the mass of condensate for the steady-state test ($M_{c,ss}$) in pounds by subtracting the tare container weight from the total container and condensate weight measured at the end of the 30-minute condensate collection test period. The error associated with the mass measurement instruments

shall not exceed ±0.5 percent of the quantity measured.

For units with step-modulating or two stage controls, the steady-state condensate collection test shall be conducted at both the maximum and reduced input rates.

3.8.2 Cyclic condensate collection tests. If existing controls do not allow for cyclical operation of the tested unit, install control devices to allow cyclical operation of the vented heater. Run three consecutive test cycles. For each cycle, operate the unit until flue gas temperatures at the end of each on-cycle, rounded to the nearest whole number, are within 5 °F of each other for two consecutive cycles. On-cycle and off-cycle times are 4 minutes and 13 minutes respectively. Control of ON and OFF operation actions shall be within ±6 seconds of the scheduled time. For fan-type vented heaters, maintain circulating air adjustments as specified in section 2.5 of this appendix. Begin condensate collection at one minute before the on-cycle period of the first test cycle. Remove the container one minute before the end of each off-cycle period. Measure condensate mass for each test-cycle. The error associated with the mass measurement instruments shall not exceed ±0.5 percent of the quantity measured.

Record fuel input during the entire test period starting at the beginning of the on-time period of the first cycle to the beginning of the on-time period of the second cycle, from the beginning of the on-time period of the second cycle to the beginning of the on-time period of the third cycle, etc., for each of the test cycles. Record fuel HHV, temperature, and pressure necessary for determining fuel energy input, Q_C. Determine the mass of condensate for each cycle, M_C, in pounds. If at the end of three cycles, the sample standard deviation is less than or equal to 20 percent of the mean value for three cycles, use total condensate collected in the three cycles as M_C; if not, continue collection for an additional three cycles and use the total condensate collected for the six cycles as M_C. Determine the fuel energy input, Q_C, during the three or six test cycles, expressed in Btu.

For units with step-modulating controls, conduct the cyclic condensate collection test at reduced input rate only. For units with two-stage controls, conduct the cyclic condensate collection test at both maximum and reduced input rates unless the balance-point temperature (T_C) as determined in section 4.1.10 of this appendix O is equal to or less than the typical outdoor design temperature of 5 °F (–5 °C), in which case, conduct testing at the reduced input rate only.

4.0 Calculations.

4.1 *Annual fuel utilization efficiency for gas fueled or oil fueled vented home heating equipment equipped without manual controls or with multiple control modes as per 2.11 and without thermal stack dampers.* The following procedure determines the annual fuel utilization efficiency for gas fueled or oil fueled vented home heating equipment equipped without manual controls and without thermal stack dampers.

4.1.1 *System number.* Obtain the system number from Table 1 of this appendix.

4.1.2 *Off-cycle flue gas draft factor.* Based on the system number, determine the off-cycle flue gas draft factor (D_F) from Table 1 of this appendix or the test method and calculations of sections 3.6 and 4.5 of this appendix.

4.1.3 *Off-cycle stack gas draft factor.* Based on the system number, determine the off-cycle stack gas draft factor (D_s) from Table 1 of this appendix or from the test method and calculations of sections 3.6 and 4.5 of this appendix,.

4.1.4 *Pilot fraction.* Calculate the pilot fraction (P_F) expressed as a decimal and defined as:

$$P_F = Q_P/Q_{in}$$

where:

Q_P = as defined in 3.5 of this appendix

Q_{in} = as defined in 3.1 of this appendix at the maximum fuel input rate

4.1.5 *Jacket loss for floor furnaces.* Determine the jacket loss (L_j) expressed as a percent and measured in accordance with section 3.2 of this appendix. For other vented heaters $L_j = 0.0$.

4.1.6 *Latent heat loss.* For non-condensing vented heaters, obtain the latent heat loss ($L_{L,A}$) from Table 2 of this appendix. For condensing vented heaters, calculate a modified latent heat loss ($L_{L,A}$*) as follows:

For steady-state conditions:

$$L_{L,A}* = L_{L,A} - L_{G,SS} + L_{C,SS}$$

where:

$L_{L,A}$ = Latent heat loss, based on fuel type, from Table 2 of this appendix,

$L_{G,SS}$ = Steady-state latent heat gain due to condensation as determined in section 4.1.6.1 of this appendix, and

$L_{C,SS}$ = Steady-state heat loss due to hot condensate going down the drain as determined in 4.1.6.2 of this appendix.

For cyclic conditions: (only for vented heaters tested under the optional tracer gas procedures of section 3.3 or 3.6)

$$L_{L,A}* = L_{L,A} - L_G + L_C$$

where:

$L_{L,A}$ = Latent heat loss, based on fuel type, from Table 2 of this appendix,

L_G = Latent heat gain due to condensation under cyclic conditions as determined in section 4.1.6.3 of this appendix, and

L_C = Heat loss due to hot condensate going down the drain under cyclic conditions as determined in section 4.1.6.4 of this appendix.

4.1.6.1 *Latent heat gain due to condensation under steady-state conditions.* Calculate the latent heat gain ($L_{G,SS}$) expressed as a percent and defined as:

$$L_{G,SS} = 100\frac{(1053.3)M_{C.SS}}{Q_{C,SS}}$$

where:

100 = conversion factor to express a decimal as a percent,

1053.3 = latent heat of vaporization of water, Btu per pound,

$M_{c,ss}$ = mass of condensate for the steady-state test as determined in section 3.8.1 of this appendix, pounds, and

$Q_{c,ss}$ = fuel energy input for steady-state test as determined in section 3.8.1 of this appendix, Btu.

4.1.6.2 *Heat loss due to hot condensate going down the drain under steady-state conditions.* Calculate the steady-state heat loss due to hot condensate going down the drain ($L_{C,SS}$) expressed as a percent and defined as:

$$L_{C,SS} = L_{G,SS}\frac{1.0\left(T_{F,SS} - 70\right) - 0.45\left(T_{F,SS} - 45\right)}{1053.3}$$

where:

$L_{G,SS}$ = Latent heat gain due to condensation under steady-state conditions as defined in section 4.1.6.1 of this appendix,

1.0 = specific heat of water, Btu/lb− °F,

$T_{F,SS}$ = Flue (or stack) gas temperature as defined in section 3.1 of this appendix, °F,

70 = assumed indoor temperature, °F,

0.45 = specific heat of water vapor, Btu/lb− °F, and

45 = average outdoor temperature for vented heaters, °F.

4.1.6.3 *Latent heat gain due to condensation under cyclic conditions.* (only for vented heaters tested under the optional tracer gas procedures of section 3.3 or 3.6 of this appendix) Calculate the latent heat gain (L_G) expressed as a percent and defined as:

$$L_G = 100\frac{(1053.3)M_C}{Q_C}$$

where:

100 = conversion factor to express a decimal as a percent,

1053.3 = latent heat of vaporization of water, Btu per pound,

M_c = mass of condensate for the cyclic test as determined in 3.8.2 of this appendix, pounds, and

Q_c = fuel energy input for cyclic test as determined in 3.8.2 of this appendix, Btu.

4.1.6.4 *Heat loss due to hot condensate going down the drain under cyclic conditions. (only for vented heaters tested under the optional tracer gas procedures of section 3.3 or 3.6 of this appendix)* Calculate the cyclic heat loss due to hot condensate going down the drain (L_C) expressed as a percent and defined as:

$$L_C = L_G\frac{1.0\left(T_{F,SS} - 70\right) - 0.45\left(T_{F,SS} - 45\right)}{1053.3}$$

where:

L_G = Latent heat gain due to condensation under cyclic conditions as defined in section 4.1.6.3 of this appendix,
1.0 = specific heat of water, Btu/lb− °F,
$T_{F,SS}$ = Flue (or stack) gas temperature as defined in section 3.1 of this appendix,
70 = assumed indoor temperature, °F,
0.45 = specific heat of water vapor, Btu/lb− °F, and
45 = average outdoor temperature for vented heaters, °F.

4.1.7 *Ratio of combustion air mass flow rate to stoichiometric air mass flow rate.* Determine the ratio of combustion air mass flow rate to stoichiometric air mass flow rate ($R_{T,F}$), and defined as:

$$R_{T,F} = A + B/X_{CO2F}$$

where:

A = as determined from Table 2 of this appendix
B = as determined from Table 2 of this appendix
X_{CO2F} = as defined in 3.1 of this appendix

4.1.8 *Ratio of combustion and relief air mass flow rate to stoichiometric air mass flow rate.* For vented heaters equipped with either an integral draft diverter or a draft hood, determine the ratio of combustion and relief air mass flow rate to stoichiometric air mass flow rate ($R_{T,S}$), and defined as:

$$R_{T,S} = A + [B/X_{CO2S}]$$

where:

A = as determined from Table 2 of this appendix,
B = as determined from Table 2 of this appendix, and
X_{CO2S} = as defined in section 3.1 of this appendix.

4.1.9 *Sensible heat loss at steady-state operation.* For vented heaters equipped with either an integral draft diverter or a draft hood, determine the sensible heat loss at steady-state operation ($L_{S,SS,A}$) expressed as a percent and defined as:

where:

$$L_{S,SS,A} = C(R_{T,S} + D)(T_{S,SS} - T_{RA})$$

C = as determined from Table 2 of this appendix
$R_{T,S}$ = as defined in 4.1.8 of this appendix
D = as determined from Table 2 of this appendix
$T_{S,SS}$ = as defined in 3.1 of this appendix
T_{RA} = as defined in 2.9 of this appendix

For vented heaters equipped without an integral draft diverter, determine ($L_{S,SS,A}$) expressed as a percent and defined as:

$$L_{S,SS,A} = C(R_{T,F} + D)(T_{F,SS} - T_{RA})$$

where:

C = as determined from Table 2 of this appendix
$R_{T,F}$ = as defined in 4.1.7 of this appendix
D = as determined from Table 2 of this appendix
$T_{F,SS}$ = as defined in 3.1 of this appendix
T_{RA} = as defined in 2.9 of this appendix

4.1.10 *Steady-state efficiency.* For vented heaters equipped with single-stage thermostats, calculate the steady-state efficiency (excluding jacket loss), $\eta_{SS,}$ expressed in percent and defined as:

$$\eta_{SS} = 100 - L_{L,A} - L_{S,SS,A}$$

where:

$L_{L,A}$ = latent heat loss, as defined in section 4.1.6 of this appendix (for condensing vented heaters $L_{L,A}$* for steady-state conditions), and
$L_{S,SS,A}$ = sensible heat loss at steady-state operation, as defined in section 4.1.9 of this appendix.

For vented heaters equipped with either two stage controls or with step-modulating controls, calculate the steady-state efficiency at the reduced fuel input rate, η_{SS-L}, expressed in percent and defined as:

$$\eta_{SS-L} = 100 - L_{L,A} - L_{S,SS,A}$$

where:

$L_{L,A}$ = latent heat loss, as defined in section 4.1.6 of this appendix (for condensing vented heaters $L_{L,A}$* for steady-state conditions at the reduced firing rate), and
$L_{S,SS,A}$ = sensible heat loss at steady-state operation, as defined in section 4.1.9 of this appendix, in which $L_{S,SS,A}$ is determined at the reduced fuel input rate.

For vented heaters equipped with two stage controls, calculate the steady-state efficiency at the maximum fuel input rate, η_{SS-H}, expressed in percent and defined as:

$$\eta_{SS-H} = 100 - L_{L,A} - L_{S,SS,A}$$

where:

$L_{L,A}$ = latent heat loss, as defined in section 4.1.6 of this appendix (for condensing vented heaters $L_{L,A}$* for steady-state conditions at the maximum fuel input rate), and
$L_{S,SS,A}$ = sensible heat loss at steady-state operation, as defined in section 4.1.9 of this appendix, in which $L_{S,SS,A}$ is measured at the maximum fuel input rate.

For vented heaters equipped with step-modulating thermostats, calculate the weighted-average steady-state efficiency in the modulating mode, η_{SS-MOD}, expressed in percent and defined as:

$$\eta_{SS-MOD} = [\eta_{SS-H} - \eta_{SS-L}]\left[\frac{T_C - T_{OA*}}{T_C - 15}\right] + \eta_{SS-L}$$

where:

η_{SS-H} = steady-state efficiency at the maximum fuel input rate, as defined in section 4.1.10 of this appendix,

η_{SS-L} = steady-state efficiency at the reduced fuel input rate, as defined in section 4.1.10 of this appendix,

T_{OA}* = average outdoor temperature for vented heaters with step-modulating thermostats operating in the modulating mode and is obtained from Table 3 or Figure 1 of this appendix, and

T_C = balance point temperature which represents a temperature used to apportion the annual heating load between the reduced input cycling mode and either the modulating mode or maximum input cycling mode and is obtained either from Table 3 of this appendix or calculated by the following equation:

$T_C = 65 - [(65 - 15)R]$

where:

65 = average outdoor temperature at which a vented heater starts operating,

15 = national average outdoor design temperature for vented heaters, and

R = ratio of reduced to maximum heat output rates, as defined in section 4.1.13 of this appendix.

4.1.11 *Reduced heat output rate.* For vented heaters equipped with either two stage thermostats or step-modulating thermostats, calculate the reduced heat output rate ($Q_{red-out}$) defined as:

$Q_{red-out} = \eta_{SS-L}\, Q_{red-in}$

where:

η_{SS-L} = as defined in 4.1.10 of this appendix

Q_{red-in} = the reduced fuel input rate

4.1.12 *Maximum heat output rate.* For vented heaters equipped with either two stage thermostats or step-modulating thermostats, calculate the maximum heat output rate ($Q_{max-out}$) defined as:

$Q_{max,out} = h_{SS,H}\, Q_{max,in}$

where:

η_{SS-H} = as defined in 4.1.10 of this appendix

Q_{max-in} = the maximum fuel input rate

4.1.13 *Ratio of reduced to maximum heat output rates.* For vented heaters equipped with either two stage thermostats or step-modulating thermostats, calculate the ratio of reduced to maximum heat output rates (R) expressed as a decimal and defined as:

$R = Q_{red-out}/Q_{max-out}$

where:

$Q_{red-out}$ = as defined in 4.1.11 of this appendix

$Q_{max-out}$ = as defined in 4.1.12 of this appendix

4.1.14 *Fraction of heating load at reduced operating mode.* For vented heaters equipped with either two stage thermostats or step-modulating thermostats, determine the fraction of heating load at the reduced operating mode (X_1) expressed as a decimal and listed in Table 3 of this appendix or obtained from Figure 2 of this appendix.

4.1.15 *Fraction of heating load at maximum operating mode or noncycling mode.* For vented heaters equipped with either two stage thermostats or step-modulating thermostats, determine the fraction of heating load at the maximum operating mode or noncycling mode (X_2) expressed as a decimal and listed in Table 3 of this appendix or obtained from Figure 2 of this appendix.

4.1.16 *Weighted-average steady-state efficiency.* For vented heaters equipped with single-stage thermostats, the weighted-average steady-state efficiency (η_{SS-WT}) is equal to $\eta_{SS,}$ as defined in section 4.1.10 of this appendix. For vented heaters equipped with two stage thermostats, η_{SS-WT} is defined as:

$\eta_{SS-WT} = X_1\eta_{SS-L} + X_2\eta_{SS-H}$

where:

X_1 = as defined in section 4.1.14 of this appendix

η_{SS-L} = as defined in section 4.1.10 of this appendix

X_2 = as defined in section 4.1.15 of this appendix

η_{SS-H} = as defined in section 4.1.10 of this appendix

For vented heaters equipped with step-modulating controls, η_{SS-WT} is defined as:

$\eta_{SS-WT} = X_1\eta_{SS-L} + X_2\eta_{SS-MOD}$

where:

X_1 = as defined in section 4.1.14 of this appendix

η_{SS-L} = as defined in section 4.1.10 of this appendix

X_2 = as defined in section 4.1.15 of this appendix

η_{SS-MOD} = as defined in section 4.1.10 of this appendix

4.1.17 *Annual fuel utilization efficiency.* Calculate the annual fuel utilization efficiency (AFUE) expressed as percent and defined as:

$AFUE = [0.968\eta_{SS\ -\ WT}] - 1.78D_F - 1.89D_S - 129P_F - 2.8\ L_J + 1.81$

where:

η_{SS-WT} = as defined in 4.1.16 of this appendix

D_F = as defined in 4.1.2 of this appendix
D_S = as defined in 4.1.3 of this appendix
P_F = as defined in 4.1.4 of this appendix
L_J = as defined in 4.1.5 of this appendix

4.2 *Annual fuel utilization efficiency for gas or oil fueled vented home heating equipment equipped with manual controls.* The following procedure determines the annual fuel utilization efficiency for gas or oil fueled vented home heating equipment equipped with manual controls.

4.2.1 *Average ratio of stack gas mass flow rate to flue gas mass flow rate at steady-state operation.* For vented heaters equipped with either direct vents or direct exhaust or that are outdoor units, the average ratio of stack gas mass flow rate to flue gas mass flow rate at steady-state operation (S/F) shall be equal to unity. (S/F = 1) For all other types of vented heaters, calculate (S/F) defined as:

$$\frac{S}{F} = 1.3\frac{R_{T,S}}{R_{T,F}}$$

where:

$R_{T,S}$ = as defined in section 4.1.8 of this appendix with X_{CO2s} as measured in section 3.1. of this appendix

$R_{T,F}$ = as defined in section 4.1.7 of this appendix with X_{CO2F} as measured in section 3.1. of this appendix

4.2.2 *Multiplication factor for infiltration loss during burner on-cycle.* Calculate the multiplication factor for infiltration loss during burner on-cycle ($K_{I,ON}$) defined as:

$$K_{I,ON} = 100(0.24)(S/F)(0.7)\frac{1 + R_{T,F}(A/F)}{HHV_A}$$

where:

100 = converts a decimal fraction into a percent
0.24 = specific heat of air
A/F = stoichiometric air/fuel ratio, determined in accordance with Table 2 of this appendix
S/F = as defined in section 4.2.1 of this appendix
0.7 = infiltration parameter
$R_{T,F}$ = as defined in section 4.1.7 of this appendix
HHV_A = average higher heating value of the test fuel, determined in accordance with Table 2 of this appendix

4.2.3 *On-cycle infiltration heat loss.* Calculate the on-cycle infiltration heat loss ($L_{I,ON}$) expressed as a percent and defined as:

$L_{I,ON} = K_{I,ON}$ (70–45)

where:

$K_{I,ON}$ = as defined in 4.2.2 of this appendix
70 = average indoor temperature
45 = average outdoor temperature

4.2.4 *Weighted-average steady-state efficiency.*

4.2.4.1 For manually controlled heaters with various input rates the weighted average steady-state efficiency (η_{SS-WT}), is determined as follows:

$\eta_{SS-WT} = 100 - L_{L,A} - L_{S,SS,A}$

where:

$L_{L,A}$ = latent heat loss, as defined in section 4.1.6 of this appendix (for condensing vented heaters, $L_{L,A}$* for steady-state conditions), and

$L_{S,SS,A}$ = steady-state efficiency at the reduced fuel input rate, as defined in section 4.1.9 of this appendix and where $L_{L,A}$ and $L_{S,SS,A}$ are determined:

(1) at 50 percent of the maximum fuel input rate as measured in either section 3.1.1 of this appendix for manually controlled gas vented heaters or section 3.1.2 of this appendix for manually controlled oil vented heaters, or

(2) at the minimum fuel input rate as measured in either section 3.1.1 of this appendix for manually controlled gas vented heaters or section 3.1.2 of this appendix for manually controlled oil vented heaters if the design of the heater is such that the ±5 percent of 50 percent of the maximum fuel input rate cannot be set, provided this minimum rate is no greater than ⅔ of the maximum input rate of the heater.

4.2.4.2 For manually controlled heater with one single firing rate the weighted average steady-state efficiency is the steady-state efficiency measured at the single firing rate.

4.2.5 *Part-load fuel utilization efficiency*. Calculate the part-load fuel utilization efficiency (η_u) expressed as a percent and defined as:

$\eta_u = \eta_{SS\text{-}WT} - L_{I,ON}$

where:

$\eta_{SS\text{-}WT}$ = as defined in 4.2.4 of this appendix
$L_{I,ON}$ = as defined in 4.2.3 of this appendix

4.2.6 *Annual Fuel Utilization Efficiency*.

4.2.6.1 For manually controlled vented heaters, calculate the AFUE expressed as a percent and defined as:

$$AFUE = \frac{2{,}950\ \eta_{SS}\ \eta_u\ Q_{in-max}}{2{,}950\ \eta_{SS}\ Q_{in-max} + 2.083(4{,}600)\eta_u\ Q_P}$$

where:

2,950 = average number of heating degree days
η_{SS} = as defined as η_{SS-WT} in 4.2.4 of this appendix
η_u = as defined in 4.2.5 of this appendix
Q_{in-max} = as defined as Q_{in} at the maximum fuel input rate, as defined in 3.1 of this appendix
4,600 = average number of non-heating season hours per year
Q_P = as defined in 3.5 of this appendix
2.083 = (65 − 15) / 24 = 50 / 24
65 = degree day base temperature, °F
15 = national average outdoor design temperature for vented heaters as defined in section 4.1.10 of this appendix
24 = number of hours in a day

4.2.6.2 For manually controlled vented heaters where the pilot light can be turned off by the user when the heater is not in use as described in section 3.5.2, calculate the AFUE expressed as a percent and defined as:

$AFUE = \eta_u$

where:

η_u = as defined in section 4.2.5 of this appendix

4.3 *Annual fuel utilization efficiency by the tracer gas method*. The annual fuel utilization efficiency shall be determined by the following tracer gas method for all vented heaters equipped with thermal stack dampers.

4.3.1 *On-cycle sensible heat loss*. For vented heaters equipped with single-stage thermostats, calculate the on-cycle sensible heat loss ($L_{S,ON}$) expressed as a percent and defined as:

$L_{S,ON} = L_{S,SS,A}$

where:

$L_{S,SS,A}$ = as defined in section 4.1.9 of this appendix

For vented heaters equipped with two stage thermostats, calculate $L_{S,ON}$ defined as:

$L_{S,ON} = X_1 L_{S,SS,A\text{-}red} + X_2 L_{S,SS,A\text{-}max}$

where:

X_1 = as defined in section 4.1.14 of this appendix
$L_{S,SS,A\text{-}red}$ = as defined as $L_{S,SS,A}$ in section 4.1.9 of this appendix at the reduced fuel input rate
X_2 = as defined in section 4.1.15 of this appendix
$L_{S,SS,A\text{-}max}$ = as defined as $L_{S,SS,A}$ in section 4.1.9 of this appendix at the maximum fuel input rate

For vented heaters with step-modulating controls, calculate $L_{S,ON}$ defined as:

$L_{S,ON} = X_1 L_{S,SS,A\text{-}red} + X_2 L_{S,SS,A\text{-}avg}$

where:

X_1 = as defined in section 4.1.14 of this appendix
$L_{LS,SS,A\text{-}red}$ = as defined in section 4.3.1 of this appendix
X_2 = as defined in section 4.1.15 of this appendix
$L_{S,SS,A\text{-}avg}$ = average sensible heat loss for step-modulating vented heaters operating in the modulating mode

$$L_{S,SS,A-avg} = \left[\left[L_{S,SS,A-max} - L_{S,SS,A-red}\right]\left[\frac{T_C - T_{OA*}}{T_C - 15}\right]\right] + L_{S,SS,A-red}$$

where:

$L_{S,SS,A\text{-}avg}$ = as defined in section 4.3.1 of this appendix
T_C = as defined in section 4.1.10 of this appendix
T_{OA*} = as defined in section 4.1.10 of this appendix

15 = as defined in section 4.1.10 of this appendix

4.3.2 *On-cycle infiltration heat loss.* For vented heaters equipped with single-stage thermostats, calculate the on-cycle infiltration heat loss ($L_{I,ON}$) expressed as a percent and defined as:

$L_{I,ON} = K_{I,ON}(70-45)$

where:

$K_{I,ON}$ = as defined in section 4.2.2 of this appendix

70 = as defined in section 4.2.3 of this appendix

45 = as defined in section 4.2.3 of this appendix

For vented heaters equipped with two stage thermostats, calculate $L_{I,ON}$ defined as:

$L_{I,ON} = X_1K_{I,ON\text{-}Max}(70-T_{OA*}) + X_2K_{I,ON,red}(70-T_{OA})$

where:

X_1 = as defined in section 4.1.14 of this appendix

$K_{I,ON\text{-}max}$ = as defined as $K_{I,ON}$ in section 4.2.2 of this appendix at the maximum heat input rate

70 = as defined in section 4.2.3 of this appendix

T_{OA*} = as defined in section 4.3.4 of this appendix

$K_{I,ON,red}$ = as defined as $K_{I,ON}$ in section 4.2.2 of this appendix at the minimum heat input rate

T_{OA} = as defined in section 4.3.4 of this appendix

X_2 = as defined in section 4.1.15 of this appendix

For vented heaters equipped with step-modulating thermostats, calculate $L_{I,ON}$ defined as:

$L_{I,ON} = X_1K_{I,ON\text{-}avg}(70-T_{OA*}) + X_2K_{I,ON,red}(70-T_{OA})$

where:

X_1 = as defined in section 4.1.14 of this appendix

$$K_{I,on,avg} = \frac{\left[K_{I,on,max} + K_{I,on,red}\right]}{2}$$

70 = as defined in section 4.2.3 of this appendix

T_{OA*} = as defined in section 4.3.4 of this appendix

X_2 = as defined in section 4.1.15 of this appendix

T_{OA} = as defined in section 4.3.4 of this appendix

4.3.3 *Off-cycle sensible heat loss.* For vented heaters equipped with single-stage thermostats, calculate the off-cycle sensible heat loss ($L_{S,OFF}$) at the maximum fuel input rate. For vented heaters equipped with step-modulating thermostats, calculate $L_{S,OFF}$ defined as:

$L_{S,OFF} = X_1\ L_{S,OFF,red}$

where:

X_1 = as defined in section 4.1.14 of this appendix, and

$L_{S,OFF,red}$ = as defined as $L_{S,OFF}$ in section 4.3.3 of this appendix at the reduced fuel input rate.

For vented heaters equipped with two stage controls, calculate $L_{S,OFF}$ defined as:

$L_{S,OFF} = X_1\ L_{S,OFF,red} + X_2\ L_{S,OFF,Max}$

where:

X_1 = as defined in section 4.1.14 of this appendix,

$L_{S,OFF,red}$ = as defined as $L_{S,OFF}$ in section 4.3.3 of this appendix at the reduced fuel input rate,

X_2 = as defined in section 4.1.15 of this appendix, and

$L_{S,OFF,Max}$ = as defined as $L_{S,OFF}$ in section 4.3.3 of this appendix at the maximum fuel input rate.

Calculate the off-cycle sensible heat loss ($L_{S,OFF}$) expressed as a percent and defined as:

$$L_{s,OFF} = \frac{100\ (0.24)}{Q_{in}t_{on}}\sum m_{s,OFF}(T_{s,OFF} - T_{RA})$$

where:

100 = conversion factor for percent,

0.24 = specific heat of air in Btu per pound—°F,

Q_{in} = fuel input rate, as defined in section 3.1 of this appendix in Btu per minute (as appropriate for the firing rate),

t_{on} = average burner on-time per cycle and is 20 minutes,

$\Sigma m_{S,OFF} (T_{S,OFF} - T_{RA})$ = summation of the ten values (for single-stage or step-modulating models) or twenty values (for two tage models) of the quantity, $m_{S,OFF}$ $(T_{S,OFF} - T_{RA})$, measured in accordance with section 3.3 of this appendix, and

$m_{S,OFF}$ = stack gas mass flow rate pounds per minute.

$$m_{S,OFF} = \frac{1.325 P_B V_T (C_{T*} - C_T)}{C_T (T_T + 460)}$$

$T_{S,OFF}$ = stack gas temperature measured in accordance with section 3.3 of this appendix,

T_{RA} = average room temperature measured in accordance with section 3.3 of this appendix,

P_B = barometric pressure in inches of mercury,

V_T = flow rate of the tracer gas through the stack in cubic feet per minute,

C_{T*} = concentration by volume of the active tracer gas in the mixture in percent and is 100 when the tracer gas is a single component gas,

C_T = concentration by volume of the active tracer gas in the diluted stack gas in percent,

T_T = temperature of the tracer gas entering the flow meter in degrees Fahrenheit, and

$(T_T + 460)$ = absolute temperature of the tracer gas entering the flow meter in degrees Rankine.

4.3.4 *Average outdoor temperature.* For vented heaters equipped with single-stage thermostats, the average outdoor temperature (T_{OA}) is 45 °F. For vented heaters equipped with either two stage thermostats or step-modulating thermostats, T_{OA} during the reduced operating mode is obtained from Table 3 or Figure 1 of this appendix. For vented heaters equipped with two stage thermostats, T_{OA*} during the maximum operating mode is obtained from Table 3 or Figure 1 of this appendix.

4.3.5 *Off-cycle infiltration heat loss.* For vented heaters equipped with single stage thermostats, calculate the off-cycle infiltration heat loss ($L_{I,OFF}$) at the maximum fuel input rate. For vented heaters equipped with step-modulating thermostats, calculate $L_{I,OFF}$ defined as:

$L_{I,OFF} = X_1 L_{I,OFF,red}$

where:

X_1 = as defined in section 4.1.14 of this appendix

$L_{I,OFF,red}$ = as defined in $L_{I,OFF}$ in section 4.3.5 of this appendix at the reduced fuel input rate

For vented heaters equipped with two stage thermostats, calculate $L_{I,OFF}$ defined as:

$L_{I,OFF} = X_1 L_{I,OFF,red} + X_2 L_{I,OFF,max}$

where:

X_1 = as defined in section 4.1.14 of this appendix

$L_{I,OFF,red}$ = as defined as $L_{I,OFF}$ in section 4.3.5 of this appendix at the reduced fuel input rate

X_2 = as defined in section 4.1.15 of this appendix

$L_{I,OFF,Max}$ = as defined as $L_{I,OFF}$ in section 4.3.5 of this appendix at the maximum fuel input rate

Calculate the off-cycle infiltration heat loss ($L_{I,OFF}$) expressed as a percent and defined as:

$$L_{I,OFF} = \frac{100(0.24)(1.3)(0.7)(70 - T_{OA})}{Q_{in} t_{on}} \sum m_{S,OFF}$$

where:

100 = conversion factor for percent

0.24 = specific heat of air in Btu per pound—°F

1.3 = dimensionless factor for converting laboratory measured stack flow to typical field conditions

0.7 = infiltration parameter

70 = assumed average indoor air temperature, °F

T_{OA} = average outdoor temperature as defined in section 4.3.4 of this appendix

Q_{in} = fuel input rate, as defined in section 3.1 of this appendix in Btu per minute (as appropriate for the firing rate)

t_{on} = average burner on-time per cycle and is 20 minutes

$\Sigma m_{S,OFF}$ = summation of the twenty values of the quantity, $m_{S,OFF}$, measured in accordance with section 3.3 of this appendix

$m_{S,OFF}$ = as defined in section 4.3.3 of this appendix

4.3.6 *Part-load fuel utilization efficiency.* Calculate the part-load fuel utilization efficiency (η_u) expressed as a percent and defined as:

$$\eta_u = 100 - L_{L,A} - C_j L_j - \left[\frac{t_{on}}{t_{on} + P_F\, t_{off}}\right] \times \left[L_{S,ON} + L_{S,OFF} + L_{I,ON} + L_{I,OFF}\right]$$

where:

C_j = 2.8, adjustment factor,
L_j = jacket loss as defined in section 4.1.5,
$L_{L,A}$ = Latent heat loss, as defined in section 4.1.6 of this appendix (for condensing vented heaters $L_{L,A}$* for cyclic conditions),
t_{on} = Average burner on time which is 20 minutes,
$L_{S,ON}$ = On-cycle sensible heat loss, as defined in section 4.3.1 of this appendix,
$L_{S,OFF}$ = Off-cycle sensible heat loss, as defined in section 4.3.3 of this appendix,
$L_{I,ON}$ = On-cycle infiltration heat loss, as defined in section 4.3.2 of this appendix,
$L_{I,OFF}$ = Off-cycle infiltration heat loss, as defined in section 4.3.5 of this appendix,
P_F = Pilot fraction, as defined in section 4.1.4 of this appendix, and
t_{OFF} = average burner off-time per cycle, which is 20 minutes.

4.3.7 Annual Fuel Utilization Efficiency.

Calculate the AFUE expressed as a percent and defined as:

$$AFUE = \frac{2{,}950\ \eta_{SS-WT}\ \eta_u\ Q_{in-max}}{2{,}950\ \eta_{SS-WT}\ Q_{in-max} + 2.083(4{,}600)\,\eta_u\ Q_P}$$

where:

2,950 = average number of heating degree days
η_{SS-WT} = as defined in 4.1.16 of this appendix
η_u = as defined in 4.3.6 of this appendix
Q_{in-max} = as defined in 4.2.6 of this appendix
4,600 = as specified in 4.2.6 of this appendix
Q_P = as defined in 3.5 of this appendix
2.083 = as specified in 4.2.6 of this appendix

4.4 *Stack damper effectiveness for vented heaters equipped with electro-mechanical stack dampers.* Determine the stack damper effectiveness for vented heaters equipped with electro-mechanical stack dampers (D_o), defined as:

$D_o = 1.62\ [1—A_D \cos \Omega/A_S]$

where:

A_D = as defined in 3.4 of this appendix
Ω = as defined in 3.4 of this appendix
A_S = as defined in 3.4 of this appendix

4.5 *Addition requirements for vented home heating equipment using indoor air for combustion and draft control.* For vented home heating equipment using indoor air for combustion and draft control, D_F, as described in section 4.1.2 of this appendix, and D_S, as described in section 4.1.3 of this appendix, shall be determined from Table 1 of this appendix.

4.5.1 *Optional procedure for determining D_P for vented home heating equipment.* Calculate the ratio (D_P) of the rate of flue gas mass through the vented heater during the off-period, $M_{F,OFF}(T_{F,SS})$, to the rate of flue gas mass flow during the on-period, $M_{F,SS}(T_{F,SS})$, and defined as:

$D_P = M_{F,OFF}(T_{F,SS})/M_{F,SS}(T_{F,SS})$

For vented heaters in which no draft is maintained during the steady-state or cool down tests, $M_{F,OFF}(T_{F,SS})$ is defined as:

$$M_{F,OFF}\left(T_{F,SS}\right) = M_{F,OFF}\left(T^*_{F,OFF}\right)\left[\frac{(T_{F,SS} - T_{RA})}{(T^*_{F,OFF} - T_{RA})}\right]^{.56}\left[\frac{(T^*_{F,OFF} + 460)}{(T_{F,SS} + 460)}\right]^{1.19}$$

For oil fueled vented heaters in which an imposed draft is maintained, as described in section 3.6 of this appendix, $M_{F,OFF}(T_{F,SS})$ is defined as:

$M_{F,OFF}(T_{F,SS}) = M_{F,OFF}(T^*_{F,OFF})$

where:

$T_{F,SS}$ = as defined in section 3.1.1 of this appendix,

$T^*_{F,OFF}$ = flue gas temperature during the off-period measured in accordance with section 3.6 of this appendix in degrees Fahrenheit, and

T_{RA} = as defined in section 2.9 of this appendix.

$$M_{F,OFF}(T^*_{F,OFF}) = \frac{1.325 P_B V_T (C_{T*} - C_T)}{C_T (T_T + 460)}$$

P_B = barometric pressure measured in accordance with section 3.6 of this appendix in inches of mercury,

V_T = flow rate of tracer gas through the vented heater measured in accordance with section 3.6 of this appendix in cubic feet per minute,

C_T = concentration by volume of tracer gas present in the flue gas sample measured in accordance with section 3.6 of this appendix in percent,

C_{T*} = concentration by volume of the active tracer gas in the mixture in percent and is 100 when the tracer gas is a single component gas,

T_T = the temperature of the tracer gas entering the flow meter measured in accordance with section 3.6 of this appendix in degrees Fahrenheit, and

$(T_T + 460)$ = absolute temperature of the tracer gas entering the flow meter in degrees Rankine.

$M_{F,SS}(T_{F,SS}) = Q_{in}[R_{T,F}(A/F) + 1]/[60HHV_A]$

Q_{in} = as defined in section 3.1 of this appendix,

$R_{T,F}$ = as defined in section 4.1.7 of this appendix,

A/F = as defined in section 4.2.2 of this appendix, and

HHV_A = as defined in section 4.2.2 of this appendix.

4.5.2 *Optional procedure for determining off-cycle draft factor for flue gas flow for vented heaters.* For systems numbered 1 through 10, calculate the off-cycle draft factor for flue gas flow (D_F) defined as:

$D_F = D_P$

For systems numbered 11 or 12: $D_F = D_P\ D_O$

For systems complying with section 3.6.1 or 3.6.2, $D_F = 0.05$

Where:

D_P = as defined in section 4.5.1. of this appendix, and

D_O = as defined in section 4.4 of this appendix.

4.5.3 *Optional procedure for determining off-cycle draft factor for stack gas flow for vented heaters.* Calculate the off-cycle draft factor for stack gas flow (D_S) defined as:

For systems numbered 1 or 2: $D_S = 1.0$

For systems numbered 3 or 4: $D_S = (D_P + 0.79)/1.4$

For systems numbered 5 or 6: $D_S = D_O$

For systems numbered 7 or 8 and if $D_O(S/F)<1$: $D_S = D_O\ D_P$

For systems numbered 7 or 8 and if $D_O(S/F)>1$:

$D_S = D_O\ D_P + [0.85 - D_O\ D_P]\ [D_O(S/F) - 1]/[S/F - 1]$

where:

D_P = as defined in section 4.5.1 or 3.6.1 of this appendix, as applicable

D_O = as defined in section 4.4 of this appendix

4.6 *Annual energy consumption.*

4.6.1 *National average number of burner operating hours.* For vented heaters equipped with single stage controls or manual controls, the national average number of burner operating hours (BOH) is defined as:

$BOH_{SS} = 1{,}416 A_F A\ DHR - 1{,}416\ B$

where:

1,416 = national average heating load hours for vented heaters based on 2,950 degree days and 15 °F outdoor design temperature

A_F = 0.7067, adjustment factor to adjust the calculated design heating requirement and heating load hours to the actual heating load experienced by the heating system

DHR = typical design heating requirements based on Q_{OUT}, from Table 4 of this appendix.

$Q_{OUT} = [(\eta_{SS}/100) - C_j\ (L_j/100)]\ Q_{in}$

L_j = jacket loss as defined in 4.1.5 of this appendix

C_j = 2.8, adjustment factor as defined in 4.3.6 of this appendix

η_{SS} = steady-state efficiency as defined in 4.1.10 of this appendix, percent

Q_{in} = as defined in 3.1 of this appendix at the maximum fuel input rate

$A = 100{,}000/[341{,}300 P_E + (Q_{in} - Q_P)\eta_u]$

$B = 2.938(Q_P)\ \eta_u\ A/100{,}000$

100,000 = factor that accounts for percent and kBtu

P_E = as defined in 3.1.3 of this appendix

Q_P = as defined in 3.5 of this appendix

η_u = as defined in 4.3.6 of this appendix for vented heaters using the tracer gas method, percent
= as defined in 4.2.5 of this appendix for manually controlled vented heaters, percent
= 2,950 AFUEη_{SS} Q_{in}/[2,950 η_{SS} Q_{in}— AFUE(2.083)(4,600)Q_P], for vented heaters equipped without manual controls and without thermal stack dampers and not using the optional tracer gas method, where:
AFUE = as defined in 4.1.17 of this appendix, percent
2,950 = average number of heating degree days as defined in 4.2.6 of this appendix
4,600 = average number of non-heating season hours per year as defined in 4.2.6 of this appendix
2.938 = (4,160/1,416) = ratio of the average length of the heating season in hours to the average heating load hours
2.083 = as specified in 4.2.6 of this appendix

4.6.1.1 For vented heaters equipped with two stage or step modulating controls the national average number of burner operating hours at the reduced operating mode is defined as:

$BOH_R = X_1 E_M / Q_{red\text{-}in}$

where:

X_1 = as defined in 4.1.14 of this appendix
$Q_{red\text{-}in}$ = as defined in 4.1.11 of this appendix
E_M = average annual energy used during the heating season
= $(Q_{in} - Q_P)BOH_{SS} + (8{,}760 - 4{,}600)Q_P$
Q_{in} = as defined in 3.1 of this appendix at the maximum fuel input rate
Q_P = as defined in 3.5 of this appendix
BOH_{SS} = as defined in 4.6.1 of this appendix, in which the term P_E in the factor A is increased by the factor R, which is defined in 3.1.3 of this appendix as:
R = 1.3 for two stage controls
= 1.4 for step modulating controls when the ratio of minimum-to-maximum fuel input is greater than or equal to 0.7
= 1.7 for step modulating controls when the ratio of minimum-to-maximum fuel input is less than 0.7 and greater than or equal to 0.5
= 2.2 for step modulating controls when the ratio of minimum-to-maximum fuel input is less than 0.5
A = 100,000/[341,300 PE R + $(Q_{in} - Q_P)\eta_u$]
8,760 = total number of hours per year
4,600 = as specified in 4.2.6 of this appendix

4.6.1.2 For vented heaters equipped with two stage or step modulating controls the national average number of burner operating hours at the maximum operating mode (BOH_H) is defined as:

$BOH_H = X_2 E_M / Q_{in}$

where:

X_2 = as defined in 4.1.15 of this appendix
E_M = average annual energy used during the heating season
= $(Q_{in} - Q_P)BOH_{SS} + (8{,}760 - 4{,}600)Q_P$
Q_{in} = as defined in 3.1 of this appendix at the maximum fuel input rate

4.6.2 *Average annual fuel energy for gas or oil fueled vented heaters.* For vented heaters equipped with single stage controls or manual controls, the average annual fuel energy consumption (E_F) is expressed in Btu per year and defined as:

$E_F = BOH_{SS}\ (Q_{in} - Q_P) + 8{,}760\ Q_P$

where:

BOH_{SS} = as defined in 4.6.1 of this appendix
Q_{in} = as defined in 3.1 of this appendix
Q_P = as defined in 3.5 of this appendix
8,760 = as specified in 4.6.1 of this appendix

4.6.2.1 For vented heaters equipped with either two stage or step modulating controls E_F is defined as:

$E_F = E_M + 4{,}600 Q_P$

where:

E_M = as defined in 4.6.1.2 of this appendix
4,600 = as specified 4.2.6 of this appendix
Q_P = as defined in 3.5 of this appendix

4.6.3 *Average annual auxiliary electrical energy consumption for vented heaters.* For vented heaters with single-stage controls or manual controls, the average annual auxiliary electrical consumption (E_{AE}) is expressed in kilowatt-hours and defined as:

$E_{AE} = BOH_{SS} P_E + E_{SO}$

Where:

BOH_{SS} = as defined in 4.6.1 of this appendix
P_E = as defined in 3.1.3 of this appendix
E_{SO} = as defined in 4.7 of this appendix

4.6.3.1 For vented heaters with two-stage or modulating controls, E_{AE} is defined as:

$E_{AE} = (BOH_R + BOH_H)P_E + E_{SO}$

Where:

BOH_R = as defined in 4.6.1 of this appendix
BOH_H = as defined in 4.6.1 of this appendix
P_E = as defined in 3.1.3 of this appendix
E_{SO} = as defined in 4.7 of this appendix

4.6.4 *Average annual energy consumption for vented heaters located in a different geographic region of the United States and in buildings with different design heating requirements.*

4.6.4.1 *Average annual fuel energy consumption for gas or oil fueled vented home heaters located in a different geographic region of the United States and in buildings with different design heating requirements.* For gas or oil fueled vented heaters the average annual fuel energy consumption for a specific geographic region and a specific typical design heating requirement (E_{FR}) is expressed in Btu per year and defined as:

$E_{FR} = (E_F - 8{,}760\ Q_P)(HLH/1{,}416) + 8{,}760 Q_P$

where:

E_F = as defined in 4.6.2 of this appendix
8,760 = as specified in 4.6.1 of this appendix
Q_P = as defined in 3.5 of this appendix
HLH = heating load hours for a specific geographic region determined from the heating load hour map in Figure 3 of this appendix
1,416 = as specified in 4.6.1 of this appendix

4.6.4.2 *Average annual auxiliary electrical energy consumption for gas or oil fueled vented home heaters located in a different geographic region of the United States and in buildings with different design heating requirements.* For gas or oil fueled vented home heaters the average annual auxiliary electrical energy consumption for a specific geographic region and a specific typical design heating requirement (E_{AER}) is expressed in kilowatt-hours and defined as:

$E_{AER} = E_{AE}$ HLH/1,416

where:

E_{AE} = as defined in 4.6.3 of this appendix
HLH = as defined in 4.6.4.1 of this appendix
1,416 = as specified in 4.6.1 of this appendix

TABLE 1—OFF–CYCLE DRAFT FACTORS FOR FLUE GAS FLOW (D_F) AND FOR STACK GAS FLOW (D_S) FOR VENTED HOME HEATING EQUIPMENT EQUIPPED WITHOUT THERMAL STACK DAMPERS

System number	(D_F)	(D_S)	Burner type	Venting system type [1]
1	1.0	1.0	Atmospheric	Draft hood or diverter.
2	0.4	1.0	Power	Draft hood or diverter.
3	1.0	1.0	Atmospheric	Barometric draft regulator.
4	0.4	0.85	Power	Barometric draft regulator.
5	1.0	D_O	Atmospheric	Draft hood or diverter with damper.
6	0.4	D_O	Power	Draft hood or diverter with damper.
7	1.0	D_O	Atmospheric	Barometric draft regulator with damper.
8	0.4	D_OD_P	Power	Barometric draft regulator with damper.
9	1.0	0	Atmospheric	Direct vent.
10	0.4	0	Power	Direct vent.
11	D_O	0	Atmospheric	Direct vent with damper.
12	0.4 D_O	0	Power	Direct vent with damper.

[1] Venting systems listed with dampers means electromechanical dampers only.

TABLE 2—VALUES OF HIGHER HEATING VALUE (HHV_A), STOICHIOMETRIC AIR/FUEL (A/F), LATENT HEAT LOSS ($L_{L,A}$) AND FUEL-SPECIFIED PARAMETERS (A, B, C, AND D) FOR TYPICAL FUELS

Fuels	HHV_A (Btu/lb)	A/F	$L_{L,A}$	A	B	C	D
No. 1 oil	19,800	14.56	6.55	0.0679	14.22	0.0179	0.167
No. 2 oil	19,500	14.49	6.50	0.0667	14.34	0.0181	0.167
Natural gas	20,120	14.45	9.55	0.0919	10.96	0.0175	0.171
Manufactured gas	18,500	11.81	10.14	0.0965	10.10	0.0155	0.235
Propane	21,500	15.58	7.99	0.0841	12.60	0.0177	0.151
Butane	20,000	15.36	7.79	0.0808	12.93	0.0180	0.143

TABLE 3—FRACTION OF HEATING LOAD AT REDUCED OPERATING MODE (X1) AND AT MAXIMUM OPERATING MODE (X2), AVERAGE OUTDOOR TEMPERATURES (TOA AND TOA*), AND BALANCE POINT TEMPERATURE (TC) FOR VENTED HEATERS EQUIPPED WITH EITHER TWO-STAGE THERMOSTATS OR STEP-MODULATING THERMOSTATS

Heat output ratio [a]	X1	X2	TOA	TOA*	TC
0.20 to 0.24	.12	.88	57	40	53
0.25 to 0.29	.16	.84	56	39	51
0.30 to 0.34	.20	.80	54	38	49
0.35 to 0.39	.30	.70	53	36	46
0.40 to 0.44	.36	.64	52	35	44
0.45 to 0.49	.43	.57	51	34	42
0.50 to 0.54	.52	.48	50	32	39
0.55 to 0.59	.60	.40	49	30	37
0.60 to 0.64	.70	.30	48	29	34
0.65 to 0.69	.76	.24	47	27	32
0.70 to 0.74	.84	.16	46	25	29
0.75 to 0.79	.88	.12	46	22	27

TABLE 3—FRACTION OF HEATING LOAD AT REDUCED OPERATING MODE (X1) AND AT MAXIMUM OPERATING MODE (X2), AVERAGE OUTDOOR TEMPERATURES (TOA AND TOA*), AND BALANCE POINT TEMPERATURE (TC) FOR VENTED HEATERS EQUIPPED WITH EITHER TWO-STAGE THERMOSTATS OR STEP-MODULATING THERMOSTATS—Continued

Heat output ratio [a]	X1	X2	TOA	TOA*	TC
0.80 to 0.84	.94	.06	45	20	23
0.85 to 0.89	.96	.04	45	18	21
0.90 to 0.94	.98	.02	44	16	19
0.95 to 0.99	.99	.01	44	13	17

[a] The heat output ratio means the ratio of minimum to maximum heat output rates as defined in 4.1.13.

TABLE 4—AVERAGE DESIGN HEATING REQUIREMENTS FOR VENTED HEATERS WITH DIFFERENT OUTPUT CAPACITIES


Vented heaters output capacity Q_{out}—(Btu/hr)	Average design heating requirements (kBtu/hr)
5,000–7,499	5.0
7,500–10,499	7.5
10,500–13,499	10.0
13,500–16,499	12.5
16,500–19,499	15.0
19,500–22,499	17.5
22,500–26,499	20.5
26,500–30,499	23.5
30,500–34,499	26.5

TABLE 4—AVERAGE DESIGN HEATING REQUIREMENTS FOR VENTED HEATERS WITH DIFFERENT OUTPUT CAPACITIES—Continued

Vented heaters output capacity Q_{out}—(Btu/hr)	Average design heating requirements (kBtu/hr)
34,500–38,499	30.0
38,500–42,499	33.5
42,500–46,499	36.5
46,500–51,499	40.0
51,500–56,499	44.0
56,500–61,499	48.0
61,500–66,499	52.0
66,500–71,499	56.0
71,500–76,500	60.0

FIGURE 1


Average Outdoor Air Temperature vs. Balance Point Temperature for Modulating Vented Heaters



This figure is based on 4500 degree-days and 15° F outdoor design temperature

FIGURE 2

Fraction of Total Annual Heating Load Applicable to Reduced Operating Mode (X_1) and to Maximum Operating Mode or Modulating Mode (X_2) vs. Balance Point Temperature for Modulating Vented Heaters



This figure is based on 4500 degree-days and 15°F outdoor design temperature.




FIGURE 3- HEATING LOAD HOURS (HLH) FOR THE UNITED STATES

4.7 *Average annual electric standby mode and off mode energy consumption.*

Calculate the annual electric standby mode and off mode energy consumption, E_{SO}, defined as, in kilowatt-hours:

$E_{SO} = ((P_{W,SB} * (4160—BOH)) + (P_{W,OFF} * 4600)) * K$

Where:

$P_{W,SB}$ = vented heater standby mode power, in watts, as measured in section 3.7 of this appendix

4160 = average heating season hours per year

$P_{W,OFF}$ = vented heater off mode power, in watts, as measured in section 3.7 of this appendix

4600 = average non-heating season hours per year
K = 0.001 kWh/Wh, conversion factor for watt-hours to kilowatt-hours
BOH = burner operating hours as calculated in section 4.6.1 of this appendix where for single-stage controls or manual controls vented heaters BOH = BOH_{SS} and for vented heaters equipped with two-stage or modulating controls BOH = (BOH_R + BOH_H).

[49 FR 12169, Mar. 28, 1984, as amended at 62 FR 26162, May 12, 1997; 77 FR 74571, Dec. 17, 2012; 80 FR 806, Jan. 6, 2015; 87 FR 30791, May 20, 2022]

APPENDIX P TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF POOL HEATERS

NOTE: On and after November 27, 2023, any representations made with respect to the energy use or efficiency of all pool heaters must be made in accordance with the results of testing pursuant to this appendix. Until November 27, 2023, manufacturers must test gas-fired pool heaters in accordance with this appendix, or appendix P as it appeared at 10 CFR part 430, subpart B revised as of January 1, 2021. Prior to November 27, 2023, if a manufacturer makes representations of standby mode and off mode energy consumption, then testing must also include the provisions of this appendix, or appendix P as it appeared at 10 CFR part 430, subpart B revised as of January 1, 2021, related to standby mode and off mode energy consumption.

1. *Definitions:*

Active electrical power means the maximum electrical power consumption in active mode for an electric pool heater.

Active mode means the condition during the pool heating season in which the pool heater is connected to the power source, and the main burner, electric resistance element, or heat pump is activated to heat pool water.

Coefficient of performance (COP), as applied to heat pump pool heaters, means the ratio of heat output in kW to the total power input in kW.

Electric heat pump pool heater means an appliance designed for heating nonpotable water and employing a compressor, water-cooled condenser, and outdoor air coil.

Electric resistance pool heater means an appliance designed for heating nonpotable water and employing electric resistance heating elements.

Fossil fuel-fired pool heater means an appliance designed for heating nonpotable water and employing gas or oil burners.

Hybrid pool heater means an appliance designed for heating nonpotable water and employing both a heat pump (compressor, water-cooled condenser, and outdoor air coil) and a fossil fueled burner as heating sources.

Input capacity means the maximum fuel input rate for a fossil fuel-fired pool heater.

Off mode means the condition during the pool non-heating season in which the pool heater is connected to the power source, and neither the main burner, nor the electric resistance elements, nor the heat pump is activated, and the seasonal off switch, if present, is in the ''off'' position.

Output capacity for an electric pool or spa heater means the maximum rate at which energy is transferred to the water.

Seasonal off switch means a switch that results in different energy consumption in off mode as compared to standby mode.

Standby mode means the condition during the pool heating season in which the pool heater is connected to the power source, and neither the main burner, nor the electric resistance elements, nor the heat pump is activated.

2. *Test method.*

2.1 *Active mode.*

2.1.1 *Fossil fuel-fired pool heaters.* The test method for testing fossil fuel-fired pool heaters in active mode is as specified in section 2.10 of ANSI Z21.56 (incorporated by reference, see §430.3), with the following additional clarifications.

1. Burner input rate is adjusted as specified in section 2.3.3 of ANSI Z21.56,

2. Equilibrium is defined as in section 9.1.3 of ASHRAE 146 (incorporated by reference; see §430.3)

3. Units are only to be tested using a recirculating loop and a pump if: the use of the recirculating loop and pump are listed as required; a minimum flow rate is specified in the installation or operation manual provided with the unit; the pump is packaged with the unit by the manufacturer; or such use is required for testing.

4. A water temperature rise of less than 40 °F is allowed only as specified in the installation or operation manual(s) provided with the unit.

2.1.2 *Electric resistance pool heaters.* The test method for testing electric resistance pool heaters in active mode is as specified in ASHRAE 146 (incorporated by reference; see §430.3).

2.1.3 *Electric heat pump pool heaters.* The test method for testing electric heat pump pool heaters in active mode is as specified in AHRI 1160 (incorporated by reference; see §430.3), which references ASHRAE 146 (incorporated by reference; see §430.3).

2.1.4 *Hybrid pool heaters.* [Reserved]

2.2 *Standby mode.* The test method for testing the energy consumption of pool heaters in standby mode is as described in sections 3 through 5 of this appendix.

2.3 *Off mode.*

2.3.1 *Pool heaters with a seasonal off switch.* For pool heaters with a seasonal off switch, no off mode test is required.

2.3.2 *Pool heaters without a seasonal off switch.* For pool heaters without a seasonal off switch, the test method for testing the energy consumption of the pool heater is as described in sections 3 through 5 of this appendix.

3. *Test conditions.*

3.1 *Active mode.*

3.1.1 *Fossil fuel-fired pool heaters.* Establish the test conditions specified in section 2.10 of ANSI Z21.56 (incorporated by reference; see §430.3).

3.1.2 *Electric resistance pool heaters.* Establish the test conditions specified in section 9.1.4 of ASHRAE 146 (incorporated by reference; see §430.3).

3.1.3 *Electric heat pump pool heaters.* Establish the test conditions specified in section 5 of AHRI 1160. The air temperature surrounding the unit shall be at the ''High Air Temperature—Mid Humidity (63% RH)'' level specified in section 6 of AHRI 1160 (incorporated by reference, see §430.3) (80.6 °F [27.0 °C] Dry-Bulb, 71.2 °F [21.8 °C]).

3.1.4 *Hybrid pool heaters.* [Reserved]

3.2 *Standby mode and off mode.* After completing the active mode tests described in sections 3.1 and 4.1 of this appendix, reduce the thermostat setting to a low enough temperature to put the pool heater into standby mode. Reapply the energy sources and operate the pool heater in standby mode for 60 minutes.

4. *Measurements*

4.1 *Active mode*

4.1.1 *Fossil fuel-fired pool heaters.* Measure the quantities delineated in section 2.10 of ANSI Z21.56 (incorporated by reference; see §430.3). The measurement of energy consumption for oil-fired pool heaters in Btu is to be carried out in appropriate units (*e.g.*, gallons).

4.1.2 *Electric resistance pool heaters.* Measure the quantities delineated in section 9.1.4 of ASHRAE 146 (incorporated by reference; see §430.3) during and at the end of the 30-minute period when water is flowing through the pool heater.

4.1.3 *Electric heat pump pool heaters.* Measure the quantities delineated in section 9.1.1 and Table 2 of ASHRAE 146 (incorporated by reference; see §430.3). Record the elapsed time, t_{HP}, from the start of electric power metering to the end, in minutes.

4.1.4 *Hybrid pool heaters.* [Reserved]

4.2 *Standby mode.* For all pool heaters, record the average electric power consumption during the standby mode test, $P_{W,SB,}$ in W, in accordance with section 5 of IEC 62301 (incorporated by reference; see §430.3). For fossil fuel-fired pool heaters, record the fossil fuel energy consumption during the standby test, Q_p, in Btu. (Milli-volt electrical consumption need not be considered in units so equipped.) Ambient temperature and voltage specifications in section 4.1 of this appendix shall apply to this standby mode testing. Round the recorded standby power ($P_{W,SB}$) to the second decimal place, and for loads greater than or equal to 10 W, record at least three significant figures.

4.3 *Off mode.*

4.3.1 *Pool heaters with a seasonal off switch.* For pool heaters with a seasonal off switch, the average electric power consumption during the off mode, $P_{W,OFF} = 0$, and the fossil fuel energy consumed during the off mode, $Q_{off} = 0$.

4.3.2 *Pool heaters without a seasonal off switch.* For all pool heaters without a seasonal off switch, record the average electric power consumption during the standby/off mode test, $P_{W,OFF} = P_{W,SB,}$ in W, in accordance with section 5 of IEC 62301 (incorporated by reference; see §430.3). For fossil fuel-fired pool heaters without a seasonal off switch, record the fossil fuel energy consumption during the off mode test, Q_{off} (= Q_p), in Btu. (Milli-volt electrical consumption need not be considered in units so equipped.) Ambient temperature and voltage specifications in section 4.1 of this appendix shall apply to this off mode testing. Round the recorded off mode power ($P_{W,OFF}$) to the second decimal place, and for loads greater than or equal to 10 W, record at least three significant figures.

5. *Calculations.*

5.1 *Thermal efficiency.*

5.1.1 *Fossil fuel-fired pool heaters.* Calculate the thermal efficiency, E_t (expressed as a percent), as specified in section 2.10 of ANSI Z21.56 (incorporated by reference; see §430.3). The expression of fuel consumption for oil-fired pool heaters shall be in Btu.

5.1.2 *Electric resistance pool heaters.* Calculate the thermal efficiency, E_t (expressed as a percent), as specified in section 11.1 of ASHRAE 146 (incorporated by reference; see §430.3).

5.1.3 *Electric heat pump pool heaters.* Calculate the COP according to section 11.1 of ASHRAE 146. Calculate the thermal efficiency, E_t (expressed as a percent): E_t = COP.

5.1.4 *Hybrid pool heaters.* [Reserved]

5.2 *Average annual fossil fuel energy for pool heaters.* For electric resistance and electric heat pump pool heaters, the average annual fuel energy for pool heaters, $E_F = 0$.

For fossil fuel-fired pool heaters, the average annual fuel energy for pool heaters, E_F, is defined as:

$$E_F = BOH\ Q_{IN} + (POH - BOH)\ Q_{PR} + (8760 - POH)\ Q_{off,R}$$

Where:

BOH = average number of burner operating hours = 104 h,

POH = average number of pool operating hours = 4,464 h,

Q_{IN} = input capacity, in Btu/h, calculated as the quantity CF x Q x H in the equation

for thermal efficiency in section 2.10.1 of ANSI Z21.56 (incorporated by reference; see §430.3) and divided by 0.5 h (For electric resistance and electric heat pump pool heaters, $Q_{IN} = 0$.),

Q_{PR} = average energy consumption rate of continuously operating pilot light, if employed, = (Q_P/1 h),

Q_P = energy consumption of continuously operating pilot light, if employed, as measured in section 4.2 of this appendix, in Btu,

8760 = number of hours in one year,

$Q_{off,R}$ = average off mode fossil fuel energy consumption rate = Q_{off}/(1 h), and

Q_{off} = off mode energy consumption as defined in section 4.3 of this appendix.

5.3 *Average annual electrical energy consumption for pool heaters.* The average annual electrical energy consumption for pool heaters, E_{AE}, is expressed in Btu and defined as:

(1) $E_{AE} = E_{AE,active} + E_{AE,standby,off}$

(2) $E_{AE,active} = BOH * PE$

(3) $E_{AE,standby,off} = (POH - BOH)\ P_{W,SB}(Btu/h) + (8760 - POH)\ P_{W,OFF}(Btu/h)$

where:

$E_{AE,active}$ = electrical consumption in the active mode,

$E_{AE,standby,off}$ = auxiliary electrical consumption in the standby mode and off mode,

PE = active electrical power, calculated as:

= $2E_c$, for fossil fuel-fired heaters tested according to section 2.10.1 of ANSI Z21.56 and for electric resistance pool heaters, in Btu/h,

= 3.412 $PE_{aux,rated}$, for fossil fuel-fired heaters tested according to section 2.10.2 of ANSI Z21.56, in Btu/h,

= $E_{c,HP} * (60/t_{HP})$, for electric heat pump pool heaters, in Btu/h.

E_c = electrical consumption in Btu per 30 min. This includes the electrical consumption (converted to Btus) of the pool heater and, if present, a recirculating pump during the 30-minute thermal efficiency test. The 30-minute thermal efficiency test is defined in section 2.10.1 of ANSI Z21.56 for fossil fuel-fired pool heaters and section 9.1.4 of ASHRAE 146 (incorporated by reference; see §430.3) for electric resistance pool heaters. 2 = conversion factor to convert unit from per 30 min. to per h.

$PE_{aux,rated}$ = nameplate rating of auxiliary electrical equipment of heater, in Watts

$E_{c,HP}$ = electrical consumption of the electric heat pump pool heater (converted to equivalent unit of Btu), including the electrical energy to the recirculating pump if used, during the thermal efficiency test, as defined in section 9.1 of ASHRAE 146, in Btu.

t_{HP} = elapsed time of data recording during the thermal efficiency test on electric heat pump pool heater, as defined in section 9.1 of ASHRAE 146, in minutes.

BOH = as defined in section 5.2 of this appendix,

POH = as defined in section 5.2 of this appendix,

$P_{W,SB}$ (Btu/h) = electrical energy consumption rate during standby mode expressed in Btu/h = 3.412 $P_{W,SB}$, Btu/h,

$P_{W,SB}$ = as defined in section 4.2 of this appendix,

$P_{W,OFF}$ (Btu/h) = electrical energy consumption rate during off mode expressed in Btu/h = 3.412 $P_{W,OFF}$, Btu/h, and

$P_{W,OFF}$ = as defined in section 4.3 of this appendix.

5.4 *Integrated thermal efficiency.*

5.4.1 Calculate the seasonal useful output of the pool heater as:

$E_{OUT} = BOH[(E_t/100)(Q_{IN} + PE)]$

where:

BOH = as defined in section 5.2 of this appendix,

E_t = thermal efficiency as defined in section 5.1 of this appendix,

Q_{IN} = as defined in section 5.2 of this appendix,

PE = as defined in section 5.3 of this appendix, and

100 = conversion factor, from percent to fraction.

5.4.2 Calculate the annual input to the pool heater as:

$E_{IN} = E_F + E_{AE}$

where:

E_F = as defined in section 5.2 of this appendix, and

E_{AE} = as defined in section 5.3 of this appendix.

5.4.3 Calculate the pool heater integrated thermal efficiency (TE_I) (in percent).

$TE_I = 100(E_{OUT}/E_{IN})$

where:

E_{OUT} = as defined in section 5.4.1 of this appendix,

E_{IN} = as defined in section 5.4.2 of this appendix, and

100 = conversion factor, from fraction to percent.

5.5 *Output capacity for electric pool heaters.*

5.5.1 Calculate the output capacity of an electric heat pump pool heater as:

$Q_{OUT,HP} = k * W * (T_{ohp} - T_{ihp}) * (60/t_{HP})$

where k is the specific heat of water, W is the mass of water collected during the test, T_{ohp} is the average outlet water temperature during the standard rating test, T_{ihp} is the average inlet water temperature during the standard rating test, all as defined in section 11.2 of ASHRAE 146, and t_{HP} is the elapsed time in minutes of data recording during the thermal efficiency test on electric heat pump pool heater, as defined in section 9.1 of ASHRAE 146.

5.5.2 Calculate the output capacity of an electric resistance pool heater as:

$Q_{OUT,ER} = k * W * (T_{mo} - T_{mi}) * (60/30)$

where k is the specific heat of water, W is the mass of water collected during the test, T_{mo} is the average outlet water temperature recorded during the primary test, and T_{mi} is the average inlet water temperature record during the primary test, all as defined in section 11.1 of ASHRAE 146, and 60/30 is the conversion factor to convert unit from per 30 minutes to per hour.

[80 FR 813, Jan. 6, 2015, as amended at 88 FR 34703, May 30, 2023]

APPENDIX Q TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF FLUORESCENT LAMP BALLASTS

Note regarding effective date: After October 14, 2020 and prior to March 15, 2021 any representations with respect to energy use or efficiency of fluorescent lamp ballasts must be in accordance with the results of testing pursuant to this appendix or the test procedures as they appeared in appendix Q to this subpart revised as of January 1, 2020. On or after March 15, 2021, any representations, including certifications of compliance for ballasts subject to any energy conservation standard, made with respect to the energy use or efficiency of fluorescent lamp ballasts must be made in accordance with the results of testing pursuant to this appendix.

0. INCORPORATION BY REFERENCE

DOE incorporated by reference ANSI C78.81–2016, ANSI C78.375A, ANSI C78.901–2016, ANSI C82.1, ANSI 82.2, ANSI 82.3, ANSI 82.11, ANSI C82.13, ANSI 82.77, IEC 60081, and IEC 62301, each in their entirety in §430.3; however, only enumerated provisions of ANSI C78.375A, ANSI C82.2, and IEC 62301 are applicable to this appendix, as follows:

(a) ANSI C78.375A, as follows:

(i) Section 4, Ambient conditions for temperature measurement, as specified in section 2.4.2 of this appendix; and

(ii) Section 9, Electrical instruments, as specified in sections 2.2.1, 2.2.2, and 2.2.3 of this appendix.

(b) ANSI C82.2, as follows:

(i) Section 3, Pertinent measurements, as specified in section 2.4.1 of this appendix;

(ii) Section 4, Electrical supply characteristics—test ballast measurement circuits, as specified in section 2.4.1 of this appendix; and

(iii) Section 7, Test measurements circuits, as specified in sections 2.5.6, 2.5.7, and 2.5.8 of this appendix.

(c) IEC 62301 as follows:

(i) Section 5, Measurements, as specified in sections 3.4.3 and 3.4.4 of this appendix.

1. DEFINITIONS

1.1. *Average total lamp arc power* means the sample mean of the total lamp arc power of the ballast units tested.

1.2. *Dimming ballast* means a ballast that is designed and marketed to vary its output and that can achieve an output less than or equal to 50 percent of its maximum electrical output.

1.3. *High frequency ballast* is as defined in ANSI C82.13 (incorporated by reference; see §430.3).

1.4. *Instant-start* is the starting method used in instant-start systems as defined in ANSI C82.13, as typically indicated on publicly available documents of a fluorescent lamp ballast (*e.g.,* product literature, catalogs, and packaging labels).

1.5. *Low-frequency ballast* is a fluorescent lamp ballast that operates at a supply frequency of 50 to 60 Hz and operates the lamp at the same frequency as the supply.

1.6. *Programmed-start* is the starting method used in a programmed-start system as defined in ANSI C82.13, as typically indicated on publicly available documents of a fluorescent lamp ballast (*e.g.,* product literature, catalogs, and packaging labels).

1.7. *Rapid-start* is the starting method used in rapid-start type systems as defined in ANSI C82.13, as typically indicated on publicly available documents of a fluorescent lamp ballast (*e.g.,* product literature, catalogs, and packaging labels).

1.8. *Reference lamp* is a fluorescent lamp that meets the operating conditions of a reference lamp as defined by ANSI C82.13.

1.9. *Residential ballast* means a fluorescent lamp ballast that meets Federal Communications Commission (FCC) consumer limits as set forth in 47 CFR part 18 and is designed and marketed for use only in residential applications.

1.10. *RMS* is the root mean square of a varying quantity.

1.11 *Sign Ballast* means a ballast that has an Underwriters Laboratories Inc. Type 2 rating and is designed and marketed for use only in outdoor signs.

2. ACTIVE MODE PROCEDURE FOR MEASURING BLE AT FULL LIGHT OUTPUT

2.1. Where ANSI C82.2 (incorporated by reference; see §430.3) references ANSI C82.1, use ANSI C82.1 (incorporated by reference; see §430.3) for testing low-frequency ballasts and use ANSI C82.11 (incorporated by reference; see §430.3) for testing high-frequency ballasts. In addition when applying ANSI C82.2, use the standards ANSI C78.375A, ANSI C78.81–2016, ANSI C82.1, ANSI C82.11, ANSI C82.13, ANSI C82.3, ANSI C82.77, and ANSI C78.901–2016 (incorporated by reference; see §430.3) instead of the normative references in ANSI 82.2. Specifications in referenced standards that are recommended, that

''shall'' or ''should'' be met, or that are not clearly mandatory, are mandatory. In cases where there is a conflict between any industry standard(s) and this appendix, the language of the test procedure in this appendix takes precedence over the industry standard(s).

2.2. Instruments

2.2.1. All instruments must meet the specifications of section 9 of ANSI C78.375A.

2.2.2. *Power Analyzer.* In addition to the specifications in section 9 of ANSI C78.375A, the power analyzer must have a maximum 100 pF capacitance to ground and frequency response between 40 Hz and 1 MHz.

2.2.3. *Current Probe.* In addition to the specifications in section 9 of ANSI C78.375A, the current probe must be galvanically isolated and have frequency response between 40 Hz and 20 MHz.

2.3. Test Setup

2.3.1. Connect the ballast to a main power source and to the fluorescent lamp(s) as specified in this section. Ensure the ballast is connected to fluorescent lamp(s) according to any manufacturer's wiring instructions on or sold with each unit (including those provided online). To test a low-frequency ballast, follow ANSI C82.1 but disregard section 5.3 of ANSI C82.1. To test a high-frequency ballast, follow ANSI C82.11 but disregard sections 5.3.1 and 5.13 and Annex D of ANSI C82.11.

2.3.2. In the test setup, all wires used in the apparatus, including any wires from the ballast to the lamps and from the lamps to the measuring devices, must meet the following specifications:

2.3.2.1. Use the wires provided by the ballast manufacturer and only the minimum wire length necessary to reach both ends of each lamp. If the wire lengths supplied with the ballast are too short to reach both ends of each lamp, add the minimum additional wire length necessary to reach both ends of each lamp, using wire of the same wire gauge(s) as the wire supplied with the ballast. If no wiring is provided with the ballast, use 18 gauge or thicker wire.

2.3.2.2. Keep wires loose. Do not shorten or allow bundling of any wires. Separate all wires from each other, and ground them to prevent parasitic capacitance.

2.3.3. Test each ballast with only one fluorescent lamp type. Select the one type of fluorescent lamp for testing as follows:

2.3.3.1. Each fluorescent lamp must meet the specifications of a reference lamp as defined by ANSI C82.13, be seasoned at least 12 hours, and be stabilized as specified in 2.5.2.1 of this appendix. Test each reference lamp with a reference ballast that meets the criteria of ANSI C82.3. For low frequency ballasts that operate:

(a) 32 W 4-foot medium bipin T8 lamps, use the following reference lamp specifications: 30.8 W, arc wattage; 1.7 W, approximate cathode wattage (with 3.6 V on each cathode); 32.5 W, total wattage; 137 V, voltage; 0.265 A, current. Test the selected reference lamp with the following reference ballast specifications: 300 V, rated input voltage; 0.265 A, reference current; 910 ohms, impedance. Use the following cathode heat requirements for rapid start: 3.6 V nominal, voltage; 2.5 V min, 4.4 V max, limits during operation; 11.0 ohms ± 0.1 ohms, dummy load resistor; 3.4 V min, 4.5 V max, voltage across dummy load.

(b) 59 W 8-foot single pin T8 lamps, use the following reference lamp specifications: 60.1 W, arc wattage; 270.3 V, voltage; 0.262 A, current. Test the selected reference lamp with the following reference ballast specifications: 625 V, rated input voltage; 0.260 A, reference current; 1960 ohms, impedance.

(c) 32 W 2-foot U-shaped medium bipin T8 lamps, use the following reference lamp specifications: 30.5 W, arc wattage; 1.7 W, approximate cathode wattage (with 3.6 V on each cathode); 32.2 W, total wattage; 137 V, voltage; 0.265 A, current. Test the selected reference lamp with the following reference ballast specifications: 300 V, rated input voltage; 0.265 A, reference current; 910 ohms, impedance. Use the following cathode heat requirements for rapid start: 3.6 V nominal, voltage; 2.5 V min, 4.4 V max, limits during operation; 11.0 ohms ± 0.1 ohms, dummy load resistor; 3.4 V min, 4.5 V max, voltage across dummy load.

2.3.3.2 For any sign ballast designed and marketed to operate both T8 and T12 lamps, use a T12 lamp as specified in Table 1 of this appendix.

2.3.3.3. For any ballast designed and marketed to operate lamps of multiple base types, select lamp(s) of one base type, in the following order of decreasing preference: Medium bipin, miniature bipin, single pin, or recessed double contact.

2.3.3.4. After selecting the base type (per section 2.3.3.3), select the diameter of the reference lamp. Any ballast designed and marketed to operate lamps of multiple diameters, except for any sign ballast capable of operating both T8 and T12 lamps, must be tested with lamps of one of those diameters, selected in the following order of decreasing preference: T8, T5, or T12.

2.3.3.5. Connect the ballast to the maximum number of lamps (lamp type as determined by 2.3.3.2, 2.3.3.3, and 2.3.3.4 of this section) the ballast is designed and marketed to operate simultaneously.

For any ballast designed and marketed to operate both 4-foot medium bipin lamps and 2-foot U-shaped lamps, test with the maximum number of 4-foot medium bipin lamp(s).

2.3.3.6. Test each ballast with the lamp type specified in Table A of this section that

corresponds to the lamp diameter and base type the ballast is designed and marketed to operate.

TABLE 1 TO SECTION 2.3.3.6—LAMP-AND-BALLAST PAIRINGS AND FREQUENCY ADJUSTMENT FACTORS

Ballast type	Lamp type		Frequency adjustment factor (β)	
	Lamp diameter and base	Nominal lamp wattage	Low-frequency	High-frequency
Ballasts that operate straight-shaped lamps (commonly referred to as 4-foot medium bipin lamps) with medium bipin bases and a nominal overall length of 48 inches.	T8 MBP (Data Sheet 7881–ANSI–1005–4)*.	32	0.94	1.0
	T12 MBP (Data Sheet 7881–ANSI–1006–1)*.	34	0.93	1.0
Ballasts that operate U-shaped lamps (commonly referred to as 2-foot U-shaped lamps) with medium bipin bases and a nominal overall length between 22 and 25 inches.	T8 MBP (Data Sheet 78901–ANSI–4027–2)*.	32	0.94	1.0
	T12 MBP**	34	0.93	1.0
Ballasts that operate lamps (commonly referred to as 8-foot-high output lamps) with recessed double contact bases and a nominal overall length of 96 inches.	T8 HO RDC (Data Sheet 7881–ANSI–1501–2)*.	86	0.92	1.0
	T12 HO RDC (Data Sheet 7881–ANSI–1017–1)*.	95	0.94	1.0
Ballasts that operate lamps (commonly referred to as 8-foot slimline lamps) with single pin bases and a nominal overall length of 96 inches.	T8 slimline SP (Data Sheet 7881–ANSI–1505–1)*.	59	0.95	1.0
	T12 slimline SP (Data Sheet 7881–ANSI–3006–1)*.	60	0.94	1.0
Ballasts that operate straight-shaped lamps (commonly referred to as 4-foot miniature bipin standard output lamps) with miniature bipin bases and a nominal length between 45 and 48 inches.	T5 SO Mini-BP (Data Sheet 60081–IEC–6640–7)*.	28	0.95	1.0
Ballasts that operate straight-shaped lamps (commonly referred to as 4-foot miniature bipin high output lamps) with miniature bipin bases and a nominal length between 45 and 48 inches.	T5 HO Mini-BP (Data Sheet 60081–IEC–6840–6)*.	54	0.95	1.0
Sign ballasts that operate lamps (commonly referred to as 8-foot high output lamps) with recessed double contact bases and a nominal overall length of 96 inches.	T8 HO RDC (Data Sheet 7881–ANSI–1501–2)*.	86	0.92	1.0
	T12 HO RDC (Data Sheet 7881–ANSI–1019–1)*.	†110	0.94	1.0

MBP, Mini-BP, RDC, and SP represent medium bipin, miniature bipin, recessed double contact, and single pin, respectively.

*Data Sheet corresponds to ANSI C78.81–2016, ANSI C78.901–2016, or IEC 60081 page number (incorporated by reference; see §430.3).

**No ANSI or IEC Data Sheet exists for 34 W T12 MBP U-shaped lamps. For ballasts designed and marketed to operate only T12 2-foot U-shaped lamps with MBP bases and a nominal overall length between 22 and 25 inches, select T12 U-shaped lamps designed and marketed as having a nominal wattage of 34 W.

†This lamp type is commonly marketed as 110 W; however, the ANSI C78.81–2016 Data Sheet (incorporated by reference; see §430.3) lists nominal wattage of 113 W. Test with specifications for operation at 0.800 amperes (A).

2.3.4. Test Circuits

2.3.4.1. The power analyzer test setup must have exactly n + 1 channels, where n is the maximum number of lamps (lamp type as determined by sections 2.3.3.2, 2.3.3.3, and 2.3.3.4 of this appendix) a ballast is designed and marketed to operate. Use the minimum number of power analyzers possible during testing. Synchronize all power analyzers. A system may be used to synchronize the power analyzers.

2.3.4.2. *Lamp Arc Voltage.* Attach leads from the power analyzer to each fluorescent lamp according to Figure 1 of this section for rapid- and programmed-start ballasts; Figure 2 of this section for instant-start ballasts operating single pin (SP) lamps; and Figure 3 of this section for instant-start ballasts operating medium bipin (MBP), miniature bipin (mini-BP), or recessed double contact (RDC) lamps. The programmed- and rapid-start ballast test setup includes two 1000 ohm resistors placed in parallel with the lamp pins to create a midpoint from which to measure lamp arc voltage.

2.3.4.3. *Lamp Arc Current.* Position a current probe on each fluorescent lamp according to Figure 1 of this section for rapid- and programmed-start ballasts; Figure 2 of this section for instant-start ballasts operating SP lamps; and Figure 3 of this section for instant-start ballasts operating MBP, mini-BP, and RDC lamps.

For the lamp arc current measurement, set the full transducer ratio in the power analyzer to match the current probe to the power analyzer.

$$Full\ Transducer\ Ratio = \frac{I_{in}}{V_{out}} \times \frac{R_{in}}{R_{in} + R_s}$$

Where: I_{in} is the current through the current transducer, V_{out} is the voltage out of the transducer, R_{in} is the power analyzer impedance, and R_s is the current probe output impedance.




Figure 1: Programmed- and Rapid-Start Ballast Instrumentation Setup




Figure 2: Instant-Start Ballasts that Operate SP Lamps Instrumentation Setup




Figure 3: Instant-Start Ballasts that Operate MBP, mini-BP, and RDC Lamps Instrumentation Setup

2.4. Test Conditions

2.4.1. Establish and maintain test conditions for testing fluorescent lamp ballasts in accordance with sections 3 and 4 of ANSI C82.2.

2.4.2. *Room Temperature and Air Circulation.* Maintain the test area at 25 ±1 °C, with minimal air movement as defined in section 4 of ANSI C78.375A.

2.4.3. *Input Voltage.* For any ballast designed and marketed for operation at only one input voltage, test at that specified voltage. For any ballast that is neither a residential ballast nor a sign ballast but is designed and marketed for operation at multiple voltages, test the ballast at 277 V ±0.1%. For any residential ballast or sign ballast designed and marketed for operation at multiple voltages, test the ballast at 120 V ±0.1%.

2.5. Test Method

2.5.1. Connect the ballast to the selected fluorescent lamps (as determined in section 2.3.3 of this appendix) and to measurement instrumentation as specified in the Test Setup in section 2.3 of this appendix.

2.5.2. Determine stable operating conditions according to Option 1 or Option 2.

2.5.2.1. Option 1. Operate the ballast for at least 15 minutes before determining stable operating conditions. Determine stable operating conditions by measuring lamp arc voltage, current, and power once per minute in accordance with the setup described in section 2.3 of this appendix. The system is stable once the difference between the maximum and minimum for each value of lamp arc voltage, current, and power divided by the average value of the measurements do not exceed one percent over a four minute moving window. Once stable operating conditions are reached, measure each of the parameters described in sections 2.5.3 through 2.5.9 of this appendix.

2.5.2.2 Option 2. Determine stable operating conditions for lamp arc voltage, current, and power according to steps 1 through 6 of section D.2.1 in Annex D of ANSI C82.11.

2.5.3. *Lamp Arc Voltage.* Measure lamp arc voltage in volts (RMS) using the setup in section 2.3.4.2.

2.5.4. *Lamp Arc Current.* Measure lamp arc current in amps (RMS) using the setup in section 2.3.4.3 of this appendix.

2.5.5. *Lamp Arc Power.* The power analyzer must calculate output power by using the measurements from sections 2.5.3 and 2.5.4 of this appendix.

2.5.6. *Input Power.* Measure the input power in watts to the ballast in accordance with section 7 of ANSI C82.2 (disregard references to Figure 1 and Figure 3).

2.5.7. *Input Voltage.* Measure the input voltage in volts (RMS) to the ballast in accordance with section 7 of ANSI C82.2 (disregard references to Figure 1 and Figure 3).

2.5.8. *Input Current.* Measure the input current in amps (RMS) to the ballast in accordance with section 7 of ANSI C82.2 (disregard references to Figure 1 and Figure 3).

2.5.9. *Lamp Operating Frequency.* Measure the frequency of the waveform delivered from the ballast to any lamp used in the test in accordance with the setup in section 2.3 of this appendix.

2.6. Calculations

2.6.1. Calculate ballast luminous efficiency (BLE) as follows (do not round values of total lamp arc power and input power prior to calculation):

$$Ballast\ Luminous\ Efficiency = \frac{Total\ Lamp\ Arc\ Power}{Input\ Power} \times \beta$$

Where: Total Lamp Arc Power is the sum of the lamp arc powers for all lamps operated by the ballast as measured in section 2.5.5 of this appendix, Input Power is as determined by section 2.5.6 of this appendix, and β is equal to the frequency adjustment factor in Table 1 of this appendix.

2.6.2. Calculate Power Factor (PF) as follows (do not round values of input power, input voltage, and input current prior to calculation):

$$PF = \frac{Input\ Power}{Input\ Voltage\ \times Input\ Current}$$

Where: Input Power is measured in accordance with section 2.5.6 of this appendix, Input Voltage is measured in accordance with section 2.5.7 of this appendix, and Input Current is measured in accordance with section 2.5.8 of this appendix.

3. STANDBY MODE PROCEDURE

3.1. The measurement of standby mode power is required to be performed only if a manufacturer makes any representations with respect to the standby mode power use of the fluorescent lamp ballast. When there is a conflict, the language of the test procedure in this appendix takes precedence over IEC 62301 (incorporated by reference; see §430.3). Specifications in referenced standards that are not clearly mandatory are mandatory. Manufacturer's instructions, such as ''instructions for use'' referenced in IEC 62301 mean the manufacturer's instructions that come packaged with or appear on the unit, including on a label. It may include an online manual if specifically referenced (*e.g.*, by date or version number) either on a label or in the packaged instructions. Instructions that appear on the unit take precedence over instructions available electronically, such as through the internet.

3.2. Test Setup

3.2.1. Take all measurements with instruments as specified in section 2.2 of this appendix. Fluorescent lamp ballasts that are designed and marketed for connection to control devices must be tested with all commercially available compatible control devices connected in all possible configurations. For each configuration, a separate measurement of standby power must be made in accordance with section 3.4 of this appendix.

3.2.2. Connect each ballast to the maximum number of lamp(s) as specified in section 2.3 (specifications in 2.3.3.1 are optional) of this appendix. Note: ballast operation with reference lamp(s) is not required.

3.3. Test Conditions

3.3.1. Establish and maintain test conditions in accordance with section 2.4 of this appendix.

3.4. Test Method and Measurements

3.4.1. Turn on all of the lamps at full light output.

3.4.2. Send a signal to the ballast instructing it to have zero light output using the appropriate ballast communication protocol or system for the ballast being tested.

3.4.3. Stabilize the ballast prior to measurement using one of the methods as specified in section 5 of IEC 62301.

3.4.4. Measure the standby mode energy consumption in watts using one of the methods as specified in section 5 of IEC 62301.

[85 FR 56494, Sept. 14, 2020]

APPENDIX R TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING ELECTRICAL AND PHOTOMETRIC CHARACTERISTICS OF GENERAL SERVICE FLUORESCENT LAMPS, INCANDESCENT REFLECTOR LAMPS, AND GENERAL SERVICE INCANDESCENT LAMPS

NOTE: After September 30, 2022 and prior to February 27, 2023 any representations with respect to energy use or efficiency of general service fluorescent lamps, incandescent reflector lamps, and general service incandescent lamps must be in accordance with the results of testing pursuant to this appendix or the test procedures as they appeared in appendix R to subpart B of part 430 revised as of January 1, 2021. On or after February 27, 2023, any representations, including certifications of compliance for lamps subject to any energy conservation standard, made with respect to the energy use or efficiency of general service fluorescent lamps, incandescent reflector lamps, and general service incandescent lamps must be made in accordance with the results of testing pursuant to this appendix.

0. Incorporation by Reference

DOE incorporated by reference in §430.3, the entire standard for: IES LM–9–20, IES LM–20–20, IES LM–45–20, IES LM–49–20, IES LM–54–20, IES LM–58–20, IES LM–78–20, ANSI C78.375A–2020, ANSI C78.81–2010, ANSI C78.901–2005, ANSI C78.81–2016, ANSI C78.901–2016, ANSI C82.3, CIE 15:2018, and CIE 13.3; however, only enumerated provisions of IES LM–9–20, IES LM–20–20, IES LM–45–20, IES LM–49–20, IES LM–58–20, and CIE 13.3, are applicable to this appendix, as follows:

0.1 IES LM–9–20

(a) Section 3.0 ''Nomenclature and Definitions'' as referenced in section 2.1 of this appendix.

(b) Section 6.2.2 ''Pre-burning'' and Section 6.2.4 ''Lamp Circuit Switching'' as referenced in section 3.2 of this appendix.

(c) Section 4.0 ''Ambient and Physical Conditions'', Section 5.0 ''Electrical Conditions'', Section 6.1 ''Lamp Orientation'', Section 6.5 ''Electrical Settings'', and Section 6.6 ''Electrical Instrumentation'' as referenced in section 4.1.1.1 of this appendix.

(d) Section 6.1 ''Lamp Orientation'', Section 6.2 ''Lamp Stabilization'', Section 6.3 ''Use of the ''Peak Lumen'' Method'', and Section 6.4 ''Unusual Conditions'' as referenced in section 4.2.1.1 of this appendix.

(e) Section 7.0 ''Photometric Test Procedures'' as referenced in section 4.2.1.3 of this appendix.

(f) Section 7.6 ''Color Measurements'' as referenced in sections 4.2.1.5 and 4.2.1.6 of this appendix.

0.2 IES LM–20–20

(a) Section 3.0 ''Definitions'' as referenced in section 2.1 of this appendix.

(b) Section 4.0 ''Ambient and Physical Conditions'' and Section 5.0 ''Electrical and Photometric Test Conditions'' as referenced in section 4.1.3 of this appendix.

(c) Section 6.0 ''Lamp Test Procedures'' as referenced in sections 4.2.3.1 and 6.2.1 of this appendix.

(d) Section 7.0 ''Photometric Characterization by Measurement of Intensity Distribution'', Section 8.0 ''Total Flux Measurement by Integrating Sphere Method'', and Section 8.2 ''Exclusion of Undirected Light by Using a Luminaire Inside an Integrating Sphere'' as referenced in section 4.2.3.3 of this appendix.

0.3 IES LM–45–20

(a) Section 3.0 ''Nomenclature and Definitions'' as referenced in section 2.1 of this appendix.

(b) Section 4.0 ''Ambient and Physical Conditions'', Section 5.0 ''Electrical Conditions'', section 6.1 ''Lamp Position'', Section 6.3 ''Electrical Settings'', and Section 6.4 ''Electrical Instrumentation'' as referenced in section 4.1.2 of this appendix.

(c) Section 6.2 ''Lamp Stabilization'' as referenced in sections 4.2.2.1 and 6.2.1 of this appendix.

(d) Section 7.0 ''Photometric Test Procedures'' as referenced in section 4.2.2.3 of this appendix.

(e) Section 7.4 ''Color Measurements'' as referenced in sections 4.2.2.5 and 4.2.2.6 of this appendix.

0.4 IES LM–49–20

(a) Section 4.0 ''Ambient and Physical Conditions'' and Section 5.0 ''Electrical Conditions'' as referenced in section 6.1 of this appendix.

(b) Section 6.4 ''Operating Cycle'' as referenced in sections 6.2.2 and 6.3 of this appendix.

0.5 IES LM–58–20

(a) Section 3.0 ''Definitions and Nomenclature'' as referenced in section 2.1 of this appendix.

(b) [Reserved]

0.6 CIE 13.3

(a) Appendix 1 ''Terminology'' as referenced in section 2.1 of this appendix.

(b) [Reserved]

1. Scope:

This appendix specifies the test methods required for determining the electrical and photometric performance characteristics of general service fluorescent lamps (GSFLs), incandescent reflector lamps (IRLs), and general service incandescent lamps (GSILs).

2. Definitions

2.1 To the extent that definitions in the referenced IES and CIE standards do not conflict with the DOE definitions, the definitions specified in Section 3.0 of IES LM–9–20, Section 3.0 of IES LM–20–20, Section 3.0 of IES LM–45–20, Section 3.0 of IES LM–58–20, and Appendix 1 of CIE 13.3 apply in this appendix.

2.2 *Initial input power* means the input power to the lamp, measured at the end of the lamp seasoning and stabilization.

2.3 *Initial lamp efficacy* means the lamp efficacy (as defined in §430.2), measured at the end of the lamp seasoning and stabilization.

2.4 *Initial lumen output* means the lumen output of the lamp, measured at the end of the lamp seasoning and stabilization.

2.5 *Time to failure* means the time elapsed between first use and the point at which the lamp ceases to produce measurable lumen output.

3. General Instructions

3.1 When there is a conflict, the language of the test procedure in this appendix takes precedence over any materials incorporated by reference.

3.2 Maintain lamp operating orientation throughout seasoning and testing, except that for T5 miniature bipin standard and high output GSFLs, follow Section 6.2.2 of IES LM–9–20. For all GSFLs, maintain lamp orientation when transferring lamps from a warm-up position to the photometric equipment per Section 6.2.4 of IES LM–9–20. Maintain lamp orientation at all other times, if practical.

3.3 If a lamp breaks, becomes defective, fails to stabilize, exhibits abnormal behavior (such as swirling), or stops producing light prior to the end of the seasoning period, replace the lamp with a new unit. However, if a lamp exhibits one of the conditions listed in the previous sentence only after the seasoning period ends, include the lamp's measurements in the sample.

3.4 Operate GSILs and IRLs at the rated voltage for incandescent lamps as defined in 10 CFR 430.2.

4. Test Method for Determining Initial Input Power, Initial Lumen Output, Initial Lamp Efficacy, CRI, and CCT

4.1 *Test Conditions and Setup*

4.1.1 *General Service Fluorescent Lamps*

4.1.1.1 Establish ambient, physical, and electrical conditions in accordance with Sections (and corresponding subsections) 4.0, 5.0, 6.1, 6.5, and 6.6 of IES LM–9–20.

4.1.1.2 Operate each lamp at the appropriate voltage and current conditions as described in ANSI C78.375A–2020 and in either ANSI C78.81–2010 or ANSI C78.901–2005. Operate each lamp using the appropriate reference ballast at input voltage specified by the reference circuit as described in ANSI C82.3. If, for a lamp, both low-frequency and high-frequency reference ballast settings are included in ANSI C78.81–2010 or ANSI C78.901–2005, operate the lamp using the low-frequency reference ballast. When testing with low-frequency reference ballast settings, include cathode power only if the circuit application of the lamp is specified as rapid start in ANSI C78.81–2010 or ANSI C78.901–2005. When testing with high-frequency reference ballast settings, do not include cathode power in the measurement.

For any lamp not listed in ANSI C78.81–2010 or ANSI C78.901–2005, operate the lamp using the following reference ballast settings:

4.1.1.2.1 For 4-Foot medium bi-pin lamps, use the following reference ballast settings:

(a) T10 or T12 lamps: 236 volts, 0.43 amps, and 439 ohms, at low frequency (60 Hz) and with cathode power. Approximate cathode wattage (with 3.6 V on each cathode): 2.0 W. Cathode characteristics for low resistance (at 3.6V): 9.6 ohms (objective), 7.0 ohms (minimum). Cathode heat for rapid start: 3.6 V (nominal); 2.5 V min, 4.0 V max (limits during operation); 9.6 ohms ±0.1 ohm (dummy load resistor); 3.4 V min, 4.5 V max (voltage across dummy load).

(b) T8 lamps greater than or equal to 32 W: 300 volts, 0.265 amps, and 910 ohms, at low frequency (60 Hz) and with cathode power. Approximate cathode wattage (with 3.6 V on each cathode): 1.7 W. Cathode characteristics for low resistance (at 3.6 V): 12.0 ±2.0 ohms; 4.75 ±0.50 (Rh/Rc ratio). Cathode heat for rapid start: 3.6 V (nominal); 2.5 V min; 4.4 V max (limits during operation); 11.0 ohms ±0.1 ohms (dummy load resistor); 3.4 V min, 4.5 V max (voltage across dummy load).

(c) T8 lamps less than 32 W: 300 volts, 0.265 amps, and 910 ohms, at low frequency (60 Hz) and without cathode power.

4.1.1.2.2 For 2-Foot U-shaped lamps, use the following reference ballast settings:

(a) T12 lamps: 236 volts, 0.430 amps, and 439 ohms, at low frequency (60 Hz) and with cathode power. Approximate cathode wattage (with 3.6 V on each cathode): 2.0 W. Cathode characteristics for low resistance (at 3.6V): 9.6 ohms (objective), 7.0 ohms (minimum). Cathode heat for rapid start: 3.6 V (nominal); 2.5 V min, 4.0 V max (limits during operation); 9.6 ohms ±0.1 ohm (dummy load resistor); 3.4 V min, 4.5 V max (voltage across dummy load).

(b) T8 lamps greater than or equal to 31 W: 300 volts, 0.265 amps, and 910 ohms, at low frequency (60 Hz) and with cathode power. Approximate cathode wattage (with 3.6 V on each cathode): 1.7 W. Cathode characteristics for low resistance (at 3.6 V): 11.0 ohms (objective); 8.0 ohms (minimum). Cathode heat for rapid start: 3.6 V (nominal); 2.5 V min; 4.4 V max (limits during operation); 11.0 ohms ±0.1 ohms (dummy load resistor); 3.4 V min, 4.5 V max (voltage across dummy load).

(c) T8 lamps less than 31 W: 300 volts, 0.265 amps, and 910 ohms, at low frequency (60 Hz) and without cathode power.

4.1.1.2.3 For 8-foot slimline lamps, use the following reference ballast settings:

(a) *T12 lamps:* 625 volts, 0.425 amps, and 1280 ohms, at low frequency (60 Hz) and without cathode power.

(b) *T8 lamps:* 625 volts, 0.260 amps, and 1960 ohms, at low frequency (60 Hz) and without cathode power.

4.1.1.2.4 For 8-foot high output lamps, use the following reference ballast settings:

(a) *T12 lamps:* 400 volts, 0.800 amps, and 415 ohms, at low frequency (60 Hz) and with cathode power. Approximate cathode wattage (with 3.6 V on each cathode): 7.0 W. Cathode characteristics for low resistance (at 3.6 V): 3.2 ohms (objective); 2.5 ohms (minimum). Cathode heat requirements for rapid start: 3.6 V (nominal); 3.0 V min, 4.0 V max (limits during operation); 3.2 ohms ±0.05 ohm (dummy load resistor); 3.4 V min, 4.5 V max (voltage across dummy load).

(b) *T8 lamps:* 450 volts, 0.395 amps, and 595 ohms, at high frequency (25 kHz) and without cathode power.

4.1.1.2.5 For 4-foot miniature bipin standard output or high output lamps, use the following reference ballast settings:

(a) *Standard Output:* 329 volts, 0.170 amps, and 950 ohms, at high frequency (25 kHz) and without cathode power.

(b) *High Output:* 235 volts, 0.460 amps, and 255 ohms, at high frequency (25 kHz) and without cathode power.

4.1.2 *General Service Incandescent Lamps:* Establish ambient, physical, and electrical conditions in accordance with Sections (and corresponding subsections) 4.0, 5.0, 6.1, 6.3 and 6.4 in IES LM–45–20.

4.1.3 *Incandescent Reflector Lamps:* Establish ambient, physical, and electrical conditions in accordance with Sections (and corresponding subsections) 4.0 and 5.0 in IES LM–20–20.

4.2 *Test Methods, Measurements, and Calculations*

Multiply all lumen measurements made with instruments calibrated to the devalued NIST lumen after January 1, 1996, by 1.011.

4.2.1 *General Service Fluorescent Lamps*

4.2.1.1 Season and stabilize lamps in accordance with Sections (and corresponding subsections) 6.1, 6.2, 6.3, and 6.4 of IES LM–9–20 and with IES LM–54–20.

4.2.1.2 Measure the initial input power (in watts).

4.2.1.3 Measure initial lumen output in accordance with Section 7.0 (and corresponding subsections) of IES LM–9–20 and with IES LM–78–20.

4.2.1.4 Calculate initial lamp efficacy by dividing the measured initial lumen output by the measured initial input power.

4.2.1.5 Calculate CRI as specified in Section 7.6 of IES LM–9–20 and CIE 13.3. Conduct the required spectroradiometric measurement and characterization in accordance with the methods set forth in IES LM–58–20.

4.2.1.6 Calculate CCT as specified in Section 7.6 of IES LM–9–20 and CIE 15:2018. Conduct the required spectroradiometric measurement and characterization in accordance with the methods set forth in IES LM–58–20.

4.2.2 *General Service Incandescent Lamps*

4.2.2.1 Season and stabilize lamps in accordance with Section (and corresponding subsections) 6.2 of IES LM–45–20 and with IES LM–54–20.

4.2.2.2 Measure the initial input power (in watts).

4.2.2.3 Measure initial lumen output in accordance with Section (and corresponding subsections) 7.0 of IES LM–45–20 and with IES LM–78–20.

4.2.2.4 Calculate initial lamp efficacy by dividing the measured initial lumen output by the measured initial input power.

4.2.2.5 Calculate CRI as specified in Section 7.4 of IES LM–45–20 and CIE 13.3. Conduct the required spectroradiometric measurement and characterization in accordance with the methods set forth in IES LM–58–20.

4.2.2.6 Calculate CCT as specified in Section 7.4 of IES LM–45–20 and CIE 15:2018. Conduct the required spectroradiometric measurement and characterization in accordance with the methods set forth in IES LM–58–20.

4.2.3 *Incandescent Reflector Lamps*

4.2.3.1 Season and stabilize lamps in accordance with Section (and corresponding subsections) 6.0 of IES LM–20–20 and with IES LM–54–20.

4.2.3.2 Measure the initial input power (in watts).

4.2.3.3 Measure initial lumen output in accordance with Sections (and corresponding subsections) 7.0 or 8.0 of IES LM–20–20 and with IES LM–78–20. When measuring in accordance with section 8.0, exclude undirected light using the method specified in section 8.2.

4.2.3.4 Calculate initial lamp efficacy by dividing the measured initial lumen output by the measured initial input power.

4.2.3.5 Calculate CRI as specified in CIE 13.3. Conduct the required spectroradiometric measurement and characterization in accordance with the methods set forth in IES LM–58–20.

4.2.3.6 Calculate CCT as specified in CIE 15:2018. Conduct the required spectroradiometric measurement and characterization in accordance with the methods set forth in IES LM–58–20.

5. Test Method for Voluntary Representations for General Service Fluorescent Lamps

Follow sections 1.0 through 4.0 of this appendix to make voluntary representations only for GSFLs that have high frequency reference ballast settings in ANSI C78.81–2016 or ANSI C78.901–2016. Where ANSI C78.81–2010 and ANSI C78.901–2005 are referenced in the preceding sections, use ANSI C78.81–2016 and ANSI C78.901–2016 instead. Operate lamps using high frequency reference ballast settings and without cathode power. Voluntary representations must be in addition to, not instead of, a representation in accordance with sections 1.0 to 4.0 of this appendix for GSFLs. As a best practice, an indication of high frequency operation should be provided with the voluntary representations.

6. Test Method for Determining Time to Failure for General Service Incandescent Lamps and Incandescent Reflector Lamps

6.1 *Test Conditions and Setup.* Establish ambient, physical, and electrical conditions as described in Sections (and corresponding subsections) 4.0 and 5.0 of IES LM–49–20.

6.2 *Test Methods, Measurements, and Calculations*

6.2.1 Season and stabilize lamps according to Section 6.2 of IES LM–45–20 for GSILs and in accordance with Section (and corresponding subsections) 6.0 of IES LM–20–20 for IRLs.

6.2.2 Measure the time to failure as specified in Section 6.4 of IES LM–49–20 and based on the lamp's operating time, expressed in hours, not including any off time.

6.3 Accelerated lifetime testing is not allowed; disregard the second paragraph of Section 6.4 of IES LM–49–20.

[87 FR 53641, Aug. 31, 2022]

APPENDIX S TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE WATER CONSUMPTION OF FAUCETS AND SHOWERHEADS

NOTE: Manufacturers must use the results of testing under this appendix to determine compliance with the relevant standards for faucets and showerheads at §430.32(g)(o) and (p) as those standards appeared in January 1, 2023 edition of 10 CFR parts 200–499. Specifically, before November 20, 2023 representations must be based upon results generated either under this appendix as codified on June 23, 2023 or under this appendix as it appeared in the 10 CFR parts 200–499 edition revised as of January 1, 2023. Any representations made on or after November 20, 2023 must be made based upon results generated

using this appendix as codified on June 23, 2023.

0. Incorporation by Reference

In §430.3, DOE incorporated by reference the entire standard for ASME A112.18.1; however, only enumerated provisions of ASME A112.18.1 apply to this appendix, as follows. In cases in which there is a conflict, the language of the test procedure in this appendix takes precedence over the referenced test standard. Treat precatory language in ASME A112.18.1 as mandatory.

0.1 ASME A112.18.1:

(a) Section 5.4 ''Flow rate,'' including Figure 3 but excluding Table 1 and excluding sections 5.4.2.3.1(a) and (c), 5.4.2.3.2(b) and (c), and 5.4.3, as specified in section 2.1 and 2.2 of this appendix;

(b) Section 5.4.2.2(c), as specified in section 3.1 of this appendix.

(c) Section 5.4.2.2(d), as specified in sections 2.2 and 3.2 of this appendix.

0.2 [Reserved]

1. Scope

This appendix covers the test requirements to measure the hydraulic performance of faucets and showerheads.

2. Flow Capacity Requirements

2.1. Faucets—Measure the water flow rate for faucets, in gallons per minute (gpm) or liters per minute (L/min), or gallons per cycle (gal/cycle) or liters per cycle (L/cycle), in accordance with the test requirements specified in section 5.4, Flow Rate, of ASME A112.18.1. Record measurements at the resolution of the test instrumentation. Round each calculation to the same number of significant digits as the previous step. Round the final water consumption value to one decimal place for non-metered faucets, or two decimal places for metered faucets.

2.2. Showerheads—Measure the water flow rate for showerheads, in gallons per minute (gpm) or liters per minute (L/min), in accordance with the test requirements specified in section 5.4, Flow Rate, of ASME A112.18.1. Record measurements at the resolution of the test instrumentation. Round each calculation to the same number of significant digits as the previous step. Round the final water consumption value to one decimal place. If using the time/volume method of section 5.4.2.2(d), position the container to ensure it collects all water flowing from the showerhead, including any leakage from the ball joint.

3. General Instruction for Measuring Flow Rate

3.1. Using the Fluid Meter Method To Measure Flow Rate

When measuring flow rate upstream of a showerhead or faucet using a fluid meter (or equivalent device) as described in section 5.4.2.2(c) of ASME A112.18.1, ensure the fluid meter (or equivalent device) meets the following additional requirements. First, ensure the fluid meter is rated for the flow rate range of the product being tested. Second, when testing showerheads or non-metering faucets, ensure that the fluid meter has a resolution for flow rate of at least 0.1 gallons (0.4 liters) per minute. When testing a metering faucet, ensure that the fluid meter has a resolution for flow rate of at least 0.01 gallons (0.04 liters) per minute. Third, verify the fluid meter is calibrated in accordance with the manufacturer printed instructions.

3.2. Using the Time/Volume Method To Measure Flow Rate

There are several additional requirements when measuring flow rate downstream of a showerhead or faucet as described in section 5.4.2.2(d) of ASME A112.18.1 to measure flow rate. First, ensure the receiving container is large enough to contain all the water for a single test and has an opening size and/or a partial cover such that loss of water from splashing is minimized. Second, conduct the time/volume test for at least one minute, with the time recorded via a stopwatch with at least 0.1-second resolution. Third, measure and record the temperature of the water using a thermocouple or other similar device either at the receiving container immediately after recording the mass of water, or at the water in the supply line anytime during the duration of the time/volume test. Fourth, measure the mass of water to a resolution of at least 0.01 lb. (0.005 kg) and normalize it to gallons based on the specific gravity of water at the recorded temperature.

[88 FR 33545, May 24, 2023]

Appendix T to Subpart B of Part 430—Uniform Test Method for Measuring the Water Consumption of Water Closets and Urinals

NOTE: After September 19, 2022, representations made with respect to the water consumption of water closets or urinals must fairly disclose the results of testing pursuant to this appendix.

On or after April 22, 2022 and prior to September 19, 2022 representations, including compliance certifications, made with respect to the water consumption of water closets or urinals must fairly disclose the results of testing pursuant to either this appendix or the appendix as it appeared at 10 CFR part 430, subpart B, in the 10 CFR parts 200 to 499 edition revised as of January 1, 2014. Representations made with respect to the water

consumption of water closets or urinals tested within that range of time must fairly disclose the results of testing under the selected version. Given that after September 19, 2022 representations with respect to the water consumption of water closets and urinals must be made in accordance with tests conducted pursuant to this appendix, manufacturers may wish to begin using this test procedure as soon as possible.

0. Incorporation by Reference

DOE incorporated by reference in §430.3, the entire standard for ASME A112.19.2–2018; however, only enumerated provisions of that document apply to this appendix, as follows. Treat precatory language in ASME A112.19.2–2018 as mandatory for the purpose of testing.

a. Section 7.1.1 ''All tests,'' including Figures 11 and 12, as specified in section 2.a of this appendix;

b. Section 7.1.2 ''Gravity flush tank water closets,'' as specified in section 2.a of this appendix;

c. Section 7.1.3 ''Flushometer tank, electro-hydraulic, or other pressurized flushing device water closets,'' as specified in section 2.a of this appendix;

d. Section 7.1.4 ''Flushometer valve water closets,'' as specified in section 2.a of this appendix;

e. Section 7.1.5 ''Procedures for standardizing the water supply system,'' including Figures 11 and 12, as specified in section 2.a of this appendix;

f. Section 7.3 ''Water consumption test,'' as specified in section 3.a of this appendix, except sections 7.3.4 and 7.3.5;

f. Section 8.2.1, including Figure 12, as specified in section 2.b of this appendix;

g. Section 8.2.2, as specified in section 2.b of this appendix;

h. Section 8.2.3, as specified in section 2.b of this appendix;

i. Section 8.6 ''Water Consumption Test,'' as specified in section 3.b of this appendix, except sections 8.6.3 and 8.6.4;

j. Table 5 ''Static test pressures for water closets, kPa (psi),'' as specified in sections 2.a and 3.a of this appendix; and

k. Table 6 ''Static test pressures for urinals, kPa (psi)'' as specified in sections 2.a and 3.a of this appendix.

In cases where there is a conflict, the language of the test procedure in this appendix takes precedence over ASME A112.19.2–2018.

1. Scope

This appendix sets forth the test requirements used to measure the hydraulic performances of water closets and urinals.

2. Test Apparatus and General Instructions

a. When testing a water closet, use the test apparatus and follow the instructions specified in Sections 7.1.1 (including Table 5), 7.1.2, 7.1.3, 7.1.4, and 7.1.5 of ASME A112.19.2–2018). The flushometer valve used in the water consumption test must represent the maximum design flush volume of the water closet. Record each measurement at the resolution of the test apparatus. Round each calculation of water consumption for each tested unit to the same number of significant digits as the previous step.

b. When testing a urinal, use the test apparatus and follow the instructions specified in Sections 8.2.1, 8.2.2, and 8.2.3 (including Table 6) of ASME A112.19.2–2018. The flushometer valve used in the water consumption test must represent the maximum design flush volume of the urinal. Record each measurement at the resolution of the test apparatus. Round each calculation of water consumption for each tested unit to the same number of significant digits as the previous step.

3. Test Measurement

a. Water closets:

(i) Measure the water flush volume for water closets, expressed in gallons per flush (gpf) or liters per flush (Lpf), in accordance with Section 7.3, Water Consumption Test, of ASME A112.19.2–2018. For dual-flush water closets, the measurement of the water flush volume shall be conducted separately for the full-flush and reduced-flush modes and in accordance with the test requirements specified Section 7.3, Water Consumption Test, of ASME A112.19.2–2018. The final measured flush volume for each tested unit is the average of the total flush volumes recorded at each test pressure as specified in Table 5 ''Static test pressures for water closets, kPa (psi),'' of ASME A112.19.2–2018, based on the average of the individual flush volumes at a given pressure from the three tests.

(ii) Flush volume and tank trim component adjustments: For gravity flush tank water closets, set trim components that can be adjusted to cause an increase in flush volume, including (but not limited to) the flapper valve, fill valve, and tank water level, in accordance with the printed installation instructions supplied by the manufacturer with the unit. If the printed installation instructions for the model to be tested do not specify trim setting adjustments, adjust these trim components to the maximum water use setting so that the maximum flush volume is produced without causing the water closet to malfunction or leak. Set the water level in the tank to the maximum water line designated in the printed installation instructions supplied by the manufacturer or the designated water line on the tank itself, whichever is higher. If the printed installation instructions or the water closet tank do not indicate a water level, adjust the water level to 1±0.1 inches below the top of the overflow tube or, for gravity flush tank water closets that do not contain an overflow tube, 1±0.1 inches below the top rim

of the water-containing vessel for each designated pressure specified in Table 5 of ASME A112.19.2–2018.

b. Urinals—Measure water flush volume for urinals, expressed in gallons per flush (gpf) or liters per flush (Lpf), in accordance with Section 8.6, Water Consumption Test, of ASME A112.19.2–2018. The final measured flush volume for each tested unit is the average of the total flush volumes recorded at each test pressure as specified in Table 6 ''Static test pressures for urinals, kPa (psi),'' of ASME A112.19.2–2018, based on the average of the individual flush volumes at a given pressure from the three tests.

[87 FR 16386, Mar. 23, 2022]

APPENDIX U TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CEILING FANS

NOTE: Prior to February 13, 2023, manufacturers must make any representations with respect to the energy use or efficiency of ceiling fans as specified in section 2 of this appendix as it appeared on January 23, 2017. On or after February 13, 2023, manufacturers of ceiling fans, as specified in section 2 of this appendix, must make any representations with respect to energy use or efficiency in accordance with the results of testing pursuant to this appendix. Representations of standby power consumption for large-diameter ceiling fans including for the purpose of certification, are not required until such time as compliance is required with an energy conservation standard for standby power consumption. Upon the compliance date(s) of any energy conservation standards for large-diameter ceiling fans with a blade span greater than 24 feet, use of the applicable provisions of this test procedure to demonstrate compliance with the energy conservation standard will also be required.

0. Incorporation by Reference

In §430.3, DOE incorporated by reference the entire standard for AMCA 208–18, AMCA 230–15, AMCA 230–15 TE, and IEC 62301; however, only enumerated provisions of AMCA 230–15, AMCA 230–15 TE, and IEC 62301 are applicable as follows:

0.1. AMCA 230–15 (including corresponding sections in AMCA 230–15 TE):

(a) Section 3—Units of Measurement, as specified in section 3.4 of this appendix;

(b) Section 4—Symbols and Subscripts; (including Table 1—Symbols and Subscripts), as specified in section 3.4 of this appendix;

(c) Section 5—Definitions (except 5.1), as specified in section 3.4 of this appendix;

(d) Section 6—Instruments and Section Methods of Measurement, as specified in section 3.4 of this appendix;

(e) Section 7—Equipment and Setups (except the last 2 bulleted items in 7.1—Allowable test setups), as specified in section 3.4 of this appendix;

(f) Section 8—Observations and Conduct of Test, as specified in section 3.5 of this appendix;

(g) Section 9—Calculations (except 9.5 and 9.6), as specified in section 3.5 of this appendix; and

(h) Test Figure 1—Vertical Airflow Setup with Load Cell (Ceiling Fans), as specified in section 3.4 of this appendix.

0.2. IEC 62301:

(a) Section 4.3.1—Supply voltage and frequency (first paragraph only), as specified in section 3.6 of this appendix;

(b) Section 4.3.2—Supply voltage waveform, as specified in section 3.6 of this appendix;

(c) Section 4.4—General conditions for measurements: Power measuring instruments, as specified in section 3.6 of this appendix;

(d) Section 5.3.1—General (except the last bulleted item), as specified in section 3.6 of this appendix and

(e) Section 5.3.2—Sampling method (first two paragraphs and Note 1), as specified in sections 3.6 and 3.6.3 of this appendix.

1. Definitions:

1.1. *40% speed* means the ceiling fan speed at which the blade RPM are measured to be 40% of the blade RPM measured at high speed.

1.2. *Airflow* means the rate of air movement at a specific fan-speed setting expressed in cubic feet per minute (CFM).

1.3. *Belt-driven ceiling fan* means a ceiling fan with a series of one or more fan heads, each driven by a belt connected to one or more motors that are located outside of the fan head.

1.4. *Blade span* means the diameter of the largest circle swept by any part of the fan blade assembly, including attachments. The represented value of blade span (D) is as determined in 10 CFR 429.32.

1.5. *Ceiling fan efficiency* means the ratio of the total airflow to the total power consumption, in units of cubic feet per minute per watt (CFM/W).

1.6. *Centrifugal ceiling fan* means a ceiling fan for which the primary airflow direction is in the same plane as the rotation of the fan blades.

1.7. *High speed* means the highest available ceiling fan speed, *i.e.*, the fan speed corresponding to the maximum blade revolutions per minute (RPM).

1.8. *High-speed small-diameter (HSSD) ceiling fan* means a small-diameter ceiling fan that is not a very-small-diameter ceiling fan, highly-decorative ceiling fan or belt-driven

ceiling fan and that has a represented value of blade edge thickness, as determined in 10 CFR 429.32(a)(3)(iii), of less than 3.2 mm or a maximum represented value of tip speed, as determined in 10 CFR 429.32(a)(3)(v), greater than the applicable limit specified in the table in this definition.

HIGH-SPEED SMALL-DIAMETER CEILING FAN BLADE AND TIP SPEED CRITERIA

Airflow direction	Thickness (t) of edges of blades		Tip speed threshold	
	Mm	Inch	m/s	feet per minute
Downward-only	4.8 > t ≥ 3.2	3/16 > t ≥ 1/8	16.3	3,200
Downward-only	t ≥ 4.8	t ≥ 3/16	20.3	4,000
Reversible	4.8 > t ≥ 3.2	3/16 > t ≥ 1/8	12.2	2,400
Reversible	t ≥ 4.8	t ≥ 3/16	16.3	3,200

1.9. *High-speed belt-driven (HSBD) ceiling fan* means a ceiling fan that is a belt-driven ceiling fan with one fan head, and that has a represented value of blade edge thickness, as determined in 10 CFR 429.32(a)(3)(iii), of less than 3.2 mm or a maximum represented value of tip speed, as determined in 10 CFR 429.32(a)(3)(v), greater than the applicable limit specified in the table in this definition.

HIGH-SPEED BELT-DRIVEN CEILING FAN BLADE AND TIP SPEED CRITERIA

Airflow direction	Thickness (t) of edges of blades		Tip speed threshold	
	Mm	Inch	m/s	feet per minute
Downward-only	4.8 > t ≥ 3.2	3/16 > t ≥ 1/8	16.3	3,200
Downward-only	t ≥ 4.8	t ≥ 3/16	20.3	4,000
Reversible	4.8 > t ≥ 3.2	3/16 > t ≥ 1/8	12.2	2,400
Reversible	t ≥ 4.8	t ≥ 3/16	16.3	3,200

1.10. *Highly-decorative ceiling fan* means a ceiling fan with a maximum represented value of blade revolutions per minute (RPM), as determined in 10 CFR 429.32(a)(3)(ii), of 90 RPM, and a represented value of airflow at high speed, as determined in 10 CFR 429.32(a)(3)(vi), of less than 1,840 CFM.

1.11. *Hugger ceiling fan* means a low-speed small-diameter ceiling fan that is not a very-small-diameter ceiling fan, highly-decorative ceiling fan, or belt-driven ceiling fan, and for which the represented value of the distance between the ceiling and the lowest point on the fan blades, as determined in 10 CFR 429.32(a)(3)(iv), is less than or equal to 10 inches.

1.12. *Large-diameter ceiling fan* means a ceiling fan that is not a highly-decorative ceiling fan or belt-driven ceiling fan and has a represented value of blade span, as determined in 10 CFR 429.32(a)(3)(i), greater than seven feet.

1.13. *Low speed* means the lowest available speed that meets the following criteria:

Number of sensors per individual axis as determined in section 3.2.2(6) of this appendix	Number of sensors per individual axis measuring 40 feet per minute or greater
3	2
4	3
5	3
6	4
7	4
8	5
9	6
10	7
11	8
12	9

1.14. *Low-speed small-diameter (LSSD) ceiling fan* means a small-diameter ceiling fan that has a represented value of blade edge thickness, as determined in 10 CFR 429.32(a)(3)(iii), greater than or equal to 3.2 mm and a maximum represented value of tip speed, as determined in 10 CFR 429.32(a)(3)(v), less than or equal to the applicable limit specified in the table in this definition.

LOW-SPEED SMALL-DIAMETER CEILING FAN BLADE AND TIP SPEED CRITERIA

Airflow direction	Thickness (t) of edges of blades		Tip speed threshold	
	Mm	Inch	m/s	feet per minute
Reversible	4.8 > t ≥ 3.2	3/16 > t ≥ 1/8	12.2	2,400
Reversible	t ≥ 4.8	t ≥ 3/16	16.3	3,200

1.15. *Multi-head ceiling fan* means a ceiling fan with more than one fan head, *i.e.*, more than one set of rotating fan blades.

1.16. *Multi-mount ceiling fan* means a low-speed small-diameter ceiling fan that can be mounted in the configurations associated with both the standard and hugger ceiling fans.

1.17. *Oscillating ceiling fan* means a ceiling fan containing one or more fan heads for which the axis of rotation of the fan blades cannot remain in a fixed position relative to the ceiling. Such fans have no inherent means by which to disable the oscillating function separate from the fan blade rotation.

1.18. *Small-diameter ceiling fan* means a ceiling fan that has a represented value of blade span, as determined in 10 CFR 429.32(a)(3)(i), less than or equal to seven feet.

1.19. *Standard ceiling fan* means a low-speed small-diameter ceiling fan that is not a very-small-diameter ceiling fan, highly-decorative ceiling fan or belt-driven ceiling fan, and for which the represented value of the distance between the ceiling and the lowest point on the fan blades, as determined in 10 CFR 429.32(a)(3)(iv), is greater than 10 inches.

1.20. *Total airflow* means the sum of the product of airflow and hours of operation at all tested speeds. For multi-head fans, this includes the airflow from all fan heads.

1.21. *Very-small-diameter (VSD) ceiling fan* means a small-diameter ceiling fan that is not a highly-decorative ceiling fan or belt-driven ceiling fan; and has one or more fan heads, each of which has a represented value of blade span, as determined in 10 CFR 429.32(a)(3)(i), of 18 inches or less. Only VSD fans that also meet the definition of an LSSD fan are required to be tested for purposes of determining compliance with energy efficiency standards established by DOE and for other representations of energy efficiency.

2. Scope:

The provisions in this appendix apply to ceiling fans except:

(1) Ceiling fans where the plane of rotation of a ceiling fan's blades is not less than or equal to 45 degrees from horizontal, or cannot be adjusted based on the manufacturer's specifications to be less than or equal to 45 degrees from horizontal;

(2) Centrifugal ceiling fans;

(3) Belt-driven ceiling fans that are not high-speed belt-driven ceiling fans; and

(4) Oscillating ceiling fans.

3. General Instructions, Test Apparatus, and Test Measurement:

The test apparatus and test measurement used to determine energy performance depend on the ceiling fan's blade span, and in some cases the ceiling fan's blade edge thickness. For each tested ceiling fan, measure the lateral distance from the center of the axis of rotation of the fan blades to the furthest fan blade edge from the center of the axis of rotation. Measure this lateral distance at the resolution of the measurement instrument, using an instrument with a measurement resolution of least 0.25 inches. Multiply the lateral distance by two and then round to the nearest whole inch to determine the blade span. For ceiling fans having a blade span greater than 18 inches and less than or equal to 84 inches, measure the ceiling fan's blade edge thickness. To measure the fan blade edge thickness, use an instrument with a measurement resolution of at least 0.001 inch and measure the thickness of one fan blade's leading edge (in the forward direction) according to the following:

(1) Locate the cross-section perpendicular to the fan blade's radial length that is at least one inch from the tip of the fan blade and for which the blade is thinnest, and

(2) Measure at the thickest point of that cross-section within one inch from the leading edge of the fan blade.

See Figure 1 of this appendix for an instructional schematic on the fan blade edge thickness measurement. Figure 1 depicts a ceiling fan from above. Round the measured blade edge thickness to the nearest 0.01 inch.




Figure 1 to Appendix U to Subpart B of Part 430: Measurement Criteria for Fan Blade Edge Thickness

3.1. General instructions.

3.1.1. Record measurements at the resolution of the test instrumentation. Round off calculations to the number of significant digits present at the resolution of the test instrumentation, except for blade span, which is rounded to the nearest inch. Round the final ceiling fan efficiency value to the nearest whole number as follows:

3.1.1.1. A fractional number at or above the midpoint between the two consecutive whole numbers shall be rounded up to the higher of the two whole numbers; or

3.1.1.2. A fractional number below the midpoint between the two consecutive whole numbers shall be rounded down to the lower of the two whole numbers.

3.1.2. For multi-head ceiling fans, the effective blade span is the blade span (as specified in section 3) of an individual fan head, if all fan heads are the same size. If the fan heads are of varying sizes, the effective blade span is the blade span (as specified in section 3) of the largest fan head.

3.2. Test apparatus for low-speed small-diameter and high-speed small-diameter ceiling fans: All instruments are to have accuracies within ±1% of reading, except for the air velocity sensors, which must have accuracies within ±5% of reading or 2 feet per minute (fpm), whichever is greater. Equipment is to be calibrated at least once a year to compensate for variation over time.

3.2.1. *Air Delivery Room Requirements*

(1) The air delivery room dimensions are to be 20 ± 0.75 feet x 20 ± 0.75 feet with an 11 ± 0.75 foot-high ceiling. The control room shall be constructed external to the air delivery room.

(2) The ceiling shall be constructed of sheet rock or stainless plate. The walls must be of adequate thickness to maintain the specified temperature and humidity during the test. The paint used on the walls, as well as the paint used on the ceiling material, must be of a type that minimizes absorption of humidity and that keeps the temperature of the room constant during the test (*e.g.*, oil-based paint).

(3) The room must not have any ventilation other than an air conditioning and return system used to control the temperature and humidity of the room. The construction of the room must ensure consistent air circulation patterns within the room. Vents must have electronically-operated damper doors controllable from a switch outside of the testing room.

3.2.2. *Equipment Set-Up*

(1) Make sure the transformer power is off. Hang the ceiling fan to be tested directly from the ceiling, according to the manufacturer's installation instructions. Hang all non-multi-mount ceiling fans in the fan configuration that minimizes the distance between the ceiling and the lowest point of the fan blades. Hang and test multi-mount fans in two configurations: The configuration associated the definition of a standard fan that minimizes the distance between the ceiling and the lowest point of the fan blades and the configuration associated with the definition of a hugger fan that minimizes the distance between the ceiling and the lowest

point of the fan blades. For all tested configurations, measure the distance between the ceiling and the lowest point of the fan blade using an instrument with a measurement resolution of at least 0.25 inches. Round the measured distance from the ceiling to the lowest point of the fan blade to the nearest quarter inch.

(2) Connect wires as directed by manufacturer's wiring instructions. *Note:* Assemble fan prior to the test; lab personnel must follow the instructions provided with the fan by the fan manufacturer. Balance the fan blade assembly in accordance with the manufacturer's instructions to avoid excessive vibration of the motor assembly (at any speed) during operation.

(3) With the ceiling fan installed, adjust the height of the air velocity sensors to ensure the vertical distance between the lowest point on the ceiling fan blades and the air velocity sensors is 43 inches.

(4) A single rotating sensor arm, two rotating sensor arms, or four fixed sensor arms can be used to take air velocity measurements along four axes, labeled A–D. Axes A, B, C, and D are at 0, 90, 180, and 270 degree positions. Axes A–D must be perpendicular to the four walls of the room. See Figure 2 of this appendix.




Figure 2 to Appendix U to Subpart B of Part 430: Testing Room and Sensor Arm Axes

(5) Minimize the amount of exposed wiring. Store all sensor lead wires under the floor, if possible.

(6) Place the sensors at intervals of 4 ± 0.0625 inches along a sensor arm, starting with the first sensor at the point where the four axes intersect, aligning the sensors perpendicular to the direction of airflow. Do not touch the actual sensor prior to testing. Use enough sensors to record air delivery within a circle 8 inches larger in diameter than the blade span of the ceiling fan being tested. The experimental set-up is shown in Figure 3 of this appendix.




Figure 3 to Appendix U to Subpart B of Part 430: Air Delivery Room Set-Up for Small-Diameter Ceiling Fans other than High-Speed Belt-Driven Ceiling Fans

(7) Table 1 of this appendix shows the appropriate number of sensors needed per each of four axes (including the first sensor at the intersection of the axes) for common fan sizes.

TABLE 1 TO APPENDIX U TO SUBPART B OF PART 430: SENSOR SELECTION REQUIREMENTS

Fan blade span* (inches)	Number of sensors
36	6
42	7
44	7
48	7
52	8
54	8
56	8
60	9
72	10
84	12

*The fan sizes listed are illustrative and do not restrict which ceiling fan sizes can be tested.

(8) Install an RPM (revolutions per minute) meter, or tachometer, to measure RPM of the ceiling fan blades.

(9) Use an RMS sensor capable of measuring power with an accuracy of ±1% to measure ceiling fan power consumption. If the ceiling fan operates on multi-phase power input, measure the active (real) power in all phases simultaneously. Measure test voltage within 6'' of the connection supplied with the ceiling fan.

(10) Complete any conditioning instructions provided in the ceiling fan's instruction or installation manual must be completed prior to conducting testing.

3.2.3. *Multi-Head Ceiling Fan Test Set-Up.*

Hang a multi-headed ceiling fan from the ceiling such that one of the ceiling fan heads is centered directly over sensor 1 (*i.e.*, at the intersection of axes A, B, C, and D). The distance between the lowest point any of the fan blades of the centered fan head can reach and the air velocity sensors is to be such that it is the same as for all other small-diameter ceiling fans (*see* Figure 3 of this appendix). If the multi-head ceiling fan has an oscillating function (*i.e.*, the fan heads change their axis of rotation relative to the ceiling) that can be switched off, switch it off prior to taking air velocity measurements. If any multi-head fan does not come with the blades preinstalled, install fan blades only on the fan head that will be directly centered over the intersection of the sensor axes. (Even if the fan heads in a multi-head ceiling fan would typically oscillate when the blades are installed on all fan heads, the ceiling fan is subject to this test procedure if the centered fan head does not oscillate when it is the only fan head with the blades installed.) If the fan blades are preinstalled on all fan heads, measure air velocity in accordance with section 3.3 of this appendix except turn on only the centered fan head. Take the power consumption measurements separately, with the fan blades installed on all fan heads and with any oscillating function, if present, switched on.

3.2.4. Test Set-Up for Ceiling Fans with Airflow Not Directly Downward

For ceiling fans where the airflow is not directly downward, adjust the ceiling fan head such that the airflow is as vertical as possible prior to testing. For ceiling fans where a fully vertical orientation of airflow cannot be achieved, orient the ceiling fan (or fan head, if the ceiling fan is a multi-head fan) such that any remaining tilt is aligned along one of the four sensor axes. Instead of measuring the air velocity for only those sensors directly beneath the ceiling fan, the air velocity is to be measured at all sensors along that axis, as well as the axis oriented 180 degrees with respect to that axis. For example, if the tilt is oriented along axis A, air velocity measurements are to be taken for all sensors along the A–C axis. No measurements would need to be taken along the B–D axis in

this case. All other aspects of test set-up remain unchanged from sections 3 through 3.2.2.

3.3. Active mode test measurement for low-speed small-diameter and high-speed small-diameter ceiling fans.

3.3.1. *Test conditions to be followed when testing:*

(1) Maintain the room temperature at 70 degrees ± 5 degrees Fahrenheit and the room humidity at 50% ± 5% relative humidity during the entire test process.

(2) If present, the ceiling fan light fixture is to be installed but turned off during testing.

(3) If present, any additional accessories or features sold with the ceiling fan that do not relate to the ceiling fan's ability to create airflow by rotation of the fan blades (for example light kit, heater, air ionization, ultraviolet technology) is to be installed but turned off during testing. If such an accessory or feature cannot be turned off, it shall be set to the lowest energy-consuming mode during testing. If the ceiling fan is offered with a default controller, test using the default controller. If multiple controllers are offered, test using the minimally functional controller.

(4) If present, turn off any oscillating function causing the axis of rotation of the fan head(s) to change relative to the ceiling during operation prior to taking air velocity measurements. Turn on any oscillating function prior to taking power measurements.

(5) Test ceiling fans rated for operation with only a single- or multi-phase power supply with single- or multi-phase electricity, respectively. Test ceiling fans capable of operating with single- and multi-phase electricity with single-phase electricity. DOE will allow manufacturers of ceiling fans capable of operating with single- and multi-phase electricity to test such fans with single-phase power and make representations of efficiency associated with both single and multi-phase electricity if a manufacturer desires to do so, but the test results in the multi-phase configuration will not be valid to assess compliance with any amended energy conservation standard. All tested power supply should be at 60 Hz.

(6) The supply voltage shall be:

(i) for ceiling fans tested with single-phase electricity, the supply voltage shall be:

(a) 120 V if the ceiling fan's minimum rated voltage is 120 V or the lowest rated voltage range contains 120 V,

(b) 240 V if the ceiling fan's minimum rated voltage is 240 V or the lowest rated voltage range contains 240 V, or

(c) The ceiling fan's minimum rated voltage (if a voltage range is not given) or the mean of the lowest rated voltage range, in all other cases.

(ii) for ceiling fans tested with multi-phase electricity, the supply voltage shall be:

(a) 240 V if the ceiling fan's minimum rated voltage is 240 V or the lowest rated voltage range contains 240 V, or

(b) The ceiling fan's minimum rated voltage (if a voltage range is not given) or the mean of the lowest rated voltage range, in all other cases.

(iii) The test voltage shall not vary by more than ±1% during the tests.

(7) Conduct the test with the fan connected to a supply circuit at the rated frequency.

(8) Measure power input at a point that includes all power-consuming components of the ceiling fan (but without any attached light kit energized; or without any additional accessory or feature energized, if possible; and if not, with the additional accessory or feature set at the lowest energy-consuming mode). If the ceiling fan is offered with a default controller, test using the default controller. If multiple controllers are offered, test using the minimally functional controller.

3.3.2. *Air Velocity and Power Consumption Testing Procedure:*

Measure the air velocity (FPM) and power consumption (W) for HSSD ceiling fans until stable measurements are achieved, measuring at high speed only. Measure the air velocity and power consumption for LSSD and VSD ceiling fans that also meet the definition of an LSSD fan until stable measurements are achieved, measuring first at low speed and then at high speed. To determine low speed, start measurements at the lowest available speed and move to the next highest speed until the low speed definition in section 1.13 of this appendix is met. Air velocity and power consumption measurements are considered stable for high speed if:

(1) The average air velocity for each sensor varies by less than 5 percent or 2 FPM, whichever is greater, compared to the average air velocity measured for that same sensor in a successive set of air velocity measurements, and

(2) Average power consumption varies by less than 1 percent in a successive set of power consumption measurements.

(a) Air velocity and power consumption measurements are considered stable for low speed if:

(1) The average air velocity for each sensor varies by less than 10 percent or 2 FPM, whichever is greater, compared to the average air velocity measured for that same sensor in a successive set of air velocity measurements, and

(2) Average power consumption varies by less than 1 percent in a successive set of power consumption measurements.

(b) These stability criteria are applied differently to ceiling fans with airflow not directly downward. *See* section 3.3.3 of this appendix.

Step 1: Set the first sensor arm (if using four fixed arms), two sensor arm (if using a

two-arm rotating setup), or single sensor arm (if using a single-arm rotating setup) to the 0 degree Position (Axis A). If necessary, use a marking as reference. If using a single-arm rotating setup or two-arm rotating setup, adjust the sensor arm alignment until it is at the 0 degree position by remotely controlling the antenna rotator.

Step 2: Set software up to read and record air velocity, expressed in feet per minute (FPM) in 1 second intervals. (Temperature does not need to be recorded in 1 second intervals.) Record current barometric pressure.

Step 3: Allow test fan to run 15 minutes at rated voltage and at high speed if the ceiling fan is an HSSD ceiling fan. If the ceiling fan is an LSSD or VSD ceiling fan that also meets the definition of an LSSD fan, allow the test fan to run 15 minutes at the rated voltage and at the lowest available ceiling fan speed. Turn off all forced-air environmental conditioning equipment entering the chamber (*e.g.*, air conditioning), close all doors and vents, and wait an additional 3 minutes prior to starting test session.

Step 4a: For a rotating sensor arm: Begin recording readings. Starting with Axis A, take 100 air velocity readings (100 seconds run-time) and record these data. For all fans except multi-head fans and fans capable of oscillating, also measure power during the interval that air velocity measurements are taken. Record the average value of the air velocity readings for each sensor in feet per minute (FPM). Determine if the readings meet the low speed definition as defined in section 1.13 of this appendix. If not, restart Step 4a at the next highest speed until the low-speed definition is met. Once the low speed definition is met, rotate the arm, stabilize the arm, and allow 30 seconds to allow the arm to stop oscillating. Repeat data recording and rotation process for Axes B, C, and D. Step 4a is complete when the readings for all axes meet the low speed definition at the same speed. Save the data for all axes only for those measurements that meet the low speed definition. Using the measurements applicable to low speed, record the average value of the power measurement in watts (W) (400 readings). Record the average value of the air velocity readings for each sensor in feet per minute (FPM) (400 readings).

Step 4b: For a two-arm rotating setup: Begin recording readings. Starting with Axes A and C, take 100 air velocity readings (100 seconds run-time) for both axes and record these data. For all fans except multi-head fans and fans capable of oscillating, also measure power during the interval that air velocity measurements are taken. Record the average value of the air velocity readings for each sensor in feet per minute (FPM). Determine if the readings meet the low speed definition as defined in section 1.13 of this appendix. If not, restart Step 4b at the next highest speed until the low speed definition is met. Once the low speed definition is met, rotate the two-arm, stabilize the arm, and allow 30 seconds to allow the arm to stop oscillating. Repeat data recording for Axes B and D. Step 4b is complete when the readings for all axes meet the low speed definition at the same speed. Save the data for all axes only for those measurements that meet the low speed definition. Using the measurements applicable to low speed, record the average value of the power measurement in watts (W) (200 readings). Record the average value of the air velocity readings for each sensor in feet per minute (FPM) (200 readings).

Step 4c: For four fixed sensor arms: Begin recording readings. Take 100 air velocity readings (100 seconds run-time) and record this data. Take the readings for all sensor arms (Axes A, B, C, and D) simultaneously. For all fans except multi-head fans and fans capable of oscillating, also measure power during the interval that air velocity measurements are taken. Record the average value of the air velocity readings for each sensor in feet per minute (FPM). Determine if the readings meet the low speed definition as defined in section 1.13 of this appendix. If not, restart Step 4c at the next highest speed until the low speed definition is met. Step 4c is complete when the readings for all axes meet the low speed definition at the same speed. Save the data for all axes only for those measurements that meet the low speed definition. Using the measurements applicable to low speed, record the average value of the power measurement in watts (W) (100 readings). Record the average value of the air velocity readings for each sensor in feet per minute (FPM) (100 readings).

Step 5: Repeat step 4a, 4b or 4c until stable measurements are achieved.

Step 6: Repeat steps 1 through 5 above on high speed for LSSD and VSD ceiling fans that also meet the definition of an LSSD fan. Note: Ensure that temperature and humidity readings are maintained within the required tolerances for the duration of the test (all tested speeds). Forced-air environmental conditioning equipment may be used and doors and vents may be opened between test sessions to maintain environmental conditions.

Step 7: If testing a multi-mount ceiling fan, repeat steps 1 through 6 with the ceiling fan in the ceiling fan configuration (associated with either hugger or standard ceiling fans) not already tested.

If a multi-head ceiling fan includes more than one category of ceiling fan head, then test at least one of each unique category. A fan head with different construction that could affect air movement or power consumption, such as housing, blade pitch, or motor, would constitute a different category of fan head.

Step 8: For multi-head ceiling fans, measure active (real) power consumption in all phases simultaneously at each speed continuously for 100 seconds with all fan heads turned on, and record the average value at each speed in watts (W).

For ceiling fans with an oscillating function, measure active (real) power consumption in all phases simultaneously at each speed continuously for 100 seconds with the oscillating function turned on. Record the average value of the power measurement in watts (W).

For both multi-head ceiling fans and fans with an oscillating function, repeat power consumption measurement until stable power measurements are achieved.

3.3.3. *Air Velocity Measurements for Ceiling Fans with Airflow Not Directly Downward:*

Using the number of sensors that cover the same diameter as if the airflow were directly downward, record air velocity at each speed from the same number of continuous sensors with the largest air velocity measurements. This continuous set of sensors must be along the axis that the ceiling fan tilt is directed in (and along the axis that is 180 degrees from the first axis). For example, a 42-inch fan tilted toward axis A may create the pattern of air velocity shown in Figure 4 of this appendix. As shown in Table 1 of this appendix, a 42-inch fan would normally require 7 active sensors per axis. However, because the fan is not directed downward, all sensors must record data. In this case, because the set of sensors corresponding to maximum air velocity are centered 3 sensor positions away from the sensor 1 along the A axis, substitute the air velocity at A axis sensor 4 for the average air velocity at sensor 1. Take the average of the air velocity at A axis sensors 3 and 5 as a substitute for the average air velocity at sensor 2, take the average of the air velocity at A axis sensors 2 and 6 as a substitute for the average air velocity at sensor 3, etc. Lastly, take the average of the air velocities at A axis sensor 10 and C axis sensor 4 as a substitute for the average air velocity at sensor 7. Stability criteria apply after these substitutions. For example, air velocity stability at sensor 7 are determined based on the average of average air velocity at A axis sensor 10 and C axis sensor 4 in successive measurements. Any air velocity measurements made along the B–D axis are not included in the calculation of average air velocity.




Figure 4 to Appendix U to Subpart B of Part 430: Example Air Velocity Pattern for Airflow Not Directly Downward

3.4. *Test apparatus for large-diameter ceiling fans and high-speed belt-driven ceiling fans:*

The test apparatus and instructions for testing large-diameter ceiling fans and HSBD ceiling fans must conform to the requirements specified in Sections 3 through 7 (including Test Figure 1) of AMCA 230–15, with the following modifications:

3.4.1. A ''ceiling fan'' is defined as in 10 CFR 430.2.

3.4.2. Test ceiling fans rated for operation with only a single- or multi-phase power supply with single- or multi-phase electricity, respectively. Test ceiling fans capable of operating with single- and multi-phase electricity with multi-phase electricity. DOE will allow manufacturers of ceiling fans capable of operating with single- and multi-phase electricity to test such fans with single-phase power and make representations of efficiency associated with both single and multi-phase electricity if a manufacturer desires to do so, but the test results in the single-phase configuration will not be valid to assess compliance with any amended energy conservation standard. All tested power supply should be at 60 Hz.

3.4.3. Supply Voltage:

(1) For ceiling fans tested with single-phase electricity, the supply voltage shall be:

(a) 120 V if the ceiling fan's minimum rated voltage is 120 V or the lowest rated voltage range contains 120 V,

(b) 240 V if the ceiling fan's minimum rated voltage is 240 V or the lowest rated voltage range contains 240 V, or

(c) The ceiling fan's minimum rated voltage (if a voltage range is not given) or the mean of the lowest rated voltage range, in all other cases.

(2) For ceiling fans tested with multi-phase electricity, the supply voltage shall be:

(a) 240 V if the ceiling fan's minimum rated voltage is 240 V or the lowest rated voltage range contains 240 V, or

(b) The ceiling fan's minimum rated voltage (if a voltage range is not given) or the mean of the lowest rated voltage range, in all other cases.

3.5. *Active mode test measurement for large-diameter ceiling fans and high-speed belt-driven ceiling fans:*

(1) Test large-diameter ceiling fans and high-speed belt-driven ceiling fans in accordance with AMCA 208–18, in all phases simultaneously at:

(a) High speed, and

(b) 40 percent or the nearest speed that is not less than 40 percent speed.

(2) When testing at 40 percent speed for large-diameter ceiling fans that can operate over an infinite number of speeds (*e.g.*, ceiling fans with VFDs), ensure the average measured RPM is within the greater of 1 percent of the average RPM at high speed or 1 RPM. For example, if the average measured RPM at high speed is 50 RPM, for testing at 40 percent speed, the average measured RPM should be between 19 RPM and 21 RPM. If the average measured RPM falls outside of this tolerance, adjust the ceiling fan speed and repeat the test. Calculate the airflow and measure the active (real) power consumption in all phases simultaneously in accordance with the test requirements specified in Sections 8 and 9, AMCA 230–15, with the following modifications:

3.5.1. Measure active (real) power consumption in all phases simultaneously at a point that includes all power-consuming components of the ceiling fan. If present, any additional accessories or features sold with the ceiling fan that do not relate to the ceiling fan's ability to create airflow by rotation of the fan blades (for example light kit, heater, air ionization, ultraviolet technology) are to be installed but turned off during testing. If the accessory/feature cannot be turned off, it shall be set to the lowest energy-consuming mode during testing. If the ceiling fan is offered with a default controller, test using the default controller. If multiple controllers are offered, test using the minimally functional controller.

3.5.2. Measure active (real) power consumption in all phases simultaneously continuously at the rated voltage that represents normal operation over the time period for which the load differential test is conducted.

3.6. *Test measurement for standby power consumption.*

(1) Measure standby power consumption if the ceiling fan offers one or more of the following user-oriented or protective functions:

(a) The ability to facilitate the activation or deactivation of other functions (including active mode) by remote switch (including remote control), internal sensor, or timer.

(b) Continuous functions, including information or status displays (including clocks), or sensor-based functions.

(2) Measure standby power consumption after completion of active mode testing and after the active mode functionality has been switched off (*i.e.,* the rotation of the ceiling fan blades is no longer energized). The ceiling fan must remain connected to the main power supply and be in the same configuration as in active mode (*i.e.*, any ceiling fan light fixture should still be attached). Measure standby power consumption according to Sections 4.3.1, 4.3.2, 4.4, and 5.3.1 through 5.3.2, of IEC 62301 with the following modifications:

3.6.1. Allow 3 minutes between switching off active mode functionality and beginning the standby power test. (No additional time before measurement is required.)

3.6.2. Simultaneously in all phases, measure active (real) power consumption continuously for 100 seconds, and record the average value of the standby power measurement in watts (W).

3.6.3. Determine power consumption according to section 5.3.2 of IEC 62301, or by using the following average reading method. Note that a shorter measurement period may be possible using the sample method in section 5.3.2 of IEC 62301.

(1) Connect the product to the power supply and power measuring instrument.

(2) Select the mode to be measured (which may require a sequence of operations and could require waiting for the product to automatically enter the desired mode) and then monitor the power.

(3) Calculate the average power using either the average power method or the accumulated energy method. For the average power method, where the power measuring instrument can record true average power over an operator selected period, the average power is taken directly from the power measuring instrument. For the accumulated energy method, determine the average power by dividing the measured energy by the time for the monitoring period. Use units of watt-hours and hours for both methods to determine average power in watts.

4. Calculation of Ceiling Fan Efficiency From the Test Results:

4.1. Calculation of effective area for small-diameter ceiling fans other than high-speed belt-driven ceiling fans:

Calculate the effective area corresponding to each sensor used in the test method for small-diameter ceiling fans other than high-speed belt-driven ceiling fans (section 3.3 of this appendix) with the following equations:

(1) For sensor 1, the sensor located directly underneath the center of the ceiling fan, the effective width of the circle is 2 inches, and the effective area is:

$$Effective\ Area\ (sq.ft.) = \pi\left(\frac{2}{12}\right)^2 = 0.0873 \qquad \text{Eq. 1}$$

(2) For the sensors between sensor 1 and the last sensor used in the measurement, the effective area has a width of 4 inches. If a sensor is a distance *d*, in inches, from sensor 1, then the effective area is:

$$Effective\ Area\ (sq.ft.) = \pi\left(\frac{d+1}{12}\right)^2 - \pi\left(\frac{d-2}{12}\right)^2 = \pi\left(\frac{24+1}{12}\right)^2 - \pi\left(\frac{24-2}{12}\right)^2 = 3.076 \qquad \text{Eq. 3}$$

(3) For the last sensor, the width of the effective area depends on the horizontal displacement between the last sensor and the point on the ceiling fan blades furthest radially from the center of the fan. The total area included in an airflow calculation is the area of a circle 8 inches larger in diameter than the ceiling fan blade span (as specified in section 3 of this appendix).

Therefore, for example, for a 42-inch ceiling fan, the last sensor is 3 inches beyond the end of the ceiling fan blades. Because only the area within 4 inches of the end of the ceiling fan blades is included in the airflow calculation, the effective width of the circle corresponding to the last sensor would be 3 inches. The calculation for the effective area corresponding to the last sensor would then be:

$$Effective\ Area\ (sq.ft.) = \pi\left(\frac{d+1}{12}\right)^2 - \pi\left(\frac{d-2}{12}\right)^2 = \pi\left(\frac{24+1}{12}\right)^2 - \pi\left(\frac{24-2}{12}\right)^2 = 3.076 \qquad \text{Eq. 3}$$

For a 46-inch ceiling fan, the effective area of the last sensor would have a width of 5 inches, and the effective area would be:

$$Effective\ Area\ (sq.ft.) = \pi\left(\frac{d+3}{12}\right)^2 - \pi\left(\frac{d-2}{12}\right)^2 = \pi\left(\frac{24+3}{12}\right)^2 - \pi\left(\frac{24-2}{12}\right)^2 = 5.345 \qquad \text{Eq. 4}$$

4.2 Calculation of airflow and efficiency for small-diameter ceiling fans other than high-speed belt-driven ceiling fans:

Calculate fan airflow using the overall average of both sets of air velocity measurements at each sensor position from the successive sets of measurements that meet the stability criteria from section 3.3 of this appendix. To calculate airflow for HSSD, LSSD, and VSD ceiling fans, multiply the overall average air velocity at each sensor position from section 3.3 (for high speed for HSSD, LSSD, and VSD ceiling fans that also meet the definition of an LSSD ceiling fan; and repeated for low speed only for LSSD and VSD ceiling fans that also meet the definition of an LSSD ceiling fan) by that sensor's effective area (see section 4.1 of this appendix), and then sum the products to obtain the overall calculated airflow at the tested speed.

For each speed, using the overall calculated airflow and the overall average power consumption measurements from the successive sets of measurements as follows:

$$Ceiling\ Fan\ Efficiency\ (CFM/W) = \frac{\sum_i (CFM_i \times OH_i)}{W_{Sb} \times OH_{Sb} + \sum_i (W_i \times OH_i)} \quad \textbf{Eq. 5}$$

Where:

CFM_i = airflow at speed *i*,

OH_i = operating hours at speed *i*, as specified in Table 2 of this appendix,

W_i = power consumption at speed *i*,

OH_{Sb} = operating hours in standby mode, as specified in Table 2 of this appendix, and

W_{Sb} = power consumption in standby mode.

Calculate two ceiling fan efficiencies for multi-mount ceiling fans: One efficiency corresponds to the ceiling fan mounted in the configuration associated with the definition of a hugger ceiling fan, and the other efficiency corresponds to the ceiling fan mounted in the configuration associated with the definition of a standard ceiling fan.

TABLE 2 TO APPENDIX U TO SUBPART B OF PART 430: DAILY OPERATING HOURS FOR CALCULATING CEILING FAN EFFICIENCY

	No standby	With standby
Daily Operating Hours for LSSD and VSD* Ceiling Fans		
High Speed	3.4	3.4
Low Speed	3.0	3.0
Standby Mode	0.0	17.6
Off Mode	17.6	0.0
Daily Operating Hours for HSSD Ceiling Fans		
High Speed	12.0	12.0
Standby Mode	0.0	12.0
Off Mode	12.0	0.0

*These values apply only to VSD fans that also meet the definition of an LSSD fan.

4.3 Calculation of airflow and efficiency for multi-head ceiling fans:

Calculate airflow for each fan head using the method described in section 4.2 of this appendix. To calculate overall airflow at a given speed for a multi-head ceiling fan, sum the airflow for each fan head included in the ceiling fan (a single airflow can be applied to each of the identical fan heads, but at least one of each unique fan head must be tested). The power consumption is the measured power consumption with all fan heads on. Using the airflow as described in this section, and power consumption measurements from section 3.3 of this appendix, calculate ceiling fan efficiency for a multi-head ceiling fan as follows:

$$Ceiling\ Fan\ Efficiency\ (CFM/W) = \frac{\sum_i (CFM_i \times OH_i)}{W_{Sb} \times OH_{Sb} + \sum_i (W_i \times OH_i)} \quad \textbf{Eq. 6}$$

Where:

CFM_i = sum of airflows for each head at speed i,

OH_i = operating hours at speed i as specified in Table 2 of this appendix,

W_i = power consumption at speed i,

OH_{Sb} = operating hours in standby mode as specified in Table 2 of this appendix, and

W_{Sb} = power consumption in standby mode.

5. Calculation of Ceiling Fan Energy Index (CFEI) From the Test Results for Large Diameter Ceiling Fan and High-Speed Belt-Driven Ceiling Fans:

Calculate CFEI, which is the FEI for large-diameter ceiling fans and high-speed belt-driven ceiling fans, at the speeds specified in section 3.5 of this appendix according to AMCA 208–18, with the following modifications:

(1) Using an Airflow Constant (Q_0) of 26,500 cubic feet per minute;

(2) Using a Pressure Constant (P_0) of 0.0027 inches water gauge; and

(3) Using a Fan Efficiency Constant (η_0) of 42 percent.

[81 FR 48639, July 25, 2016; 81 FR 54721, Aug. 17, 2016, as amended at 86 FR 28473, May 27, 2021; 87 FR 50424, Aug. 16, 2022]

APPENDIX V TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CEILING FAN LIGHT KITS PACKAGED WITH OTHER FLUORESCENT LAMPS (NOT COMPACT FLUORESCENT LAMPS OR GENERAL SERVICE FLUORESCENT LAMPS), PACKAGED WITH CONSUMER-REPLACEABLE SSL (NOT INTEGRATED LED LAMPS), PACKAGED WITH NON-CONSUMER-REPLACEABLE SSL, OR PACKAGED WITH OTHER SSL LAMPS THAT HAVE AN ANSI STANDARD BASE (NOT INTEGRATED LED LAMPS)

NOTE: Manufacturers must use the results of testing under this appendix to determine compliance with the relevant standards for ceiling fan light kits as those standards appeared in January 1, 2023 edition of 10 CFR parts 200–499. Specifically, before October 10, 2023 representations must be based upon results generated either under this appendix as codified on May 11, 2023 or under appendix V1 as it appeared in the 10 CFR parts 200–499 edition revised as of January 1, 2023. Any representations made on or after October 10, 2023 must be made based upon results generated using this appendix as codified on May 11, 2023.

0. Incorporation by Reference.

DOE incorporated by reference in §430.3 the entire standard for: IES LM–9–20, IES LM–54–20, IES LM–75–19, IES LM–78–20, and IES LM–79–19; however, only enumerated provisions of IES LM–9–20 and IES LM–79–19 are applicable to this appendix as follows:

0.1 IES LM–9–20 as referenced by section 3 of this appendix

(a) Section 4.0 ''Ambient and Physical Conditions''.

(b) Section 5.0 ''Electrical Conditions''.

(c) Section 6.0 ''Lamp Test Procedures''.

(d) Section 7.0 ''Photometric Test Procedures''.0.2 IES LM–79–19 as referenced by section 3 of this appendix

(a) Section 4.0 ''Physical and Environmental Test Conditions''.

(b) Section 5.0 ''Electrical Test Conditions''.

(c) Section 6.0 ''Test Preparation''.

(d) Section 7.0 ''Total Luminous Flux and Integrated Optical Measurements''.

1. SCOPE

This appendix establishes the test requirements to measure the energy efficiency of all ceiling fan light kits (CFLKs) packaged with fluorescent lamps other than compact fluorescent lamps (CFLs) or general service fluorescent lamps (GSFLs), packaged with consumer-replaceable solid-state lighting (SSL) (not integrated light-emitting diode [LED] lamps), packaged with non-consumer-replaceable SSL, or packaged with SSL lamps that have an American National Standards Institute (ANSI) standard base (not integrated LED lamps).

2. DEFINITIONS

2.1. *CFLK with non-consumer-replaceable SSL* means a CFLK with a non-ANSI-standard base that has an SSL light source, driver, heat sink, and intermediate circuitry (such as wiring between a driver and a light source) that are not consumer replaceable, *i.e.,* a consumer cannot replace the light source and all components necessary for the starting and stable operation of the light source, without permanently altering the product and must replace the entire CFLK upon failure. Permanently altering the product constitutes the cutting of wires, use of a soldering iron, or damage to or destruction of the CFLK and does not constitute connecting or disconnecting wire nuts, fasteners or screws, or preserving the CFLK as it was sold.

2.2. *CFLK with consumer-replaceable SSL* means a CFLK with a non-ANSI-standard base that has an SSL light source, driver, heat sink, and intermediate circuitry (such as wiring between a driver and light source) that are consumer replaceable, *i.e.,* a consumer can replace the light source and all components necessary for the starting and stable operation of the light source, without permanently altering the product. Permanently altering the product constitutes the cutting of wires, use of a soldering iron, or damage to or destruction of the CFLK and does not constitute connecting or disconnecting wire nuts, fasteners or screws, or preserving the CFLK as it was sold.

2.3. *Covers* means materials used to diffuse or redirect light produced by an SSL light source in CFLKs with non-consumer-replaceable SSL.

2.4. *Other (non-CFL and non-GSFL) fluorescent lamp* means a low-pressure mercury electric-discharge lamp in which a fluorescing coating transforms some of the ultraviolet energy generated by the mercury discharge into light, including but not limited to circline fluorescent lamps, and excluding any compact fluorescent lamp and any general service fluorescent lamp.

2.5. *Solid-State Lighting (SSL)* means technology where light is emitted from a solid object—a block of semiconductor—rather than from a filament or plasma, as in the case of incandescent and fluorescent lighting. This includes inorganic light-emitting diodes (LEDs) and organic light-emitting diodes (OLEDs).

3. TEST CONDITIONS AND MEASUREMENTS

For any CFLK that utilizes consumer replaceable lamps or consumer-replaceable SSL, measure the lamp efficacy of each basic

model of lamp or SSL light source packaged with the CFLK. For any CFLK only with non-consumer-replaceable SSL, measure the luminaire efficacy of the CFLK. For any CFLK that includes consumer replaceable lamps or consumer-replaceable SSL and non-consumer-replaceable SSL, measure both the lamp efficacy of each basic model of lamp or consumer-replaceable SSL light source packaged with the CFLK and the luminaire efficacy of the CFLK with all consumer replaceable lamps or consumer-replaceable SSL light sources removed. Take measurements at full light output. For each test, use the test procedures in the table in this section. CFLKs with non-consumer-replaceable SSL and consumer replaceable covers may be measured with their covers removed but must otherwise be measured according to the table in this section.

Lighting technology	Lamp or luminaire efficacy measured	Referenced test procedure
Other (non-CFL and non-GSFL) fluorescent lamps.	Lamp Efficacy	IES LM–9–20, sections 4–7 and corresponding subsections including references to IES LM–54–20 (lamp seasoning); IES–LM–78–20 (integrating sphere measurements).
CFLKs with consumer-replaceable SSL.	Lamp Efficacy	IES LM–79–19, sections 4–7 and corresponding subsections. Where IES LM–78–17 and IES LM–75–01/R12 are referenced in these sections and corresponding subsections, use IES LM–78–20 (integrating sphere measurements) and IES LM–75–19 (goniophotometer measurements) instead.
CFLKs with non-consumer-replaceable SSL.	Luminaire Efficacy	IES LM–79–19, sections 4–7 and corresponding subsections. Where IES LM–78–17 and IES LM–75–01/R12 are referenced in these sections and corresponding subsections, use IES LM–78–20 (integrating sphere measurements) and IES LM–75–19 (goniophotometer measurements) instead.
Other SSL lamps that have an ANSI standard base and are not integrated LED lamps.	Lamp Efficacy	IES LM–79–19, sections 4–7 and corresponding subsections. Where IES LM–78–17 and IES LM–75–01/R12 are referenced in these sections and corresponding, use IES LM–78–20 (integrating sphere measurements) and IES LM–75–19 (goniophotometer measurements) instead.

[88 FR 21073, Apr. 10, 2023]

APPENDIX W TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF COMPACT FLUORESCENT LAMPS

NOTE: Before February 27, 2017, any representations, including certifications of compliance, made with respect to the energy use or efficiency of medium base compact fluorescent lamps must be made in accordance with the results of testing pursuant either to this appendix, or to the applicable test requirements set forth in 10 CFR parts 429 and 430 as they appeared in the 10 CFR parts 200 to 499 annual edition revised as of January 1, 2016.

On or after February 27, 2017, any representations, including certifications of compliance (if required), made with respect to the energy use or efficiency of CFLs must be made in accordance with the results of testing pursuant to this appendix.

1. Scope:

1.1. Integrated compact fluorescent lamps.

1.1.1. This appendix specifies the test methods required to measure the initial lamp efficacy, lumen maintenance at 1,000 hours, lumen maintenance at 40 percent of lifetime, time to failure, power factor, correlated color temperature (CCT), color rendering index (CRI), and start time of an integrated compact fluorescent lamp.

1.1.2. This appendix describes how to conduct rapid cycle stress testing for integrated compact fluorescent lamps.

1.1.3. This appendix specifies test methods required to measure standby mode energy consumption applicable to integrated CFLs capable of operation in standby mode (as defined in §430.2), such as those that can be controlled wirelessly.

1.2. Non-integrated compact fluorescent lamps.

1.2.1. This appendix specifies the test methods required to measure the initial lamp efficacy, lumen maintenance at 40 percent of lifetime, time to failure, CCT, and CRI for non-integrated compact fluorescent lamps.

2. Definitions:

2.1. *Ballasted adapter* means a ballast that is not permanently attached to a compact fluorescent lamp, has no consumer-replaceable components, and serves as an adapter by incorporating both a lamp socket and a lamp base.

2.2. *Hybrid compact fluorescent lamp* means a compact fluorescent lamp that incorporates one or more supplemental light sources of different technology.

2.3. *Initial lamp efficacy* means the lamp efficacy (as defined in §430.2) at the end of the seasoning period, as calculated pursuant to section 3.2.2.9 of this appendix.

2.4. *Integrated compact fluorescent lamp* means an integrally ballasted compact fluorescent lamp that contains all components necessary for the starting and stable operation of the lamp, contains an ANSI standard base, does not include any replaceable or interchangeable parts, and is capable of being connected directly to a branch circuit through a corresponding ANSI standard lamp-holder (socket).

2.5. *Labeled wattage* means the highest wattage marked on the lamp and/or lamp packaging.

2.6. *Lumen maintenance* means the lumen output measured at a given time in the life of the lamp and expressed as a percentage of the measured initial lumen output.

2.7. *Measured initial input power* means the input power to the lamp, measured at the end of the lamp seasoning period, and expressed in watts (W).

2.8. *Measured initial lumen output* means the lumen output of the lamp measured at the end of the lamp seasoning period, expressed in lumens (lm).

2.9. *Non-integrated compact fluorescent lamp* means a compact fluorescent lamp that is not an integrated compact fluorescent lamp.

2.10. *Percent variability* means the result of dividing the difference between the maximum and minimum values by the average value for a contiguous set of separate time-averaged light output values spanning the specified time period. For a waveform of measured light output values, the time-averaged light output is computed over one full cycle of sinusoidal input voltage, as a moving average where the measurement interval is incremented by one sample for each successive measurement value.

2.11. *Power factor* means the measured input power (watts) divided by the product of the measured RMS input voltage (volts) and the measured RMS input current (amps).

2.12. *Rated input voltage* means the voltage(s) marked on the lamp as the intended operating voltage or, if not marked on the lamp, 120 V.

2.13. *Start plateau* means the first 100 millisecond period of operation during which the percent variability does not exceed 5 percent.

2.14. *Start time* means the time, measured in milliseconds, between the application of power to the compact fluorescent lamp and the beginning of the start plateau.

2.15. *Time to failure* means the time elapsed between first use and the point at which the compact fluorescent lamp (for a hybrid CFL, the primary light source) ceases to produce measurable lumen output.

3. Active Mode Test Procedures

3.1. General Instructions.

3.1.1. In cases where there is a conflict, the language of the test procedure in this appendix takes precedence over any materials incorporated by reference.

3.1.2. Maintain lamp operating orientation throughout seasoning and testing, including storage and handling between tests.

3.1.3. Season CFLs prior to photometric and electrical testing in accordance with sections 4, 5, 6.1, and 6.2.2.1 of IES LM–54–12 (incorporated by reference, see §430.3). Season the CFL for a minimum of 100 hours in accordance with section 6.2.2.1 of IES LM–54–12. During the 100 hour seasoning period, cycle the CFL (operate the lamps for 180 minutes, 20 minutes off) as specified in section 6.4 of IES LM–65–14 (incorporated by reference; see §430.3).

3.1.3.1. Unit operating time during seasoning may be counted toward time to failure, lumen maintenance at 40 percent of lifetime of a compact fluorescent lamp (as defined in §430.2), and lumen maintenance at 1,000 hours if the required operating cycle and test conditions for time to failure testing per section 3.3.1 of this appendix are satisfied.

3.1.3.2. If a lamp breaks, becomes defective, fails to stabilize, exhibits abnormal behavior (such as swirling), or stops producing light prior to the end of the seasoning period, the lamp must be replaced with a new unit. If a lamp exhibits one of the conditions listed in the previous sentence after the seasoning period, the lamp's measurements must be included in the sample. Record number of lamps replaced, if any.

3.1.4. Conduct all testing with the lamp operating at labeled wattage. This requirement applies to all CFLs, including those that are dimmable or multi-level.

3.1.5. Operate the CFL at the rated input voltage throughout testing. For a CFL with multiple rated input voltages including 120 volts, operate the CFL at 120 volts. If a CFL with multiple rated input voltages is not rated for 120 volts, operate the CFL at the highest rated input voltage.

3.1.6. Test CFLs packaged with ballasted adapters or designed exclusively for use with ballasted adapters as non-integrated CFLs, with no ballasted adapter in the circuit.

3.1.7. Conduct all testing of hybrid CFLs with all supplemental light sources in the lamp turned off, if possible. Before taking measurements, verify that the lamp has stabilized in the operating mode that corresponds to its primary light source.

3.2. Test Procedures for Determining Initial Lamp Efficacy, Lumen Maintenance, CCT, CRI, and Power Factor.

Determine initial lamp efficacy, lumen maintenance at 40 percent of lifetime of a compact fluorescent lamp (as defined in in §430.2), CCT, and CRI for integrated and non-

integrated CFLs. Determine lumen maintenance at 1,000 hours and power factor for integrated CFLs only.

3.2.1. Test Conditions and Setup

3.2.1.1. Test half of the units in the sample in the base up position, and half of the units in the base down position; if the position is restricted by the manufacturer, test the units in the manufacturer-specified position.

3.2.1.2. Establish ambient conditions, power supply, auxiliary equipment, circuit setup, lamp connections, and instrumentation in accordance with the specifications in sections (and corresponding subsections) 4.0, 5.0 and 6.0 of IES LM–66–14 (incorporated by reference; see §430.3), except maintain ambient temperature at 25 ± 1 °C (77 ± 1.8 °F).

3.2.1.3. Non-integrated CFLs must adhere to the reference ballast requirements in section 5.2 of IES LM–66 (incorporated by reference; see §430.3).

3.2.1.3.1. Test non-integrated lamps rated for operation on and having reference ballast characteristics for either low frequency or high frequency circuits (*e.g.,* many preheat start lamps) at low frequency.

3.2.1.3.2. For low frequency operation, test non-integrated lamps rated for operation on either preheat start (starter) or rapid start (no starter) circuits on preheat.

3.2.1.3.3. Operate non-integrated CFLs not listed in ANSI C78.901–2014 (incorporated by reference; see §430.3) using the following reference ballast settings:

3.2.1.3.3.1. Operate 25–28 W, T5 twin 2G11-based lamps that are lower wattage replacements of 40 W, T5 twin 2G11-based lamps using the following reference ballast settings: 60 Hz, 400 volts, 0.270 amps, and 1240 ohms.

3.2.1.3.3.2. Operate 14–15 W, T4 quad G24q-2-based lamps that are lower wattage replacements of 18 W, T4 quad G24q-2-based lamps using the following reference ballast settings: 60 Hz, 220 volts, 0.220 amps, and 815 ohms.

3.2.1.3.3.3. Operate 21 W, T4 quad G24q-3-based lamps that are lower wattage replacements of 26 W, T4 quad G24q-3-based lamps using the following reference ballast settings: 60 Hz, 220 volts, 0.315 amps, and 546 ohms.

3.2.1.3.3.4. Operate 21 W, T4 quad G24d-3-based lamps that are lower wattage replacements of 26 W, T4 quad G24d-3-based lamps using the following reference ballast settings: 60 Hz, 220 volts, 0.315 amps, and 546 ohms.

3.2.1.3.3.5. Operate 21 W, T4 multi (6) GX24q-3-based lamps that are lower wattage replacements of 26 W, T4 multi (6) GX24q-3-based lamps using the following reference ballast settings: 60 Hz, 220 volts, 0.315 amps, and 546 ohms.

3.2.1.3.3.6. Operate 27–28 W, T4 multi (6) GX24q-3-based lamps that are lower wattage replacements of 32 W, T4 multi (6) GX24q-3-based lamps using the following reference ballast settings: 20–26 kHz, 200 volts, 0.320 amps, and 315 ohms.

3.2.1.3.3.7. Operate 33–38 W, T4 multi (6) GX24q-4-based lamps that are lower wattage replacements of 42 W, T4 multi (6) GX24q-4-based lamps using the following reference ballast settings: 20–26 kHz, 270 volts, 0.320 amps, and 420 ohms.

3.2.1.3.3.8. Operate 10 W, T4 square GR10q-4-based lamps using the following reference ballast settings: 60 Hz, 236 volts, 0.165 amps, and 1,200 ohms.

3.2.1.3.3.9. Operate 16 W, T4 square GR10q-4-based lamps using the following reference ballast settings: 60 Hz, 220 volts, 0.195 amps, and 878 ohms.

3.2.1.3.3.10. Operate 21 W, T4 square GR10q-4-based lamps using the following reference ballast settings: 60 Hz, 220 volts, 0.260 amps, and 684 ohms.

3.2.1.3.3.11. Operate 28 W, T6 square GR10q-4-based lamps using the following reference ballast settings: 60 Hz, 236 volts, 0.320 amps, and 578 ohms.

3.2.1.3.3.12. Operate 38 W, T6 square GR10q-4-based lamps using the following reference ballast settings: 60 Hz, 236 volts, 0.430 amps, and 439 ohms.

3.2.1.3.3.13. Operate 55 W, T6 square GRY10q-3-based lamps using the following reference ballast settings: 60 Hz, 236 volts, 0.430 amps, and 439 ohms.

3.2.1.3.3.14. For all other lamp designs not listed in ANSI C78.901–2014 (incorporated by reference; see §430.3) or section 3.2.1.3.3 of this appendix:

3.2.1.3.3.14.1. If the lamp is a lower wattage replacement of a lamp with specifications in ANSI C78.901–2014, use the reference ballast characteristics of the corresponding higher wattage lamp replacement in ANSI C78.901–2014.

3.2.1.3.3.14.2. For all other lamps, use the reference ballast characteristics in ANSI C78.901–2014 for a lamp with the most similar shape, diameter, and base specifications, and next closest wattage.

3.2.2. Test Methods, Measurements, and Calculations

3.2.2.1. Season CFLs. (See section 3.1.3 of this appendix.)

3.2.2.2. Stabilize CFLs as specified in section 6.2.1 of IES LM–66 (incorporated by reference; see §430.3).

3.2.2.3. Measure the input power (in watts), the input voltage (in volts), and the input current (in amps) as specified in section 5.0 of IES LM–66 (incorporated by reference; see §430.3).

3.2.2.4. Measure initial lumen output as specified in section 6.3.1 of IES LM–66 (incorporated by reference; see §430.3) and in accordance with IESNA LM–78–07 (incorporated by reference; see §430.3).

3.2.2.5. Measure lumen output at 1,000 hours as specified in section 6.3.1 of IES LM–66 (incorporated by reference; see §430.3) and in accordance with IESNA LM–78–07 (incorporated by reference; see §430.3).

3.2.2.6. Measure lumen output at 40 percent of lifetime of a compact fluorescent lamp (as defined in 10 CFR 430.2) as specified in section 6.3.1 of IES LM–66 (incorporated by reference; see §430.3) and in accordance with IESNA LM–78–07 (incorporated by reference; see §430.3).

3.2.2.7. Determine CCT as specified in section 6.4 of IES LM–66 (incorporated by reference; see §430.3) and in accordance with CIE 15 (incorporated by reference; see §430.3).

3.2.2.8. Determine CRI as specified in section 6.4 of IES LM–66 (incorporated by reference; see §430.3) and in accordance with CIE 13.3 (incorporated by reference; see §430.3).

3.2.2.9. Determine initial lamp efficacy by dividing measured initial lumen output by the measured initial input power.

3.2.2.10. Determine lumen maintenance at 1,000 hours by dividing measured lumen output at 1,000 hours by the measured initial lumen output.

3.2.2.11. Determine lumen maintenance at 40 percent of lifetime of a compact fluorescent lamp (as defined in §430.2) by dividing measured lumen output at 40 percent of lifetime of a compact fluorescent lamp (as defined in §430.2) by the measured initial lumen output.

3.2.2.12. Determine power factor by dividing the measured input power (watts) by the product of measured RMS input voltage (volts) and measured RMS input current (amps).

3.3. Test Method for Time to Failure and Rapid Cycle Stress Test.

Determine time to failure for integrated and non-integrated CFLs. Conduct rapid cycle stress testing for integrated CFLs only. Disregard section 3.0 of IES LM–65–14.

3.3.1. Test Conditions and Setup

3.3.1.1. Test half of the units in the base up position and half of the units in the base down position; if the position is restricted by the manufacturer, test in the manufacturer-specified position.

3.3.1.2. Establish the ambient and physical conditions and electrical conditions in accordance with the specifications in sections 4.0 and 5.0 of IES LM–65–14 (incorporated by reference; see §430.3). Do not, however, test lamps in fixtures or luminaires.

3.3.1.3. Non-integrated CFLs must adhere to ballast requirements as specified in section 3.2.1.3 of this appendix.

3.3.2. Test Methods and Measurements

3.3.2.1. Season CFLs. (See section 3.1.3 of this appendix.)

3.3.2.2. Measure time to failure of CFLs as specified in section 6.0 of IES LM–65–14 (incorporated by reference; see §430.3).

3.3.2.3. Conduct rapid cycle stress testing of integrated CFLs as specified in section 6.0 of IES LM–65–14 (incorporated by reference; see §430.3), except cycle the lamp continuously with each cycle consisting of one 5-minute ON period followed by one 5-minute OFF period.

3.4. Test Method for Start Time.

Determine start time for integrated CFLs only.

3.4.1. Test Conditions and Setup

3.4.1.1. Test all units in the base up position; if the position is restricted by the manufacturer, test units in the manufacturer-specified position.

3.4.1.2. Establish the ambient conditions, power supply, auxiliary equipment, circuit setup, lamp connections, and instrumentation in accordance with the specifications in sections 4.0 and 5.0 of IES LM–66 (incorporated by reference; see §430.3), except maintain ambient temperature at 25 ± 1 °C (77 ± 1.8 °F).

3.4.2. Test Methods and Measurement

3.4.2.1. Season CFLs. (See section 3.1.3 of this appendix.)

3.4.2.2. After seasoning, store units at 25 ± 5 °C ambient temperature for a minimum of 16 hours prior to the test, after which the ambient temperature must be 25 ± 1 °C for a minimum of 2 hours immediately prior to the test. Any units that have been off for more than 24 hours must be operated for a minimum of 3.0 hours and then be turned off for 16 to 24 hours prior to testing.

3.4.2.3. Connect multichannel oscilloscope with data storage capability to record input voltage to CFL and light output. Set oscilloscope to trigger at 10 V lamp input voltage. Set oscilloscope vertical scale such that vertical resolution is 1 percent of measured initial light output or finer. Set oscilloscope to sample the light output waveform at a minimum rate of 2 kHz.

3.4.2.4. Operate the CFL at the rated voltage and frequency.

3.4.2.5. Upon the commencement of start time testing, record sampled light output until start plateau has been determined.

3.4.2.6. Calculate the time-averaged light output value at least once every millisecond where the time-averaged light output is computed over one full cycle of sinusoidal input voltage, as a moving average where the measurement interval is incremented by one sample for each successive measurement value.

3.4.2.7. Determine start time.

4. Standby Mode Test Procedure

Measure standby mode energy consumption for only integrated CFLs that are capable of operating in standby mode. The standby mode test method in this section may be completed before or after the active test method for determining lumen output, input power, CCT, CRI, and power factor in section 3 of this appendix. The standby mode test

method in this section must be completed before the active mode test method for determining time to failure in section 3.3 of this appendix. The standby mode test method must be completed in accordance with applicable provisions in section 3.1.

4.1. *Test Conditions and Setup*

4.1.1. Position half of the units in the sample in the base up position and half of the units in the base down position; if the position is restricted by the manufacturer, test units in the manufacturer-specified position.

4.1.2. Establish the ambient conditions (including air flow), power supply, electrical settings, and instrumentation in accordance with the specifications in sections 4.0, 5.0 and 6.0 of IES LM–66 (incorporated by reference; see §430.3), except maintain ambient temperature at 25 ± 1 °C (77 ± 1.8 °F).

4.2. *Test Methods, Measurements, and Calculations*

4.2.1. Season CFLs. (See section 3.1.3 of this appendix.)

4.2.2. Connect the integrated CFL to the manufacturer-specified wireless control network (if applicable) and configure the integrated CFL in standby mode by sending a signal to the integrated CFL instructing it to have zero light output. The integrated CFL must remain connected to the network throughout the entire duration of the test.

4.2.3. Stabilize the integrated CFL prior to measurement as specified in section 5 of IEC 62301–W (incorporated by reference; see §430.3).

4.2.4. Measure the standby mode energy consumption in watts as specified in section 5 of IEC 62301–W (incorporated by reference; see §430.3).

[81 FR 59418, Aug. 29, 2016]

APPENDIX X TO SUBPART B OF PART 430 [RESERVED]

APPENDIX X1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF DEHUMIDIFIERS

NOTE: After January 22, 2024, any representations made with respect to the energy efficiency of a dehumidifier must be made in accordance with the results of testing pursuant to this appendix. Manufacturers conducting tests of a dehumidifier prior to January 22, 2024, must conduct such test in accordance with either this appendix or the previous version of this appendix as it appeared in the Code of Federal Regulations on January 1, 2023. Any representations made with respect to the energy efficiency of such dehumidifier must be in accordance with whichever version is selected.

Any representations made on or after the compliance date of any amended energy conservation standards, with respect to the energy use or efficiency of portable or whole-home dehumidifiers, must be made in accordance with the results of testing pursuant to this appendix.

0. Incorporation by Reference

DOE incorporated by reference in §430.3, the entire standard for AHAM DH–1–2022, ANSI/AMCA 210, ANSI/ASHRAE 41.1, and IEC 62301; however, only enumerated provisions of those documents are applicable to this appendix. To the extent there is a conflict between the terms or provisions of a referenced industry standard and the CFR, the CFR provisions control.

0.1 AHAM DH–1–2022

(a) Section 3 ''Definitions'', as specified in sections 2 and 3.1.2 of this appendix.

(b) Section 4 ''Instrumentation'', as specified in sections 3.1.1 and 3.1.2 of this appendix.

(c) Section 5.1 ''General'', as specified in sections 3.1.1 and 3.1.2 of this appendix.

(d) Section 5.2 ''Test Room'', as specified in sections 3.1.1 and 3.1.2 of this appendix.

(e) Section 5.3 ''Positioning of Test Unit'', as specified in sections 3.1.1 and 3.1.1.2 of this appendix.

(f) Section 5.5 ''Control settings'', as specified in sections 3.1.1, 3.1.1.4, and 3.1.2 of this appendix.

(g) Section 7 ''Test Tolerances'', as specified in section 4.1.1 of this appendix.

(h) Section 8 ''Capacity Test'', as specified in sections 4.1.1 and 4.1.2 of this appendix.

(i) Section 8.3 ''Standard Test Voltage'', as specified in section 3.2.2.1 of this appendix.

(j) Section 8.4 ''Psychrometer Placement'', as specified in section 3.1.1.2 of this appendix.

(k) Section 9 ''Energy Consumption'', as specified in sections 4.1.1 and 4.1.2 of this appendix.

(l) Section 9.3.2 ''Inactive/Off Mode'', as specified in section 4.2 of this appendix.

(m) Section 9.3.1 ''Off-Cycle Mode'', as specified in section 4.3 of this appendix.

(n) Section 9.4 ''Calculation of Test Results'', as specified in section 4.1.2 of this appendix.

0.2 ANSI/AMCA 210

(a) Section 5.2.1.6 ''Airflow straightener'', as specified in section 3.1.2.1 of this appendix.

(b) Figure 6A ''Flow Straightener—Cell Type'', as specified in section 3.1.2.1 of this appendix.

(c) Section 4.2.2 ''Pitot-static tube'', as specified in section *3.1.2.2.3.1* of this appendix.

(d) Section 4.2.3 ''Static pressure tap'', as specified in section *3.1.2.2.3.1* of this appendix.

(e) Section 4.3.1 ''Pitot Traverse'', as specified in section *3.1.2.2.3.1* of this appendix.

(f) Section 4.3.2 ''Flow nozzle'', as specified in section *3.1.2.2.3.1* of this appendix.

(g) Section 7.5.2 ''Pressure Losses'', as specified in section *3.1.2.2.3.1* of this appendix.

(h) Section 7.3.1 ''Velocity Traverse'', as specified in section *3.1.2.2.3.2* of this appendix.

(i) Section 7.3.2 ''Nozzle'', as specified in section *3.1.2.2.3.2* of this appendix.

(j) Section 7.3 ''Fan airflow rate at test conditions'', as specified in section 5.6 of this appendix.

0.3 ANSI/ASHRAE 41.1

(a) Section 5.3.5 ''Centers of Segments—Grids'', as specified in section 3.1.2.2.1 of this appendix.

(b) [Reserved]

0.4 IEC 62301

(a) Section 5.2 ''Preparation of product'', as specified in section 3.2.1 of this appendix.

(b) Section 4.3.2 ''Supply voltage waveform'', as specified in section 3.2.2.2 of this appendix.

(c) Section 4.4 ''Power measuring instruments'', as specified in section 3.2.3 of this appendix.

(d) Section 4.2 ''Test room'', as specified in section 3.2.4 of this appendix.

1. SCOPE

This appendix covers the test requirements used to measure the energy performance of dehumidifiers.

2. Definitions

Definitions for terms, modes, calculations, etc. are in accordance with AHAM DH–1–2022, section 3, with the following added definitions:

Energy factor for dehumidifiers means a measure of energy efficiency of a dehumidifier calculated by dividing the water removed from the air by the energy consumed, measured in liters per kilowatt-hour (L/kWh).

External static pressure (ESP) means the process air outlet static pressure minus the process air inlet static pressure, measured in inches of water column (in. w.c.).

Process air means the air supplied to the dehumidifier from the dehumidified space and discharged to the dehumidified space after some of the moisture has been removed by means of the refrigeration system.

Product capacity for dehumidifiers means a measure of the ability of the dehumidifier to remove moisture from its surrounding atmosphere, measured in pints collected per 24 hours of operation under the specified ambient conditions.

Product case volume for whole-home dehumidifiers means a measure of the rectangular volume that the product case occupies, exclusive of any duct attachment collars or other external components.

Reactivation air means the air drawn from unconditioned space to remove moisture from the desiccant wheel of a refrigerant-desiccant dehumidifier and discharged to unconditioned space.

3. TEST APPARATUS AND GENERAL INSTRUCTIONS

3.1 *Active mode.*

3.1.1 *Portable dehumidifiers and whole-home dehumidifiers other than refrigerant-desiccant dehumidifiers.* The test apparatus and instructions for testing in dehumidification mode and off-cycle mode must conform to the requirements specified in Section 4, ''Instrumentation,'' section 5.1, ''General,'' section 5.2, ''Test Room,'' Section 5.3, ''Positioning of Test Unit,'' and section 5.5, ''Control settings'' of AHAM DH–1–2022, with the following exceptions. If a product is able to operate as either a portable or whole-home dehumidifier by means of removal or installation of an optional ducting kit, in accordance with any manufacturer instructions available to a consumer, test and rate both configurations.

3.1.1.1 *Testing configuration for whole-home dehumidifiers other than refrigerant-desiccant dehumidifiers.* Test dehumidifiers, other than refrigerant-desiccant dehumidifiers, with ducting attached to the process air outlet port. The duct configuration and component placement must conform to the requirements specified in section 3.1.3 of this appendix and Figure 1 or Figure 3, except that the flow straightener and dry-bulb temperature and relative humidity instruments are not required. Maintain the external static pressure in the process air flow and measure the external static pressure as specified in section 3.1.2.2.3.1 of this appendix.

3.1.1.2 *Instrumentation placement.* If using a sampling tree, follow the instrumentation placement instructions in sections 5.3 and 8.4 of AHAM DH–1–2022. If not using a sampling tree, place the aspirating psychrometer or relative humidity and dry-bulb temperature sensors perpendicular to, and 1 ft. in front of, the center of the process air intake grille. During each test, use the psychrometer or relative humidity and dry-bulb sensors to monitor inlet conditions of only one unit under test. When using relative humidity and dry-bulb temperature sensors without sampling trees to test a unit that has multiple process air intake grilles, place a relative humidity sensor and dry-bulb temperature sensor perpendicular to, and 1 ft. in front of, the center of each process air intake grille.

3.1.1.3 *Condensate collection.* If means are provided on the dehumidifier for draining condensate away from the cabinet, collect the condensate in a substantially closed vessel to prevent re-evaporation and place the

vessel on the weight-measuring instrument. If no means for draining condensate away from the cabinet are provided, disable any automatic shutoff of dehumidification mode operation that is activated when the collection container is full and collect any overflow in a pan. Select a collection pan large enough to ensure that all water that overflows from the full internal collection container during the rating test period is captured by the collection pan. Cover the pan as much as possible to prevent re-evaporation without impeding the collection of overflow water. Place both the dehumidifier and the overflow pan on the weight-measuring instrument for direct reading of the condensate weight collected during the rating test. Do not use any internal pump to drain the condensate into a substantially closed vessel unless such pump operation is provided for by default in dehumidification mode.

3.1.1.4 *Control settings.* Follow the control settings instructions in section 5.5 of AHAM DH–1–2022.

3.1.1.5 *Run-in period.* Perform a single run-in period during which the compressor operates for a cumulative total of at least 24 hours prior to dehumidification mode testing.

3.1.2 *Refrigerant-desiccant dehumidifiers.* The test apparatus and instructions for testing refrigerant-desiccant dehumidifiers in dehumidification mode must conform to the requirements specified in section 3, ''Definitions,'' section 4, ''Instrumentation,'' and section 5.1, ''General,'' section 5.2, ''Test Room,'' and section 5.5, ''Control settings,'' of AHAM DH–1–2022, except as follows.

3.1.2.1 *Testing configuration.* Test refrigerant-desiccant dehumidifiers with ducting attached to the process air inlet and outlet ports and the reactivation air inlet port. The duct configuration and components must conform to the requirements specified in section 3.1.3 of this appendix and Figure 1 through Figure 3. Install a cell-type airflow straightener that conforms to the specifications in Section 5.2.1.6, ''Airflow straightener'', and Figure 6A, ''Flow Straightener—Cell Type'', of ANSI/AMCA 210 (incorporated by reference, see §430.3) in each duct consistent with Figure 1 through Figure 3.

3.1.2.2 *Instrumentation.*

3.1.2.2.1 *Temperature.* Install dry-bulb temperature sensors in a grid centered in the duct, with the plane of the grid perpendicular to the axis of the duct. Determine the number and locations of the sensors within the grid according to Section 5.3.5, ''Centers of Segments—Grids,'' of ANSI/ASHRAE 41.1 (incorporated by reference, see §430.3).

3.1.2.2.2 *Relative humidity.* Measure relative humidity with a duct-mounted, relative humidity sensor with an accuracy within ±1 percent relative humidity. Place the relative humidity sensor at the duct centerline within 1 inch of the dry-bulb temperature grid plane.

3.1.2.2.3 *Pressure.* The pressure instruments used to measure the external static pressure and velocity pressures must have an accuracy within ±0.01 in. w.c. and a resolution of no more than 0.01 in. w.c.

3.1.2.2.3.1 External static pressure. Measure static pressures in each duct using pitot-static tube traverses, a flow nozzle or a bank of flow nozzles. For pitot-static tube traverses, conform to the specifications in section 4.3.1, ''Pitot Traverse,'' of ANSI/AMCA 210 and section 4.2.2, ''Pitot-Static Tube,'' of ANSI/AMCA 210, except use only two intersecting and perpendicular rows of pitot-static tube traverses. For a flow nozzle or bank of flow nozzles, conform to the specifications in section 4.3.2, ''Flow nozzle,'' of ANSI/AMCA 210 and section 4.2.3, ''Static pressure tap'' of ANSI/AMCA 210. Record the static pressure within the test duct as follows. When using pitot-static tube traverses, record the pressure as measured at the pressure tap in the manifold of the traverses that averages the individual static pressures at each pitot-static tube. When using a flow nozzle or bank of nozzles, record the pressure or in accordance with section 4.2.3.2, ''Averaging,'' of ANSI/AMCA 210. Calculate duct pressure losses between the unit under test and the plane of each static pressure measurement in accordance with section 7.5.2, ''Pressure Losses,'' of ANSI/AMCA 210. The external static pressure is the difference between the measured inlet and outlet static pressure measurements, minus the sum of the inlet and outlet duct pressure losses. For any port with no duct attached, use a static pressure of 0.00 in. w.c. with no duct pressure loss in the calculation of external static pressure. During dehumidification mode testing, the external static pressure must equal 0.20 in. w.c. ± 0.02 in. w.c.

3.1.2.2.3.2 Velocity pressure. Measure velocity pressures using the same pitot traverses or nozzles as used for measuring external static pressure, which are specified in section 3.1.2.2.3.1 of this appendix. When using pitot-static tube traverses, determine velocity pressures at each pitot-static tube in a traverse as the difference between the pressure at the impact pressure tap and the pressure at the static pressure tap and calculate volumetric flow rates in each duct in accordance with section 7.3.1, ''Velocity Traverse,'' of ANSI/AMCA 210. When using a flow nozzle or a bank of flow nozzles, calculate the volumetric flow rates in each duct in accordance with section 7.3.2, ''Nozzle,'' of ANSI/AMCA 210.

3.1.2.2.4 *Weight.* No weight-measuring instruments are required.

3.1.2.3 *Control settings.* Follow the control settings instructions in section 5.5 of AHAM DH–1–2022.

3.1.2.4 *Run-in period.* Perform a single run-in period during which the compressor operates for a cumulative total of at least 24 hours prior to dehumidification mode testing.

3.1.3 *Ducting for whole-home dehumidifiers.* Cover and seal with tape any port designed for intake of air from outside or unconditioned space, other than for supplying reactivation air for refrigerant-desiccant dehumidifiers. Use only ducting constructed of galvanized mild steel and with a 10-inch diameter. Position inlet and outlet ducts either horizontally or vertically to accommodate the default dehumidifier port orientation. Install all ducts with the axis of the section interfacing with the dehumidifier perpendicular to plane of the collar to which each is attached. If manufacturer-recommended collars do not measure 10 inches in diameter, use transitional pieces to connect the ducts to the collars. The transitional pieces must not contain any converging element that forms an angle with the duct axis greater than 7.5 degrees or a diverging element that forms an angle with the duct axis greater than 3.5 degrees. Install mechanical throttling devices in each outlet duct consistent with Figure 1 and Figure 3 to adjust the external static pressure and in the inlet reactivation air duct for a refrigerant-desiccant dehumidifier. Cover the ducts with thermal insulation having a minimum R value of 6 h-ft^2 − °F/Btu (1.1 m^2 − K/W). Seal seams and edges with tape.




Figure 1. Inlet and Outlet Horizontal Duct Configurations and Instrumentation Placement




Figure 2: Inlet Vertical Duct Configuration and Instrumentation Placement




Figure 3: Outlet Vertical Duct Configurations and Instrumentation Placement

3.1.4 *Recording and rounding.* When testing either a portable dehumidifier or a whole-home dehumidifier, record measurements at the resolution of the test instrumentation. Record measurements for portable dehumidifiers and whole-home dehumidifiers other than refrigerant-desiccant dehumidifiers at intervals no greater than 10 minutes. Record measurements for refrigerant-desiccant dehumidifiers at intervals no greater than 1 minute. Round off calculations to the same number of significant digits as the previous step. Round the final product capacity, energy factor and integrated energy factor values to two decimal places, and for whole-home dehumidifiers, round the final product case volume to one decimal place.

3.2 *Inactive mode and off mode.*

3.2.1 *Installation requirements.* For the inactive mode and off mode testing, install the dehumidifier in accordance with Section 5, Paragraph 5.2 of IEC 62301 (incorporated by reference, see §430.3), disregarding the provisions regarding batteries and the determination, classification, and testing of relevant modes.

3.2.2 *Electrical energy supply.*

3.2.2.1 *Electrical supply*. For the inactive mode and off mode testing, maintain the electrical supply voltage and frequency indicated in section 8.3, ''Standard Test Voltage,'' of AHAM DH–1–2022. The electrical supply frequency shall be maintained ±1 percent.

3.2.2.2 *Supply voltage waveform*. For the inactive mode and off mode testing, maintain the electrical supply voltage waveform indicated in Section 4, Paragraph 4.3.2 of IEC 62301 (incorporated by reference, see § 430.3).

3.2.3 *Inactive mode, off mode, and off-cycle mode wattmeter*. The wattmeter used to measure inactive mode, off mode, and off-cycle mode power consumption must meet the requirements specified in Section 4, Paragraph 4.4 of IEC 62301 (incorporated by reference, see § 430.3).

3.2.4 *Inactive mode and off mode ambient temperature*. For inactive mode and off mode testing, maintain room ambient air temperature conditions as specified in Section 4, Paragraph 4.2 of IEC 62301 (incorporated by reference, see § 430.3).

3.3 *Case dimensions for whole-home dehumidifiers*. Measure case dimensions using equipment with a resolution of no more than 0.1 in.

4. Test Measurement

4.1 *Dehumidification mode*.

4.1.1 *Portable dehumidifiers and whole-home dehumidifiers other than refrigerant-desiccant dehumidifiers*. Measure the energy consumption in dehumidification mode, EDM, in kilowatt-hours (kWh), the average percent relative humidity, Ht, either as measured using a relative humidity sensor or using Tables 2 and 3 when using an aspirating psychrometer, and the product capacity, Ct, in pints per day (pints/day), in accordance with the test requirements specified in section 7, ''Test Tolerances,'' section 8, ''Capacity Test,'' and section 9, ''Energy Consumption,'' of AHAM DH–1–2022, with two exceptions. First, the rating test period must be 2 hours. Second, maintain the standard test conditions as shown in Table 1.

Table 1 to Paragraph 4.1.1.—Standard Test Conditions for Dehumidifier Testing

Configuration	Dry-bulb temperature (°F)	Aspirating psychrometer wet-bulb temperature (°F)	Relative humidity sensor relative humidity (%)
Portable dehumidifiers	65 ± 2.0	56.6 ± 1.0	60 ± 2
Whole-home dehumidifiers	73 ± 2.0	63.6 ± 1.0	60 ± 2

When using relative humidity and dry-bulb temperature sensors, for dehumidifiers with multiple process air intake grilles, average the measured relative humidities and average the measured dry-bulb temperatures to determine the overall intake air conditions.

Table 2 to Paragraph 4.1.1.—Relative Humidity as a Function of Dry-Bulb and Wet-Bulb Temperatures for Portable Dehumidifiers

Wet-bulb temperature (°F)	Dry-bulb temperature (°F)										
	64.5	64.6	64.7	64.8	64.9	65	65.1	65.2	65.3	65.4	65.5
56.3	60.32	59.94	59.57	59.17	58.8	58.42	58.04	57.67	57.3	56.93	56.56
56.4	60.77	60.38	60	59.62	59.24	58.86	58.48	58.11	57.73	57.36	56.99
56.5	61.22	60.83	60.44	60.06	59.68	59.3	58.92	58.54	58.17	57.8	57.43
56.6	61.66	61.27	60.89	60.5	60.12	59.74	59.36	58.98	58.6	58.23	57.86
56.7	62.4	61.72	61.33	60.95	60.56	60.18	59.8	59.42	59.04	58.67	58.29
56.8	62.56	62.17	61.78	61.39	61	60.62	60.24	59.86	59.48	59.1	58.73
56.9	63.01	62.62	62.23	61.84	61.45	61.06	60.68	60.3	59.92	59.54	59.16

Table 3 to Paragraph 4.1.1.—Relative Humidity as a Function of Dry-Bulb and Wet-Bulb Temperatures for Whole-Home Dehumidifiers

Wet-bulb temperature (°F)	Dry-bulb temperature (°F)										
	72.5	72.6	72.7	72.8	72.9	73	73.1	73.2	73.3	73.4	73.5
63.3	60.59	60.26	59.92	59.59	59.26	58.92	58.6	58.27	57.94	57.62	57.3
63.4	60.98	60.64	60.31	59.75	59.64	59.31	58.98	58.65	58.32	58	57.67
63.5	61.37	61.03	60.7	60.36	60.02	59.69	59.36	59.03	58.7	58.38	58.05
63.6	61.76	61.42	61.08	60.75	60.41	60.08	59.74	59.41	59.08	58.76	58.43
63.7	62.16	61.81	61.47	61.13	60.8	60.46	60.13	59.8	59.47	59.14	58.81
63.8	62.55	62.2	61.86	61.52	61.18	60.85	60.51	60.18	59.85	59.52	59.19

TABLE 3 TO PARAGRAPH 4.1.1.—RELATIVE HUMIDITY AS A FUNCTION OF DRY-BULB AND WET-BULB TEMPERATURES FOR WHOLE-HOME DEHUMIDIFIERS—Continued

Wet-bulb temperature (°F)	Dry-bulb temperature (°F)										
	72.5	72.6	72.7	72.8	72.9	73	73.1	73.2	73.3	73.4	73.5
63.9	62.94	62.6	62.25	61.91	61.57	61.23	60.9	60.56	60.23	59.9	59.57

4.1.2 *Refrigerant-desiccant dehumidifiers.* Establish the testing conditions set forth in section 3.1.2 of this appendix. Measure the energy consumption, EDM, in kWh, in accordance with the test requirements specified in section 8, ''Capacity Test,'' and section 9, ''Energy Consumption,'' respectively, of AHAM DH–1–2022, with the following exceptions and adjustments:

(a) Each measurement of the temperature and relative humidity of the air entering the process air inlet duct and the reactivation air inlet must be within 73 °F ± 2.0 °F dry-bulb temperature and 60 percent ± 5 percent relative humidity, and the arithmetic average of the inlet test conditions over the test period shall be within 73 °F ± 0.5 °F dry-bulb temperature and 60 percent ± 2 percent relative humidity;

(b) Disregard the instructions for psychrometer placement;

(c) Record dry-bulb temperatures, relative humidities, static pressures, velocity pressures in each duct, volumetric air flow rates, and the number of measurements in the test period;

(d) Disregard the requirement to weigh the condensate collected during the test;

(e) The rating test period must be 2 hours; and

(f) To perform the calculations in section 9.4, ''Calculation of Test Results,'' of AHAM DH–1–2022:

(i) Replace ''Condensate collected (lb)'' and ''mlb'', with the weight of condensate removed, W, as calculated in section 5.6 of this appendix; and

(ii) Use the recorded relative humidities, not the tables in section 4.1.1 of this appendix, to determine average relative humidity.

4.2 *Off-cycle mode.* Follow requirements for test measurement in off-cycle mode of operation in accordance with section 9.3.2 of AHAM DH–1–2022.

4.3 *Inactive and off mode.* Follow requirements for test measurement in inactive and off modes of operation in accordance with section 9.3.1 of AHAM DH–1–2022.

4.4 *Product case volume for whole-home dehumidifiers.* Measure the maximum case length, D_L, in inches, the maximum case width, D_W, in inches, and the maximum height, D_H, in inches, exclusive of any duct collar attachments or other external components.

5. CALCULATION OF DERIVED RESULTS FROM TEST MEASUREMENTS

5.1 *Corrected relative humidity.* Calculate the average relative humidity, for portable and whole-home dehumidifiers, corrected for barometric pressure variations as:

$$H_{c,p} = H_t \times [1 + 0.0083 \times (29.921 - B)]$$
$$H_{c,wh} = H_t \times [1 + 0.0072 \times (29.921 - B)]$$

Where:

$H_{c,p}$ = portable dehumidifier average relative humidity from the test data in percent, corrected to the standard barometric pressure of 29.921 in. mercury (Hg);

$H_{c,wh}$ = whole-home dehumidifier average relative humidity from the test data in percent, corrected to the standard barometric pressure of 29.921 in. Hg;

H_t = average relative humidity from the test data in percent; and

B = average barometric pressure during the test period in in. Hg.

5.2 *Corrected product capacity.* Calculate the product capacity, for portable and whole-home dehumidifiers, corrected for variations in temperature and relative humidity as:

$$C_{r,p} = C_t + 0.0352 \times C_t \times (65 - T_t) + 0.0169 \times C_t \times (60 - H_{C,p})$$
$$C_{r,wh} = C_t + 0.0344 \times C_t \times (73 - T_t) + 0.017 \times C_t \times (60 - H_{C,wh})$$

Where:

$C_{r,p}$ = portable dehumidifiers product capacity in pints/day, corrected to standard rating conditions of 65 °F dry-bulb temperature and 60 percent relative humidity;

$C_{r,wh}$ = whole-home dehumidifier product capacity in pints/day, corrected to standard rating conditions of 73 °F dry-bulb temperature and 60 percent relative humidity;

C_t = product capacity determined from test data in pints/day, as measured in section 4.1.1 of this appendix for portable and refrigerant-only whole-home dehumidifiers or calculated in section 5.6 of this appendix for refrigerant-desiccant whole-home dehumidifiers;

T_t = average dry-bulb temperature during the test period in °F;

$H_{C,p}$ = portable dehumidifier corrected relative humidity in percent, as determined in section 5.1 of this appendix; and

$H_{C,wh}$ = whole-home dehumidifier corrected relative humidity in percent, as determined in section 5.1 of this appendix.

5.3 *Annual combined low-power mode energy consumption*. Calculate the annual combined low-power mode energy consumption for dehumidifiers, E_{TLP}, expressed in kWh per year:

$E_{TLP} = [(P_{IO} \times S_{IO}) + (P_{OC} \times S_{OC})] \times K$

Where:

$P_{IO} = P_{IA}$, dehumidifier inactive mode power, or P_{OM}, dehumidifier off mode power in watts, as measured in section 4.3 of this appendix;

P_{OC} = dehumidifier off-cycle mode power in watts, as measured in section 4.2 of this appendix;

S_{IO} = 1,840.5 dehumidifier inactive mode or off mode annual hours;

S_{OC} = 1,840.5 dehumidifier off-cycle mode annual hours; and

K = 0.001 kWh/Wh conversion factor for watt-hours to kWh.

5.4 *Integrated energy factor*. Calculate the integrated energy factor, IEF, in L/kWh, rounded to two decimal places, according to the following:

$$IEF = \frac{\left(C_r \times \frac{2 \times 1.04}{24}\right) \times 0.454}{\left[E_{DM} + \left(\left(\frac{E_{TLP}}{1095}\right) \times 2\right)\right]}$$

Where:

C_r = corrected product capacity in pints per day, as determined in section 5.2 of this appendix;

2 = dehumidification mode test duration in hours;

E_{DM} = energy consumption during the 2-hour dehumidification mode test in kWh, as measured in section 4.1 of this appendix;

E_{TLP} = annual combined low-power mode energy consumption in kWh per year, as calculated in section 5.3 of this appendix;

1,095 = dehumidification mode annual hours, used to convert E_{TLP} to combined low-power mode energy consumption per hour of dehumidification mode;

1.04 = the density of water in pounds per pint;

0.454 = the liters of water per pound of water; and

24 = the number of hours per day.

5.5 *Absolute humidity for refrigerant-desiccant dehumidifiers*. Calculate the absolute humidity of the air entering and leaving the refrigerant-desiccant dehumidifier in the process air stream, expressed in pounds of water per cubic foot of air, according to the following set of equations.

5.5.1 Temperature in Kelvin. The air dry-bulb temperature, in Kelvin, is:

$$T_K = \left(\frac{5}{9}(T_F - 32)\right) - 273.15$$

Where:

T_F = the measured dry-bulb temperature of the air in °F.

5.5.2 Water saturation pressure. The water saturation pressure, expressed in kilopascals (kPa), is:

$$P_{ws} = e^{\left(-\left(\frac{5.8\times10^3}{T_K}\right)-5.516-\left(4.864\times10^{-2}T_K\right)+\left(4.176\times10^{-5}{T_K}^2\right)-\left(1.445\times10^{-8}{T_K}^3\right)+6.546\,ln(T_K)\right)}$$

Where:

T_K = the calculated dry-bulb temperature of the air in K, calculated in section 5.5.1 of this appendix.

5.5.3 Vapor pressure. The water vapor pressure, expressed in kilopascals (kPa), is:

$$P_w = \frac{RH \times P_{ws}}{100}$$

Where:

RH = percent relative humidity during the rating test period; and

P_{ws} = water vapor saturation pressure in kPa, calculated in section 5.5.2 of this appendix.

5.5.4 Mixing humidity ratio. The mixing humidity ratio, the mass of water per mass of dry air, is:

$$HR = \frac{0.62198 \times P_w}{(P \times 3.386) - P_w}$$

Where:

P_w = water vapor pressure in kPa, calculated in section 5.5.3 of this appendix;

P = measured ambient barometric pressure in in. Hg;

3.386 = the conversion factor from in. Hg to kPa; and

0.62198 = the ratio of the molecular weight of water to the molecular weight of dry air.

5.5.5 Specific volume. The specific volume, expressed in feet cubed per pounds of dry air, is:

$$\nu = \left(\frac{0.287055 \times T_K}{(P \times 3.386) - P_w}\right) \times 16.016$$

Where:

T_K = dry-bulb temperature of the air in K, as calculated in section 5.5.1 of this appendix;

P = measured ambient barometric pressure in in. Hg;

P_w = water vapor pressure in kPa, calculated in section 5.5.3 of this appendix;

0.287055 = the specific gas constant for dry air in kPa times cubic meter per kg per K;

3.386 = the conversion factor from in. Hg to kPa; and

16.016 = the conversion factor from cubic meters per kilogram to cubic feet per pound.

5.5.6 Absolute humidity. The absolute humidity, expressed in pounds of water per cubic foot of air, is:

$$AH = \frac{HR}{\nu}$$

Where:

HR = the mixing humidity ratio, the mass of water per mass of dry air, as calculated in section 5.5.4 of this appendix; and

ν = the specific volume in cubic feet per pound of dry air, as calculated in section 5.5.5 of this appendix.

5.6 *Product capacity for refrigerant-desiccant dehumidifiers.* The weight of water removed during the test period, W, expressed in pounds is:

$$W=\sum_{i=1}^{n}\left(\left(AH_{I,i}\times X_{I,i}\right)-\left(AH_{O,i}\times X_{O,i}\right)\right)\times\frac{t}{60}$$

Where:

n = number of samples during the test period in section 4.1.1.2 of this appendix;

$AH_{I,i}$ = absolute humidity of the process air on the inlet side of the unit in pounds of water per cubic foot of dry air, as calculated for sample *i* in section 5.5.6 of this appendix;

$X_{I,i}$ = volumetric flow rate of the process air on the inlet side of the unit in cubic feet per minute, measured for sample *i* in section 4.1.1.2 of this appendix. Calculate the volumetric flow rate in accordance with Section 7.3, ''Fan airflow rate at test conditions,'' of ANSI/AMCA 210 (incorporated by reference, see §430.3);

$AH_{O,i}$ = absolute humidity of the process air on the outlet side of the unit in pounds of water per cubic foot of dry air, as calculated for sample *i* in section 5.5.6 of this appendix;

$X_{O,i}$ = volumetric flow rate of the process air on the outlet side of the unit in cubic feet per minute, measured for sample *i* in section 4.1.1.2 of this appendix. Calculate the volumetric flow rate in accordance with Section 7.3, ''Fan airflow rate at test conditions,'' of ANSI/AMCA 210 (incorporated by reference, see §430.3);

t = time interval in seconds between samples, with a maximum of 60; and

60 = conversion from minutes to seconds.

The capacity, C_t, expressed in pints/day, is:

$$C_t=\frac{W\times 24}{1.04\times T}$$

Where:

24 = number of hours per day;

1.04 = density of water in pounds per pint; and

T = total test period time in hours.

Then correct the product capacity, $C_{r,wh}$, according to section 5.2 of this appendix.

5.7 *Product case volume for whole-home dehumidifiers.* The product case volume, V, in cubic feet, is:

$$V=\frac{D_L\times D_W\times D_H}{1728}$$

Where:

D_L = product case length in inches, measured in section 4.4 of this appendix;

D_W = product case width in inches, measured in section 4.4 of this appendix;

D_H = product case height in inches, measured in section 4.4 of this appendix; and

1,728 = conversion from cubic inches to cubic feet.

[80 FR 45826, July 31, 2015, as amended at 88 FR 48052, July 26, 2023]

APPENDIX Y TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF BATTERY CHARGERS

NOTE 1: For all Battery Chargers, including UPSs, compliance with the relevant standard in §430.32(z) or any representation must be based upon results generated under the corresponding appendix listed in the following table:

	Battery chargers other than UPSs	UPS
On or After July 3, 2024 and Before October 16, 2024	Use appendix Y as it appeared on either March 7, 2023, or July 3, 2024.	Use appendix Y as it appeared on either March 7, 2023, or July 3, 2024

	Battery chargers other than UPSs	UPS
On or After October 16, 2024 and Before compliance date of any new or amended standards published any time after September 2022.	Use appendix Y as it appeared on July 3, 2024..	Use appendix Y as it appeared on July 3, 2024.
On or After compliance date of any new or amended standards published any time after September 2022.	Use appendix Y1	Use appendix Y1.

For any amended standards for battery chargers published after September 8, 2022, manufacturers must use the results of testing under appendix Y1 to determine compliance. Representations related to energy consumption must be made in accordance with the appropriate appendix that applies (*i.e.*, appendix Y or appendix Y1) when determining compliance with the relevant standard. Manufacturers may also use appendix Y1 to certify compliance with amended standards, published after September 8, 2022, prior to the applicable compliance date for those standards.

0. INCORPORATION BY REFERENCE

DOE incorporated by reference in §430.3 the entire test standard for IEC 62040–3 Ed. 3.0. However, only enumerated provisions of this standard are applicable to this appendix, as follows. In cases in which there is a conflict, the language of the test procedure in this appendix takes precedence over the referenced test standard.

0.1 IEC 62040–3 Ed. 3.0:

(a) Section 3.5, Specified values;

(b) Section 3.5.49, total harmonic distortion;

(c) Section 5, Electrical conditions, performance and declared values;

(d) Section 5.2, UPS input specification, as specified in section 2.28.2 of this appendix;

(e) Section 5.2.1, Conditions for normal mode of operation; Clause 5.2.1.a;

(f) Clause 5.2.1.b;

(g) Section 5.2.2, Conditions to be declared by the manufacturer; Clause 5.2.2.k;

(h) Clause 5.2.2.l;

(i) Clause 5.2.2.m;

(j) Section 5.3, UPS output specification; Section 5.3.2, Characteristics to be declared by the manufacturer; Clause 5.3.2.b;

(k) Clause 5.3.2.c;

(l) Clause 5.3.2.d;

(m) Clause 5.3.2.e;

(n) Section 5.3.4.2, Input dependency AAA;

(o) Section 6.2, Routine test procedure; Section 6.2.2, Electrical; Section 6.2.2.4, No load, as specified in section 4.3.3(c) of this appendix;

(p) Section 6.2.2.7, AC input failure, as specified in Note to section 2.28.1 of this appendix;

(q) Section 6.4, Type test procedure (electrical); Section 6.4.1, Input—AC input power compatibility; Section 6.4.1.2, Steady state input voltage tolerance and VI input independency, as specified in Note to section 2.28.3 of this appendix;

(r) Section 6.4.1.3, Combined input voltage/frequency tolerance and VFI input independency, as specified in Note to section 2.28.2 of this appendix;

(s) Annex G—AC input power failure—Test method;

(t) Annex J—UPS efficiency and no load losses—Methods of measurement, as specified in sections 4.2.1 and 4.3.3 of this appendix.

0.2 [RESERVED]

1. SCOPE

This appendix provides the test requirements used to measure the energy consumption of battery chargers operating at either DC or United States AC line voltage (115V at 60Hz). This appendix also provides the test requirements used to measure the energy efficiency of uninterruptible power supplies as defined in section 2 of this appendix that utilize the standardized National Electrical Manufacturer Association (NEMA) plug, 1–15P or 5–15P, as specified in ANSI/NEMA WD 6–2016 (incorporated by reference, see §430.3) and have an AC output. This appendix does not provide a method for testing back-up battery chargers.

2. DEFINITIONS

The following definitions are for the purposes of explaining the terminology associated with the test method for measuring battery charger energy consumption.[1]

2.1. *Active mode* or *charge mode* is the state in which the battery charger system is connected to the main electricity supply, and the battery charger is delivering current, equalizing the cells, and performing other one-time or limited-time functions in order to bring the battery to a fully charged state.

2.2. *Active power* or *real power* (P) means the average power consumed by a unit. For a two terminal device with current and voltage waveforms i(t) and v(t), which are periodic with period T, the real or active power P is:

[1] For clarity on any other terminology used in the test method, please refer to IEEE Standard 1515–2000.

$$P = \frac{1}{T}\int_0^T v(t)i(t)dt$$

2.3. *Ambient temperature* is the temperature of the ambient air immediately surrounding the unit under test.

2.4. *Apparent power* (S) is the product of root-mean-square (RMS) voltage and RMS current in volt-amperes (VA).

2.5. *Batch charger* is a battery charger that charges two or more identical batteries simultaneously in a series, parallel, series-parallel, or parallel-series configuration. A batch charger does not have separate voltage or current regulation, nor does it have any separate indicators for each battery in the batch. When testing a batch charger, the term ''battery'' is understood to mean, collectively, all the batteries in the batch that are charged together. A charger can be both a batch charger and a multi-port charger or multi-voltage charger.

2.6. *Battery* or *battery pack* is an assembly of one or more rechargeable cells and any integral protective circuitry intended to provide electrical energy to a consumer product, and may be in one of the following forms: (a) Detachable battery (a battery that is contained in a separate enclosure from the consumer product and is intended to be removed or disconnected from the consumer product for recharging); or (b) integral battery (a battery that is contained within the consumer product and is not removed from the consumer product for charging purposes). The word ''intended'' in this context refers to the whether a battery has been designed in such a way as to permit its removal or disconnection from its associated consumer product.

2.7. *Battery energy* is the energy, in watt-hours, delivered by the battery under the specified discharge conditions in the test procedure.

2.8. *Battery maintenance mode* or *maintenance mode* is the mode of operation when the battery charger is connected to the main electricity supply and the battery is fully charged, but is still connected to the charger.

2.9. *Battery rest period* is a period of time between discharge and charge or between charge and discharge, during which the battery is resting in an open-circuit state in ambient air.

2.10. *C-Rate (C)* is the rate of charge or discharge, calculated by dividing the charge or discharge current by the nameplate battery charge capacity of the battery. For example, a 0.2 C-rate would result in a charge or discharge period of 5 hours.

2.11. *Cradle* is an electrical interface between an integral battery product and the rest of the battery charger designed to hold the product between uses.

2.12. *Energy storage system* is a system consisting of single or multiple devices designed to provide power to the UPS inverter circuitry.

2.13. *Equalization* is a process whereby a battery is overcharged, beyond what would be considered ''normal'' charge return, so that cells can be balanced, electrolyte mixed, and plate sulfation removed.

2.14. *Instructions* or *manufacturer's instructions* means the documentation packaged with a product in printed or electronic form and any information about the product listed on a Web site maintained by the manufacturer and accessible by the general public at the time of the test. It also includes any information on the packaging or on the product itself. ''Instructions'' also includes any service manuals or data sheets that the manufacturer offers to independent service technicians, whether printed or in electronic form.

2.15. *Measured charge capacity* of a battery is the product of the discharge current in amperes and the time in decimal hours required to reach the specified end-of-discharge voltage.

2.16. *Manual on-off switch* is a switch activated by the user to control power reaching the battery charger. This term does not apply to any mechanical, optical, or electronic switches that automatically disconnect mains power from the battery charger when a battery is removed from a cradle or charging base, or for products with non-detachable batteries that control power to the product itself.

2.17. *Multi-port charger* means a battery charger that charges two or more batteries (which may be identical or different) simultaneously. The batteries are not connected in series or in parallel but with each port having separate voltage and/or current regulation. If the charger has status indicators, each port has its own indicator(s). A charger can be both a batch charger and a multi-port charger if it is capable of charging two or more batches of batteries simultaneously and each batch has separate regulation and/or indicator(s).

2.18. *Multi-voltage charger* is a battery charger that, by design, can charge a variety of batteries (or batches of batteries, if also a batch charger) that are of different nameplate battery voltages. A multi-voltage charger can also be a multi-port charger if it can charge two or more batteries simultaneously with independent voltages and/or current regulation.

2.19. *Normal mode* is a mode of operation for a UPS in which:

(1) The AC input supply is within required tolerances and supplies the UPS,

(2) The energy storage system is being maintained at full charge or is under recharge, and

(3) The load connected to the UPS is within the UPS's specified power rating.

2.20. *Off mode* is the condition, applicable only to units with manual on-off switches, in which the battery charger:

(1) Is connected to the main electricity supply;

(2) Is not connected to the battery; and

(3) All manual on-off switches are turned off.

2.21. *Nameplate battery voltage* is specified by the battery manufacturer and typically printed on the label of the battery itself. If there are multiple batteries that are connected in series, the nameplate battery voltage of the batteries is the total voltage of the series configuration—that is, the nameplate voltage of each battery multiplied by the number of batteries connected in series. Connecting multiple batteries in parallel does not affect the nameplate battery voltage.

2.22. *Nameplate battery charge capacity* is the capacity, claimed by the battery manufacturer on a label or in instructions, that the battery can store, usually given in ampere-hours (Ah) or milliampere-hours (mAh) and typically printed on the label of the battery itself. If there are multiple batteries that are connected in parallel, the nameplate battery charge capacity of the batteries is the total charge capacity of the parallel configuration, that is, the nameplate charge capacity of each battery multiplied by the number of batteries connected in parallel. Connecting multiple batteries in series does not affect the nameplate charge capacity.

2.23. *Nameplate battery energy capacity* means the product (in watts-hours (Wh)) of the nameplate battery voltage and the nameplate battery charge capacity.

2.24. *Reference test load* is a load or a condition with a power factor of greater than 0.99 in which the AC output socket of the UPS delivers the active power (W) for which the UPS is rated.

2.25. *Standby mode* or *no-battery mode* means the condition in which:

(1) The battery charger is connected to the main electricity supply;

(2) The battery is not connected to the charger; and

(3) For battery chargers with manual on-off switches, all such switches are turned on.

2.26. *Total harmonic distortion (THD),* expressed as a percent, is as defined in section 3.5.9 of IEC 62040–3 Ed. 3.0.

2.27. *Uninterruptible power supply or UPS* means a battery charger consisting of a combination of convertors, switches and energy storage devices (such as batteries), constituting a power system for maintaining continuity of load power in case of AC input power failure.

2.27.1. *Voltage and frequency dependent UPS or VFD UPS* means a UPS that protects the load from a complete loss of AC input power. The output of a VFD UPS is dependent on changes in voltage and frequency of the AC input power and is not intended to provide additional voltage corrective functions, such as those arising from the use of tapped transformers.

NOTE TO 2.27.1: VFD input dependency may be verified by performing the AC input failure test in section 6.2.2.7 of IEC 62040–3 Ed. 3.0 and observing that, at a minimum, the UPS switches from normal mode of operation to battery power while the input is interrupted.

2.27.2. *Voltage and frequency independent UPS or VFI UPS* means a UPS that is independent of AC input power voltage and frequency variations as specified and declared in section 5.2 of IEC 62040–3 Ed. 3.0 and shall protect the load against adverse effects from such variations without discharging the energy storage device.

NOTE TO 2.27.2: VFI input dependency may be verified by performing the combined input voltage/frequency tolerance and VFI input independency test in section 6.4.1.3 of IEC 62040–3 Ed. 3.0 respectively and observing that, at a minimum, the UPS produces an output voltage and frequency within the specified output range when the input voltage is varied by ±10% of the rated input voltage and the input frequency is varied by ±2% of the rated input frequency.

2.27.3. *Voltage independent UPS or VI UPS* means a UPS that protects the load as required for VFD and also from (a) under-voltage applied continuously to the input, and (b) over-voltage applied continuously to the input. The output voltage of a VI UPS shall remain within declared voltage limits (provided by voltage corrective functions, such as those arising from the use of active and/or passive circuits). The output voltage tolerance band shall be narrower than the input voltage tolerance band.

NOTE TO 2.27.3: VI input dependency may be verified by performing the steady state input voltage tolerance test in section 6.4.1.2 of IEC 62040–3 Ed. 3.0 and ensuring that the UPS remains in normal mode with the output voltage within the specified output range when the input voltage is varied by ±10% of the rated input voltage.

2.28. *Unit under test* (UUT) in this appendix refers to the combination of the battery charger and battery being tested.

3. Testing Requirements for all Battery Chargers Other Than Uninterruptible Power Supplies

3.1. Standard Test Conditions

3.1.1 General

The values that may be measured or calculated during the conduct of this test procedure have been summarized for easy reference in Table 3.1.1. of this appendix.

TABLE 3.1.1—LIST OF MEASURED OR CALCULATED VALUES

Name of measured or calculated value	Reference
1. Duration of the charge and maintenance mode test.	Section 3.3.2.
2. Battery Discharge Energy	Section 3.3.8.
3. Initial time and power (W) of the input current of connected battery.	Section 3.3.6.
4. Active and Maintenance Mode Energy Consumption.	Section 3.3.6.
5. Maintenance Mode Power	Section 3.3.9.
6. 24 Hour Energy Consumption	Section 3.3.10.
7. Standby Mode Power	Section 3.3.11.
8. Off Mode Power	Section 3.3.12.
9. Unit Energy Consumption, UEC (kWh/yr).	Section 3.3.13.

3.1.2. Verifying Accuracy and Precision of Measuring Equipment

Any power measurement equipment utilized for testing must conform to the uncertainty and resolution requirements outlined in section 4, ''General conditions for measurement'', as well as annexes B, ''Notes on the measurement of low power modes'', and D, ''Determination of uncertainty of measurement'', of IEC 62301 (incorporated by reference, see §430.3).

3.1.3. Setting Up the Test Room

All tests, battery conditioning, and battery rest periods shall be carried out in a room with an air speed immediately surrounding the UUT of ≤0.5 m/s. The ambient temperature shall be maintained at 20 °C ± 5 °C throughout the test. There shall be no intentional cooling of the UUT such as by use of separately powered fans, air conditioners, or heat sinks. The UUT shall be conditioned, rested, and tested on a thermally non-conductive surface. When not undergoing active testing, batteries shall be stored at 20 °C ± 5 °C.

3.1.4. Verifying the UUT's Input Voltage and Input Frequency

(a) If the UUT is intended for operation on AC line-voltage input in the United States, it shall be tested at 115 V at 60 Hz. If the UUT is intended for operation on AC line-voltage input but cannot be operated at 115 V at 60 Hz, it shall not be tested.

(b) If a charger is powered by a low-voltage DC or AC input, and the manufacturer packages the charger with an external power supply (''EPS''), sells, or recommends an optional EPS capable of providing that low voltage input, then the charger shall be tested using that EPS and the input reference source shall be 115 V at 60 Hz. If the EPS cannot be operated with AC input voltage at 115 V at 60 Hz, the charger shall not be tested.

(c) If the UUT is designed for operation only on DC input voltage and the provisions of section 3.1.4(b) of this appendix do not apply, it shall be tested with one of the following input voltages: 5.0 V DC for products drawing power from a computer USB port or the midpoint of the rated input voltage range for all other products. The input voltage shall be within ±1 percent of the above specified voltage.

(d) If the input voltage is AC, the input frequency shall be within ±1 percent of the specified frequency. The THD of the input voltage shall be ≤2 percent, up to and including the 13th harmonic. The crest factor of the input voltage shall be between 1.34 and 1.49.

(e) If the input voltage is DC, the AC ripple voltage (RMS) shall be:

(1) ≤0.2 V for DC voltages up to 10 V; or

(2) ≤2 percent of the DC voltage for DC voltages over 10 V.

3.2. UNIT UNDER TEST SETUP REQUIREMENTS

3.2.1. General Setup

(a) The battery charger system shall be prepared and set up in accordance with the manufacturer's instructions, except where those instructions conflict with the requirements of this test procedure. If no instructions are given, then factory or ''default'' settings shall be used, or where there are no indications of such settings, the UUT shall be tested in the condition as it would be supplied to an end user.

(b) If the battery charger has user controls to select from two or more charge rates (such as regular or fast charge) or different charge currents, the test shall be conducted at the fastest charge rate that is recommended by the manufacturer for everyday use, or, failing any explicit recommendation, the factory-default charge rate. If the charger has user controls for selecting special charge cycles that are recommended only for occasional use to preserve battery health, such as equalization charge, removing memory, or battery conditioning, these modes are not required to be tested. The settings of the controls shall be listed in the report for each test.

3.2.2. Selection and Treatment of the Battery Charger

The UUT, including the battery charger and its associated battery, shall be new products of the type and condition that would be sold to a customer. If the battery is lead-acid chemistry and the battery is to be stored for more than 24 hours between its initial acquisition and testing, the battery shall be charged before such storage.

3.2.3. Selection of Batteries To Use for Testing

(a) For chargers with integral batteries, the battery packaged with the charger shall be used for testing. For chargers with detachable batteries, the battery or batteries to be used for testing will vary depending on

whether there are any batteries packaged with the battery charger.

(1) If batteries are packaged with the charger, batteries for testing shall be selected from the batteries packaged with the battery charger, according to the procedure in section 3.2.3(b) of this appendix.

(2) If no batteries are packaged with the charger, but the instructions specify or recommend batteries for use with the charger, batteries for testing shall be selected from those recommended or specified in the instructions, according to the procedure in section 3.2.3(b) of this appendix.

(3) If no batteries are packaged with the charger and the instructions do not specify or recommend batteries for use with the charger, batteries for testing shall be selected from any that are suitable for use with the charger, according to the procedure in section 3.2.3(b) of this appendix.

(b)(1) From the detachable batteries specified above, use Table 3.2.1 of this appendix to select the batteries to be used for testing, depending on the type of battery charger being tested. The battery charger types represented by the rows in the table are mutually exclusive. Find the single applicable row for the UUT, and test according to those requirements. Select only the single battery configuration specified for the battery charger type in Table 3.2.1 of this appendix.

(2) If the battery selection criteria specified in Table 3.2.1 of this appendix results in two or more batteries or configurations of batteries of different chemistries, but with equal voltage and capacity ratings, determine the maintenance mode power, as specified in section 3.3.9 of this appendix, for each of the batteries or configurations of batteries, and select for testing the battery or configuration of batteries with the highest maintenance mode power.

(c) A charger is considered as:

(1) Single-capacity if all associated batteries have the same nameplate battery charge capacity (see definition) and, if it is a batch charger, all configurations of the batteries have the same nameplate battery charge capacity.

(2) Multi-capacity if there are associated batteries or configurations of batteries that have different nameplate battery charge capacities.

(d) The selected battery or batteries will be referred to as the ''test battery'' and will be used through the remainder of this test procedure.

TABLE 3.2.1—BATTERY SELECTION FOR TESTING

Type of charger			Tests to perform
Multi-voltage	Multi-port	Multi-capacity	Battery selection (from all configurations of all associated batteries)
No	No	No	Any associated battery.
No	No	Yes	Highest charge capacity battery.
No	Yes	Yes or No	Use all ports. Use the maximum number of identical batteries with the highest nameplate battery charge capacity that the charger can accommodate.
Yes	No	No	Highest voltage battery.
Yes	Yes to either or both		Use all ports. Use the battery or configuration of batteries with the highest individual voltage. If multiple batteries meet this criteria, then use the battery or configuration of batteries with the highest total nameplate battery charge capacity at the highest individual voltage.

3.2.4. Limiting Other Non-Battery-Charger Functions

(a) If the battery charger or product containing the battery charger does not have any additional functions unrelated to battery charging, this subsection may be skipped.

(b) Any optional functions controlled by the user and not associated with the battery charging process (*e.g.*, the answering machine in a cordless telephone charging base) shall be switched off. If it is not possible to switch such functions off, they shall be set to their lowest power-consuming mode during the test.

(c) If the battery charger takes any physically separate connectors or cables not required for battery charging but associated with its other functionality (such as phone lines, serial or USB connections, Ethernet, cable TV lines, *etc.*), these connectors or cables shall be left disconnected during the testing.

(d) Any manual on-off switches specifically associated with the battery charging process shall be switched on for the duration of the charge, maintenance, and no-battery mode tests, and switched off for the off mode test.

3.2.5. Accessing the Battery for the Test

(a) The technician may need to disassemble the end-use product or battery charger to gain access to the battery terminals for the Battery Discharge Energy Test in section 3.3.8 of this appendix. If the battery terminals are not clearly labeled, the technician shall use a voltmeter to identify the positive and negative terminals. These

terminals will be the ones that give the largest voltage difference and are able to deliver significant current (0.2 C or 1/hr) into a load.

(b) All conductors used for contacting the battery must be cleaned and burnished prior to connecting in order to decrease voltage drops and achieve consistent results.

(c) Manufacturer's instructions for disassembly shall be followed, except those instructions that:

(1) Lead to any permanent alteration of the battery charger circuitry or function;

(2) Could alter the energy consumption of the battery charger compared to that experienced by a user during typical use, *e.g.*, due to changes in the airflow through the enclosure of the UUT; or

(3) Conflict requirements of this test procedure.

(d) Care shall be taken by the technician during disassembly to follow appropriate safety precautions. If the functionality of the device or its safety features is compromised, the product shall be discarded after testing.

(e) Some products may include protective circuitry between the battery cells and the remainder of the device. If the manufacturer provides a description for accessing the connections at the output of the protective circuitry, these connections shall be used to discharge the battery and measure the discharge energy. The energy consumed by the protective circuitry during discharge shall not be measured or credited as battery energy.

(f) If any of the following conditions noted immediately below in sections 3.2.5.(f)(1) to 3.2.5.(f)(3) are applicable, preventing the measurement of the Battery Discharge Energy and the Charging and Maintenance Mode Energy, a manufacturer must submit a petition for a test procedure waiver in accordance with §430.27:

(1) Inability to access the battery terminals;

(2) Access to the battery terminals destroys charger functionality; or

(3) Inability to draw current from the test battery.

3.2.6. Determining Charge Capacity for Batteries With No Rating

(a) If there is no rating for the battery charge capacity on the battery or in the instructions, then the technician shall determine a discharge current that meets the following requirements. The battery shall be fully charged and then discharged at this constant-current rate until it reaches the end-of-discharge voltage specified in Table 3.3.2 of this appendix. The discharge time must be not less than 4.5 hours nor more than 5 hours. In addition, the discharge test (section 3.3.8 of this appendix) (which may not be starting with a fully-charged battery) shall reach the end-of-discharge voltage within 5 hours. The same discharge current shall be used for both the preparations step (section 3.3.4 of this appendix) and the discharge test (section 3.3.8 of this appendix). The test report shall include the discharge current used and the resulting discharge times for both a fully-charged battery and for the discharge test.

(b) For this section, the battery is considered as ''fully charged'' when either: it has been charged by the UUT until an indicator on the UUT shows that the charge is complete; or it has been charged by a battery analyzer at a current not greater than the discharge current until the battery analyzer indicates that the battery is fully charged.

(c) When there is no capacity rating, a suitable discharge current must generally be determined by trial and error. Since the conditioning step does not require constant-current discharges, the trials themselves may also be counted as part of battery conditioning.

3.3. Test Measurement

The test sequence to measure the battery charger energy consumption is summarized in Table 3.3.1 of this appendix, and explained in detail in this appendix. Measurements shall be made under test conditions and with the equipment specified in sections 3.1 and 3.2 of this appendix.

Table 3.3.1—Test Sequence

Step/Description	Data taken?	Equipment needed				
		Test battery	Charger	Battery analyzer or constant-current load	AC power meter	Thermometer (for flooded lead-acid battery chargers only)
1. Record general data on UUT; Section 3.3.1.	Yes	X	X			
2. Determine test duration; Section 3.3.2	No.					
3. Battery conditioning; Section 3.3.3	No	X	X	X		
4. Prepare battery for charge test; Section 3.3.4.	No	X	X			
5. Battery rest period; Section 3.3.5	No	X				X

TABLE 3.3.1—TEST SEQUENCE—Continued

Step/Description	Data taken?	Equipment needed				
		Test battery	Charger	Battery analyzer or constant-current load	AC power meter	Thermometer (for flooded lead-acid battery chargers only)
6. Conduct Charge Mode and Battery Maintenance Mode Test; Section 3.3.6.	Yes	X	X		X	
7. Battery Rest Period; Section 3.3.7	No	X				X
8. Battery Discharge Energy Test; Section 3.3.8.	Yes	X		X		
9. Determining the Maintenance Mode Power; Section 3.3.9.	Yes	X	X		X	
10. Calculating the 24-Hour Energy Consumption; Section 3.3.10.	No.					
11. Standby Mode Test; Section 3.3.11	Yes		X		X	
12. Off Mode Test; Section 3.3.12	Yes		X		X	

3.3.1. Recording General Data on the UUT

The technician shall record:

(a) The manufacturer and model of the battery charger;

(b) The presence and status of any additional functions unrelated to battery charging;

(c) The manufacturer, model, and number of batteries in the test battery;

(d) The nameplate battery voltage of the test battery;

(e) The nameplate battery charge capacity of the test battery; and

(f) The nameplate battery charge energy of the test battery.

(g) The settings of the controls, if battery charger has user controls to select from two or more charge rates.

3.3.2. Determining the Duration of the Charge and Maintenance Mode Test

(a) The charging and maintenance mode test, described in detail in section 3.3.6 of this appendix, shall be 24 hours in length or longer, as determined by the items below. Proceed in order until a test duration is determined.

(1) If the battery charger has an indicator to show that the battery is fully charged, that indicator shall be used as follows: If the indicator shows that the battery is charged after 19 hours of charging, the test shall be terminated at 24 hours. Conversely, if the full-charge indication is not yet present after 19 hours of charging, the test shall continue until 5 hours after the indication is present.

(2) If there is no indicator, but the manufacturer's instructions indicate that charging this battery or this capacity of battery should be complete within 19 hours, the test shall be for 24 hours. If the instructions indicate that charging may take longer than 19 hours, the test shall be run for the longest estimated charge time plus 5 hours.

(3) If there is no indicator and no time estimate in the instructions, but the charging current is stated on the charger or in the instructions, calculate the test duration as the longer of 24 hours or:

$$Duration = 1.4 \cdot \frac{RatedChargeCapacity\,(\mathrm{Ah})}{ChargeCurrent\,(\mathrm{A})} + 5\mathrm{h}$$

(b) If none of the above applies, the duration of the test shall be 24 hours.

3.3.3. Battery Conditioning

(a) No conditioning is to be done on lithium-ion batteries. The test technician shall proceed directly to battery preparation, section 3.3.4 of this appendix, when testing chargers for these batteries.

(b) Products with integral batteries will have to be disassembled per the instructions in section 3.2.5 of this appendix, and the battery disconnected from the charger for discharging.

(c) Batteries of other chemistries that have not been previously cycled are to be conditioned by performing two charges and two discharges, followed by a charge, as below. No data need be recorded during battery conditioning.

(1) The test battery shall be fully charged for the duration specified in section 3.3.2 of this appendix or longer using the UUT.

(2) The test battery shall then be fully discharged using either:

(i) A battery analyzer at a rate not to exceed 1 C, until its average cell voltage under load reaches the end-of-discharge voltage specified in Table 3.3.2 of this appendix for the relevant battery chemistry; or

(ii) The UUT, until the UUT ceases operation due to low battery voltage.

(3) The test battery shall again be fully charged as in step (c)(1) of this section.

(4) The test battery shall again be fully discharged as per step (c)(2) of this section.

(5) The test battery shall be again fully charged as in step (c)(1) of this section.

(d) Batteries of chemistries, other than lithium-ion, that are known to have been through at least two previous full charge/discharge cycles shall only be charged once per step (c)(5), of this section.

3.3.4. Preparing the Battery for Charge Testing

Following any conditioning prior to beginning the battery charge test (section 3.3.6 of this appendix), the test battery shall be fully discharged to the end of discharge voltage prescribed in Table 3.3.2 of this appendix, or until the UUT circuitry terminates the discharge.

3.3.5. Resting the Battery

The test battery shall be rested between preparation and the battery charge test. The rest period shall be at least one hour and not exceed 24 hours. For batteries with flooded cells, the electrolyte temperature shall be less than 30 °C before charging, even if the rest period must be extended longer than 24 hours.

3.3.6. Testing Charge Mode and Battery Maintenance Mode

(a) The Charge and Battery Maintenance Mode test measures the energy consumed during charge mode and some time spent in the maintenance mode of the UUT. Functions required for battery conditioning that happen only with some user-selected switch or other control shall not be included in this measurement. (The technician shall manually turn off any battery conditioning cycle or setting.) Regularly occurring battery conditioning or maintenance functions that are not controlled by the user will, by default, be incorporated into this measurement.

(b) During the measurement period, input power values to the UUT shall be recorded at least once every minute.

(1) If possible, the technician shall set the data logging system to record the average power during the sample interval. The total energy is computed as the sum of power samples (in watts) multiplied by the sample interval (in hours).

(2) If this setting is not possible, then the power analyzer shall be set to integrate or accumulate the input power over the measurement period and this result shall be used as the total energy.

(c) The technician shall follow these steps:

(1) Ensure that the user-controllable device functionality not associated with battery charging and any battery conditioning cycle or setting are turned off, as instructed in section 3.2.4 of this appendix;

(2) Ensure that the test battery used in this test has been conditioned, prepared, discharged, and rested as described in sections 3.3.3 through 3.3.5 of this appendix;

(3) Connect the data logging equipment to the battery charger;

(4) Record the start time of the measurement period, and begin logging the input power;

(5) Connect the test battery to the battery charger within 3 minutes of beginning logging. For integral battery products, connect the product to a cradle or EPS within 3 minutes of beginning logging;

(6) After the test battery is connected, record the initial time and power (W) of the input current to the UUT. These measurements shall be taken within the first 10 minutes of active charging;

(7) Record the input power for the duration of the ''Charging and Maintenance Mode Test'' period, as determined by section 3.3.2 of this appendix. The actual time that power is connected to the UUT shall be within ±5 minutes of the specified period; and

(8) Disconnect power to the UUT, terminate data logging, and record the final time.

3.3.7. Resting the Battery

The test battery shall be rested between charging and discharging. The rest period shall be at least 1 hour and not more than 4 hours, with an exception for flooded cells. For batteries with flooded cells, the electrolyte temperature shall be less than 30 °C before charging, even if the rest period must be extended beyond 4 hours.

3.3.8. Battery Discharge Energy Test

(a) If multiple batteries were charged simultaneously, the discharge energy is the sum of the discharge energies of all the batteries.

(1) For a multi-port charger, batteries that were charged in separate ports shall be discharged independently.

(2) For a batch charger, batteries that were charged as a group may be discharged individually, as a group, or in sub-groups connected in series and/or parallel. The position of each battery with respect to the other batteries need not be maintained.

(b) During discharge, the battery voltage and discharge current shall be sampled and recorded at least once per minute. The values recorded may be average or instantaneous values.

(c) For this test, the technician shall follow these steps:

(1) Ensure that the test battery has been charged by the UUT and rested according to sections 3.3.6. and 3.3.7 of this appendix.

(2) Set the battery analyzer for a constant discharge rate and the end-of-discharge voltage in Table 3.3.2 of this appendix for the relevant battery chemistry.

(3) Connect the test battery to the analyzer and begin recording the voltage, current, and wattage, if available from the battery analyzer. When the end-of-discharge voltage is reached or the UUT circuitry terminates the discharge, the test battery shall be returned to an open-circuit condition. If current continues to be drawn from the test battery after the end-of-discharge condition is first reached, this additional energy is not to be counted in the battery discharge energy.

(d) If not available from the battery analyzer, the battery discharge energy (in watt-hours) is calculated by multiplying the voltage (in volts), current (in amperes), and sample period (in hours) for each sample, and then summing over all sample periods until the end-of-discharge voltage is reached.

3.3.9. Determining the Maintenance Mode Power

After the measurement period is complete, the technician shall determine the average maintenance mode power consumption by examining the power-versus-time data from the charge and maintenance test and:

(a) If the maintenance mode power is cyclic or shows periodic pulses, compute the average power over a time period that spans a whole number of cycles and includes at least the last 4 hours.

(b) Otherwise, calculate the average power value over the last 4 hours.

3.3.10. Determining the 24-Hour Energy Consumption

The accumulated energy or the average input power, integrated over the test period from the charge and maintenance mode test, shall be used to calculate 24-hour energy consumption.

TABLE 3.3.2—REQUIRED BATTERY DISCHARGE RATES AND END-OF-DISCHARGE BATTERY VOLTAGES

Battery chemistry	Discharge rate (C)	End-of-discharge voltage * (volts per cell)
Valve-Regulated Lead Acid (VRLA)	0.2	1.75
Flooded Lead Acid	0.2	1.70
Nickel Cadmium (NiCd)	0.2	1.0
Nickel Metal Hydride (NiMH)	0.2	1.0
Lithium-Ion (Li-Ion)	0.2	2.5
Lithium-Ion Polymer	0.2	2.5
Lithium Iron Phosphate	0.2	2.0
Rechargeable Alkaline	0.2	0.9
Silver Zinc	0.2	1.2

* If the presence of protective circuitry prevents the battery cells from being discharged to the end-of-discharge voltage specified, then discharge battery cells to the lowest possible voltage permitted by the protective circuitry.

3.3.11. Standby Mode Energy Consumption Measurement

The standby mode measurement depends on the configuration of the battery charger, as follows:

(a) Conduct a measurement of standby power consumption while the battery charger is connected to the power source. Disconnect the battery from the charger, allow the charger to operate for at least 30 minutes, and record the power (*i.e.*, watts) consumed as the time series integral of the power consumed over a 10-minute test period, divided by the period of measurement. If the battery charger has manual on-off switches, all must be turned on for the duration of the standby mode test.

(b) Standby mode may also apply to products with integral batteries, as follows:

(1) If the product uses a cradle and/or adapter for power conversion and charging, then ''disconnecting the battery from the charger'' will require disconnection of the end-use product, which contains the batteries. The other enclosures of the battery charging system will remain connected to the main electricity supply, and standby mode power consumption will equal that of the cradle and/or adapter alone.

(2) If the product is powered through a detachable AC power cord and contains integrated power conversion and charging circuitry, then only the cord will remain connected to mains, and standby mode power consumption will equal that of the AC power cord (*i.e.*, zero watts).

(3) If the product contains integrated power conversion and charging circuitry but is powered through a non-detachable AC power cord or plug blades, then no part of the system will remain connected to mains, and standby mode measurement is not applicable.

3.3.12. Off Mode Energy Consumption Measurement

The off mode measurement depends on the configuration of the battery charger, as follows:

(a) If the battery charger has manual on-off switches, record a measurement of off mode energy consumption while the battery charger is connected to the power source. Remove the battery from the charger, allow the charger to operate for at least 30 minutes, and record the power (*i.e.*, watts) consumed as the time series integral of the power consumed over a 10-minute test period, divided by the period of measurement, with all manual on-off switches turned off. If the battery charger does not have manual on-off switches, record that the off mode measurement is not applicable to this product.

(b) Off mode may also apply to products with integral batteries, as follows:

(1) If the product uses a cradle and/or adapter for power conversion and charging, then ''disconnecting the battery from the charger'' will require disconnection of the end-use product, which contains the batteries. The other enclosures of the battery charging system will remain connected to the main electricity supply, and off mode power consumption will equal that of the cradle and/or adapter alone.

(2) If the product is powered through a detachable AC power cord and contains integrated power conversion and charging circuitry, then only the cord will remain connected to mains, and off mode power consumption will equal that of the AC power cord (*i.e.*, zero watts).

(3) If the product contains integrated power conversion and charging circuitry but is powered through a non-detachable AC power cord or plug blades, then no part of the system will remain connected to mains, and off mode measurement is not applicable.

3.3.13. Unit Energy Consumption Calculation

Unit energy consumption (UEC) shall be calculated for a battery charger using one of the two equations (equation (i) or equation (ii)) listed in this section. If a battery charger is tested and its charge duration as determined in section 3.3.2 of this appendix minus 5 hours is greater than the threshold charge time listed in Table 3.3.3 of this appendix (*i.e.* (t_{cd} − 5) * n > $t_{a\&m}$), equation (ii) shall be used to calculate UEC; otherwise a battery charger's UEC shall be calculated using equation (i).

$$\text{(i) } UEC = 365\left(n(E_{24} - 5P_m - Measured\ E_{batt})\frac{24}{t_{cd}} + \left(P_m(t_{a\&m} - (t_{cd} - 5)n)\right) + (P_{sb}t_{sb}) + \left(P_{off}t_{off}\right)\right) \text{ or,}$$

$$\text{(ii) } UEC = 365\left(n(E_{24} - 5P_m - Measured\ E_{batt})\frac{24}{(t_{cd} - 5)} + (P_{sb}t_{sb}) + \left(P_{off}t_{off}\right)\right)$$

Where:

E_{24} = 24-hour energy as determined in section 3.3.10 of this appendix,

Measured E_{batt} = Measured battery energy as determined in section 3.3.8. of this appendix,

P_m = Maintenance mode power as determined in section 3.3.9. of this appendix,

P_{sb} = Standby mode power as determined in section 3.3.11. of this appendix,

P_{off} = Off mode power as determined in section 3.3.12. of this appendix,

t_{cd} = Charge test duration as determined in section 3.3.2. of this appendix, and

$t_{a\&m}$, n, t_{sb}, and t_{off}, are constants used depending upon a device's product class and found in Table 3.3.3:

TABLE 3.3.3—BATTERY CHARGER USAGE PROFILES

Product class				Hours per day***			Charges (n)	Threshold charge time*
Number	Description	Measured battery energy (measured E_{batt})**	Special characteristic or highest nameplate battery voltage	Active + maintenance (t_a&$_m$)	Standby (t_{sb})	Off (t_{off})	Number per day	Hours
1	Low-Energy	≤5 Wh	Inductive Connection****.	20.66	0.10	0.00	0.15	137.73
2	Low-Energy, Low-Voltage.	<100 Wh	<4 V	7.82	5.29	0.00	0.54	14.48
3	Low-Energy, Medium-Voltage.		4–10 V	6.42	0.30	0.00	0.10	64.20
4	Low-Energy, High-Voltage.		>10 V	16.84	0.91	0.00	0.50	33.68
5	Medium-Energy, Low-Voltage.	100–3000 Wh	<20 V	6.52	1.16	0.00	0.11	59.27
6	Medium-Energy, High-Voltage.		≥20 V	17.15	6.85	0.00	0.34	50.44
7	High-Energy	>3000 Wh	.....	8.14	7.30	0.00	0.32	25.44

*If the duration of the charge test (minus 5 hours) as determined in section 3.3.2. of this appendix exceeds the threshold charge time, use equation (ii) to calculate UEC otherwise use equation (i).
**Measured E_{batt} = Measured battery energy as determined in section 3.3.8.
***If the total time does not sum to 24 hours per day, the remaining time is allocated to unplugged time, which means there is 0 power consumption and no changes to the UEC calculation needed.
****Fixed-location inductive wireless charger only.

4. TESTING REQUIREMENTS FOR UNINTERRUPTIBLE POWER SUPPLIES

4.1. STANDARD TEST CONDITIONS

4.1.1. Measuring Equipment

(a) The power or energy meter must provide true root mean square (r. m. s) measurements of the active input and output measurements, with an uncertainty at full rated load of less than or equal to 0.5% at the 95% confidence level notwithstanding that voltage and current waveforms can include harmonic components. The meter must measure input and output values simultaneously.

(b) All measurement equipment used to conduct the tests must be calibrated within the measurement equipment manufacturer specified calibration period by a standard traceable to International System of Units such that measurements meet the uncertainty requirements specified in section 4.1.1(a) of this appendix.

4.1.2. Test Room Requirements

All portions of the test must be carried out in a room with an air speed immediately surrounding the UUT of ≤0.5 m/s in all directions. Maintain the ambient temperature in the range of 20.0 °C to 30.0 °C, including all inaccuracies and uncertainties introduced by the temperature measurement equipment, throughout the test. No intentional cooling of the UUT, such as by use of separately powered fans, air conditioners, or heat sinks, is permitted. Test the UUT on a thermally non-conductive surface.

4.1.3. Input Voltage and Input Frequency

The AC input voltage and frequency to the UPS during testing must be within 3 percent of the highest rated voltage and within 1 percent of the highest rated frequency of the device.

4.2. UNIT UNDER TEST SETUP REQUIREMENTS

4.2.1. General Setup

Configure the UPS according to Annex J.2 of IEC 62040–3 Ed. 3.0 with the following additional requirements:

(a) *UPS Operating Mode Conditions.* If the UPS can operate in two or more distinct normal modes as more than one UPS architecture, conduct the test in its lowest input dependency as well as in its highest input dependency mode where VFD represents the highest possible input dependency, followed by VI and then VFI.

(b) *Energy Storage System.* The UPS must not be modified or adjusted to disable energy storage charging features. Minimize the transfer of energy to and from the energy storage system by ensuring the energy storage system is fully charged (at the start of testing) as follows:

(1) If the UUT has a battery charge indicator, charge the battery for 5 hours after the UUT has indicated that it is fully charged.

(2) If the UUT does not have a battery charge indicator but the user manual shipped with the UUT specifies a time to reach full charge, charge the battery for 5 hours longer than the time specified.

(3) If the UUT does not have a battery charge indicator or user manual instructions, charge the battery for 24 hours.

(c) *DC output port(s).* All DC output port(s) of the UUT must remain unloaded during testing.

4.2.2. Additional Features

(a) Any feature unrelated to maintaining the energy storage system at full charge or delivery of load power (*e.g.*, LCD display) shall be switched off. If it is not possible to switch such features off, they shall be set to their lowest power-consuming mode during the test.

(b) If the UPS takes any physically separate connectors or cables not required for maintaining the energy storage system at full charge or delivery of load power but associated with other features (such as serial or USB connections, Ethernet, etc.), these connectors or cables shall be left disconnected during the test.

(c) Any manual on-off switches specifically associated with maintaining the energy storage system at full charge or delivery of load power shall be switched on for the duration of the test.

4.3. TEST MEASUREMENT AND CALCULATION

Efficiency can be calculated from either average power or accumulated energy.

4.3.1. Average Power Calculations

If efficiency calculation are to be made using average power, calculate the average power consumption (P_{avg}) by sampling the power at a rate of at least 1 sample per second and computing the arithmetic mean of all samples over the time period specified for each test as follows:

$$P_{avg} = \frac{1}{n}\sum_{i=1}^{n} P_i$$

Where:

P_{avg} = average power
P_i = power measured during individual measurement (i)
n = total number of measurements

4.3.2. Steady State

Operate the UUT and the load for a sufficient length of time to reach steady state conditions. To determine if steady state conditions have been attained, perform the following steady state check, in which the difference between the two efficiency calculations must be less than 1 percent:

(a)(1) Simultaneously measure the UUT's input and output power for at least 5 minutes, as specified in section 4.3.1 of this appendix, and record the average of each over the duration as P_{avg_in} and P_{avg_out}, respectively. Or,

(2) Simultaneously measure the UUT's input and output energy for at least 5 minutes and record the accumulation of each over the duration as E_{in} and E_{out}, respectively.

(b) Calculate the UUT's efficiency, Eff_1, using one of the following two equations:

(1)

$$Eff = \frac{P_{avg_out}}{P_{avg_in}}$$

Where:

Eff is the UUT efficiency
P_{avg_out} is the average output power in watts
P_{avg_in} is the average input power in watts

(2)

$$Eff = \frac{E_{out}}{E_{in}}$$

Where:

Eff is the UUT efficiency

E_{out} is the accumulated output energy in watt-hours

E_{in} in the accumulated input energy in watt-hours

(c) Wait a minimum of 10 minutes.

(d) Repeat the steps listed in paragraphs (a) and (b) of section 4.3.2 of this appendix to calculate another efficiency value, Eff_2.

(e) Determine if the product is at steady state using the following equation:

$$Percentage\ difference = \frac{|Eff_1 - Eff_2|}{Average(Eff_1, Eff_2)}$$

If the percentage difference of Eff_1 and Eff_2 as described in the equation, is less than 1 percent, the product is at steady state.

(f) If the percentage difference is greater than or equal to 1 percent, the product is not at steady state. Repeat the steps listed in paragraphs (c) to (e) of section 4.3.2 of this appendix until the product is at steady state.

4.3.3. Power Measurements and Efficiency Calculations

Measure input and output power of the UUT according to section J.3 of Annex J of IEC 62040–3 Ed. 3.0, or measure the input and output energy of the UUT for efficiency calculations with the following exceptions:

(a) Test the UUT at the following reference test load conditions, in the following order: 100 percent, 75 percent, 50 percent, and 25 percent of the rated output power.

(b) Perform the test at each of the reference test loads by simultaneously measuring the UUT's input and output power in Watts (W), or input and output energy in Watt-Hours (Wh) over a 15 minute test period at a rate of at least 1 Hz. Calculate the efficiency for that reference load using one of the following two equations:

(1)

$$Eff_{n\%} = \frac{P_{avg_out\ n\%}}{P_{avg_in\ n\%}}$$

Where:

$Eff_{n\%}$ = the efficiency at reference test load $n\%$

$P_{avg_out\ n\%}$ = the average output power at reference load $n\%$

$P_{avg_in\ n\%}$ = the average input power at reference load $n\%$

(2)

$$Eff_{n\%} = \frac{E_{out\ n\%}}{E_{in\ n\%}}$$

Where:

$Eff_{n\%}$ = the efficiency at reference test load $n\%$

$E_{out\ n\%}$ = the accumulated output energy at reference load $n\%$

$E_{in\ n\%}$ = the accumulated input energy at reference load $n\%$

(c) For representations of no-load losses, measure the active power at the UPS input port with no load applied in accordance with section 6.2.2.4 of IEC 62040–3 Ed. 3.0.

4.3.4. UUT Classification

Optional Test for determination of UPS architecture. Determine the UPS architecture by performing the tests specified in the definitions of VI, VFD, and VFI (sections 2.28.1 through 2.28.3 of this appendix).

4.3.5. Output Efficiency Calculation

(a) Use the load weightings from Table 4.3.1 to determine the average load adjusted efficiency as follows:

$$Eff_{avg} = (t_{25\%} \times Eff|_{25\%}) + (t_{50\%} \times Eff|_{50\%}) + (t_{75\%} \times Eff|_{75\%}) + (t_{100\%} \times Eff|_{100\%})$$

Where:

Eff_{avg} = the average load adjusted efficiency

$t_{n\%}$ = the portion of time spent at reference test load $n\%$ as specified in Table 4.3.1

$Eff|_{n\%}$ = the measured efficiency at reference test load $n\%$

TABLE 4.3.1—LOAD WEIGHTINGS

Rated output power (W)	UPS architecture	Portion of time spent at reference load			
		25%	50%	75%	100%
P ≤ 1500 W	VFD	0.2	0.2	0.3	0.3
	VI or VFI	0*	0.3	0.4	0.3
P > 1500 W	VFD, VI, or VFI	0*	0.3	0.4	0.3

*Measuring efficiency at loading points with 0 time weighting is not required.

(b) Round the calculated efficiency value to one tenth of a percentage point.

[76 FR 31776, June 1, 2011, as amended at 81 FR 31842, May 20, 2016; 81 FR 42235, June 29, 2016; 81 FR 89822, Dec. 12, 2016; 87 FR 28756, May 11, 2022; 87 FR 55122, Sept. 8, 2022; 89 FR 28592, Apr. 19, 2024]

APPENDIX Y1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF BATTERY CHARGERS

NOTE 1: For all Battery Chargers, including UPSs, compliance with the relevant standard in §430.32(z) or any representation must be based upon results generated under the corresponding appendix listed in the following table:

	Battery chargers other than UPSs	UPS
On or After July 3, 2024 and Before October 16, 2024	Use appendix Y as it appeared on either March 7, 2023, or July 3, 2024.	Use appendix Y as it appeared on either March 7, 2023, or July 3, 2024
On or After October 16, 2024 and Before compliance date of any new or amended standards published any time after September 2022.	Use appendix Y as it appeared on July 3, 2024..	Use appendix Y as it appeared on July 3, 2024.
On or After compliance date of any new or amended standards published any time after September 2022.	Use appendix Y1	Use appendix Y1.

0. INCORPORATION BY REFERENCE

DOE incorporated by reference in §430.3 the entire test standard for IEC 62040–3 Ed. 3.0. However, only enumerated provisions of this standard are applicable to this appendix, as follows. In cases in which there is a conflict, the language of the test procedure in this appendix takes precedence over the referenced test standard.

0.1 IEC 62040–3 Ed. 3.0:

(a) Section 3.5, Specified values;

(b) Section 3.5.49, total harmonic distortion;

(c) Section 5, Electrical conditions, performance and declared values;

(d) Section 5.2, UPS input specification, as specified in section 2.28.2 of this appendix;

(e) Section 5.2.1, Conditions for normal mode of operation; Clause 5.2.1.a;

(f) Clause 5.2.1.b;

(g) Section 5.2.2, Conditions to be declared by the manufacturer; Clause 5.2.2.k;

(h) Clause 5.2.2.l;

(i) Clause 5.2.2.m;

(j) Section 5.3, UPS output specification; Section 5.3.2, Characteristics to be declared by the manufacturer; Clause 5.3.2.b;

(k) Clause 5.3.2.c;

(l) Clause 5.3.2.d;

(m) Clause 5.3.2.e;

(n) Section 5.3.4.2, Input dependency AAA;

(o) Section 6.2, Routine test procedure; Section 6.2.2, Electrical; Section 6.2.2.4, No load, as specified in section 4.3.3(c) of this appendix;

(p) Section 6.2.2.7, AC input failure, as specified in Note to section 2.28.1 of this appendix;

(q) Section 6.4, Type test procedure (electrical); Section 6.4.1, Input—AC input power compatibility; Section 6.4.1.2, Steady state input voltage tolerance and VI input independency, as specified in Note to section 2.28.3 of this appendix;

(r) Section 6.4.1.3, Combined input voltage/frequency tolerance and VFI input independency, as specified in Note to section 2.28.2 of this appendix;

(s) Annex G—AC input power failure—Test method;

(t) Annex J—UPS efficiency and no load losses—Methods of measurement, as specified in sections 4.2.1 and 4.3.3 of this appendix.

0.2 [Reserved]

1. Scope

This appendix provides the test requirements used to measure the energy consumption of battery chargers, including fixed-location wireless chargers designed for charging batteries with less than 100 watt-hour battery energy and open-placement wireless chargers, operating at either DC or United States AC line voltage (nominally 115V at 60Hz). This appendix also provides the test requirements used to measure the energy efficiency of uninterruptible power supplies as defined in section 2 of this appendix that utilize the standardized National Electrical Manufacturer Association (NEMA) plug, 1–15P or 5–15P, as specified in ANSI/NEMA WD 6–2016 (incorporated by reference, see §430.3) and have an AC output. This appendix does not provide a method for testing back-up battery chargers.

2. Definitions

The following definitions are for the purposes of explaining the terminology associated with the test method for measuring battery charger energy consumption.[1]

[1] For clarity on any other terminology used in the test method, please refer to IEEE 1515–2000, (Sources for information and guidance, see §430.4).

2.1. *Active mode* or *charge mode* is the state in which the battery charger system is connected to the main electricity supply, and the battery charger is delivering current, equalizing the cells, and performing other one-time or limited-time functions in order to bring the battery to a fully charged state.

2.2. *Active power* or *real power* (P) means the average power consumed by a unit. For a two terminal device with current and voltage waveforms i(t) and v(t), which are periodic with period T, the real or active power P is:

$$P = \frac{1}{T}\int_0^T v(t)i(t)dt$$

2.3. *Ambient temperature* is the temperature of the ambient air immediately surrounding the unit under test.

2.4. *Apparent power (S)* is the product of root-mean-square (RMS) voltage and RMS current in volt-amperes (VA).

2.5. *Batch charger* is a battery charger that charges two or more identical batteries simultaneously in a series, parallel, series-parallel, or parallel-series configuration. A batch charger does not have separate voltage or current regulation, nor does it have any separate indicators for each battery in the

batch. When testing a batch charger, the term ''battery'' is understood to mean, collectively, all the batteries in the batch that are charged together. A charger can be both a batch charger and a multi-port charger or multi-voltage charger.

2.6. *Battery* or *battery pack* is an assembly of one or more rechargeable cells and any integral protective circuitry intended to provide electrical energy to a consumer product, and may be in one of the following forms:

(a) Detachable battery (a battery that is contained in a separate enclosure from the consumer product and is intended to be removed or disconnected from the consumer product for recharging); or

(b) Integral battery (a battery that is contained within the consumer product and is not removed from the consumer product for charging purposes). The word ''intended'' in this context refers to whether a battery has been designed in such a way as to permit its removal or disconnection from its associated consumer product.

2.7. *Battery energy* is the energy, in watt-hours, delivered by the battery under the specified discharge conditions in the test procedure.

2.8. *Battery maintenance mode* or *maintenance mode*, is a subset of standby mode in which the battery charger is connected to the main electricity supply and the battery is fully charged, but is still connected to the charger.

2.9. *Battery rest period* is a period of time between discharge and charge or between charge and discharge, during which the battery is resting in an open-circuit state in ambient air.

2.10. *C-Rate* (C) is the rate of charge or discharge, calculated by dividing the charge or discharge current by the nameplate battery charge capacity of the battery. For example, a 0.2 C-rate would result in a charge or discharge period of 5 hours.

2.11. *Cradle* is an electrical interface between an integral battery product and the rest of the battery charger designed to hold the product between uses.

2.12. *Energy storage system* is a system consisting of single or multiple devices designed to provide power to the UPS inverter circuitry.

2.13. *Equalization* is a process whereby a battery is overcharged, beyond what would be considered ''normal'' charge return, so that cells can be balanced, electrolyte mixed, and plate sulfation removed.

2.14. *Instructions* or *manufacturer's instructions* means the documentation packaged with a product in printed or electronic form and any information about the product listed on a website maintained by the manufacturer and accessible by the general public at the time of the test. It also includes any information on the packaging or on the product itself. ''Instructions'' also includes any service manuals or data sheets that the manufacturer offers to independent service technicians, whether printed or in electronic form.

2.15. *Measured charge capacity of a battery* is the product of the discharge current in amperes and the time in decimal hours required to reach the specified end-of-discharge voltage.

2.16. *Manual on-off switch* is a switch activated by the user to control power reaching the battery charger. This term does not apply to any mechanical, optical, or electronic switches that automatically disconnect mains power from the battery charger when a battery is removed from a cradle or charging base, or for products with non-detachable batteries that control power to the product itself.

2.17. *Multi-port charger* means a battery charger that charges two or more batteries (which may be identical or different) simultaneously. The batteries are not connected in series or in parallel but with each port having separate voltage and/or current regulation. If the charger has status indicators, each port has its own indicator(s). A charger can be both a batch charger and a multi-port charger if it is capable of charging two or more batches of batteries simultaneously and each batch has separate regulation and/or indicator(s).

2.18. *Multi-voltage charger* is a battery charger that, by design, can charge a variety of batteries (or batches of batteries, if also a batch charger) that are of different nameplate battery voltages. A multi-voltage charger can also be a multi-port charger if it can charge two or more batteries simultaneously with independent voltages and/or current regulation.

2.19. *Normal mode* is a mode of operation for a UPS in which:

(a) The AC input supply is within required tolerances and supplies the UPS,

(b) The energy storage system is being maintained at full charge or is under recharge, and

(c) The load connected to the UPS is within the UPS's specified power rating.

2.20. *Off mode* is the condition, applicable only to units with manual on-off switches, in which the battery charger:

(a) Is connected to the main electricity supply;

(b) Is not connected to the battery; and

(c) All manual on-off switches are turned off.

2.21. *Nameplate battery voltage* is specified by the battery manufacturer and typically printed on the label of the battery itself. If there are multiple batteries that are connected in series, the nameplate battery voltage of the batteries is the total voltage of the series configuration—that is, the nameplate voltage of each battery multiplied by

the number of batteries connected in series. Connecting multiple batteries in parallel does not affect the nameplate battery voltage.

2.22. *Nameplate battery charge capacity* is the capacity, claimed by the battery manufacturer on a label or in instructions, that the battery can store, usually given in ampere-hours (Ah) or milliampere-hours (mAh) and typically printed on the label of the battery itself. If there are multiple batteries that are connected in parallel, the nameplate battery charge capacity of the batteries is the total charge capacity of the parallel configuration, that is, the nameplate charge capacity of each battery multiplied by the number of batteries connected in parallel. Connecting multiple batteries in series does not affect the nameplate charge capacity.

2.23. *Nameplate battery energy capacity* means the product (in watts-hours (Wh)) of the nameplate battery voltage and the nameplate battery charge capacity.

2.24. *No-battery mode* is a subset of standby mode and means the condition in which:

(a) The battery charger is connected to the main electricity supply;

(b) The battery is not connected to the charger; and

(c) For battery chargers with manual on-off switches, all such switches are turned on.

2.25. *Reference test load* is a load or a condition with a power factor of greater than 0.99 in which the AC output socket of the UPS delivers the active power (W) for which the UPS is rated.

2.26. *Standby mode* means the condition in which the battery charge is either in maintenance mode or no battery mode as defined in this appendix.

2.27. *Total harmonic distortion (THD)*, expressed as a percent, is as defined in section 3.5.9 of IEC 62040–3 Ed. 3.0.

2.28. *Uninterruptible power supply or UPS* means a battery charger consisting of a combination of convertors, switches and energy storage devices (such as batteries), constituting a power system for maintaining continuity of load power in case of AC input power failure.

2.28.1. *Voltage and frequency dependent UPS or VFD UPS* means a UPS that protects the load from a complete loss of AC input power. The output of a VFD UPS is dependent on changes in voltage and frequency of the AC input power and is not intended to provide additional voltage corrective functions, such as those arising from the use of tapped transformers.

NOTE TO 2.28.1: VFD input dependency may be verified by performing the AC input failure test in section 6.2.2.7 of IEC 62040–3 Ed. 3.0 and observing that, at a minimum, the UPS switches from normal mode of operation to battery power while the input is interrupted.

2.28.2. *Voltage and frequency independent UPS or VFI UPS* means a UPS that is independent of AC input power voltage and frequency variations as specified and declared in section 5.2 of IEC 62040–3 Ed. 3.0 and shall protect the load against adverse effects from such variations without discharging the energy storage device.

NOTE TO 2.28.2: VFI input dependency may be verified by performing the combined input voltage/frequency tolerance and VFI input independency test in section 6.4.1.3 of IEC 62040–3 Ed. 3.0 respectively and observing that, at a minimum, the UPS produces an output voltage and frequency within the specified output range when the input voltage is varied by ±10% of the rated input voltage and the input frequency is varied by ±2% of the rated input frequency.

2.28.3. *Voltage independent UPS or VI UPS* means a UPS that protects the load as required for VFD and also from (a) under-voltage applied continuously to the input, and (b) over-voltage applied continuously to the input. The output voltage of a VI UPS shall remain within declared voltage limits (provided by voltage corrective functions, such as those arising from the use of active and/or passive circuits). The output voltage tolerance band shall be narrower than the input voltage tolerance band.

NOTE TO 2.28.3: VI input dependency may be verified by performing the steady state input voltage tolerance test in section 6.4.1.2 of IEC 62040–3 Ed. 3.0 and ensuring that the UPS remains in normal mode with the output voltage within the specified output range when the input voltage is varied by ±10% of the rated input voltage.

2.29. *Unit under test* (UUT) in this appendix refers to the combination of the battery charger and battery being tested.

2.30. *Wireless charger* is a battery charger that can charge batteries inductively.

2.30.1. *Fixed-location wireless charger* is an inductive wireless battery charger that incorporates a physical receiver locating feature (e.g., by physical peg, cradle, locking mechanism, magnet, etc.) to repeatably align or orient the position of the receiver with respect to the transmitter.

2.30.2. *Open-placement wireless charger* is an inductive wireless charger that does not incorporate a physical receiver locating feature (e.g., by a physical peg, cradle, locking mechanism, magnet etc.) to repeatably align or orient the position of the receiver with respect to the transmitter.

3. Testing Requirements for all Battery Chargers Other Than Uninterruptible Power Supplies and Open-Placement Wireless Chargers

3.1. Standard Test Conditions

3.1.1. General

The values that may be measured or calculated during the conduct of this test procedure have been summarized for easy reference in Table 3.1.1 of this appendix.

TABLE 3.1.1—LIST OF MEASURED OR CALCULATED VALUES

Name of measured or calculated value	Reference
1. Duration of the Charge and Maintenance Modes test	Section 3.3.2.
2. Battery Discharge Energy (E_{batt})	Section 3.3.8.
3. Initial time and power (W) of the input current of connected battery	Section 3.3.6.
4. Active and Maintenance Modes Energy Consumption	Section 3.3.6.
5. Maintenance Mode Power (P_m)	Section 3.3.9.
6. Active mode Energy Consumption (E_a)	Section 3.3.10.
7. No-Battery Mode Power (P_{nb})	Section 3.3.11.
8. Off Mode Power (P_{off})	Section 3.3.12.
9. Standby Mode Power (P_{sb})	Section 3.3.13.

3.1.2. Verifying Accuracy and Precision of Measuring Equipment

Any power measurement equipment utilized for testing must conform to the uncertainty and resolution requirements outlined in Section 4, ''General conditions for measurement'', as well as Annexes B, ''Notes on the measurement of low-power modes'', and D, ''Determination of uncertainty of measurement'', of IEC 62301 (incorporated by reference, see §430.3).

3.1.3. Setting Up the Test Room

All tests, battery conditioning, and battery rest periods shall be carried out in a room with an air speed immediately surrounding the UUT of ≤0.5 m/s. The ambient temperature shall be maintained at 20 °C ± 5 °C throughout the test. There shall be no intentional cooling of the UUT such as by use of separately powered fans, air conditioners, or heat sinks. The UUT shall be conditioned, rested, and tested on a thermally non-conductive surface. When not undergoing active testing, batteries shall be stored at 20 °C ± 5 °C.

3.1.4. Verifying the UUT's Input Voltage and Input Frequency

(a) If the UUT is intended for operation on AC line-voltage input in the United States, it shall be tested at 115 V at 60 Hz. If the UUT is intended for operation on AC line-voltage input but cannot be operated at 115 V at 60 Hz, it shall not be tested.

(b) If a battery charger is powered by a low-voltage DC or AC input and the manufacturer packages the battery charger with an external power supply (''EPS''), test the battery charger using the packaged EPS; if the battery charger does not include a prepackaged EPS, then test the battery charger with an EPS sold and recommended by the manufacturer; if the manufacturer does not recommend an EPS that it sells, test the battery charger with an EPS that the manufacturer recommends for use in the manufacturer materials. The input reference source shall be 115 V at 60 Hz. If the EPS cannot be operated with AC input voltage at 115 V at 60 Hz, the charger shall not be tested.

(c) If a battery charger is designed for operation only on DC input voltage and if the provisions of section 3.1.4.(b) of this appendix do not apply, test the battery charger with an external power supply that minimally complies with the applicable energy conservation standard and meets the external power supply parameters specified by the battery charger manufacturer. The input voltage shall be within ±1 percent of the battery charger manufacturer specified voltage.

(d) If the input voltage is AC, the input frequency shall be within ±1 percent of the specified frequency. The THD of the input voltage shall be ≤2 percent, up to and including the 13th harmonic. The crest factor of the input voltage shall be between 1.34 and 1.49.

(e) If the input voltage is DC, the AC ripple voltage (RMS) shall be:

(1) ≤0.2 V for DC voltages up to 10 V; or

(2) ≤2 percent of the DC voltage for DC voltages over 10 V.

3.2. Unit Under Test Setup Requirements

3.2.1. General Setup

(a) The battery charger system shall be prepared and set up in accordance with the manufacturer's instructions, except where those instructions conflict with the requirements of this test procedure. If no instructions are given, then factory or ''default'' settings shall be used, or where there are no indications of such settings, the UUT shall

be tested in the condition as it would be supplied to an end user.

(b) If the battery charger has user controls to select from two or more charge rates (such as regular or fast charge) or different charge currents, the test shall be conducted at the fastest charge rate that is recommended by the manufacturer for everyday use, or, failing any explicit recommendation, the factory-default charge rate. If the charger has user controls for selecting special charge cycles that are recommended only for occasional use to preserve battery health, such as equalization charge, removing memory, or battery conditioning, these modes are not required to be tested. The settings of the controls shall be listed in the report for each test.

3.2.2. Selection and Treatment of the Battery Charger

The UUT, including the battery charger and its associated battery, shall be new products of the type and condition that would be sold to a customer. If the battery is lead-acid chemistry and the battery is to be stored for more than 24 hours between its initial acquisition and testing, the battery shall be charged before such storage.

3.2.3. Selection of Batteries To Use for Testing

(a) For chargers with integral batteries, the battery packaged with the charger shall be used for testing. For chargers with detachable batteries, the battery or batteries to be used for testing will vary depending on whether there are any batteries packaged with the battery charger.

(1) If batteries are packaged with the charger, batteries for testing shall be selected from the batteries packaged with the battery charger, according to the procedure in section 3.2.3(b) of this appendix.

(2) If no batteries are packaged with the charger, but the instructions specify or recommend batteries for use with the charger, batteries for testing shall be selected from those recommended or specified in the instructions, according to the procedure in section 3.2.3(b) of this appendix.

(3) If no batteries are packaged with the charger and the instructions do not specify or recommend batteries for use with the charger, batteries for testing shall be selected from any that are suitable for use with the charger, according to the procedure in section 3.2.3(b) of this appendix.

(b)(1) From the detachable batteries specified in section 3.2.3.(a) of this appendix, use Table 3.2.1 of this appendix to select the batteries to be used for testing, depending on the type of battery charger being tested. The battery charger types represented by the rows in the table are mutually exclusive. Find the single applicable row for the UUT, and test according to those requirements. Select only the single battery configuration specified for the battery charger type in Table 3.2.1 of this section.

(2) If the battery selection criteria specified in Table 3.2.1 of this appendix results in two or more batteries or configurations of batteries of different chemistries, but with equal voltage and capacity ratings, determine the maintenance mode power, as specified in section 3.3.9 of this appendix, for each of the batteries or configurations of batteries, and select for testing the battery or configuration of batteries with the highest maintenance mode power.

(c) A charger is considered as:

(1) Single-capacity if all associated batteries have the same nameplate battery charge capacity (see definition) and, if it is a batch charger, all configurations of the batteries have the same nameplate battery charge capacity.

(2) Multi-capacity if there are associated batteries or configurations of batteries that have different nameplate battery charge capacities.

(d) The selected battery or batteries will be referred to as the ''test battery'' and will be used through the remainder of this test procedure.

TABLE 3.2.1—BATTERY SELECTION FOR TESTING

Type of charger			Tests to perform
Multi-voltage	Multi-port	Multi-capacity	Battery selection (from all configurations of all associated batteries)
No	No	No	Any associated battery.
No	No	Yes	Highest charge capacity battery.
No	Yes	Yes or No	Use all ports. Use the maximum number of identical batteries with the highest nameplate battery charge capacity that the charger can accommodate.
Yes	No	No	Highest voltage battery.
Yes	Yes to either or both		Use all ports. Use the battery or configuration of batteries with the highest individual voltage. If multiple batteries meet this criteria, then use the battery or configuration of batteries with the highest total nameplate battery charge capacity at the highest individual voltage.

3.2.4. Limiting Other Non-Battery-Charger Functions

(a) If the battery charger or product containing the battery charger does not have any additional functions unrelated to battery charging, this section may be skipped.

(b) Any optional functions controlled by the user and not associated with the battery charging process (e.g., the answering machine in a cordless telephone charging base) shall be switched off. If it is not possible to switch such functions off, they shall be set to their lowest power-consuming mode during the test.

(c) If the battery charger takes any physically separate connectors or cables not required for battery charging but associated with its other functionality (such as phone lines, serial or USB connections, Ethernet, cable TV lines, etc.), these connectors or cables shall be left disconnected during the testing.

(d) Any manual on-off switches specifically associated with the battery charging process shall be switched on for the duration of the charge, maintenance, and no-battery mode tests, and switched off for the off mode test.

3.2.5. Accessing the Battery for the Test

(a) The technician may need to disassemble the end-use product or battery charger to gain access to the battery terminals for the Battery Discharge Energy Test in section 3.3.8 of this appendix. If the battery terminals are not clearly labeled, the technician shall use a voltmeter to identify the positive and negative terminals. These terminals will be the ones that give the largest voltage difference and are able to deliver significant current (0.2 C or 1/hr) into a load.

(b) All conductors used for contacting the battery must be cleaned and burnished prior to connecting in order to decrease voltage drops and achieve consistent results.

(c) Manufacturer's instructions for disassembly shall be followed, except those instructions that:

(1) Lead to any permanent alteration of the battery charger circuitry or function;

(2) Could alter the energy consumption of the battery charger compared to that experienced by a user during typical use, e.g., due to changes in the airflow through the enclosure of the UUT; or

(3) Conflict requirements of this test procedure.

(d) Care shall be taken by the technician during disassembly to follow appropriate safety precautions. If the functionality of the device or its safety features is compromised, the product shall be discarded after testing.

(e) Some products may include protective circuitry between the battery cells and the remainder of the device. If the manufacturer provides a description for accessing the connections at the output of the protective circuitry, these connections shall be used to discharge the battery and measure the discharge energy. The energy consumed by the protective circuitry during discharge shall not be measured or credited as battery energy.

(f) If any of the following conditions specified in sections 3.2.5.(f)(1) to 3.2.5.(f)(3) of this appendix are applicable, preventing the measurement of the Battery Discharge Energy and the Charging and Maintenance Mode Energy, a manufacturer must submit a petition for a test procedure waiver in accordance with §430.27:

(1) Inability to access the battery terminals;

(2) Access to the battery terminals destroys charger functionality; or

(3) Inability to draw current from the test battery.

3.2.6. Determining Charge Capacity for Batteries With No Rating

(a) If there is no rating for the battery charge capacity on the battery or in the instructions, then the technician shall determine a discharge current that meets the following requirements. The battery shall be fully charged and then discharged at this constant-current rate until it reaches the end-of-discharge voltage specified in Table 3.3.2 of this appendix. The discharge time must be not less than 4.5 hours nor more than 5 hours. In addition, the discharge test (section 3.3.8 of this appendix) (which may not be starting with a fully-charged battery) shall reach the end-of-discharge voltage within 5 hours. The same discharge current shall be used for both the preparations step (section 3.3.4 of this appendix) and the discharge test (section 3.3.8 of this appendix). The test report shall include the discharge current used and the resulting discharge times for both a fully-charged battery and for the discharge test.

(b) For this section, the battery is considered as ''fully charged'' when either: it has been charged by the UUT until an indicator on the UUT shows that the charge is complete; or it has been charged by a battery analyzer at a current not greater than the discharge current until the battery analyzer indicates that the battery is fully charged.

(c) When there is no capacity rating, a suitable discharge current must generally be determined by trial and error. Since the conditioning step does not require constant-current discharges, the trials themselves may also be counted as part of battery conditioning.

3.3. Test Measurement

The test sequence to measure the battery charger energy consumption is summarized in Table 3.3.1 of this appendix, and explained

in detail in this appendix. Measurements shall be made under test conditions and with the equipment specified in sections 3.1 and 3.2 of this appendix.

TABLE 3.3.1—TEST SEQUENCE

Step/description	Equipment needed					
	Data taken?	Test battery	Charger	Battery analyzer or constant-current load	AC power meter	Thermometer (for flooded lead-acid battery chargers only)
1. Record general data on UUT; Section 3.3.1	Yes	X	X			
2. Determine Active and Maintenance Modes Test duration; Section 3.3.2.	No					
3. Battery conditioning; Section 3.3.3	No	X	X	X		
4. Prepare battery for Active Mode test; Section 3.3.4	No	X	X			
5. Battery rest period; Section 3.3.5	No	X				X
6. Conduct Active and Maintenance Modes Test; Section 3.3.6.	Yes	X	X		X	
7. Battery Rest Period; Section 3.3.7	No	X				X
8. Battery Discharge Energy Test; Section 3.3.8	Yes	X		X		
9. Determine the Maintenance Mode Power; Section 3.3.9.	Yes	X	X		X	
10. Determine Active Charge Energy; Section 3.3.10	Yes	X	X		X	
11. Conduct No-Battery Mode Test; Section 3.3.11	Yes		X		X	
12. Conduct Off Mode Test; Section 3.3.12	Yes		X		X	
13. Calculating Standby Mode Power; Section 3.3.13	Yes					

3.3.1. Recording General Data on the UUT

The technician shall record:

(a) The manufacturer and model of the battery charger;

(b) The presence and status of any additional functions unrelated to battery charging;

(c) The manufacturer, model, and number of batteries in the test battery;

(d) The nameplate battery voltage of the test battery;

(e) The nameplate battery charge capacity of the test battery; and

(f) The nameplate battery charge energy of the test battery.

(g) The settings of the controls, if battery charger has user controls to select from two or more charge rates.

3.3.2. Determining the Duration of the Charge and Maintenance Modes Test

(a) The charge and maintenance modes test, described in detail in section 3.3.6 of this appendix, shall be 24 hours in length or longer, as determined by the items in sections 3.3.2.(a)(1) to 3.3.2.(a)(3) of this appendix. Proceed in order until a test duration is determined. In case when the battery charger does not enter its true battery maintenance mode, the test shall continue until 5 hours after the true battery maintenance mode has been captured.

(1) If the battery charger has an indicator to show that the battery is fully charged, that indicator shall be used as follows: if the indicator shows that the battery is charged after 19 hours of charging, the test shall be terminated at 24 hours. Conversely, if the full-charge indication is not yet present after 19 hours of charging, the test shall continue until 5 hours after the indication is present.

(2) If there is no indicator, but the manufacturer's instructions indicate that charging this battery or this capacity of battery should be complete within 19 hours, the test shall be for 24 hours. If the instructions indicate that charging may take longer than 19 hours, the test shall be run for the longest estimated charge time plus 5 hours.

(3) If there is no indicator and no time estimate in the instructions, but the charging current is stated on the charger or in the instructions, calculate the test duration as the longer of 24 hours or:

$$Duration = 1.4 * \frac{RatedChargeCapacity(Ah)}{ChargeCurrent(A)} + 5h$$

(b) If none of section 3.3.2.(a) applies, the duration of the test shall be 24 hours.

3.3.3. Battery Conditioning

(a) No conditioning is to be done on lithium-ion batteries. The test technician shall proceed directly to battery preparation, section 3.3.4 of this appendix, when testing chargers for these batteries.

(b) Products with integral batteries will have to be disassembled per the instructions in section 3.2.5 of this appendix, and the battery disconnected from the charger for discharging.

(c) Batteries of other chemistries that have not been previously cycled are to be conditioned by performing two charges and two discharges, followed by a charge, as sections 3.3.3.(c)(1) to 3.3.3.(c)(5) of this appendix. No data need be recorded during battery conditioning.

(1) The test battery shall be fully charged for the duration specified in section 3.3.2 of this appendix or longer using the UUT.

(2) The test battery shall then be fully discharged using either:

(i) A battery analyzer at a rate not to exceed 1 C, until its average cell voltage under load reaches the end-of-discharge voltage specified in Table 3.3.2 of this appendix for the relevant battery chemistry; or

(ii) The UUT, until the UUT ceases operation due to low battery voltage.

(3) The test battery shall again be fully charged per step in section 3.3.3(c)(1) of this appendix.

(4) The test battery shall again be fully discharged per step in section 3.3.3(c)(2) of this appendix.

(5) The test battery shall be again fully charged per step in section 3.3.3(c)(1) of this appendix.

(d) Batteries of chemistries, other than lithium-ion, that are known to have been through at least two previous full charge/discharge cycles shall only be charged once per step in section 3.3.3(c)(5) of this appendix.

3.3.4. Preparing the Battery for Charge Testing

Following any conditioning prior to beginning the battery charge test (section 3.3.6 of this appendix), the test battery shall be fully discharged to the end of discharge voltage prescribed in Table 3.3.2 of this appendix, or until the UUT circuitry terminates the discharge.

3.3.5. Resting the Battery

The test battery shall be rested between preparation and the battery charge test. The rest period shall be at least one hour and not exceed 24 hours. For batteries with flooded cells, the electrolyte temperature shall be less than 30 °C before charging, even if the rest period must be extended longer than 24 hours.

3.3.6. Testing Active Charge Mode and Battery Maintenance Mode

(a) The Active Charge and Battery Maintenance Modes test measures energy consumed during charge mode and some time spent in the maintenance mode of the UUT. Functions required for battery conditioning that happen only with some user-selected switch or other control shall not be included in this measurement. (The technician shall manually turn off any battery conditioning cycle or setting.) Regularly occurring battery conditioning or maintenance functions that are not controlled by the user will, by default, be incorporated into this measurement.

(b) During the measurement period, input power values to the UUT shall be recorded at least once every minute.

(1) If possible, the technician shall set the data logging system to record the average power during the sample interval. The total energy is computed as the sum of power samples (in watts) multiplied by the sample interval (in hours).

(2) If this setting is not possible, then the power analyzer shall be set to integrate or accumulate the input power over the measurement period and this result shall be used as the total energy.

(c) The technician shall follow these steps:

(1) Ensure that the user-controllable device functionality not associated with battery charging and any battery conditioning cycle or setting are turned off, as instructed in section 3.2.4 of this appendix;

(2) Ensure that the test battery used in this test has been conditioned, prepared, discharged, and rested as described in sections 3.3.3. through 3.3.5. of this appendix;

(3) Connect the data logging equipment to the battery charger;

(4) Record the start time of the measurement period, and begin logging the input power;

(5) Connect the test battery to the battery charger within 3 minutes of beginning logging. For integral battery products, connect the product to a cradle or EPS within 3 minutes of beginning logging;

(6) After the test battery is connected, record the initial time and power (W) of the input current to the UUT. These measurements shall be taken within the first 10 minutes of active charging;

(7) Record the input power for the duration of the ''Maintenance Mode Test'' period, as determined by section 3.3.2. of this appendix. The actual time that power is connected to the UUT shall be within ±5 minutes of the specified period; and

(8) Disconnect power to the UUT, terminate data logging, and record the final time.

3.3.7. Resting the Battery

The test battery shall be rested between charging and discharging. The rest period

shall be at least 1 hour and not more than 4 hours, with an exception for flooded cells. For batteries with flooded cells, the electrolyte temperature shall be less than 30 °C before charging, even if the rest period must be extended beyond 4 hours.

3.3.8. Battery Discharge Energy Test

(a) If multiple batteries were charged simultaneously, the discharge energy (E_{batt}) is the sum of the discharge energies of all the batteries.

(1) For a multi-port charger, batteries that were charged in separate ports shall be discharged independently.

(2) For a batch charger, batteries that were charged as a group may be discharged individually, as a group, or in sub-groups connected in series and/or parallel. The position of each battery with respect to the other batteries need not be maintained.

(b) During discharge, the battery voltage and discharge current shall be sampled and recorded at least once per minute. The values recorded may be average or instantaneous values.

(c) For this test, the technician shall follow these steps:

(1) Ensure that the test battery has been charged by the UUT and rested according to the procedures prescribed in sections 3.3.6 and 3.3.7 of this appendix.

(2) Set the battery analyzer for a constant discharge rate and the end-of-discharge voltage in Table 3.3.2 of this appendix for the relevant battery chemistry.

(3) Connect the test battery to the analyzer and begin recording the voltage, current, and wattage, if available from the battery analyzer. When the end-of-discharge voltage is reached or the UUT circuitry terminates the discharge, the test battery shall be returned to an open-circuit condition. If current continues to be drawn from the test battery after the end-of-discharge condition is first reached, this additional energy is not to be counted in the battery discharge energy.

(d) If not available from the battery analyzer, the battery discharge energy (in watt-hours) is calculated by multiplying the voltage (in volts), current (in amperes), and sample period (in hours) for each sample, and then summing over all sample periods until the end-of-discharge voltage is reached.

TABLE 3.3.2—REQUIRED BATTERY DISCHARGE RATES AND END-OF-DISCHARGE BATTERY VOLTAGES

Battery chemistry	Discharge rate (C)	End-of-discharge voltage* (volts per cell)
Valve-Regulated Lead Acid (VRLA)	0.2	1.75
Flooded Lead Acid	0.2	1.70
Nickel Cadmium (NiCd)	0.2	1.0
Nickel Metal Hydride (NiMH)	0.2	1.0
Lithium-ion (Li-Ion)	0.2	2.5
Lithium-ion Polymer	0.2	2.5
Lithium Iron Phosphate	0.2	2.0
Rechargeable Alkaline	0.2	0.9
Silver Zinc	0.2	1.2

*If the presence of protective circuitry prevents the battery cells from being discharged to the end-of-discharge voltage specified, then discharge battery cells to the lowest possible voltage permitted by the protective circuitry.

3.3.9. Determining the Maintenance Mode Power

After the measurement period is complete, the technician shall determine the average maintenance mode power consumption (P_m) by examining the power-versus-time data from the charge and maintenance mode test and:

(a) If the maintenance mode power is cyclic or shows periodic pulses, compute the average power over a time period that spans a whole number of cycles and includes at least the last 4 hours.

(b) Otherwise, calculate the average power value over the last 4 hours.

3.3.10. Determining the Active Charge Energy

After the measurement period is complete, the technician shall determine the total active charge energy (E_a) by examining the power-versus-time data from the charge and maintenance mode test and:

(a) First determine when the battery charger enters maintenance mode by examining the power-versus-time data to identify when the input power enters either a steady state or a cyclic state with average power for that period being the same as the maintenance mode power determined in section 3.3.9. of this appendix.

(b) The accumulated energy or the average input power, integrated over the test period from the initial recorded input time up until when the battery charger enters maintenance mode would be the active charge energy, E_a.

3.3.11. No-Battery Mode Energy Consumption Measurement

The no-battery mode measurement depends on the configuration of the battery charger, as follows:

(a) Conduct a measurement of no-battery power consumption while the battery charger is connected to the power source. Disconnect the battery from the charger, allow the charger to operate for at least 30 minutes, and record the power (*i.e.*, watts) consumed as the time series integral of the power consumed over a 10-minute test period, divided by the period of measurement. If the battery charger has manual on-off switches, all must be turned on for the duration of the no-battery mode test.

(b) No-battery mode may also apply to products with integral batteries, as follows:

(1) If the product uses a cradle and/or adapter for power conversion and charging, then ''disconnecting the battery from the charger'' will require disconnection of the end-use product, which contains the batteries. The other enclosures of the battery charging system will remain connected to the main electricity supply, and no-battery mode power consumption will equal that of the cradle and/or adapter alone.

(2) If the product is powered through a detachable AC power cord and contains integrated power conversion and charging circuitry, then only the cord will remain connected to mains, and no-battery mode power consumption will equal that of the AC power cord (*i.e.*, zero watts).

(3) If the product contains integrated power conversion and charging circuitry but is powered through a non-detachable AC power cord or plug blades, then no part of the system will remain connected to mains, and no-battery mode measurement is not applicable.

3.3.12. Off Mode Energy Consumption Measurement

The off mode measurement depends on the configuration of the battery charger, as follows:

(a) If the battery charger has manual on-off switches, record a measurement of off mode energy consumption while the battery charger is connected to the power source. Remove the battery from the charger, allow the charger to operate for at least 30 minutes, and record the power (*i.e.*, watts) consumed as the time series integral of the power consumed over a 10-minute test period, divided by the period of measurement, with all manual on-off switches turned off. If the battery charger does not have manual on-off switches, record that the off mode measurement is not applicable to this product.

(b) Off mode may also apply to products with integral batteries, as follows:

(1) If the product uses a cradle and/or adapter for power conversion and charging, then ''disconnecting the battery from the charger'' will require disconnection of the end-use product, which contains the batteries. The other enclosures of the battery charging system will remain connected to the main electricity supply, and off mode power consumption will equal that of the cradle and/or adapter alone.

(2) If the product is powered through a detachable AC power cord and contains integrated power conversion and charging circuitry, then only the cord will remain connected to mains, and off mode power consumption will equal that of the AC power cord (*i.e.*, zero watts).

(3) If the product contains integrated power conversion and charging circuitry but is powered through a non-detachable AC power cord or plug blades, then no part of the system will remain connected to mains, and off mode measurement is not applicable.

3.3.13. Standby Mode Power

The standby mode power (P_{sb}) is the summation power of battery maintenance mode power (P_m) and no-battery mode power (P_{nb}).

4. Testing Requirements for Uninterruptible Power Supplies

4.1. Standard Test Conditions

4.1.1. Measuring Equipment

(a) The power or energy meter must provide true root mean square (r.m.s) measurements of the active input and output measurements, with an uncertainty at full rated load of less than or equal to 0.5 percent at the 95 percent confidence level notwithstanding that voltage and current waveforms can include harmonic components. The meter must measure input and output values simultaneously.

(b) All measurement equipment used to conduct the tests must be calibrated within the measurement equipment manufacturer specified calibration period by a standard traceable to International System of Units such that measurements meet the uncertainty requirements specified in section 4.1.1(a) of this appendix.

4.1.2. Test Room Requirements

All portions of the test must be carried out in a room with an air speed immediately surrounding the UUT of ≤0.5 m/s in all directions. Maintain the ambient temperature in the range of 20.0 °C to 30.0 °C, including all inaccuracies and uncertainties introduced by the temperature measurement equipment, throughout the test. No intentional cooling of the UUT, such as by use of separately powered fans, air conditioners, or heat sinks, is permitted. Test the UUT on a thermally non-conductive surface.

4.1.3. Input Voltage and Input Frequency

The AC input voltage and frequency to the UPS during testing must be within 3 percent of the highest rated voltage and within 1 percent of the highest rated frequency of the device.

4.2. Unit Under Test Setup Requirements

4.2.1. General Setup

Configure the UPS according to Annex J.2 of IEC 62040–3 Ed. 3.0 with the following additional requirements:

(a) UPS Operating Mode Conditions. If the UPS can operate in two or more distinct normal modes as more than one UPS architecture, conduct the test in its lowest input dependency as well as in its highest input dependency mode where VFD represents the lowest possible input dependency, followed by VI and then VFI.

(b) Energy Storage System. The UPS must not be modified or adjusted to disable energy storage charging features. Minimize the transfer of energy to and from the energy storage system by ensuring the energy storage system is fully charged (at the start of testing) as follows:

(1) If the UUT has a battery charge indicator, charge the battery for 5 hours after the UUT has indicated that it is fully charged.

(2) If the UUT does not have a battery charge indicator but the user manual shipped with the UUT specifies a time to reach full charge, charge the battery for 5 hours longer than the time specified.

(3) If the UUT does not have a battery charge indicator or user manual instructions, charge the battery for 24 hours.

(c) DC output port(s). All DC output port(s) of the UUT must remain unloaded during testing.

4.2.2. Additional Features

(a) Any feature unrelated to maintaining the energy storage system at full charge or delivery of load power (e.g., LCD display) shall be switched off. If it is not possible to switch such features off, they shall be set to their lowest power-consuming mode during the test.

(b) If the UPS takes any physically separate connectors or cables not required for maintaining the energy storage system at full charge or delivery of load power but associated with other features (such as serial or USB connections, Ethernet, etc.), these connectors or cables shall be left disconnected during the test.

(c) Any manual on-off switches specifically associated with maintaining the energy storage system at full charge or delivery of load power shall be switched on for the duration of the test.

4.3. Test Measurement and Calculation

Efficiency can be calculated from either average power or accumulated energy.

4.3.1. Average Power Calculations

If efficiency calculation are to be made using average power, calculate the average power consumption (P_{avg}) by sampling the power at a rate of at least 1 sample per second and computing the arithmetic mean of all samples over the time period specified for each test as follows:

$$P_{avg} = \frac{1}{n}\sum_{i=1}^{n} P_i$$

Where:

P_{avg} = average power
P_i = power measured during individual measurement (i)
n = total number of measurements

4.3.2. Steady State

Operate the UUT and the load for a sufficient length of time to reach steady state conditions. To determine if steady state conditions have been attained, perform the following steady state check, in which the difference between the two efficiency calculations must be less than 1 percent:

(a)(1) Simultaneously measure the UUT's input and output power for at least 5 minutes, as specified in section 4.3.1 of this appendix, and record the average of each over the duration as P_{avg_in} and P_{avg_out}, respectively; or,

(2) Simultaneously measure the UUT's input and output energy for at least 5 minutes and record the accumulation of each over the duration as E_{in} and E_{out}, respectively.

(b) Calculate the UUT's efficiency, Eff_1, using one of the following two equations:

(1)

$$Eff = \frac{P_{avg_out}}{P_{avg_in}}$$

Where:

Eff is the UUT efficiency

P_{avg_out} is the average output power in watts

P_{avg_in} is the average input power in watts

(2)

$$Eff = \frac{E_{out}}{E_{in}}$$

Where:

Eff is the UUT efficiency

E_{out} is the accumulated output energy in watt-hours

E_{in} in the accumulated input energy in watt-hours

(c) Wait a minimum of 10 minutes.

(d) Repeat the steps listed in paragraphs (a) and (b) of section 4.3.2 of this appendix to calculate another efficiency value, Eff_2.

(e) Determine if the product is at steady state using the following equation:

$$Percentage\ difference = \frac{|Eff_1 - Eff_2|}{Average(Eff_1, Eff_2)}$$

If the percentage difference of Eff_1 and Eff_2 as described in the equation, is less than 1 percent, the product is at steady state.

(f) If the percentage difference is greater than or equal to 1 percent, the product is not at steady state. Repeat the steps listed in paragraphs (c) to (e) of section 4.3.2 of this appendix until the product is at steady state.

4.3.3. Power Measurements and Efficiency Calculations

Measure input and output power of the UUT according to section J.3 of Annex J of IEC 62040–3 Ed. 3.0, or measure the input and output energy of the UUT for efficiency calculations with the following exceptions:

(a) Test the UUT at the following reference test load conditions, in the following order: 100 percent, 75 percent, 50 percent, and 25 percent of the rated output power.

(b) Perform the test at each of the reference test loads by simultaneously measuring the UUT's input and output power in Watts (W), or input and output energy in Watt-Hours (Wh) over a 15 minute test period at a rate of at least 1 Hz. Calculate the efficiency for that reference load using one of the following two equations:

(1)

$$Eff_{n\%} = \frac{P_{avg_out\ n\%}}{P_{avg_in\ n\%}}$$

Where:

$Eff_{n\%}$ = the efficiency at reference test load $n\%$

$P_{avg_out\ n\%}$ = the average output power at reference load $n\%$

$P_{avg_in\ n\%}$ = the average input power at reference load $n\%$

(2)

$$Eff_{n\%} = \frac{E_{out\ n\%}}{E_{in\ n\%}}$$

Where:

$Eff_{n\%}$ = the efficiency at reference test load $n\%$

$E_{out\ n\%}$ = the accumulated output energy at reference load $n\%$

$E_{in\ n\%}$ = the accumulated input energy at reference load $n\%$

(c) For representations of no-load losses, measure the active power at the UPS input port with no load applied in accordance with section 6.2.2.4 of IEC 62040–3 Ed. 3.0.

4.3.4. UUT Classification

Optional Test for determination of UPS architecture. Determine the UPS architecture by performing the tests specified in the definitions of VI, VFD, and VFI (sections 2.28.1 through 2.28.3 of this appendix).

4.3.5. Output Efficiency Calculation

(a) Use the load weightings from Table 4.3.1 to determine the average load adjusted efficiency as follows:

$Eff_{avg} = (t_{25\%} \times Eff|_{25\%}) + (t_{50\%} \times Eff|_{50\%}) + (t_{75\%} \times Eff|_{75\%}) + (t_{100\%} \times Eff|_{100\%})$

Where:

Eff_{avg} = the average load adjusted efficiency

$t_{n\%}$ = the portion of time spent at reference test load $n\%$ as specified in Table 4.3.1

$Eff|_{n\%}$ = the measured efficiency at reference test load $n\%$

TABLE 4.3.1—LOAD WEIGHTINGS

		Portion of time spent at reference load			
Rated output power (W)	UPS architecture	25%	50%	75%	100%
P ≤ 1500 W	VFD	0.2	0.2	0.3	0.3
	VI or VFI	0*	0.3	0.4	0.3
P > 1500 W	VFD, VI, or VFI	0*	0.3	0.4	0.3

*Measuring efficiency at loading points with 0 time weighting is not required.

(b) Round the calculated efficiency value to one tenth of a percentage point.

5. Testing Requirements for Open-Placement Wireless Chargers

5.1. Standard Test Conditions and UUT Setup Requirements

The technician will set up the testing environment according to the test conditions as specified in sections 3.1.2, 3.1.3, and 3.1.4 of this appendix. The unit under test will be configurated according to section 3.2.1 and all other non-battery charger related functions will be turned off according to section 3.2.4.

5.2. Active Mode Test

[Reserved]

5.3. No-Battery Mode Test

(a) Connect the UUT to mains power and place it in no-battery mode by ensuring there are no foreign objects on the charging surface (*i.e.*, without any load).

(b) Monitor the AC input power for a period of 5 minutes to assess the stability of the UUT. If the power level does not drift by more than 1percent from the maximum value observed, the UUT is considered stable.

(c) If the AC input power is not stable, follow the specifications in Section 5.3.3. of IEC 62301 for measuring average power or accumulated energy over time for the input. If the UUT is stable, record the measurements of the AC input power over a 5-minute period.

(d) Power consumption calculation. The power consumption of the no-battery mode is equal to the active AC input power (W).

[87 FR 55125, Sept. 8, 2022, as amended at 89 FR 28593, Apr. 19, 2024]

APPENDIX Z TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF EXTERNAL POWER SUPPLIES

NOTE: Starting on February 15, 2023, manufacturers must make any representations regarding the energy efficiency or power consumption of external power supplies based upon results generated under this appendix. Prior to that date, manufacturers must make any representations regarding the energy efficiency or power consumption of external power supplies based upon results generated under this appendix as it appeared at

10 CFR part 430, subpart B revised as of January 1, 2021. The provisions at section (4)(g) of this appendix regarding the testing of units for which a wire or cord is not provided by the manufacturer are not required for use until such time as compliance is required with any amended standards for external power supplies provided in §430.32(w) that are published after January 1, 2021.

0. Incorporation by reference.

DOE incorporated by reference the entire standard for IEC 62301 in §430.3; however, only enumerated provisions of this document are applicable to this appendix, as follows:

0.1 IEC 62301, (''IEC 62301''), Household electrical appliances—Measurement of standby power, (Edition 2.0, 2011–01), as follows:

(a) Section 4.3.2 ''Supply voltage waveform,'' as referenced in section 3 of this appendix;

(b) Section 4.4.1 ''Power measurement uncertainty,'' as referenced in section 4 of this appendix;

(c) Section 5.3.3 ''Average reading method,'' as referenced in sections 5 and 6 of this appendix;

(d) Annex B ''Notes on the measurement of low power modes,'' as referenced in section 4 of this appendix; and

(e) Annex D ''Determination of uncertainty of measurement,'' as referenced in section 4 of this appendix.

0.2 Reserved.

1. [Reserved]

2. Scope:

This appendix covers the test requirements used to measure the energy consumption of external power supplies subject to the energy conservation standards set forth at §430.32(w)(1). Additionally, this appendix does not apply to external power supplies for which the primary load of the converted voltage within the device is not delivered to a separate end-use product, *i.e.*, products in which the primary load of converted voltage is delivered within the device itself to execute the primary function of the device. Examples of excluded products may include, but are not limited to, consumer electronics with USB outputs and lighting products with USB outputs.

3. Definitions:

The following definitions are for the purposes of understanding terminology associated with the test method for measuring external power supply energy consumption.

Active mode means the mode of operation when the external power supply is connected to the main electricity supply and the output is (or ''all outputs are'' for external power supplies with multiple outputs) connected to a load (or ''loads'' for external power supplies with multiple outputs).

Active mode efficiency is the ratio, expressed as a percentage, of the total real output power produced by a power supply to the real input power required to produce it. IEEE Standard 1515–2000, 4.3.1.1 (Reference for guidance only, see §430.4.)

Active power (P) (also *real power*) means the average power consumed by a unit. For a two-terminal device with current and voltage waveforms i(t) and v(t), respectively, which are periodic with period T, the real or active power P is:

$$P = \frac{1}{T}\int_0^T v(t)i(t)dt$$

Adaptive external power supply means an external power supply that can alter its output voltage during active-mode based on an established digital communication protocol with the end-use application without any user-generated action.

Ambient temperature means the temperature of the ambient air immediately surrounding the unit under test.

Average Active-Mode Efficiency means the average of the active mode efficiencies at the loading conditions (100, 75, 50 percent, and 25 percent of unit under test's nameplate output current) for which that unit can sustain the output current.

Manual on-off switch is a switch activated by the user to control power reaching the device. This term does not apply to any mechanical, optical, or electronic switches that automatically disconnect mains power from the device when a load is disconnected from the device, or that control power to the load itself.

Minimum output current means the minimum current that must be drawn from an output bus for an external power supply to operate within its specifications.

Multiple-voltage external power supply means an external power supply that is designed to convert line voltage AC input into

more than one simultaneous lower-voltage output.

Nameplate output current means the current output of the power supply as specified on the manufacturer's label on the power supply housing (either DC or AC) or, if absent from the housing, as provided by the manufacturer.

Nameplate output power means the power output of the power supply as specified on the manufacturer's label on the power supply housing or, if absent from the housing, as specified in documentation provided by the manufacturer. For an adaptive external power supply with USB–PD ports, in place of the nameplate output power at the lowest voltage, use an output power calculated as the product of its lowest nameplate output voltage and 2 amps for each USB–PD port and as specified on the manufacturer's label or documentation at the highest voltage. This definition only applies to DOE testing and certification requirements and is unrelated to the physical nameplate label or documentation of an EPS.

Nameplate output voltage means the voltage output of the power supply as specified on the manufacturer's label on the power supply housing (either DC or AC).

No-load mode means the mode of operation when an external power supply is connected to the main electricity supply and the output is (or ''all outputs are'' for a multiple-voltage external power supply) not connected to a load (or ''loads'' for a multiple-voltage external power supply).

Off-mode is the condition, applicable only to units with manual on-off switches, in which the external power supply is:

(1) Connected to the main electricity supply;

(2) The output is not connected to any load; and

(3) All manual on-off switches are turned off.

Output bus means any of the outputs of the power supply to which loads can be connected and from which power can be drawn, as opposed to signal connections used for communication.

RMS means root mean square.

Single-voltage external AC–AC power supply means an external power supply that is designed to convert line voltage AC input into lower voltage AC output and is able to convert to only one AC output voltage at a time.

Single-voltage external AC–DC power supply means an external power supply that is designed to convert line voltage AC input into lower-voltage DC output and is able to convert to only one DC output voltage at a time.

Standby mode means the condition in which the external power supply is in no-load mode and, for external power supplies with manual on-off switches, all such switches are turned on.

Switch-selectable single voltage external power supply means a single-voltage AC–AC or AC–DC power supply that allows users to choose from more than one output voltage.

Total harmonic distortion (THD), expressed as a percentage, is the RMS value of an AC signal after the fundamental component is removed and interharmonic components are ignored, divided by the RMS value of the fundamental component. THD of current is defined as:

$$THD = \frac{\sqrt{I_2^2 + I_3^2 + I_4^2 + \cdots I_n^2}}{I_1}$$

where I_n is the RMS value of the nth harmonic of the current signal.

Unit under test (UUT) is the external power supply being tested.

USB Power Delivery (USB–PD) EPS means an adaptive EPS that utilizes a USB Type-C output port and uses a digital protocol to communicate between the EPS and the end-use product to automatically switch between any output voltage within the range of 3.3 volts to 20 volts. The USB–PD output bus must be capable of delivering 3 amps at the lowest output voltage, and the currents must not exceed any of the following values for the supported voltages: 3 amps at 9 volts; 3 amps at 15 volts; and 5 amps at 20 volts.

USB Type-C means the reversible 24-pin physical USB connector system that supports USB–PD and allows for the transmission of data and power between compatible USB products.

4. Test Apparatus and General Instructions

(a) Any power measurements recorded, as well as any power measurement equipment utilized for testing, shall conform to the uncertainty and resolution specifications in Section 4.4.1, ''Power measurement uncertainty,'' as well as Annexes B, ''Notes on the measurement of low power modes,'' and D, ''Determination of uncertainty of measurement,'' of IEC 62301.

(b) Carry out tests in a room that has an air speed close to the UUT of ≤0.5 m/s. Maintain ambient temperature at 20 ± 5 °C throughout the test. Do not intentionally cool the UUT, for example, by use of separately powered fans, air conditioners, or heat sinks. Test the UUT on a thermally non-conductive surface. Products intended for outdoor use may be tested at additional temperatures, provided those are in addition to the conditions specified and are noted in a separate section on the test report.

(c) If the UUT is intended for operation on AC line-voltage input in the United States, test it at 115 V at 60 Hz. If the UUT is intended for operation on AC line-voltage input but cannot be operated at 115 V at 60 Hz, do not test it. Ensure the input voltage is within ±1 percent of the above specified voltage and the input frequency is within ±1 percent of the specified frequency.

(d) The input voltage source must be capable of delivering at least 10 times the nameplate input power of the UUT as is specified in IEEE 1515–2000 (Referenced for guidance only, see § 430.4). Regardless of the AC source type, the THD of the supply voltage when supplying the UUT in the specified mode must not exceed 2 percent, up to and including the 13th harmonic. The peak value of the test voltage must be within 1.34 and 1.49 multiplied by its RMS value.

(e) Select all leads used in the test set-up with appropriate wire gauges and lengths to minimize voltage drops across the wires during testing. See Table B.2 — ''Commonly used values for wire gages [*sic*] and related voltage drops'' in IEEE 1515–2000 for further guidance.

(f) Test Load. To load the power supply to produce all active-mode loading conditions, use passive loads, such as rheostats, or active loads, such as electronic loads. Resistive loads need not be measured precisely with an ohmmeter; simply adjust a variable resistor to the point where the ammeter confirms that the desired percentage of nameplate output current is flowing. For electronic loads, adjust the desired output current in constant current mode rather than adjusting the required output power in constant power mode.

(g) Test the external power supply at the end of the wire or cord that connects to an end-use product, regardless of whether the end of the wire or cord is integrated into an end-use product or plugs into and out of an end-use product. If a separate wire or cord is provided by the manufacturer to connect the external power supply to an end-use product, use this wire or cord and perform tests at the end of the cord that connects to an end-use product. An external power supply that is not supplied with a wire or cord must be tested with a wire or an output cord recommended by the manufacturer. If the external power supply is not supplied with a wire or cord and for which the manufacturer does not recommend one, the EPS must be tested with a 3-foot-long output wire or cord with a conductor thickness that is minimally sufficient to carry the maximum required current.

(1) If the connection to an end-use product is removable, there are two options for connecting metering equipment to the output connection of the external power supply:

(i) Cut the cord immediately adjacent to the output connector, or

(ii) Attach leads and measure the efficiency from the output connector itself.

(2) If the connection to an end-use product is not removable, cut the cord immediately adjacent to the powered product and connect metering equipment at that point.

(h) Conduct the tests on the sets of output wires that constitute the output busses. If the product has more than two output wires, including those wires that are necessary for controlling the product, the manufacturer must supply a connection diagram or test fixture that will allow the testing laboratory to put the UUT into active mode. Figure 1 of this section provides one illustration of how to set up a single-voltage external power supply for testing; however, the actual test setup may vary pursuant to the type of external power supply being tested and the requirements of this appendix.




Figure 1. Example Connection Diagram for Single-Voltage External Power Supply Efficiency Measurements

(i) Except as provided in section 4(j) of this appendix, external power supplies must be tested in their final, completed configuration in order to represent their measured efficiency on product labels or specification sheets. Although the same procedure may be used to test the efficiency of a bare circuit board power supply prior to its incorporation into a finished housing and the attachment of its DC output cord, the efficiency of the bare circuit board power supply may not be used to characterize the efficiency of the final product (once enclosed in a case and fitted with a DC output cord). For example, a power supply manufacturer or component manufacturer may wish to assess the efficiency of a design that it intends to provide to an OEM for incorporation into a finished external power supply, but these results may not be used to represent the efficiency of the finished external power supply.

(j) If a product serves one or more other major functions in addition to converting household electric current into DC current or lower-voltage AC current, components of the product that serve other functions may be disconnected before testing so that test measurements do not include power used by other functions and as long as disconnecting such components do not affect the ability of the product to convert household electric current into DC current or lower-voltage AC current. For example, consider an EPS that also acts as a surge protector that offers outlets supplying AC household electric current and one or more USB outputs supplying DC current. If power is provided to the AC outlets through a surge protection circuit, but power to the USB outlet(s) is not, then the surge protection circuit may be disconnected from AC power during testing. Similarly, if a lighted manual on-off switch disconnects power only to the AC outlets, but not the USB outputs, then the manual on-off switch may be turned off and power to the light disconnected during testing. If a disconnection is performed by a technician, the disconnection must be able to be replicated by a third-party test facility.

5. Test Measurement for all External Power Supplies Other than Adaptive External Power Supplies:

(a) Single-Voltage External Power Supply

(1) Standby Mode and Active-Mode Measurement.

(i) Place in the ''on'' position any built-in switch in the UUT controlling power flow to the AC input and note the existence of such a switch in the final test report.

(ii) Operate the UUT at 100 percent of nameplate output current for at least 30 minutes immediately prior to conducting efficiency measurements. After this warm-up period, monitor AC input power for a period of 5 minutes to assess the stability of the UUT. If the power level does not drift by more than 5 percent from the maximum value observed, the UUT is considered stable. If the UUT is stable, record the measurements obtained at the end of this 5-minute period. Measure subsequent loading conditions under the same 5-minute stability parameters. Note that only one warm-up period of 30 minutes is required for each UUT at the beginning of the test procedure. If the AC input power is not stable over a 5-minute period, follow the guidelines established by Section 5.3.3 of IEC 62301 for measuring average power or accumulated energy over time for both input and output.

(iii) Test the UUT at the nameplate output voltage(s) at the loading conditions listed in Table 1, derated per the proportional allocation method presented in section 5(a)(1)(iv) of this appendix. Conduct efficiency measurements in sequence from Loading Condition 1 to Loading Condition 4 as indicated in Table 1 of this section. For Loading Condition 5, place the UUT in no-load mode, disconnect any additional signal connections to the UUT, and measure input power.

TABLE 1—LOADING CONDITIONS FOR UNIT UNDER TEST

Loading Condition 1	100% of Derated Nameplate Output Current ±2%.
Loading Condition 2	75% of Derated Nameplate Output Current ±2%.
Loading Condition 3	50% of Derated Nameplate Output Current ±2%.
Loading Condition 4	25% of Derated Nameplate Output Current ±2%.
Loading Condition 5	0%.

Note: The 2 percent allowance pertains to nameplate output current, not the calculated current value. For example, a UUT at Loading Condition 3 may be tested in a range from 48 percent to 52 percent of the derated output current.

(A) If testing of additional, optional loading conditions is desired, conduct that testing in accordance with this test procedure and subsequent to completing the sequence described in section 5(a)(1)(iii) of this appendix.

(B) Where the external power supply lists both an instantaneous and continuous output current, test the external power supply at the continuous condition only.

(C) If an external power supply cannot sustain output at one or more of the Loading Conditions 1–4 as specified in Table 1 of this section, test the external power supply only at the loading conditions for which it can sustain output.

(iv) Use the following proportional allocation method to provide consistent loading conditions for single-voltage external power supplies with multiple-output busses. For additional explanation (provided for guidance only), please refer to section 6.1.1 of the California Energy Commission's ''Generalized Test Protocol for Calculating the Energy Efficiency of Internal Ac-Dc Power Supplies Revision 6.7,'' March 2014.

(A) Consider a power supply with N output busses, each with the same nameplate output voltages V_1, * * *, V_N, corresponding output current ratings I_1, * * *, I_N, and a nameplate output power P. Calculate the derating factor D by dividing the power supply maximum output power P by the sum of the maximum output powers of the individual output busses, equal to the product of port nameplate output voltage and current I_iV_i, as follows:

$$D = \frac{P}{\sum_{i=1}^{N} V_i I_i},$$

(B) If D ≥1, then loading every port to its nameplate output current does not exceed the overall maximum output power for the power supply. In this case, load each output bus to the percentages of its nameplate output current listed in Table 1 of this section. However, if D <1, it is an indication that loading each port to its nameplate output current will exceed the overall maximum output power for the power supply. In this case, and at each loading condition, load each output bus to the appropriate percentage of its nameplate output current as listed in Table 1, multiplied by the derating factor D.

(v) Test switch-selectable single-voltage external power supplies twice—once at the highest nameplate output voltage and once at the lowest.

(vi) Efficiency calculation. Calculate and record efficiency at each loading point by dividing the UUT's measured active output power at a given loading condition by the active AC input power measured at that loading condition.

(A) Calculate and record average efficiency of the UUT as the arithmetic mean of the efficiency values calculated at Loading Conditions 1, 2, 3, and 4 in Table 1 of this section.

(B) If, when tested, a UUT cannot sustain output current at one or more of the loading conditions as specified in Table 1, the average active-mode efficiency is calculated as the average of the loading conditions for which it can sustain output.

(C) If the UUT can only sustain one output current at any of the output busses, test it at the loading condition that allows for the maximum output power on that bus (*i.e.,* the highest output current possible at the highest output voltage on that bus).

(vii) Power consumption calculation. The power consumption of Loading Condition 5 (no-load) is equal to the active AC input power (W) at that loading condition.

(viii) Off-Mode Measurement. If the UUT incorporates manual on-off switches, place the UUT in off-mode, and measure and record its power consumption at Loading Condition 5 in Table 1 of this section. The measurement of the off-mode energy consumption must conform to the requirements specified in section 5(a)(1) of this appendix, except that all manual on-off switches must be placed in the ''off'' position for the off-mode measurement. The UUT is considered stable if, over 5 minutes with samples taken at least once every second, the AC input power does not drift from the maximum value observed by more than 1 percent or 50 milliwatts, whichever is greater. Measure the off-mode power consumption of a switch-selectable single-voltage external power supply twice—once at the highest nameplate output voltage and once at the lowest.

(b) Multiple-Voltage External Power Supply.

(1) Standby-Mode and Active-Mode Measurement.

(i) Place in the ''on'' position any built-in switch in the UUT controlling power flow to the AC input and note the existence of such a switch in the final test report.

(ii) Operate the UUT at 100 percent of nameplate output current for at least 30 minutes immediately prior to conducting efficiency measurements. After this warm-up period, monitor AC input power for a period of 5 minutes to assess the stability of the UUT. If the power level does not drift by more than 1 percent from the maximum value observed, the UUT is considered stable. If the UUT is stable, record the measurements obtained at the end of this 5-minute period. Measure subsequent loading conditions under the same 5-minute stability parameters. Note that only one warm-up period of 30 minutes is required for each UUT at the beginning of the test procedure. If the AC input power is not stable over a 5-minute period, follow the guidelines established by Section 5.3.3 of IEC 62301 for measuring average power or accumulated energy over time for both input and output.

(iii) Test the UUT at the nameplate output voltage(s) at the loading conditions listed in Table 2 of this section, derated per the proportional allocation method presented in section 5(b)(1)(iv) of this appendix. Active or passive loads used for efficiency testing of the UUT must maintain the required current loading set point for each output voltage within an accuracy of ±0.5 percent. Conduct efficiency measurements in sequence from Loading Condition 1 to Loading Condition 4 as indicated in Table 2 of this section. For Loading Condition 5, place the UUT in no-load mode, disconnect any additional signal connections to the UUT, and measure input power.

TABLE 2—LOADING CONDITIONS FOR UNIT UNDER TEST

Loading Condition 1	100% of Derated Nameplate Output Current ±2%.
Loading Condition 2	75% of Derated Nameplate Output Current ±2%.
Loading Condition 3	50% of Derated Nameplate Output Current ±2%.
Loading Condition 4	25% of Derated Nameplate Output Current ±2%.
Loading Condition 5	0%.

Note: The 2 percent allowance pertains to nameplate output current, not the calculated current value. For example, a UUT at Loading Condition 3 may be tested in a range from 48 percent to 52 percent of the derated output current.

(A) If testing of additional, optional loading conditions is desired, conduct that testing in accordance with this test procedure and subsequent to completing the sequence described in section 5(b)(1)(iii) of this appendix.

(B) Where the external power supply lists both an instantaneous and continuous output current, test the external power supply at the continuous condition only.

(C) If an external power supply cannot sustain output at one or more of the Loading Conditions 1–4 as specified in Table 2 of this section, test the external power supply only at the loading conditions for which it can sustain output.

(iv) Use the following proportional allocation method to provide consistent loading conditions for multiple-voltage external power supplies. For additional explanation (provided for guidance only), please refer to section 6.1.1 of the California Energy Commission's ''Proposed Test Protocol for Calculating the Energy Efficiency of Internal Ac-Dc Power Supplies Revision 6.7,'' March 2014.

(A) Consider a power supply with N output busses, and nameplate output voltages V_1, * * *, V_N, corresponding output current ratings I_1, * * *, I_N, and a maximum output power P as specified on the manufacturer's label on the power supply housing, or, if absent from the housing, as specified in the documentation provided with the unit by the manufacturer. Calculate the derating factor D by dividing the power supply maximum output power P by the sum of the maximum output powers of the individual output busses, equal to the product of bus nameplate output voltage and current I_iV_i, as follows:

$$D = \frac{P}{\sum_{i=1}^{N} V_i I_i},$$

(B) If D ≥1, then loading every bus to its nameplate output current does not exceed the overall maximum output power for the power supply. In this case, load each output bus to the percentages of its nameplate output current listed in Table 2 of this section. However, if D <1, it is an indication that loading each bus to its nameplate output current will exceed the overall maximum output power for the power supply. In this case, and at each loading condition, load each output bus to the appropriate percentage of its nameplate output current listed in Table 2 of this section, multiplied by the derating factor D.

(v) Minimum output current requirements. Depending on their application, some multiple-voltage power supplies may require a minimum output current for each output bus of the power supply for correct operation. In these cases, ensure that the load current for each output at Loading Condition 4 in Table 2 is greater than the minimum output current requirement. Thus, if the test method's calculated load current for a given voltage bus is smaller than the minimum output current requirement, the minimum output current must be used to load the bus. This load current shall be properly recorded in any test report.

(vi) Efficiency calculation. Calculate and record efficiency at each loading point by dividing the UUT's measured active output power at a given loading condition by the active AC input power measured at that loading condition.

(A) Calculate and record average efficiency of the UUT as the arithmetic mean of the efficiency values calculated at Loading Conditions 1, 2, 3, and 4, in Table 2 of this section.

(B) If, when tested, a UUT cannot sustain output current at one or more of the loading conditions as specified in Table 2 of this section, the average active mode efficiency is calculated as the average of the loading conditions for which it can sustain output.

(C) If the UUT can only sustain one output current at any of the output busses, test it at the loading condition that allows for the maximum output power on that bus (*i.e.*, the highest output current possible at the highest output voltage on that bus).

(vii) Power consumption calculation. The power consumption of Loading Condition 5 (no-load) is equal to the active AC input power (W) at that loading condition.

(2) Off-mode Measurement—If the UUT incorporates manual on-off switches, place the UUT in off-mode and measure and record its power consumption at Loading Condition 5 in Table 2 of this section. The measurement of the off-mode energy consumption must conform to the requirements specified in section (5)(b)(1) of this appendix, except that all manual on-off switches must be placed in the ''off'' position for the off-mode measurement. The UUT is considered stable if, over 5 minutes with samples taken at least once every second, the AC input power does not drift from the maximum value observed by more than 1 percent or 50 milliwatts, whichever is greater.

6. Test Measurement for Adaptive External Power Supplies:

(a) Single-Voltage Adaptive External Power Supply.

(1) Standby Mode and Active-Mode Measurement.

(i) Place in the ''on'' position any built-in switch in the UUT controlling power flow to the AC input and note the existence of such a switch in the final test report.

(ii) Operate the UUT at 100 percent of nameplate output current for at least 30 minutes immediately prior to conducting efficiency measurements. After this warm-up period, monitor AC input power for a period of 5 minutes to assess the stability of the UUT. If the power level does not drift by more than 5 percent from the maximum value observed, the UUT is considered stable. If the UUT is stable, record the measurements obtained at the end of this 5-minute period. Measure subsequent loading conditions under the same 5-minute stability parameters. Note that only one warm-up period of 30 minutes is required for each UUT at the beginning of the test procedure. If the AC input power is not stable over a 5-minute period, follow the guidelines established by Section 5.3.3 of IEC 62301 for measuring average power or accumulated energy over time for both input and output.

(iii) Test the UUT at the nameplate output voltage(s) at the loading conditions listed in Table 3 of this section, derated per the proportional allocation method presented in section 6(a)(1)(iv) of this appendix. Adaptive external power supplies must be tested twice—once at the highest nameplate output voltage and once at the lowest nameplate output voltage as described in the following sections.

(A) At the highest nameplate output voltage, test adaptive external power supplies in sequence from Loading Condition 1 to Loading Condition 4, as indicated in Table 3 of this section. For Loading Condition 5, place the UUT in no-load mode, disconnect any additional signal connections, and measure the input power.

(B) At the lowest nameplate output voltage, with the exception of USB–PD EPSs, test all adaptive external power supplies in sequence from Loading Condition 1 to Loading Condition 4, as indicated in Table 3 of this section. For USB–PD adaptive external power supplies, at the lowest nameplate output voltage, test the external power supply such that for Loading Conditions 1, 2, 3, and 4, all adaptive ports are loaded to 2 amperes, 1.5 amperes, 1 ampere, and 0.5 amperes, respectively. All non-adaptive ports will continue to be loaded as indicated in Table 3 of this section. For Loading Condition 5, test all adaptive external power supplies by placing the UUT in no-load mode, disconnecting any additional signal connections, and measuring the input power.

TABLE 3—LOADING CONDITIONS FOR A SINGLE-VOLTAGE ADAPTIVE EXTERNAL POWER SUPPLY

Loading Condition 1	100% of Derated Nameplate Output Current ±2%.
Loading Condition 2	75% of Derated Nameplate Output Current ±2%.
Loading Condition 3	50% of Derated Nameplate Output Current ±2%.
Loading Condition 4	25% of Derated Nameplate Output Current ±2%.
Loading Condition 5	0%.

Note: The 2 percent allowance pertains to nameplate output current, not the calculated current value. For example, a UUT at Loading Condition 3 may be tested in a range from 48 percent to 52 percent of the derated output current.

(C) If testing of additional, optional loading conditions is desired, conduct that testing in accordance with this test procedure and subsequent to completing the sequence described in section 6(a)(1)(iii) of this appendix.

(D) Where the external power supply lists both an instantaneous and continuous output current, test the external power supply at the continuous condition only.

(E) If an external power supply cannot sustain output at one or more of the Loading Conditions 1–4 as specified in Table 3 of this section, test the external power supply only at the loading conditions for which it can sustain output.

(iv) Use the following proportional allocation method to provide consistent loading conditions for single-voltage adaptive external power supplies with multiple-output busses. For additional explanation, please refer to section 6.1.1 of the California Energy Commission's ''Proposed Test Protocol for Calculating the Energy Efficiency of Internal Ac-Dc Power Supplies Revision 6.7,'' March 2014.

(A) Consider a power supply with N output busses, each with the same nameplate output voltages V_1, * * *, V_N, corresponding output current ratings I_1, * * *, I_N, and a maximum output power P as specified on the manufacturer's label on the power supply housing, or, if absent from the housing, as specified in the documentation provided with the unit by the manufacturer. Calculate the derating

factor D by dividing the power supply maximum output power P by the sum of the maximum output powers of the individual output busses, equal to the product of port nameplate output voltage and current I_iV_i, as follows:

$$D = \frac{P}{\sum_{i=1}^{N} V_i I_i},$$

For USB–PD adaptive external power supplies, at the lowest nameplate output voltage, limit the contribution from each port to 10W when calculating the derating factor.

(B) If D ≥1, then loading every port to its nameplate output current does not exceed the overall maximum output power for the power supply. In this case, load each output bus to the percentages of its nameplate output current listed in Table 3 of this section. However, if D <1, it is an indication that loading each port to its nameplate output current will exceed the overall maximum output power for the power supply. In this case, and at each loading condition, each output bus will be loaded to the appropriate percentage of its nameplate output current listed in Table 3 of this section, multiplied by the derating factor D.

(v) Efficiency calculation. Calculate and record the efficiency at each loading point by dividing the UUT's measured active output power at that loading condition by the active AC input power measured at that loading condition.

(A) Calculate and record average efficiency of the UUT as the arithmetic mean of the efficiency values calculated at Loading Conditions 1, 2, 3, and 4 in Table 3 of this section.

(B) If, when tested, a UUT cannot sustain the output current at one or more of the loading conditions as specified in Table 3 of this section, the average active-mode efficiency is calculated as the average of the loading conditions for which it can sustain output.

(C) If the UUT can only sustain one output current at any of the output busses, test it at the loading condition that allows for the maximum output power on that bus (*i.e.,* the highest output current possible at the highest output voltage on that bus).

(vi) Power consumption calculation. The power consumption of Loading Condition 5 (no-load) is equal to the active AC input power (W) at that loading condition.

(2) Off-Mode Measurement—If the UUT incorporates manual on-off switches, place the UUT in off-mode and measure and record its power consumption at Loading Condition 5 in Table 3 of this section. The measurement of the off-mode energy consumption must conform to the requirements specified in section 6(a)(1) of this appendix, except that all manual on-off switches must be placed in the ''off'' position for the off-mode measurement. The UUT is considered stable if, over 5 minutes with samples taken at least once every second, the AC input power does not drift from the maximum value observed by more than 1 percent or 50 milliwatts, whichever is greater. Measure the off-mode power consumption of a single-voltage adaptive external power supply twice—once at the highest nameplate output voltage and once at the lowest.

(b) Multiple-Voltage Adaptive External Power Supply.

(1) Standby Mode and Active-Mode Measurement.

(i) Place in the ''on'' position any built-in switch in the UUT controlling power flow to the AC input and note the existence of such a switch in the final test report.

(ii) Operate the UUT at 100 percent of nameplate output current for at least 30 minutes immediately prior to conducting efficiency measurements. After this warm-up period, monitor AC input power for a period of 5 minutes to assess the stability of the UUT. If the power level does not drift by more than 1 percent from the maximum value observed, the UUT is considered stable. If the UUT is stable, record the measurements obtained at the end of this 5-minute period. Measure subsequent loading conditions under the same 5-minute stability parameters. Note that only one warm-up period of 30 minutes is required for each UUT at the beginning of the test procedure. If the AC input power is not stable over a 5-minute period, follow the guidelines established by Section 5.3.3 of IEC 62301 for measuring average power or accumulated energy over time for both input and output.

(iii) Test the UUT at the nameplate output voltage(s) at the loading conditions listed in Table 4 of this section, derated per the proportional allocation method presented in section 6(b)(1)(iv) of this appendix. Active or passive loads used for efficiency testing of the UUT must maintain the required current loading set point for each output voltage within an accuracy of ±0.5 percent. Adaptive external power supplies must be tested twice—once at the highest nameplate output voltage and once at the lowest nameplate output voltage as described in the following sections.

(A) At the highest nameplate output voltage, test adaptive external power supplies in sequence from Loading Condition 1 to Loading Condition 4, as indicated in Table 4 of this section. For Loading Condition 5, place the UUT in no-load mode, disconnect any additional signal connections, and measure the input power.

(B) At the lowest nameplate output voltage, with the exception of USB–PD EPSs, test all other adaptive external power supplies, in sequence from Loading Condition 1 to Loading Condition 4, as indicated in Table 4 of this section. For USB–PD adaptive external power supplies, at the lowest nameplate output voltage, test the external power supply such that for Loading Conditions 1, 2, 3, and 4, all adaptive ports are loaded to 2 amperes, 1.5 amperes, 1 ampere, and 0.5 amperes, respectively. All non-adaptive ports will continue to be loaded as indicated in Table 4 of this section. For Loading Condition 5, test all adaptive external power supplies by placing the UUT in no-load mode, disconnecting any additional signal connections, and measuring the input power.

TABLE 4—LOADING CONDITIONS FOR A MULTIPLE-VOLTAGE ADAPTIVE EXTERNAL POWER SUPPLY

Loading Condition 1	100% of Derated Nameplate Output Current ±2%.
Loading Condition 2	75% of Derated Nameplate Output Current ±2%.
Loading Condition 3	50% of Derated Nameplate Output Current ±2%.
Loading Condition 4	25% of Derated Nameplate Output Current ±2%.
Loading Condition 5	0%.

Note: The 2 percent allowance pertains to nameplate output current, not the calculated current value. For example, a UUT at Loading Condition 3 may be tested in a range from 48 percent to 52 percent of the derated output current.

(C) If testing of additional, optional loading conditions is desired, conduct that testing in accordance with this test procedure and subsequent to completing the sequence described in section 6(b)(1)(iii) of this appendix.

(D) Where the external power supply lists both an instantaneous and continuous output current, test the external power supply at the continuous condition only.

(E) If an adaptive external power supply is operating as a multiple-voltage external power supply at only the highest nameplate output voltage or lowest nameplate output voltage, test this external power supply as a multiple-voltage adaptive external power supply at both the highest nameplate output voltage and the lowest nameplate output voltage.

(F) If an external power supply has both adaptive and non-adaptive ports, and these ports operate simultaneously at multiple voltages, ensure that testing is performed with all ports active at both the highest and lowest nameplate output voltage. For example, if an external power supply has a USB–PD adaptive output bus that operates at 5 volts and 20 volts and a second non-adaptive output bus that operates at 9 volts, test this EPS at the highest nameplate output voltage with both the adaptive and non-adaptive ports respectively loaded at 20 volts and 9 volts; likewise, test it at the lowest nameplate output voltage with both the adaptive and non-adaptive ports respectively loaded at 5 volts and 9 volts.

(G) If an external power supply cannot sustain output at one or more of the Loading Conditions 1–4 as specified in Table 4 of this section, test the external power supply only at the loading conditions for which it can sustain output.

(iv) Use the following proportional allocation method to provide consistent loading conditions for multiple-voltage adaptive external power supplies. For additional explanation, please refer to section 6.1.1 of the California Energy Commission's ''Proposed Test Protocol for Calculating the Energy Efficiency of Internal Ac-Dc Power Supplies Revision 6.7,'' March 2014.

(A) Consider a multiple-voltage power supply with N output busses, and nameplate output voltages V_1, * * *, V_N, corresponding output current ratings I_1, * * *, I_N, and a maximum output power P as specified on the manufacturer's label on the power supply housing, or, if absent from the housing, as specified in the documentation provided with the unit by the manufacturer. Calculate the derating factor D by dividing the power supply maximum output power P by the sum of the maximum output powers of the individual output busses, equal to the product of bus nameplate output voltage and current I_iV_i, as follows:

$$D = \frac{P}{\sum_{i=1}^{N} V_i I_i},$$

For USB–PD adaptive external power supplies, at the lowest nameplate output voltage, limit the contribution from each port to 10W when calculating the derating factor.

(B) If D ≥1, then loading every bus to its nameplate output current does not exceed the overall maximum output power for the power supply. In this case, load each output bus to the percentages of its nameplate output current listed in Table 4 of this section. However, if D <1, it is an indication that loading each bus to its nameplate output current will exceed the overall maximum output power for the power supply. In this case, at each loading condition, load each output bus to the appropriate percentage of its nameplate output current listed in Table 4 of this section, multiplied by the derating factor D.

(v) Minimum output current requirements. Depending on their application, some multiple-voltage adaptive external power supplies may require a minimum output current for each output bus of the power supply for correct operation. In these cases, ensure that the load current for each output at Loading Condition 4 in Table 4 of this section is greater than the minimum output current requirement. Thus, if the test method's calculated load current for a given voltage bus is smaller than the minimum output current requirement, use the minimum output current to load the bus. Record this load current in any test report.

(vi) Efficiency calculation. Calculate and record the efficiency at each loading point by dividing the UUT's measured active output power at that loading condition by the active AC input power measured at that loading condition.

(A) Calculate and record average efficiency of the UUT as the arithmetic mean of the efficiency values calculated at Loading Conditions 1, 2, 3, and 4 in Table 4 of this section.

(B) If, when tested, a UUT cannot sustain the output current at one or more of the loading conditions as specified in Table 4, the average active-mode efficiency is calculated as the average of the loading conditions for which it can sustain output.

(C) If the UUT can only sustain one output current at any of the output busses, test it at the loading condition that allows for the maximum output power on that bus (*i.e.,* the highest output current possible at the highest output voltage on that bus).

(vii) Power consumption calculation. The power consumption of Loading Condition 5 (no-load) is equal to the active AC input power at that loading condition.

(2) Off-mode Measurement—If the UUT incorporates manual on-off switches, place the UUT in off-mode, and measure and record its power consumption at Loading Condition 5 in Table 4 of this section. The measurement of the off-mode energy consumption must conform to the requirements specified in section (6)(b)(1) of this appendix, except that all manual on-off switches must be placed in the ''off'' position for the off-mode measurement. The UUT is considered stable if, over 5 minutes with samples taken at least once every second, the AC input power does not drift from the maximum value observed by more than 1 percent or 50 milliwatts, whichever is greater. Measure the off-mode power consumption of a multiple-voltage adaptive external power supply twice—once at the highest nameplate output voltage and once at the lowest.

[87 FR 51221, Aug. 19, 2022]

APPENDIX AA TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF FURNACE FANS

NOTE: Prior to October 9, 2024, any representations with respect to energy use or efficiency of furnace fans must be made either in accordance with the results of testing pursuant to this appendix or with the results of testing pursuant to this appendix as it appeared in the 10 CFR parts 200–499 edition revised as of January 1, 2023. On or after October 9, 2024, any representations, including certifications of compliance, made with respect to the energy use or efficiency of furnace fans must be made in accordance with the results of testing pursuant to this appendix.

0. *Incorporation by Reference*

DOE incorporated by reference in §430.3, the entire standard for ASHRAE 37–2009 (RA 2019), as corrected by the ASHRAE 37–2009 Errata Sheet; ASHRAE 41.1–1986; as well as Chapter 1 of the 2021 ASHRAE Handbook and ASHRAE 103–2017. In cases where there is a conflict, the language of the test procedure in this appendix takes precedence over the incorporated standards.

1. Scope. This appendix covers the test requirements used to measure the energy consumption of fans used in weatherized and non-weatherized gas furnaces, oil furnaces, electric furnaces, and modular blowers. This appendix does not apply to furnace fans used in dual-fuel units.

2. *Definitions.* Definitions include the definitions as specified in section 3 of ASHRAE 103–2017 and the following additional definitions, some of which supersede definitions found in ASHRAE 103–2017:

2.1. *Active mode* means the condition in which the product in which the furnace fan is integrated is connected to a power source and circulating air through ductwork.

2.2. *Airflow-control settings* are programmed or wired control system configurations that control a fan to achieve discrete, differing ranges of airflow—often designated for performing a specific function (*e.g.*, cooling, heating, or constant circulation)—without manual adjustment other than interaction with a user-operable control such as a thermostat that meets the manufacturer specifications for installed-use. For the purposes of this appendix, manufacturer specifications for installed-use shall be found in the product literature shipped with the unit.

2.3. *Dual-fuel unit* means a consumer product that includes both a heat pump and a burner in a single cabinet.

2.4. *External static pressure* (ESP) means the difference between static pressures measured in the outlet duct and return air opening (or return air duct when used for testing) of the product in which the furnace fan is integrated.

2.5. *Furnace fan* means an electrically-powered device used in a consumer product for the purpose of circulating air through ductwork.

2.6. *Modular blower* means a product which only uses single-phase electric current, and which:

(a) Is designed to be the principal air circulation source for the living space of a residence;

(b) Is not contained within the same cabinet as a furnace or central air conditioner; and

(c) Is designed to be paired with HVAC products that have a heat input rate of less than 225,000 Btu per hour and cooling capacity less than 65,000 Btu per hour.

2.7. *Off mode* means the condition in which the product in which the furnace fan is integrated either is not connected to the power source or is connected to the power source but not energized.

2.8. *Seasonal off switch* means a switch on the product in which the furnace fan is integrated that, when activated, results in a measurable change in energy consumption between the standby and off modes.

2.9. *Specified airflow-control settings* are the airflow-control settings specified for installed-use by the manufacturer. For the purposes of this appendix, manufacturer specifications for installed-use are those specifications provided for typical consumer installations in the product literature shipped with the product in which the furnace fan is installed. In instances where a manufacturer specifies multiple airflow-control settings for a given function to account for varying installation scenarios, the highest airflow-control setting specified for the given function shall be used for the procedures specified in this appendix, unless otherwise specified within this test procedure.

2.10. *Standby mode* means the condition in which the product in which the furnace fan is integrated is connected to the power source and energized, but the furnace fan is not circulating air.

2.11. *Thermal stack damper* means a type of stack damper that opens only during the direct conversion of thermal energy of the stack gases.

3. *Classifications.* Classifications are as specified in section 4 of ASHRAE 103–2017.

4. *Requirements.* Requirements are as specified in section 5 of ASHRAE 103–2017. In addition, Fan Energy Rating (FER) of furnace fans shall be determined using test data and estimated national average operating hours pursuant to section 10.1 of this appendix.

5. *Instruments.* Instruments must be as specified in section 6, not including section 6.2, of ASHRAE 103–2017; and as specified in sections 5.1 and 5.2 of this appendix.

5.1. *Temperature.* Temperature measuring instruments shall meet the provisions specified in section 5.1 of ASHRAE 37–2009 (RA 2019) (as corrected by the ASHRAE 37–2009 Errata Sheet), including the references to ASHRAE 41.1–1986, and shall be accurate to within 0.75 degrees Fahrenheit (within 0.4 degrees Celsius).

5.1.1. *Outlet Air Temperature Thermocouple Grid.* Outlet air temperature shall be measured as described in section 8.2.1.5.5 of ASHRAE 103–2017 and illustrated in Figure 2 of ASHRAE 103–2017. Thermocouples shall be placed downstream of pressure taps used for external static pressure measurement.

5.2. *Humidity.* Air humidity shall be measured with a relative humidity sensor that is accurate to within 5% relative humidity. Air humidity shall be measured as close as possible to the inlet of the product in which the furnace fan is installed.

6. *Apparatus.* The apparatus used in conjunction with the furnace during the testing shall be as specified in section 7 of ASHRAE 103–2017 except for section 7.1, the second paragraph of sections 7.2.2.2, 7.2.2.5, and 7.7, and as specified in sections 6.1, 6.2, 6.3, 6.4, 6.5, and 6.6 of this appendix.

6.1. *General.* The product in which the furnace fan is integrated shall be installed in the test room in accordance with the product manufacturer's written instructions that are shipped with the product unless required otherwise by a specific provision of this appendix. The apparatus described in this section is used in conjunction with the product in which the furnace fan is integrated. Each piece of the apparatus shall conform to material and construction specifications and

the reference standard cited. Test rooms containing equipment shall have suitable facilities for providing the utilities necessary for performance of the test and be able to maintain conditions within the limits specified.

6.2. *Downflow furnaces.* Install the internal section of vent pipe the same size as the flue collar for connecting the flue collar to the top of the unit, if not supplied by the manufacturer. Do not insulate the internal vent pipe during steady-state test described in section 9.1 of ASHRAE 103–2017. Do not insulate the internal vent pipe before the cooldown and heat-up tests described in sections 9.5 and 9.6, respectively, of ASHRAE 103–2017. If the vent pipe is surrounded by a metal jacket, do not insulate the metal jacket. Install a 5-ft test stack of the same cross-sectional area or perimeter as the vent pipe above the top of the furnace. Tape or seal around the junction connecting the vent pipe and the 5-ft test stack. Insulate the 5-ft test stack with insulation having a minimum R-value of 7 and an outer layer of aluminum foil. (*See* Figure 3–E of ASHRAE 103–2017.)

6.3. *Modular Blowers.* A modular blower shall be equipped with the electric heat resistance kit that is likely to have the largest volume of retail sales with that particular basic model of modular blower.

6.4. *Ducts and Plenums.* Ducts and plenums shall be built to the geometrical specifications in section 7 of ASHRAE 103–2017 and section 6.7 of this appendix. An apparatus for measuring external static pressure shall be integrated in the plenum and test duct as specified in sections 6.4 of ASHRAE 37–2009 (RA 2019) (as corrected by the ASHRAE 37–2009 Errata Sheet), excluding specifications regarding the minimum length of the ducting and minimum distance between the external static pressure taps and product inlet and outlet, and section 6.5 of ASHRAE 37–2009 (RA 2019) (as corrected by the ASHRAE 37–2009 Errata Sheet). External static pressure measuring instruments shall be placed between the furnace openings and any restrictions or elbows in the test plenums or ducts. For all test configurations, external static pressure taps shall be placed 18 inches from the outlet.

6.4.1. *For tests conducted using a return air duct.* Additional external static pressure taps shall be placed 12 inches from the product inlet. Pressure shall be directly measured as a differential pressure as depicted in Figure 8 of ASHRAE 37–2009 (RA 2019) rather than determined by separately measuring inlet and outlet static pressure and subtracting the results.

6.4.2. *For tests conducted without a return air duct.* External static pressure shall be directly measured as the differential pressure between the outlet duct static pressure and the ambient static pressure as depicted in Figure 7a of ASHRAE 37–2009 (RA 2019).

6.5. *Air Filters.* Air filters shall be removed.

6.6. *Electrical Measurement.* Only electrical input power to the furnace fan (and electric resistance heat kit for electric furnaces and modular blowers) shall be measured for the purposes of this appendix. Electrical input power to the furnace fan and electric resistance heat kit shall be sub-metered separately. Electrical input power to all other electricity-consuming components of the product in which the furnace fan is integrated shall not be included in the electrical input power measurements used in the FER calculation. If the procedures of this appendix are being conducted at the same time as another test that requires metering of components other than the furnace fan and electric resistance heat kit, the electrical input power to the furnace fan and electric resistance heat kit shall be sub-metered separately from one another and separately from other electrical input power measurements.

7. *Test Conditions.* The testing conditions shall be as specified in section 8, not including sections 8.5.2 and 8.6.1.1 of ASHRAE 103–2017; and as specified in sections 7.1 and 7.2 of this appendix.

7.1 *Ambient Temperature and Humidity Conditions.* During the time required to perform all tests, maintain the room temperature within ±5 °F (2.8 °C) of the air temperature value measured at the end of the steady-state performance test (T_{RA}). For condensing furnaces and boilers, maintain the relative humidity within ±5% of the relative humidity measured at the end of the steady-state performance test. During all tests, the room temperature shall not fall below 65 °F (18.3 °C) or exceed 85 °F (29.4 °C) and the relative humidity shall not fall below 20% or exceed 80%.

7.2. *Measurement of Jacket Surface Temperature (optional).* The jacket of the furnace or boiler shall be subdivided into 6-inch squares when practical, and otherwise into 36-square-inch regions comprising 4 in. x 9 in. or 3 in. x 12 in. sections, and the surface temperature at the center of each square or section shall be determined with a surface thermocouple. The 36-square-inch areas shall be recorded in groups where the temperature differential of the 36-square-inch area is less than 10 °F for temperature up to 100 °F above room temperature and less than 20 °F for temperature more than 100 °F above room temperature. For forced air central furnaces, the circulating air blower compartment is considered as part of the duct system and no surface temperature measurement of the blower compartment needs to be recorded for the purpose of this test. For downflow furnaces, measure all cabinet surface temperatures of the heat exchanger and combustion section, including the bottom around the outlet duct, and the burner door, using the 36 square-inch thermocouple grid. The cabinet surface temperatures around the blower section do not

need to be measured (*see* Figure 3–E of ASHRAE 103–2017.)

8. *Test Procedure.* Testing and measurements shall be as specified in section 9 of ASHRAE 103–2017 except for sections 9.1.2.1, 9.3, 9.5.1.1, 9.5.1.2.1, 9.5.1.2.2, 9.5.2.1, and section 9.7.1; and as specified in sections 8.1 through 8.6 of this appendix.

8.1. *Direct Measurement of Off-Cycle Losses Testing Method.* [Reserved]

8.2. *Measurement of Electrical Standby and Off Mode Power.* [Reserved]

8.3. *Steady-State Conditions for Hot Flow Tests for Gas and Oil Furnaces.* Steady-state conditions are indicated by an external static pressure within the range shown in table 1 to this appendix and a temperature variation in three successive readings, taken 15 minutes apart, of not more than any of the following:

(a) 3 °F in the stack gas temperature for furnaces equipped with draft diverters;

(b) 5 °F in the stack gas temperature for furnaces equipped with either draft hoods, direct exhaust, or direct vent systems; and

(c) 1 °F in the flue gas temperature for condensing furnaces.

8.4. *Steady-State Conditions for Hot Flow Tests for Electric Furnaces and Modular Blowers.* Steady-state conditions are indicated by an external static pressure within the range shown in table 1 to this appendix and a temperature variation of not more than 5 °F in the outlet air temperature in four successive temperature readings taken 15 minutes apart.

8.5. *Steady-State Conditions for Cold Flow Tests.* For tests during which the burner or electric heating elements are turned off (*i.e.*, cold flow tests), steady-state conditions are indicated by an external static pressure within the range shown in table 1 to this appendix and a variation in the difference between outlet temperature and ambient temperature of not more than 3 °F in three successive temperature readings taken 15 minutes apart.

8.6. *Fan Energy Rating (FER) Test.*

8.6.1. *Initial FER test conditions and maximum airflow-control setting measurements.* Measure the relative humidity (φ) and dry bulb temperature (T_{db}) of the test room.

8.6.1.1. *Furnace fans for which the maximum airflow-control setting is not a specified heating airflow-control setting.* The main burner or electric heating elements shall be turned off. Adjust the external static pressure to within the range shown in table 1 to this appendix. Maintain these settings until steady-state conditions are attained as specified in sections 8.3, 8.4, and 8.5 of this appendix. Measure furnace fan electrical input power (E_{Max}), external static pressure (ESP_{Max}), and outlet air temperature ($T_{Max,Out}$). The measurement of E_{Max} shall be taken over the final 30 seconds of the steady-state period, at intervals of no less than 1 per second, and averaged over the 30 second period.

8.6.1.2. *Furnace fans for which the maximum airflow-control setting is a specified heating airflow-control setting.* Adjust the main burner or electric heating element controls to the default heat setting designated for the maximum airflow-control setting. Burner adjustments shall be made as specified by section 8.4.1 of ASHRAE 103–2017. Adjust the furnace fan controls to the maximum airflow-control setting. Adjust the external static to within the range shown in table 1 to this appendix. Maintain these settings until steady-state conditions are attained as specified in sections 8.3, 8.4, and 8.5 of this appendix and the temperature rise (ΔT_{Max}) is at least 18 °F. Measure furnace fan electrical input power (E_{Max}), fuel or electric resistance heat kit input energy ($Q_{IN,H}$), external static pressure (ESP_{Max}), steady-state efficiency for this setting ($Effy_{SS,Max}$) as specified in sections 11.2 and 11.3 of ASHRAE 103–2017, outlet air temperature ($T_{Max,Out}$), and temperature rise (ΔT_{Max}). The measurement of E_{Max} shall be taken over the final 30 seconds of the steady-state period, at intervals of no less than 1 per second, and averaged over the 30 second period.

TABLE 1—REQUIRED MINIMUM EXTERNAL STATIC PRESSURE IN THE MAXIMUM AIRFLOW-CONTROL SETTING BY INSTALLATION TYPE

Installation type	ESP (in. wc.)*
Units with an internal, factory-installed evaporator coil	0.50–0.55
Units designed to be paired with an evaporator coil, but without one installed	0.65–0.70
Mobile home	0.30–0.35

*Once the specified ESP has been achieved, the same outlet duct restrictions shall be used for the remainder of the furnace fan test. If the unit under test is unable to complete the testing (*i.e.,* the unit shuts down before completing a test), reduce the target ESP range by 0.05″ w.c. and restart the test. Repeat this process until the test can be completed.

8.6.2. *Constant circulation airflow-control setting measurements.* The main burner or electric heating elements shall be turned off. The furnace fan controls shall be adjusted to the specified constant circulation airflow-control setting. If the manufacturer does not specify a constant circulation airflow-control setting in the installation and operations manual supplied with the unit, the lowest airflow-control setting shall be used.

Maintain these settings until steady-state conditions are attained as specified in sections 8.3, 8.4, and 8.5 of this appendix. Measure furnace fan electrical input power (E_{Circ}) and external static pressure (ESP_{Circ}). The measurement of E_{Circ} shall be taken over the final 30 seconds of the steady-state period, at intervals of no less than 1 per second, and averaged over the 30 second period.

8.6.3. *Heating airflow-control setting measurements.* For single-stage gas and oil furnaces, the burner shall be fired at the maximum heat input rate. For single-stage electric furnaces, the electric heating elements shall be energized at the maximum heat input rate. For multi-stage and modulating furnaces, the reduced heat input rate settings shall be used. Burner adjustments shall be made as specified by section 8.4.1 of ASHRAE 103–2017. After the burner is activated and adjusted or the electric heating elements are energized, the furnace fan controls shall be adjusted to operate the fan in the specified heating airflow-control setting that also allows for operation within the manufacturer-specified temperature rise range. In instances where a manufacturer specifies multiple airflow-control settings for a given function to account for varying installation scenarios, the highest airflow-control setting specified for the given function that also allows for operation within the manufacturer-specified temperature rise range shall be used. High heat and reduced heat shall be considered different functions for multi-stage heating units. Maintain these settings until steady-state conditions are attained as specified in sections 8.3, 8.4, and 8.5 of this appendix and the temperature rise (ΔT_{Heat}) is at least 18 °F. Measure furnace fan electrical input power (E_{Heat}), fuel or electric resistance heat kit input energy ($Q_{IN,k}$)external static pressure (ESP_{Heat}), steady-state efficiency for this setting ($Effy_{SS}$) as specified in sections 11.2 and 11.3 of ASHRAE 103–2017, outlet air temperature ($T_{Heat,\ Out}$) and temperature rise (ΔT_{Heat}). The measurement of E_{Heat} shall be taken over the final 30 seconds of the steady-state period, at intervals of no less than 1 per second, and averaged over the 30 second period.

9. *Nomenclature.* Nomenclature shall include the nomenclature specified in section 10 of ASHRAE 103–2017 and the following additional variables:

60 = conversion factor from hours to minutes, (min/h)

0.24 = approximate specific heat capacity of dry air, (Btu/lb- °F)

0.44 = approximate specific heat capacity of saturated water vapor, (Btu/lb- °F)

$Effy_{SS,i}$ = Steady-State Efficiency in airflow-control setting *i*. For gas and oil furnaces $Effy_{SS,i}$ is specified in sections 11.2.7 (Non-Condensing and Modulating), 11.3.7.3 (Condensing and Non-modulating), 11.4.8.8 (Non-Condensing and Non-modulating), or 11.5 (Condensing and Modulating) of ASHRAE 103–2017, in %. For electric furnaces or modular blowers, $Effy_{SS,i}$ equals 100, in %.

L_J = jacket loss as determined as specified in section 8.6 of ASHRAE 103–2017 or a default value of 1% if the jacket loss test is not performed, in %

CCH = annual furnace fan constant-circulation hours

E_{Circ} = furnace fan electrical consumption at the specified constant-circulation airflow-control setting (or minimum airflow-control setting operating point if a default constant-circulation airflow-control setting is not specified), in watts

E_{Heat} = furnace fan electrical consumption in the specified heat airflow-control setting for single-stage heating products or the specified low-heat setting for multi-stage heating products, in watts

E_{Max} = furnace fan electrical consumption in the maximum airflow-control setting, in watts

ESP_i = external static pressure, in inches water column, at time of the electrical power measurement in airflow-control setting *i*, where *i* can be ''Circ'' to represent constant-circulation (or minimum airflow) mode, ''Heat'' to represent heating mode, or ''Max'' to represent cooling (or maximum airflow mode).

FER = fan energy rating, in watts/1000 cfm

HH = annual furnace fan heating operating hours

HCR = heating capacity ratio (nameplate reduced heat input capacity divided by nameplate maximum input heat capacity)

k_{ref} = physical descriptor characterizing the reference system

T_{db} = dry bulb temperature of the test room in, °F

$T_{i,k,in}$ = inlet air temperature at time of the electrical power measurement, in °F, in airflow-control setting *i* and heat setting *k*, where *i* can be ''Circ'' to represent constant-circulation (or minimum airflow) mode, ''Heat'' to represent heating mode, or ''Max'' to represent maximum airflow (typically designated for cooling) mode. If *i* = Heat, *k* can be ''H'' to represent high heat setting or ''R'' to represent the reduced heat setting. If *i* = Max or Circ, *k* is not needed.

$T_{i,k,out}$ = average outlet air temperature as measured by the outlet thermocouple grid at time of the electrical power measurement, in °F, in airflow-control setting *i* and heat setting *k*, where *i* can be ''Circ'' to represent constant-circulation (or minimum airflow) mode, ''Heat'' to represent heating mode, or ''Max'' to represent maximum airflow (typically designated for cooling) mode. If *i* = Heat, *k* can be ''H'' to represent high heat setting or ''R'' to represent the reduced heat

setting. If i = Max or Circ, k is not needed.

$\Delta T_{i,k}$ = $T_{i,k,Out}$ minus $T_{i,k,in}$, which is the air throughput temperature rise in setting i and heat setting k, in °F

Qi,k = airflow in airflow-control setting i and heat setting k, in cubic feet per minute (CFM)

MH = annual furnace fan maximum airflow hours

$Q_{IN,k}$ = nameplate fuel energy input rate, in Btu/h, at specified operating conditions k, based on the fuel's high heating value (''HHV'') determined as required in section 8.2.1.3 or 8.2.2.3 of ASHRAE 103–2017, where k can be ''H'' for the maximum heat setting or ''R'' for the reduced heat setting.

W = humidity ratio in pounds water vapor per pounds dry air

v_{air} = specific volume of dry air at specified operating conditions per the 2021 ASHRAE Handbook, in ft^3/lb

10. *Calculation of derived results from test measurements for a single unit.* Calculations shall be as specified in section 11 of ASHRAE 103–2017, except for appendices B and C; and as specified in sections 10.1 through 10.10 and Figure 1 of this appendix.

10.1. *Fan Energy Rating (FER)*

$$FER = \frac{(MH \times E_{Max}) + (HH \times E_{Heat}) + (CCH \times E_{circ})}{(MH + 830 + CCH) + Q_{Max}} \times 1000$$

Where: Q_{Max} = Q_{Heat} for products for which the maximum airflow-control setting is a specified heat setting, or

$$Q_{Max} = Q_{Heat}\sqrt{\frac{ESP_{Max}}{ESP_{Heat}} \times \frac{(T_{Heat,Out} + 460)}{(T_{Max,Out} + 460)}}$$

For products for which the maximum airflow control setting is only designated for cooling; and

$$Q_{i,k} = \frac{\left(Effy_{SS,i} - L_J\right) \times Q_{IN,k} + (3.413 \times E_k)}{60 \times (0.24 + 0.44 \times W) \times \left(\frac{1}{v_{air}}\right) \times \Delta T_{i,k}}$$

The estimated national average operating hours presented in table 2 to this appendix shall be used to calculate FER.

TABLE 2—ESTIMATED NATIONAL AVERAGE OPERATING HOUR VALUES FOR CALCULATING FER

Operating mode	Variable	Single-stage (hours)	Multi-stage or modulating (hours)
Heating	HH	830	830/HCR.
Maximum Airflow	MH	640	640.
Constant Circulation	CCH	400	400.

Where:

$$HCR = \frac{Q_{IN,R\ (nameplate)}}{Q_{IN,H\ (nameplate)}}$$

[89 FR 25801, Apr. 12, 2024]

APPENDIX BB TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE INPUT POWER, LUMEN OUTPUT, LAMP EFFICACY, CORRELATED COLOR TEMPERATURE (CCT), COLOR RENDERING INDEX (CRI), POWER FACTOR, TIME TO FAILURE, AND STANDBY MODE POWER OF INTEGRATED LIGHT-EMITTING DIODE (LED) LAMPS

NOTE: On or after March 20, 2019, any representations made with respect to the energy use or efficiency of integrated light-emitting diode lamps must be made in accordance with the results of testing pursuant to this appendix.

1. *Scope:* This appendix specifies the test methods required to measure input power, lumen output, lamp efficacy, CCT, CRI, power factor, time to failure, and standby mode power for integrated LED lamps.

2. Definitions

2.1. The definitions specified in section 1.3 of IES LM–79–08 except section 1.3(f) (incorporated by reference; see §430.3) apply.

2.2. *Initial lumen output* means the measured lumen output after the lamp is initially energized and stabilized using the stabilization procedures in section 3 of this appendix.

2.3. *Interval lumen output* means the measured lumen output at constant intervals after the initial lumen output measurement in accordance with section 4 of this appendix.

2.4. *Rated input voltage* means the voltage(s) marked on the lamp as the intended operating voltage. If not marked on the lamp, assume 120 V.

2.5. *Test duration* means the operating time of the LED lamp after the initial lumen output measurement and before, during, and including the final lumen output measurement, in units of hours.

2.6. *Time to failure* means the time elapsed between the initial lumen output measurement and the point at which the lamp reaches 70 percent lumen maintenance as measured in section 4 of this appendix.

3. Active Mode Test Method for Determining Lumen Output, Input Power, CCT, CRI, Power Factor, and Lamp Efficacy

In cases where there is a conflict, the language of the test procedure in this appendix takes precedence over IES LM–79–08 (incorporated by reference; see §430.3).

3.1. Test Conditions and Setup

3.1.1. Establish the ambient conditions, power supply, electrical settings, and instrumentation in accordance with the specifications in sections 2.0, 3.0, 7.0, and 8.0 of IES LM–79–08 (incorporated by reference; see §430.3), respectively.

3.1.2. Position an equal number of integrated LED lamps in the base-up and base-down orientations throughout testing; if the position is restricted by the manufacturer, test units in the manufacturer-specified position.

3.1.3. Operate the integrated LED lamp at the rated voltage throughout testing. For an integrated LED lamp with multiple rated voltages including 120 volts, operate the lamp at 120 volts. If an integrated LED lamp with multiple rated voltages is not rated for 120 volts, operate the lamp at the highest rated input voltage. Additional tests may be conducted at other rated voltages.

3.1.4. Operate the lamp at the maximum input power. If multiple modes occur at the same maximum input power (such as variable CCT or CRI), the manufacturer can select any of these modes for testing; however, all measurements described in sections 3 and 4 of this appendix must be taken at the same selected mode. The test report must indicate which mode was selected for testing and include detail such that another laboratory could operate the lamp in the same mode.

3.2. Test Method, Measurements, and Calculations

3.2.1. The test conditions and setup described in section 3.1 of this appendix apply to this section 3.2.

3.2.2. Stabilize the integrated LED lamp prior to measurement as specified in section 5.0 of IES LM–79–08 (incorporated by reference; see §430.3). Calculate the stabilization variation as [(maximum—minimum)/minimum] of at least three readings of the input power and lumen output over a period of 30 minutes, taken 15 minutes apart.

3.2.3. Measure the input power in watts as specified in section 8.0 of IES LM–79–08.

3.2.4. Measure the input voltage in volts as specified in section 8.0 of IES LM–79–08.

3.2.5. Measure the input current in amps as specified in section 8.0 of IES LM–79–08.

3.2.6. Measure lumen output as specified in section 9.1 and 9.2 of IES LM–79–08. Do not use goniophotometers.

3.2.7. Determine CCT according to the method specified in section 12.0 of IES LM–

79–08 with the exclusion of section 12.2 and 12.5 of IES LM–79–08. Do not use goniophotometers.

3.2.8. Determine CRI according to the method specified in section 12.0 of IES LM–79–08 with the exclusion of section 12.2 and 12.5 of IES LM–79–08. Do not use goniophotometers.

3.2.9. Determine lamp efficacy by dividing measured initial lumen output by the measured input power.

3.2.10. Determine power factor for AC-input lamps by dividing measured input power by the product of the measured input voltage and measured input current.

4. Active Mode Test Method to Measure Time to Failure

In cases where there is a conflict, the language of the test procedure in this appendix takes precedence over IES LM–84 (incorporated by reference; see §430.3) and IES TM–28 (incorporated by reference; see §430.3).

4.1. Lamp Handling, Tracking, and Time Recording

4.1.1. Handle, transport, and store the integrated LED lamp as described in section 7.2 of IES LM–84 (incorporated by reference; see §430.3).

4.1.2. Mark and track the integrated LED lamp as specified in section 7.3 of IES LM–84.

4.1.3. Measure elapsed operating time and calibrate all equipment as described in section 7.5 of IES LM–84.

4.1.4. Check the integrated LED lamps regularly for failure as specified in section 7.8 of IES LM–84.

4.2. *Measure Initial Lumen Output.* Measure the initial lumen output according to section 3 of this appendix.

4.3. *Test Duration.* Operate the integrated LED lamp for a period of time (the test duration) after the initial lumen output measurement and before, during, and including the final lumen output measurement.

4.3.1. There is no minimum test duration requirement for the integrated LED lamp. The test duration is selected by the manufacturer. See section 4.6 of this appendix for instruction on the maximum time to failure.

4.3.2. The test duration only includes time when the integrated LED lamp is energized and operating.

4.4. Operating Conditions and Setup Between Lumen Output Measurements

4.4.1. Electrical settings must be as described in section 5.1 of IES LM–84 (incorporated by reference; see §430.3).

4.4.2. LED lamps must be handled and cleaned as described in section 4.1 of IES LM–84.

4.4.3. Vibration around each lamp must be as described in section 4.3 of IES LM–84.

4.4.4. Ambient temperature conditions must be as described in section 4.4 of IES LM–84. Maintain the ambient temperature at 25 °C ± 5 °C or at a manufacturer-selected temperature higher than 25 °C with the same ±5 °C tolerance.

4.4.5. Humidity in the testing environment must be as described in section 4.5 of IES LM–84.

4.4.6. Air movement around each lamp must be as described in section 4.6 of IES LM–84.

4.4.7. Position a lamp in either the base-up and base-down orientation throughout testing. An equal number of lamps in the sample must be tested in the base-up and base-down orientations, except that, if the manufacturer restricts the position, test all of the units in the sample in the manufacturer-specified position.

4.4.8. Operate the lamp at the rated input voltage as described in section 3.1.3 of this appendix for the entire test duration.

4.4.9. Operate the lamp at the maximum input power as described in section 3.1.4 of this appendix for the entire test duration.

4.4.10. Line voltage waveshape must be as described in section 5.2 of IES LM–84.

4.4.11. Monitor and regulate rated input voltage as described in section 5.4 of IES LM–84.

4.4.12. Wiring of test racks must be as specified in section 5.5 of IES LM–84.

4.4.13. Operate the integrated LED lamp continuously.

4.5. Measure Interval Lumen Output. Measure interval lumen output according to section 3 of this appendix.

4.5.1. Record interval lumen output and elapsed operating time as described in section 4.2 of IES TM–28 (incorporated by reference; see §430.3).

4.5.1.1. For test duration values greater than or equal to 3,000 hours and less than 6,000 hours, measure lumen maintenance of the integrated LED lamp at an interval in accordance with section 4.2.2 of IES TM–28.

4.5.1.2. For test duration values greater than or equal to 6,000 hours, measure lumen maintenance at an interval in accordance with section 4.2.1 of IES TM–28.

4.6. Calculate Lumen Maintenance and Time to Failure

4.6.1. Calculate the lumen maintenance of the lamp at each interval by dividing the interval lumen output ''x_t'' by the initial lumen output ''x_0''. Measure initial and interval lumen output in accordance with sections 4.2 and 4.5 of this appendix, respectively.

4.6.2. For lumen maintenance values less than 0.7, including lamp failures that result in complete loss of light output, time to failure is equal to the previously recorded lumen

output measurement (at a shorter test duration) where the lumen maintenance is greater than or equal to 0.7.

4.6.3. For lumen maintenance values equal to 0.7, time to failure is equal to the test duration.

4.6.4. For lumen maintenance values greater than 0.7, use the following method:

4.6.4.1. For test duration values less than 3,000 hours, do not project time to failure. Time to failure equals the test duration.

4.6.4.2. For test duration values greater than or equal to 3,000 hours but less than 6,000 hours, time to failure is equal to the lesser of the projected time to failure calculated according to section 4.6.4.2.1 of this appendix or the test duration multiplied by the limiting multiplier calculated in section 4.6.4.2.2 of this appendix.

4.6.4.2.1. Project time to failure using the projection method described in section 5.1.4 of IES TM–28 (incorporated by reference; see §430.3). Project time to failure for each individual LED lamp. Do not use data obtained prior to a test duration value of 1,000 hours.

4.6.4.2.2. Calculate the limiting multiplier from the following equation:

$$Limiting\ multiplier = \frac{1}{600} * test\ duration - 4$$

4.6.4.3. For test duration values greater than 6,000 hours, time to failure is equal to the lesser of the projected time to failure calculated according to section 4.6.4.3.1 or the test duration multiplied by six.

4.6.4.3.1. Project time to failure using the projection method described in section 5.1.4 of IES TM–28 (incorporated by reference; see §430.3). Project time to failure for each individual LED lamp. Data used for the time to failure projection method must be as specified in section 5.1.3 of IES TM–28.

5. Standby Mode Test Method for Determining Standby Mode Power

Measure standby mode power consumption for integrated LED lamps capable of operating in standby mode. The standby mode test method in this section 5 may be completed before or after the active mode test method for determining lumen output, input power, CCT, CRI, power factor, and lamp efficacy in section 3 of this appendix. The standby mode test method in this section 5 must be completed before the active mode test method for determining time to failure in section 4 of this appendix. In cases where there is a conflict, the language of the test procedure in this appendix takes precedence over IES LM–79 (incorporated by reference; see §430.3) and IEC 62301 (incorporated by reference; see §430.3).

5.1. Test Conditions and Setup

5.1.1. Establish the ambient conditions, power supply, electrical settings, and instrumentation in accordance with the specifications in sections 2.0, 3.0, 7.0, and 8.0 of IES LM–79 (incorporated by reference; see §430.3), respectively. Maintain the ambient temperature at 25 °C ± 1 °C.

5.1.2. Position a lamp in either the base-up and base-down orientation throughout testing. An equal number of lamps in the sample must be tested in the base-up and base-down orientations.

5.1.3. Operate the integrated LED lamp at the rated voltage throughout testing. For an integrated LED lamp with multiple rated voltages, operate the integrated LED lamp at 120 volts. If an integrated LED lamp with multiple rated voltages is not rated for 120 volts, operate the integrated LED lamp at the highest rated input voltage.

5.2. Test Method, Measurements, and Calculations

5.2.1. The test conditions and setup described in section 3.1 of this appendix apply to this section.

5.2.2. Connect the integrated LED lamp to the manufacturer-specified wireless control network (if applicable) and configure the integrated LED lamp in standby mode by sending a signal to the integrated LED lamp instructing it to have zero light output. Lamp must remain connected to the network throughout the duration of the test.

5.2.3. Stabilize the integrated LED lamp as specified in section 5 of IEC 62301 (incorporated by reference; see §430.3) prior to measurement.

5.2.4. Measure the standby mode power in watts as specified in section 5 of IEC 62301.

[81 FR 43427, July 1, 2016, as amended at 83 FR 47812, Sept. 21, 2018]

APPENDIX CC TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF PORTABLE AIR CONDITIONERS

NOTE: Manufacturers must use the results of testing under this appendix to determine compliance with the relevant standards for portable air conditioners at §430.32(cc) with

which compliance is required as of January 10, 2025. Specifically, before November 13, 2023 representations must be based upon results generated either under this appendix or under this appendix CC as it appeared in the 10 CFR parts 200–499 edition revised as of January 1, 2021. Any representations made on or after November 13, 2023 but before the compliance date of any amended standards for portable ACs must be made based upon results generated using this appendix.

Manufacturers must use the results of testing under appendix CC1 to this subpart to determine compliance with any standards that amend the portable air conditioners standard at §430.32(cc) with which compliance is required on January 10, 2025 and that use the Annualized Energy Efficiency Ratio (AEER) metric. Any representations related to energy also must be made in accordance with the appendix that applies (*i.e.,* this appendix or appendix CC1) when determining compliance with the relevant standard. Manufacturers may also use appendix CC1 to certify compliance with any amended standards prior to the applicable compliance date for those standards.

0. Incorporation by Reference

DOE incorporated by reference in §430.3 the entire standard for ANSI/AHAM PAC–1–2015, ANSI/AMCA 210–99, ASHRAE 37–2009, ASHRAE 41.1–1986, ASHRAE 41.6–1994, and IEC 62301; however, only enumerated provisions of ANSI/AHAM PAC–1–2015, ANSI/AMCA 210–99, ASHRAE 37–2009, and IEC 62301 apply to this appendix CC as follows. Treat ''should'' in IEC 62301 as mandatory. When there is a conflict, the language of this appendix takes precedence over those documents.

0.1 ANSI/AHAM PAC–1–2015

(a) Section 4 ''Definitions,'' as specified in section 3.1.1 of this appendix, except for AHAM's definition for ''Portable Air Conditioner'';

(b) Section 7 ''Tests,'' as specified in sections 3.1.1, 3.1.1.3, 3.1.1.4, 4.1.1, and 4.1.2 of this appendix.

0.2 ANSI/AMCA 210–99 (''ANSI/AMCA 210'')

(a) Figure 12 ''Outlet chamber Setup—Multiple Nozzles in Chamber'' as specified in section 4.1.1 of this appendix;

(b) Figure 12 Notes as specified in section 4.1.1 of this appendix.

0.3 ASHRAE 37–2009

(a) Section 5.4 ''Electrical Instruments,'' as specified in sections 4.1.1 and 4.1.2 of this appendix;

(b) Section 7.3 ''Indoor and Outdoor Air Enthalpy Methods,'' as specified in sections 4.1.1 and 4.1.2 of this appendix;

(c) Section 7.6 ''Outdoor Liquid Coil Method,'' as specified in sections 4.1.1 and 4.1.2 of this appendix;

(d) Section 7.7 ''Airflow Rate Measurement,'' as specified in sections 4.1.1 and 4.1.2 of this appendix;

(e) Section 8.7 ''Test Procedure for Cooling Capacity Tests,'' as specified in sections 4.1.1 and 4.1.2 of this appendix;

(f) Section 9.2 ''Test Tolerances,'' as specified in sections 4.1.1 and 4.1.2 of this appendix;

(g) Section 11.1 ''Symbols Used In Equations,'' as specified in sections 4.1.1 and 4.1.2 of this appendix.

0.4 IEC 62301

(a) Paragraph 4.2 ''Test room,'' as specified in section 3.2.4 of this appendix;

(b) Paragraph 4.3.2 ''Supply voltage waveform,'' as specified in section 3.2.2.2 of this appendix;

(c) Paragraph 4.4 ''Power measuring instruments,'' as specified in section 3.2.3 of this appendix;

(d) Paragraph 5.1, ''General,'' Note 1, as specified in section 4.3 of this appendix;

(e) Paragraph 5.2 ''Preparation of product,'' as specified in section 3.2.1 of this appendix;

(f) Paragraph 5.3.2 ''Sampling method,'' as specified in section 4.3 of this appendix;

(g) Annex D, ''Determination of Uncertainty of Measurement,'' as specified in sections 3.2.1, 3.2.2.2, and 3.2.3 of this appendix.

1. Scope

This appendix covers the test requirements used to measure the energy performance of single-duct and dual-duct portable air conditioners, as defined at 10 CFR 430.2.

2. Definitions

Combined-duct means the condenser inlet and outlet air streams flow through separate ducts housed in a single duct structure.

Combined energy efficiency ratio means the energy efficiency of a portable air conditioner as measured in accordance with this test procedure in Btu per watt-hours (Btu/Wh) and determined in section 5.4 of this appendix.

Cooling mode means a mode in which a portable air conditioner either has activated the main cooling function according to the thermostat or temperature sensor signal, including activating the refrigeration system, or has activated the fan or blower without activating the refrigeration system.

Dual-duct means drawing some or all of the condenser inlet air from outside the conditioned space through a duct attached to an adjustable window bracket, potentially drawing additional condenser inlet air from the conditioned space, and discharging the condenser outlet air outside the conditioned

space by means of a separate duct attached to an adjustable window bracket.

Full compressor speed (full) means the compressor speed at which the unit operates at full load test conditions, when using user controls with a unit thermostat setpoint of 75 °F to achieve maximum cooling capacity.

Inactive mode means a standby mode that facilitates the activation of an active mode or off-cycle mode by remote switch (including remote control), internal sensor, or timer, or that provides continuous status display.

Low compressor speed (low) means the compressor speed specified by the manufacturer, at which the unit operates at low load test conditions (*i.e.*, Test Condition C and Test Condition E in Table 2 of this appendix, for a dual-duct and single-duct portable air conditioner, respectively), such that the measured cooling capacity at this speed is no less than 50 percent and no greater than 60 percent of the measured cooling capacity with the full compressor speed at full load test conditioners (*i.e.*, Test Condition A and Test Condition C in Table 2 of this appendix, for a dual-duct and single-duct portable air conditioner, respectively).

Off-cycle mode means a mode in which a portable air conditioner:

(a) Has cycled off its main cooling or heating function by thermostat or temperature sensor signal;

(b) May or may not operate its fan or blower; and

(c) Will reactivate the main function according to the thermostat or temperature sensor signal.

Off mode means a mode that may persist for an indefinite time in which a portable air conditioner is connected to a mains power source, and is not providing any active mode, off-cycle mode, or standby mode function. This includes an indicator that only shows the user that the portable air conditioner is in the off position.

Seasonally adjusted cooling capacity means the amount of cooling provided to the indoor conditioned space, measured under the specified ambient conditions, in Btu/h,

Seasonally adjusted cooling capacity, full means the amount of cooling provided to the indoor conditions space, measured under the specified ambient conditions when the unit compressor is operating at full speed at each condition, in Btu/h.

Single-duct means drawing all of the condenser inlet air from the conditioned space without the means of a duct, and discharging the condenser outlet air outside the conditioned space through a single duct attached to an adjustable window bracket.

Single-speed means incapable of automatically adjusting the compressor speed based on detected conditions.

Standby mode means any mode where a portable air conditioner is connected to a mains power source and offers one or more of the following user-oriented or protective functions which may persist for an indefinite time:

(a) To facilitate the activation of other modes (including activation or deactivation of cooling mode) by remote switch (including remote control), internal sensor, or timer; or

(b) Continuous functions, including information or status displays (including clocks) or sensor-based functions. A timer is a continuous clock function (which may or may not be associated with a display) that provides regular scheduled tasks (*e.g.*, switching) and that operates on a continuous basis.

Theoretical comparable single-speed means a hypothetical single-speed unit that would have the same cooling capacity and electrical power input as the variable-speed unit under test, with no cycling losses considered, when operating with the full compressor speed and at the test conditions in Table 1 of this appendix.

Variable-speed means capable of automatically adjusting the compressor speed based on detected conditions.

3. Test Apparatus and General Instructions

3.1 Active mode.

3.1.1 *Test conduct.* The test apparatus and instructions for testing portable air conditioners in cooling mode and off-cycle mode must conform to the requirements specified in section 4, ''Definitions'' and section 7, ''Tests,'' of ANSI/AHAM PAC–1–2015, except as otherwise specified in this appendix. Measure duct heat transfer and infiltration air heat transfer according to sections 4.1.1 and 4.1.2 of this appendix, respectively.

3.1.1.1 *Duct setup.* Use all ducting components provided by or required by the manufacturer and no others. Ducting components include ducts, connectors for attaching the duct(s) to the test unit, sealing, insulation, and window mounting fixtures. Do not apply additional sealing or insulation. For combined-duct units, the manufacturer must provide the testing facility an adapter that allows for the individual connection of the condenser inlet and outlet airflows to the test facility's airflow measuring apparatuses. Use that adapter to measure the condenser inlet and outlet airflows for any corresponding unit.

3.1.1.2 *Single-duct evaporator inlet test conditions.* When testing single-duct portable air conditioners, maintain the evaporator inlet dry-bulb temperature within a range of 1.0 °F with an average difference within 0.3 °F.

3.1.1.3 *Condensate Removal.* Set up the test unit in accordance with manufacturer instructions. If the unit has an auto-evaporative feature, keep any provided drain plug installed as shipped and do not provide other means of condensate removal. If the internal condensate collection bucket fills during the

test, halt the test, remove the drain plug, install a gravity drain line, and start the test from the beginning. If no auto-evaporative feature is available, remove the drain plug and install a gravity drain line. If no auto-evaporative feature or gravity drain is available and a condensate pump is included, or if the manufacturer specifies the use of an included condensate pump during cooling mode operation, then test the portable air conditioner with the condensate pump enabled. For units tested with a condensate pump, apply the provisions in Section 7.1.2 of ANSI/AHAM PAC–1–2015 if the pump cycles on and off.

3.1.1.4 *Unit Placement*. There shall be no less than 3 feet between any test chamber wall surface and any surface on the portable air conditioner, except the surface or surfaces of the portable air conditioner that include a duct attachment. The distance between the test chamber wall and a surface with one or more duct attachments is prescribed by the test setup requirements in Section 7.3.7 of ANSI/AHAM PAC–1–2015.

3.1.1.5 *Electrical supply*. Maintain the input standard voltage at 115 V ±1 percent. Test at the rated frequency, maintained within ±1 percent.

3.1.1.6 *Duct temperature measurements*. Install any insulation and sealing provided by the manufacturer. For a dual-duct or single-duct unit, adhere four thermocouples per duct, spaced along the entire length equally, to the outer surface of the duct. Measure the surface temperatures of each duct. For a combined-duct unit, adhere sixteen thermocouples to the outer surface of the duct, spaced evenly around the circumference (four thermocouples, each 90 degrees apart, radially) and down the entire length of the duct (four sets of four thermocouples, evenly spaced along the entire length of the duct), ensuring that the thermocouples are spaced along the entire length equally, on the surface of the combined duct. Place at least one thermocouple preferably adjacent to, but otherwise as close as possible to, the condenser inlet aperture and at least one thermocouple on the duct surface preferably adjacent to, but otherwise as close as possible to, the condenser outlet aperture. Measure the surface temperature of the combined duct at each thermocouple. Temperature measurements must have an error no greater than ±0.5 °F over the range being measured.

3.1.2 *Control settings*. For a single-speed unit, set the controls to the lowest available temperature setpoint for cooling mode, as described in section 4.1.1 of this appendix. For a variable-speed unit, set the thermostat setpoint to 75 °F to achieve the full compressor speed and use the manufacturer instructions to achieve the low compressor speed, as described in section 4.1.2 of this appendix. If the portable air conditioner has a user-adjustable fan speed, select the maximum fan speed setting. If the unit has an automatic louver oscillation feature and there is an option to disable that feature, disable that feature throughout testing. If the unit has adjustable louvers, position the louvers parallel with the air flow to maximize air flow and minimize static pressure loss. If the portable air conditioner has network functions, that an end-user can disable and the product's user manual provides instructions on how to do so, disable all network functions throughout testing. If an end-user cannot disable a network function or the product's user manual does not provide instruction for disabling a network function, test the unit with that network function in the factory default configuration for the duration of the test.

3.2 Standby Mode and Off Mode

3.2.1 *Installation requirements*. For the standby mode and off mode testing, install the portable air conditioner in accordance with Paragraph 5.2 of IEC 62301, referring to Annex D of that standard as necessary. Disregard the provisions regarding batteries and the determination, classification, and testing of relevant modes.

3.2.2 *Electrical energy supply*.

3.2.2.1 *Electrical supply*. For the standby mode and off mode testing, maintain the input standard voltage at 115 V ±1 percent. Maintain the electrical supply at the rated frequency ±1 percent.

3.2.2.2 *Supply voltage waveform*. For the standby mode and off mode testing, maintain the electrical supply voltage waveform indicated in, Paragraph 4.3.2 of IEC 62301, referring to Annex D of that standard as necessary.

3.2.3 *Standby mode and off mode wattmeter*. The wattmeter used to measure standby mode and off mode power consumption must meet the requirements specified in Paragraph 4.4 of IEC 62301, using a two-tailed confidence interval and referring to Annex D of that standard as necessary.

3.2.4 *Standby mode and off mode ambient temperature*. For standby mode and off mode testing, maintain room ambient air temperature conditions as specified in Section 4, Paragraph 4.2 of IEC 62301 (incorporated by reference; see § 430.3).

4. Test Measurement

4.1 Cooling Mode

NOTE: For the purposes of this cooling mode test procedure, evaporator inlet air is considered the ''indoor air'' of the conditioned space and condenser inlet air is considered the ''outdoor air'' outside of the conditioned space.

4.1.1 *Single-Speed Cooling Mode Test*. For single-speed portable air conditioners, measure the indoor room cooling capacity and

overall power input in cooling mode in accordance with sections 7.1.b and 7.1.c of ANSI/AHAM PAC–1–2015, respectively, including the references to sections 5.4, 7.3, 7.6, 7.7, and 11 of ASHRAE 37–2009. Determine the test duration in accordance with section 8.7 of ASHRAE 37–2009, including the reference to section 9.2 of the same standard, referring to Figure 12 and the Figure 12 Notes of ANSI/AMCA 210 to determine placement of static pressure taps, and including references to ASHRAE 41.1–1986 and ASHRAE 41.6–1994. Disregard the test conditions in Table 3 of ANSI/AHAM PAC–1–2015. Instead, apply the test conditions for single-duct and dual-duct portable air conditioners presented in Table 1 of this appendix. For single-duct units, measure the indoor room cooling capacity, $Capacity_{SD}$, and overall power input in cooling mode, P_{SD}, in accordance with the ambient conditions for test condition 1.C, presented in Table 1 of this appendix. For dual-duct units, measure the indoor room cooling capacity and overall power input twice, first in accordance with ambient conditions for test condition 1.A ($Capacity_{95}$, P_{95}), and then in accordance with test condition 1.B ($Capacity_{83}$, P_{83}), both presented in Table 1 of this appendix. For the remainder of this test procedure, test combined-duct single-speed portable air conditioners following any instruction for dual-duct single-speed portable air conditioners, unless otherwise specified.

TABLE 1—SINGLE-SPEED EVAPORATOR (INDOOR) AND CONDENSER (OUTDOOR) INLET TEST CONDITIONS

Test condition	Evaporator inlet air, °F (°C)		Condenser inlet air, °F (°C)	
	Dry bulb	Wet bulb	Dry bulb	Wet bulb
1.A	80 (26.7)	67 (19.4)	95 (35.0)	75 (23.9)
1.B	80 (26.7)	67 (19.4)	83 (28.3)	67.5 (19.7)
1.C	80 (26.7)	67 (19.4)	80 (26.7)	67 (19.4)

4.1.2 *Variable-Speed Cooling Mode Test*. For variable-speed portable air conditioners, measure the indoor room cooling capacity and overall power input in cooling mode in accordance with sections 7.1.b and 7.1.c of ANSI/AHAM PAC–1–2015, respectively, including the references to sections 5.4, 7.3, 7.6, 7.7, and 11 of ASHRAE 37–2009, except as detailed below. Determine the test duration in accordance with section 8.7 of ASHRAE 37–2009, including the reference to section 9.2 of the same standard. Disregard the test conditions in Table 3 of ANSI/AHAM PAC–1–2015. Instead, apply the test conditions for single-duct and dual-duct portable air conditioners presented in Table 2 of this appendix. For a single-duct unit, measure the indoor room cooling capacity and overall power input in cooling mode twice, first in accordance with the ambient conditions and compressor speed settings for test condition 2.D ($Capacity_{SD__Full}$, $P_{SD__Full}$), and then in accordance with the ambient conditions for test condition 2.E ($Capacity_{SD__Low}$, $P_{SD__Low}$), both presented in Table 2 of this appendix. For dual-duct units, measure the indoor room cooling capacity and overall power input three times, first in accordance with ambient conditions for test condition 2.A ($Capacity_{95__Full}$, $P_{95__Full}$), second in accordance with the ambient conditions for test condition 2.B ($Capacity_{83__Full}$, $P_{83__Full}$), and third in accordance with the ambient conditions for test condition 2.C ($Capacity_{83__Low}$, $P_{83__Low}$), each presented in Table 2 of this appendix. For the remainder of this test procedure, test combined-duct variable-speed portable air conditioners following any instruction for dual-duct variable-speed portable air conditioners, unless otherwise specified. For test conditions 2.A, 2.B, and 2.D, achieve the full compressor speed with user controls, as defined in section 2.13 of this appendix. For test conditions 2.C and 2.E, set the required compressor speed in accordance with instructions the manufacturer provided to DOE.

TABLE 2—VARIABLE-SPEED EVAPORATOR (INDOOR) AND CONDENSER (OUTDOOR) INLET TEST CONDITIONS

Test condition	Evaporator inlet air °F (°C)		Condenser inlet air °F (°C)		Compressor speed
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
2.A	80 (26.7)	67 (19.4)	95 (35.0)	75 (23.9)	Full.
2.B	80 (26.7)	67 (19.4)	83 (28.3)	67.5 (19.7)	Full.
2.C	80 (26.7)	67 (19.4)	83 (28.3)	67.5 (19.7)	Low.
2.D	80 (26.7)	67 (19.4)	80 (26.7)	67 (19.4)	Full.
2.E	80 (26.7)	67 (19.4)	80 (26.7)	67 (19.4)	Low.

4.1.3. *Duct Heat Transfer*

Throughout the cooling mode test, measure the surface temperature of the condenser exhaust duct and condenser inlet duct, where applicable. Calculate the average temperature at each thermocouple placement location. Then calculate the average surface temperature of each duct. For single-duct and dual-duct units, calculate the average of the four average temperature measurements taken on the duct. For combined-duct units, calculate the average of the sixteen average temperature measurements taken on the duct. Calculate the surface area ($A_{duct__j}$) of each duct according to:

$A_{duct__j} = Cj \times Lj$

Where:

Cj = the circumference of duct ''j'', including any manufacturer-supplied insulation, measured by wrapping a flexible measuring tape, or equivalent, around the outside of a combined duct, making sure the tape is on the outermost ridges or, alternatively, if the duct has a circular cross-section, by multiplying the outer diameter by 3.14.

Lj = the extended length of duct ''j'' while under test.

j represents the condenser exhaust duct for single-duct units, the condenser exhaust duct and the condenser inlet duct for dual-duct units, and the combined duct for combined-duct units.

Calculate the total heat transferred from the surface of the duct(s) to the indoor conditioned space while operating in cooling mode at each test condition, as follows:

For single-duct single-speed portable air conditioners:

$Q_{duct__SD} = 3 \times A_{duct__j} \times (T_{duct__j} - T_{ei})$

For dual-duct single-speed portable air conditioners:

$Q_{duct__DD__95} = \Sigma_j\{3 \times A_{duct__j} \times (T_{duct__95__j} - T_{ei})\}$
$Q_{duct__DD__83} = \Sigma_j\{3 \times A_{duct__j} \times (T_{duct__83__j} - T_{ei})\}$

For single-duct variable-speed portable air conditioners:

$Q_{duct__SD__Full} = 3 \times A_{duct} \times (T_{duct__Full__j} - T_{ei})$
$Q_{duct__SD__Low} = 3 \times A_{duct} \times (T_{duct__Low__j} - T_{ei})$

For dual-duct variable-speed portable air conditioners:

$Q_{duct__DD__95__Full} = \Sigma_j\{3 \times A_{duct__j} \times (T_{duct__Full__95__j} - T_{ei})\}$
$Q_{duct__DD__83__Full} = \Sigma_j\{3 \times A_{duct__j} \times (T_{duct__Full__83__j} - T_{ei})\}$
$Q_{duct__DD__83__Low} = \Sigma_j\{3 \times A_{duct__j} \times (T_{duct__Low__83__j} - T_{ei})\}$

Where:

$Q_{duct__SD}$ = the total heat transferred from the duct to the indoor conditioned space in cooling mode, in Btu/h, when tested at Test Condition 1.C.

$Q_{duct__DD__95}$ and $Q_{duct__DD__83}$ = the total heat transferred from the ducts to the indoor conditioned space in cooling mode, in Btu/h, when tested at Test Conditions 1.A and 1.B, respectively.

$Q_{duct__SD__Full}$ and $Q_{duct__SD__Low}$ = the total heat transferred from the duct to the indoor conditioned space in cooling mode, in Btu/h, when tested at Test Conditions 2.D and 2.E, respectively.

$Q_{duct__DD__95__Full}$, $Q_{duct__DD__83__Full}$, and $Q_{duct__DD__83__Low}$ = the total heat transferred from the ducts to the indoor conditioned space in cooling mode, in Btu/h, when tested at Test Condition 2.A, Test Condition 2.B, and Test Condition 2.C, respectively.

3 = empirically-derived convection coefficient in Btu/h per square foot per °F.

$A_{duct__j}$ = surface area of the duct ''j'', as calculated in this section, in square feet.

$T_{duct__j}$ = average surface temperature for duct ''j'' of single-duct single-speed portable air conditioners, in °F, as measured at Test Condition 1.C.

$T_{duct__95__j}$ and $T_{duct__83__j}$ = average surface temperature for duct ''j'' of dual-duct single-speed portable air conditioners, in °F, as measured at Test Conditions 1.A and 1.B, respectively.

$T_{duct__Full__j}$ and $T_{duct__Low__j}$ = average surface temperature for duct ''j'' of single-duct variable-speed portable air conditioners, in °F, as measured at Test Conditions 2.D and 2.E, respectively.

$T_{duct__Full__95__j}$, $T_{duct__Full__83__j}$, and $T_{duct__Low__83__j}$ = average surface temperature for duct ''j'' of dual-duct variable-speed portable air conditioners, in °F, as measured at Test Conditions 2.A, 2.B, and 2.C, respectively.

j represents the condenser exhaust duct for single-duct units, the condenser exhaust duct and the condenser inlet duct for dual-duct units, and the combined duct for combined-duct units.

T_{ei} = average evaporator inlet air dry-bulb temperature, as measured in section 4.1 of this appendix, in °F.

4.1.4. *Infiltration Air Heat Transfer*.

Calculate the sample unit's heat contribution from infiltration air into the conditioned space for each cooling mode test as follows:

Calculate the dry air mass flow rate of infiltration air, which affects the sensible and latent components of heat contribution from infiltration air, according to the following equations.

For a single-duct single-speed unit:

$$\dot{m}_{SD} = \frac{V_{co_SD} \times \rho_{co_SD}}{\left(1 + \omega_{co_SD}\right)}$$

For a dual-duct single-speed unit:

$$\dot{m}_{95} = \frac{V_{co_95} \times \rho_{co_95}}{\left(1 + \omega_{co_95}\right)} - \frac{V_{ci_95} \times \rho_{ci_95}}{\left(1 + \omega_{ci_95}\right)}$$

$$\dot{m}_{83} = \frac{V_{co_83} \times \rho_{co_83}}{\left(1 + \omega_{co_83}\right)} - \frac{V_{ci_83} \times \rho_{ci_83}}{\left(1 + \omega_{ci_83}\right)}$$

For a single-duct variable-speed unit:

$$\dot{m}_{SD_Full} = \frac{V_{co_SD_Full} \times \rho_{co_SD_Full}}{\left(1 + \omega_{co_SD_Full}\right)}$$

$$\dot{m}_{SD_Low} = \frac{V_{co_Low} \times \rho_{co_Low}}{\left(1 + \omega_{co_Low}\right)}$$

For a dual-duct variable-speed unit:

$$\dot{m}_{95_Full} = \frac{V_{co_95_Full} \times \rho_{co_95_Full}}{\left(1 + \omega_{co_95_Full}\right)} - \frac{V_{ci_95_Full} \times \rho_{ci_95_Full}}{\left(1 + \omega_{ci_95_Full}\right)}$$

$$\dot{m}_{83_Full} = \frac{V_{co_83_Full} \times \rho_{co_83_Full}}{\left(1 + \omega_{co_83_Full}\right)} - \frac{V_{ci_83_Full} \times \rho_{ci_83_Full}}{\left(1 + \omega_{ci_83_Full}\right)}$$

$$\dot{m}_{83_Low} = \frac{V_{co_83_Low} \times \rho_{co_83_Low}}{\left(1 + \omega_{co_83_Low}\right)} - \frac{V_{ci_83_Low} \times \rho_{ci_83_Low}}{\left(1 + \omega_{ci_83_Low}\right)}$$

Where:

$\dot{m}_{SD}$, $\dot{m}_{SD_Full}$, and $\dot{m}_{SD_Low}$ = dry air mass flow rate of infiltration air for single-duct portable air conditioners, in pounds per minute (lb/m) when tested at Test Conditions 1.C, 2.D, and 2.E, respectively.

$\dot{m}_{95}$, $\dot{m}_{83}$, $\dot{m}_{95_Full}$, $\dot{m}_{83_Full}$, and $\dot{m}_{83_Low}$ = dry air mass flow rate of infiltration air for dual-duct portable air conditioners, in lb/m, when tested at Test Conditions 1.A, 1.B, 2.A, 2.B, and 2.C, respectively.

V_{co_SD}, $V_{co_SD_Full}$, $V_{co_SD_Low}$, V_{co_95}, V_{co_83}, $V_{co_95_Full}$, $V_{co_83_Full}$, and

$V_{co_83_Low}$ = average volumetric flow rate of the condenser outlet air, in cubic feet per minute (cfm), as measured at Test Conditions 1.C, 2.D, 2.E, 1.A, 1.B, 2.A, 2.B, and 2.C, respectively, as required in sections 4.1.1 and 4.1.2 of this appendix.

V_{ci_95}, V_{ci_83}, $V_{ci_95_Full}$, $V_{ci_83_Full}$, and $V_{ci_83_Low}$ = average volumetric flow rate of the condenser inlet air, in cfm, as measured at Test Conditions 1.A, 1.B, 2.A, 2.B, and 2.C, respectively, as required in sections 4.1.1 and 4.1.2 of this appendix.

ρ_{co_SD}, $\rho_{co_SD_Full}$, $\rho_{co_SD_Low}$, ρ_{co_95}, ρ_{co_83}, $\rho_{co_95_Full}$, $\rho_{co_83_Full}$, and $\rho_{co_83_Low}$ = average density of the condenser outlet air, in pounds mass per cubic foot (lb_m/ft^3), as measured at Test Conditions 1.C, 2.D, 2.E, 1.A, 1.B, 2.A, 2.B, and 2.C, respectively, as required in sections 4.1.1 and 4.1.2 of this appendix.

ρ_{ci_95}, ρ_{ci_83}, $\rho_{ci_95_Full}$, $\rho_{ci_83_Full}$, and $\rho_{ci_83_Low}$ = average density of the condenser inlet air, in lb_m/ft^3, as measured at Test Conditions 1.A, 1.B, 2.A, 2.B, and 2.C, respectively, as required in sections 4.1.1 and 4.1.2 of this appendix.

ω_{co_SD}, $\omega_{co_SD_Full}$, $\omega_{co_SD_Low}$, ω_{co_95}, ω_{co_83}, $\omega_{co_95_Full}$, $\omega_{co_83_Full}$, and $\omega_{co_83_Low}$ = average humidity ratio of condenser outlet air, in pounds mass of water vapor per pounds mass of dry air (lb_w/lb_{da}), as measured at Test Conditions 1.C, 2.D, 2.E, 1.A, 1.B, 2.A, 2.B, and 2.C, respectively, as required in sections 4.1.1 and 4.1.2 of this appendix.

ω_{ci_95}, ω_{ci_83}, $\omega_{ci_95_Full}$, $\omega_{ci_83_Full}$, and $\omega_{ci_83_Low}$ = average humidity ratio of condenser inlet air, in lb_w/lb_{da}, as measured at Test Conditions 1.A, 1.B, 2.A, 2.B, and 2.C, respectively, as required in sections 4.1.1 and 4.1.2 of this appendix.

Calculate the sensible component of infiltration air heat contribution according to the following equations.

For single-duct single-speed units:

$$Q_{s_SD_95} = \dot{m}_{SD} \times 60 \times [c_{p_da} \times (95 - 80) + (c_{p_wv} \times (0.0141 \times 95 - 0.0112 \times 80))]$$

$$Q_{s_SD_83} = \dot{m}_{SD} \times 60 \times [(c_{p_da} \times (83 - 80) + (c_{p_wv} \times (0.01086 \times 83 - 0.0112 \times 80))]$$

For dual-duct single-speed units:

$$Q_{s_DD_95} = \dot{m}_{95} \times 60 \times [c_{p_da} \times (95 - 80) + (c_{p_wv} \times (0.0141 \times 95 - 0.0112 \times 80))]$$

$$Q_{s_DD_83} = \dot{m}_{83} \times 60 \times [(c_{p_da} \times (83 - 80) + (c_{p_wv} \times (0.01086 \times 83 - 0.0112 \times 80))]$$

For single-duct variable-speed units:

$$Q_{s_SD_95_Full} = \dot{m}_{SD_Full} \times 60 \times [c_{p_da} \times (95 - 80) + (c_{p_wv} \times (0.0141 \times 95 - 0.0112 \times 80))]$$

$$Q_{s_SD_83_Full} = \dot{m}_{SD_Full} \times 60 \times [(c_{p_da} \times (83 - 80) + (c_{p_wv} \times (0.01086 \times 83 - 0.0112 \times 80))]$$

$$Q_{s_SD_83_Low} = \dot{m}_{SD_Low} \times 60 \times [(c_{p_da} \times (83 - 80) + (c_{p_wv} \times (0.01086 \times 83 - 0.0112 \times 80))]$$

For dual-duct variable-speed units:

$$Q_{s_DD_95_Full} = \dot{m}_{95_Full} \times 60 \times [c_{p_da} \times (95 - 80) + (c_{p_wv} \times (0.0141 \times 95 - 0.0112 \times 80))]$$

$$Q_{s_DD_83_Full} = \dot{m}_{83_Full} \times 60 \times [(c_{p_da} \times (83 - 80) + (c_{p_wv} \times (0.01086 \times 83 - 0.0112 \times 80))]$$

$$Q_{s_DD_83_Low} = \dot{m}_{83_Low} \times 60 \times [(c_{p_da} \times (83 - 80) + (c_{p_wv} \times (0.01086 \times 83 - 0.0112 \times 80))]$$

Where:

$Q_{s_SD_95}$, $Q_{s_SD_83}$, $Q_{s_DD_95}$, and $Q_{s_DD_83}$ = sensible heat added to the room by infiltration air, in Btu/h, for each duct configuration and temperature condition.

$Q_{s_SD_95_Full}$, $Q_{s_SD_83_Full}$, $Q_{s_SD_83_Low}$, $Q_{s_DD_95_Full}$, $Q_{s_DD_83_Full}$, and $Q_{s_DD_83_Low}$ = sensible heat added to the room by infiltration air, in Btu/h, for each duct configuration, temperature condition, and compressor speed.

$\dot{m}_{SD}$, $\dot{m}_{95}$, and $\dot{m}_{83}$ = dry air mass flow rate of infiltration air for single-speed portable air conditioners, in lb/m, as calculated in section 4.1.4 of this appendix.

$\dot{m}_{SD_95_Full}$, $\dot{m}_{SD_83_Low}$, $\dot{m}_{95_Full}$ and $\dot{m}_{83_Low}$ = dry air mass flow rate of infiltration air for variable-speed portable air conditioners, in lb/m, as calculated in section 4.1.4 of this appendix.

c_{p_da} = specific heat of dry air, 0.24 Btu/(lbm °F).

c_{p_wv} = specific heat of water vapor, 0.444 Btu/(lbm °F).

80 = indoor chamber dry-bulb temperature, in °F.

95 = infiltration air dry-bulb temperature for Test Conditions 1.A and 2.A, in °F.

83 = infiltration air dry-bulb temperature for Test Conditions 1.B, 2.B, and 2.C, in °F.

0.0141 = humidity ratio of the dry-bulb infiltration air for Test Conditions 1.A and 2.A, in lb_w/lb_{da}.

0.01086 = humidity ratio of the dry-bulb infiltration air for Test Conditions 1.B, 2.B, and 2.C, in lb_w/lb_{da}.

0.0112 = humidity ratio of the indoor chamber air, in lb_w/lb_{da} (ω_{indoor}).

60 = conversion factor from minutes to hours.

Calculate the latent heat contribution of the infiltration air according to the following equations. For a single-duct single-speed unit:

$$Q_{l_SD_95} = \dot{m}_{SD} \times 60 \times 1061 \times (0.0141 - 0.0112)$$

$$Q_{l_SD_83} = \dot{m}_{SD} \times 60 \times 1061 \times (0.01086 - 0.0112)$$

For a dual-duct single-speed unit:

$$Q_{l_DD_95} = \dot{m}_{95} \times 60 \times 1061 \times (0.0141 - 0.0112)$$

$$Q_{l_DD_83} = \dot{m}_{83} \times 60 \times 1061 \times (0.01086 - 0.0112)$$

For a single-duct variable-speed unit:

$$Q_{l_SD_95_Full} = \dot{m}_{SD_Full} \times 60 \times 1061 \times (0.0141 - 0.0112)$$

$$Q_{l_SD_83_Full} = \dot{m}_{SD_Full} \times 60 \times 1061 \times (0.01086 - 0.0112)$$

$$Q_{l_SD_83_Low} = \dot{m}_{SD_Low} \times 60 \times 1061 \times (0.01086 - 0.0112)$$

For a dual-duct variable-speed unit:

$$Q_{l_DD_95_Full} = \dot{m}_{95_Full} \times 60 \times 1061 \times (0.0141 - 0.0112)$$

$Q_{l__DD__83__Full} = \dot{m}_{83__Full} \times 60 \times 1061 \times (0.01086 - 0.0112)$

$Q_{l__DD__83__Low} = \dot{m}_{83__Low} \times 60 \times 1061 \times (0.01086 - 0.0112)$

Where:

$Q_{l__SD__95}$, $Q_{l__SD__83}$, $Q_{l__DD__95}$, and $Q_{l__DD__83}$ = latent heat added to the room by infiltration air, in Btu/h, for each duct configuration and temperature condition.

$Q_{l__SD__95__Full}$, $Q_{l__SD__83__Full}$, $Q_{l__SD__Low}$, $Q_{l__DD__95__Full}$, $Q_{l__DD__83__Full}$, and $Q_{l__DD__83__Low}$ = latent heat added to the room by infiltration air, in Btu/h, for each duct configuration, temperature condition, and compressor speed.

$\dot{m}_{SD}$, $\dot{m}_{95}$, and $\dot{m}_{83}$ = dry air mass flow rate of infiltration air for portable air conditioners, in lb/m, when tested at Test Conditions 1.C, 1.A, and 1.B, respectively, as calculated in section 4.1.4 of this appendix.

$\dot{m}_{SD__Full}$, $\dot{m}_{SD__Low}$, $\dot{m}_{95__Full}$, $\dot{m}_{83__Full}$ and $\dot{m}_{83__Low}$ = dry air mass flow rate of infiltration air for portable air conditioners, in lb/m, when tested at Test Conditions 2.D, 2.E, 2.A, 2.B, and 2.C, respectively, as calculated in section 4.1.4 of this appendix.

1061 = latent heat of vaporization for water vapor, in Btu/lb_m (H_{fg}).

0.0141 = humidity ratio of the dry-bulb infiltration air for Test Conditions 1.A and 2.A, in lb_w/lb_{da}.

0.01086 = humidity ratio of the dry-bulb infiltration air for Test Conditions 1.B, 2.B, and 2.C, in lb_w/lb_{da}.

0.0112 = humidity ratio of the indoor chamber air, in lb_w/lb_{da}.

60 = conversion factor from minutes to hours.

Calculate the total heat contribution of the infiltration air at each test condition by adding the sensible and latent heat according to the following equations.

For a single-duct single-speed unit:

$Q_{infiltration__SD__95} = Q_{s__SD__95} + Q_{l__SD__95}$

$Q_{infiltration__SD__83} = Q_{s__SD__83} + Q_{l__SD__83}$

For a dual-duct single-speed unit:

$Q_{infiltration__DD__95} = Q_{s__DD__95} + Q_{l__DD__95}$

$Q_{infiltration__DD__83} = Q_{s__DD__83} + Q_{l__DD__83}$

For a single-duct variable-speed unit:

$Q_{infiltration__SD__95__Full} = Q_{s__SD__95__Full} + Q_{l__SD__95__Full}$

$Q_{infiltration__SD__83__Full} = Q_{s__SD__83__Full} + Q_{l__SD__83__Full}$

$Q_{infiltration__SD__83__Low} = Q_{s__SD__83__Low} + Q_{l__SD__83__Low}$

For a dual-duct variable-speed unit:

$Q_{infiltration__DD__95__Full} = Q_{s__DD__95__Full} + Q_{l__DD__95__Full}$

$Q_{infiltration__DD__83__Full} = Q_{s__DD__83__Full} + Q_{l__DD__83__Full}$

$Q_{infiltration__DD__83__Low} = Q_{s__DD__83__Low} + Q_{l__DD__83__Low}$

Where:

$Q_{infiltration__SD__95}$, $Q_{infiltration__SD__83}$, $Q_{infiltration__DD__95}$, $Q_{infiltration__DD__83}$ = total infiltration air heat in cooling mode, in Btu/h, for each duct configuration and temperature condition.

$Q_{infiltration__SD__95__Full}$, $Q_{infiltration__SD__83__Full}$, $Q_{infiltration__SD__83__Low}$, $Q_{infiltration__DD__95__Full}$, $Q_{infiltration__DD__83__Full}$, and $Q_{infiltration__DD__83__Low}$ = total infiltration air heat in cooling mode, in Btu/h, for each duct configuration, temperature condition, and compressor speed.

$Q_{s__SD__95}$, $Q_{s__SD__83}$, $Q_{s__DD__95}$, and $Q_{s__DD__83}$ = sensible heat added to the room by infiltration air, in Btu/h, for each duct configuration, temperature condition, and compressor speed.

$Q_{s__SD__95__Full}$, $Q_{s__SD__83__Full}$, $Q_{s__SD__83__Low}$, $Q_{s__DD__95__Full}$, $Q_{s__DD__83__Full}$, and $Q_{s__DD__83__Low}$ = sensible heat added to the room by infiltration air, in Btu/h, for each duct configuration, temperature condition, and compressor speed.

$Q_{l__SD__95}$, $Q_{l__SD__83}$, $Q_{l__DD__95}$, and $Q_{l__DD__83}$ = latent heat added to the room by infiltration air, in Btu/h, for each duct configuration, and temperature condition.

$Q_{l__SD__95__Full}$, $Q_{l__SD__83__Full}$, $Q_{l__SD__83__Low}$, $Q_{l__DD__95__Full}$, $Q_{l__DD__83__Full}$, and $Q_{l__DD__83__Low}$ = latent heat added to the room by infiltration air, in Btu/h, for each duct configuration, temperature condition, and compressor speed.

4.2 *Off-cycle mode.* Establish the test conditions specified in section 3.1.1 of this appendix for off-cycle mode and use the wattmeter specified in section 3.2.3 of this appendix (but do not use the duct measurements in section 3.1.1.6). Begin the off-cycle mode test period 5 minutes following the cooling mode test period. Adjust the setpoint higher than the ambient temperature to ensure the product will not enter cooling mode and begin the test 5 minutes after the compressor cycles off due to the change in setpoint. Do not change any other control settings between the end of the cooling mode test period and the start of the off-cycle mode test period. The off-cycle mode test period must be 2 hours in duration, during which period, record the power consumption at the same intervals as recorded for cooling mode testing. Measure and record the average off-cycle mode power of the portable air conditioner, P_{oc}, in watts.

4.3 *Standby mode and off mode.* Establish the testing conditions set forth in section 3.2 of this appendix, ensuring that the unit does not enter any active modes during the test. As discussed in Paragraph 5.1, Note 1 of IEC 62301, allow sufficient time for the unit to reach the lowest power state before proceeding with the test measurement. Follow the test procedure specified in Paragraph 5.3.2 of IEC 62301 for testing in each possible mode as described in sections 4.3.1 and 4.3.2

of this appendix. If the standby mode is cyclic and irregular or unstable, collect 10 cycles worth of data.

4.3.1 If the portable air conditioner has an inactive mode, as defined in section 2.6 of this appendix, but not an off mode, as defined in section 2.8 of this appendix, measure and record the average inactive mode power of the portable air conditioner, P_{ia}, in watts.

4.3.2 If the portable air conditioner has an off mode, as defined in section 2.8 of this appendix, measure and record the average off mode power of the portable air conditioner, P_{om}, in watts.

5. Calculation of Derived Results From Test Measurements

5.1 *Adjusted Cooling Capacity*

5.1.1 *Single-Speed Adjusted Cooling Capacity*. For a single-speed portable air conditioner, calculate the adjusted cooling capacity at each outdoor temperature operating condition, in Btu/h, according to the following equations.

For a single-duct single-speed portable air conditioner unit:

$$ACC_{SD_95_SS} = Capacity_{SD} - Q_{duct_SD} - Q_{inflitration_SD_95}$$

$$ACC_{SD_83_SS} = Capacity_{SD} - Q_{duct_SD} - Q_{inflitration_SD_83}$$

For a dual-duct single-speed portable air conditioner unit:

$$ACC_{DD_95_SS} = Capacity_{95} - Q_{duct_DD_95} - Q_{inflitration_DD_95}$$

$$ACC_{DD_83_SS} = Capacity_{83} - Q_{duct_DD_83} - Q_{inflitration_DD_83}$$

Where:

$Capacity_{SD}$, $Capacity_{95}$, and $Capacity_{83}$ = cooling capacity for each duct configuration or temperature condition measured in section 4.1.1 of this appendix.

Q_{duct_SD}, $Q_{duct_DD_95}$, and $Q_{duct_DD_83}$ = duct heat transfer for each duct configuration or temperature condition while operating in cooling mode, calculated in section 4.1.3 of this appendix.

$Q_{infiltration_SD_95}$, $Q_{infiltration_SD_83}$, $Q_{infiltration_DD_95}$, $Q_{infiltration_DD_83}$ = total infiltration air heat transfer in cooling mode for each duct configuration and temperature condition, calculated in section 4.1.4 of this appendix.

5.1.2 *Variable-Speed Adjusted Cooling Capacity*. For variable-speed portable air conditioners, calculate the adjusted cooling capacity at each outdoor temperature operating condition, in Btu/h, according to the following equations:

For a single-duct variable-speed portable air conditioner unit:

$$ACC_{SD_95} = Capacity_{SD_Full} - Q_{duct_SD_Full} - Q_{inflitration_SD_95_Full}$$

$$ACC_{SD_83_Full} = Capacity_{SD_Full} - Q_{duct_SD_Full} - Q_{inflitration_SD_83_Full}$$

$$ACC_{SD_83_Low} = Capacity_{SD_Low} - Q_{duct_SD_Low} - Q_{inflitration_SD_83_Low}$$

For a dual-duct variable-speed portable air conditioner unit:

$$ACC_{DD_95} = Capacity_{DD_95_Full} - Q_{duct_DD_95_Full} - Q_{inflitration_DD_95_Full}$$

$$ACC_{DD_83_Full} = Capacity_{DD_83_Full} - Q_{duct_DD_83_Full} - Q_{inflitration_DD_83_Full}$$

$$ACC_{DD_83_Low} = Capacity_{DD_83_Low} - Q_{duct_DD_83_Low} - Q_{inflitration_DD_83_Low}$$

Where:

$Capacity_{SD_Full}$, $Capacity_{SD_Low}$, $Capacity_{DD_95_Full}$, $Capacity_{DD_83_Full}$, and $Capacity_{DD_83_Low}$ = cooling capacity in Btu/h for each duct configuration, temperature condition (where applicable), and compressor speed, as measured in section 4.1.2 of this appendix.

$Q_{duct_SD_Full}$, $Q_{duct_SD_Low}$, $Q_{duct_DD_95_Full}$, $Q_{duct_DD_83_Full}$, and $Q_{duct_DD_83_Low}$ = combined duct heat transfer for each duct configuration, temperature condition (where applicable), and compressor speed, as calculated in section 4.1.3 of this appendix.

$Q_{infiltration_SD_95_Full}$, $Q_{infiltration_SD_83_Full}$, $Q_{infiltration_SD_83_Low}$, $Q_{infiltration_DD_95_Full}$, $Q_{infiltration_DD_83_Full}$, and $Q_{infiltration_DD_83_Low}$ = total infiltration air heat transfer in cooling mode for each duct configuration, temperature condition, and compressor speed, as calculated in section 4.1.4 of this appendix.

5.2 *Seasonally Adjusted Cooling Capacity*

5.2.1 Calculate the unit's seasonally adjusted cooling capacity, SACC, in Btu/h, according to the following equations:

For a single-speed portable air conditioner unit:

$$SACC_{SD} = ACC_{SD_95_SS} \times 0.2 + ACC_{SD_83_SS} \times 0.8$$

$$SACC_{DD} = ACC_{DD_95_SS} \times 0.2 + ACC_{SD_83_SS} \times 0.8$$

For a variable-speed portable air conditioner unit:

$$SACC_{SD} = ACC_{SD_95} \times 0.2 + ACC_{SD_83_Low} \times 0.8$$

$$SACC_{DD} = ACC_{DD_95} \times 0.2 + ACC_{DD_83_Low} \times 0.8$$

Where:

$ACC_{SD_95_SS}$, $ACC_{SD_83_SS}$, $ACC_{DD_95_SS}$, and $ACC_{DD_83_SS}$ = adjusted cooling capacity for single-speed portable air conditioners for each duct configuration and temperature condition, in Btu/h, calculated in section 5.1.1 of this appendix.

ACC_{SD_95}, $ACC_{SD_83_Low}$, ACC_{DD_95}, and $ACC_{DD_83_Low}$ = adjusted cooling capacity for variable-speed portable air conditioners for each duct configuration, temperature condition, and compressor speed, in Btu/h, calculated in section 5.1.2 of this appendix.

0.2 = weighting factor for the 95 °F test condition.
0.8 = weighting factor for the 83 °F test condition.

5.2.2 For variable-speed portable ACs determine a Full-Load Seasonally Adjusted Cooling Capacity ($SACC_{Full__SD}$ for single-speed units and $SACC_{Full__DD}$ for dual-duct units) using the following formulas:

$SACC_{Full__SD} = ACC_{SD__95} \times 0.2 + ACC_{SD__83__Full} \times 0.8$

$SACC_{Full__DD} = ACC_{DD__95} \times 0.2 + ACC_{DD__83__Full} \times 0.8$

$ACC_{SD__95}$, $ACC_{SD__83__Full}$, $ACC_{DD__95}$, and $ACC_{DD__83__Full}$ = adjusted cooling capacity for variable-speed portable air conditioners for each duct configuration, temperature condition, and compressor speed (where applicable), in Btu/h, calculated in section 5.1.2 of this appendix.
0.2 = weighting factor for the 95 °F test condition.
0.8 = weighting factor for the 83 °F test condition.

5.3 *Annual Energy Consumption.* Calculate the sample unit's annual energy consumption in each operating mode according to the equation below. For each operating mode, use the following annual hours of operation and equation:

Type of portable air conditioner	Operating mode	Subscript	Annual operating hours
Variable speed (single- or dual-duct).	Cooling Mode: Test Conditions 2.A, 2.B, 2.C, 2.D, and 2.E [1].	DD__95__Full, DD__83__Full, DD__83__Low, SD__Full, and SD__Low.	750
Single speed (single- or dual-duct)	Cooling Mode: Test Conditions 1.A, 1.B, and 1C [1].	DD__95, DD__83, and SD	750
all	Off-Cycle	oc	880
all	Inactive or Off	ia or om	1,355

[1] These operating mode hours are for the purposes of calculating annual energy consumption under different ambient conditions and are not a division of the total cooling mode operating hours. The total cooling mode operating hours are 750 hours.

$AEC_m = P_m \times t_m \times 0.001$

Where:

AEC_m = annual energy consumption in the operating mode, in kWh/year.
m represents the operating mode as shown in the table above with each operating mode's respective subscript.
P_m = average power in the operating mode, in watts, as determined in sections 4.1.1 and 4.1.2.
t_m = number of annual operating time in each operating mode, in hours.
0.001 kWh/Wh = conversion factor from watt-hours to kilowatt-hours.

Calculate the sample unit's total annual energy consumption in off-cycle mode and inactive or off mode as follows:

$$AEC_T = \sum_{ncm} AEC_{ncm}$$

Where:

AEC_T = total annual energy consumption attributed to off-cycle mode and inactive or off mode, in kWh/year;
AEC_m = total annual energy consumption in the operating mode, in kWh/year.
ncm represents the following two non-cooling operating modes: off-cycle mode and inactive or off mode.

5.4 Combined Energy Efficiency Ratio

5.4.1 *Combined Energy Efficiency Ratio for Single-Speed Portable Air Conditioners.*

Using the annual operating hours established in section 5.3 of this appendix, calculate the combined energy efficiency ratio, CEER, in Btu/Wh, for single-speed portable air conditioners according to the following equation, as applicable:

$$CEER_{SD} = \left[\frac{\left(ACC_{SD_95_SS} \times 0.2 + ACC_{SD_83_SS} \times 0.8\right)}{\left(\frac{AEC_{SD} + AEC_T}{0.750}\right)}\right]$$

$$CEER_{DD} = \left[\frac{ACC_{DD_95_SS}}{\left(\frac{AEC_{DD_95} + AEC_T}{0.750}\right)}\right] \times 0.2 + \left[\frac{ACC_{DD_83_SS}}{\left(\frac{AEC_{DD_83} + AEC_T}{0.750}\right)}\right] \times 0.8$$

Where:

$CEER_{SD}$ and $CEER_{DD}$ = combined energy efficiency ratio for a single-duct unit and dual-duct unit, respectively, in Btu/Wh.

$ACC_{SD_95_SS}$, $ACC_{SD_83_SS}$, $ACC_{DD_95_SS}$, $ACC_{DD_83_SS}$ = adjusted cooling capacity for each duct configuration and temperature condition, in Btu/h, calculated in section 5.1 of this appendix.

AEC_{SD}, AEC_{DD_95} and AEC_{DD_83} = annual energy consumption in cooling mode for each duct configuration and temperature condition, in kWh/year, calculated in section 5.3 of this appendix.

AEC_T = total annual energy consumption attributed to all modes except cooling, in kWh/year, calculated in section 5.3 of this appendix.

0.750 = number of cooling mode hours per year, 750, multiplied by the conversion factor for watt-hours to kilowatt-hours, 0.001 kWh/Wh.

0.2 = weighting factor for the 95 °F dry-bulb outdoor condition test.

0.8 = weighting factor for the 83 °F dry-bulb outdoor condition test.

5.4.2 *Unadjusted Combined Energy Efficiency Ratio for Variable-Speed Portable Air Conditioners.*

For a variable-speed portable air conditioner, calculate the unit's unadjusted combined energy efficiency ratio, $CEER_{UA}$, in Btu/Wh, as follows:

For single-duct variable-speed portable air conditioners:

$$CEER_{SD_UA} = \left[\frac{ACC_{SD_95}}{\left(\frac{AEC_{SD_Full} + AEC_{ia/om}}{0.750}\right)}\right] \times 0.2 + \left[\frac{ACC_{SD_83_Low}}{\left(\frac{AEC_{SD_Low} + AEC_{ia/om}}{0.750}\right)}\right] \times 0.8$$

For dual-duct variable-speed portable air conditioners:

$$CEER_{DD_UA} = \left[\frac{ACC_{DD_95}}{\left(\frac{AEC_{DD_95_Full} + AEC_{ia/om}}{0.750}\right)}\right] \times 0.2 + \left[\frac{ACC_{DD_83_Low}}{\left(\frac{AEC_{DD_83_Low} + AEC_{ia/om}}{0.750}\right)}\right] \times 0.8$$

Where:

$CEER_{SD_UA}$, and $CEER_{DD_UA}$ = unadjusted combined energy efficiency ratio for a single-duct and dual-duct sample unit, in Btu/Wh, respectively.

ACC_{SD_95}, $ACC_{SD_83_Low}$, ACC_{DD_95}, and ACC_{DD_83} = adjusted cooling capacity for each duct configuration, temperature condition, and compressor speed, as calculated in section 5.1.2 of this appendix, in Btu/h.

AEC_{SD_Full}, AEC_{SD_Low}, $AEC_{DD_95_Full}$, and $AEC_{DD_83_Low}$ = annual energy consumption for each duct configuration, temperature condition, and compressor speed in cooling mode operation, as calculated in section 5.3 of this appendix, in kWh/year.

$AEC_{ia/om}$ = annual energy consumption attributed to inactive or off mode, in kWh/year, calculated in section 5.3 of this appendix.

0.750 = number of cooling mode hours per year, 750, multiplied by the conversion factor for watt-hours to kilowatt-hours, 0.001 kWh/Wh.

0.2 = weighting factor for the 95 °F dry-bulb outdoor temperature operating condition.

0.8 = weighting factor for the 83 °F dry-bulb outdoor temperature operating condition.

5.5 *Adjustment of the Combined Energy Efficiency Ratio.* Adjust the sample unit's unadjusted combined energy efficiency ratio as follows.

5.5.1 *Theoretical Comparable Single-Speed Portable Air Conditioner Cooling Capacity and Power at the Lower Outdoor Temperature Operating Condition.* Calculate the cooling capacity without and with cycling losses, in British thermal units per hour (Btu/h), and electrical power input, in watts, for a single-duct or dual-duct theoretical comparable single-speed portable air conditioner at an 83 °F outdoor dry-bulb outdoor temperature operating condition according to the following equations:

For a single-duct theoretical comparable single speed portable air conditioner:

$Capacity_{SD__83__SS} = Capacity_{SD__Full}$

$Capacity_{SD__83__SS__CF} = Capacity_{SD__Full} \times 0.82$

$P_{SD__83__SS} = P_{SD__Full}$

For a dual-duct theoretical comparable single speed portable air conditioner:

$Capacity_{DD__83__SS} = Capacity_{83__Full}$

$Capacity_{DD__83__SS__CF} = Capacity_{83__Full} \times 0.77$

$P_{DD__83__SS} = P_{83__Full}$

Where:

$Capacity_{SD__83__SS}$ and $Capacity_{DD__83__SS}$ = cooling capacity of a single-duct and dual-duct theoretical comparable single-speed portable air conditioner, calculated for the 83 °F dry-bulb outdoor temperature operating condition (Test Conditions 2.E and 2.B, respectively), in Btu/h.

$Capacity_{SD__83__SS__CF}$ and $Capacity_{DD__83__SS__CF}$ = cooling capacity of a single-duct and dual-duct theoretical comparable single-speed portable air conditioner with cycling losses, in Btu/h, calculated for the 83 °F dry-bulb outdoor temperature operating condition (Test Conditions 2.E and 2.B, respectively).

$Capacity_{SD__Full}$ and $Capacity_{83__Full}$ = cooling capacity of the sample unit, measured in section 4.1.2 of this appendix at Test Conditions 2.D and 2.B, in Btu/h.

$P_{SD__83__SS}$ and $P_{DD__83__SS}$ = power input of a single-duct and dual-duct theoretical comparable single-speed portable air conditioner calculated for the 83 °F dry-bulb outdoor temperature operating condition (Test Conditions 2.E and 2.B, respectively), in watts.

$P_{SD__Full}$ and $P_{83__Full}$ = electrical power input of the sample unit, measured in section 4.1.2 of this appendix at Test Conditions 2.D and 2.B, in watts.

0.82 = empirically-derived cycling factor for the 83 °F dry-bulb outdoor temperature operating condition for single-duct units.

0.77 = empirically-derived cycling factor for the 83 °F dry-bulb outdoor temperature operating condition for dual-duct units.

5.5.2 *Duct Heat Transfer for a Theoretical Comparable Single-Speed Portable Air Conditioner at the Lower Outdoor Temperature Operating Condition.* Calculate the duct heat transfer to the conditioned space for a single-duct or dual-duct theoretical comparable single-speed portable air conditioner at the 83 °F dry-bulb outdoor temperature operating condition as follows:

For a single-duct theoretical comparable single-speed portable air conditioner:

$Q_{duct__SD__83__SS} = Q_{duct__SD__Full}$

For a dual-duct theoretical comparable single-speed portable air conditioner:

$Q_{duct__DD__83__SS} = Q_{duct__DD__83__Full}$

Where:

$Q_{duct__SD__83__SS}$ and $Q_{duct__DD__83__SS}$ = total heat transferred from the condenser exhaust duct to the indoor conditioned space in cooling mode, for single-duct and dual-duct theoretical comparable single-speed portable air conditioners, respectively, at the 83 °F dry-bulb outdoor temperature operating condition (Test Conditions 2.E and 2.B, respectively), in Btu/h.

$Q_{duct__SD__Full}$ and $Q_{duct__DD__83__Full}$ = the total heat transferred from the duct to the indoor conditioned space in cooling mode, when tested at Test Conditions 2.D and 2.B, respectively, as calculated in section 4.1.3 of this appendix, in Btu/h.

5.5.3 *Infiltration Air Heat Transfer for a Theoretical Comparable Single-Speed Portable Air Conditioner at the Lower Outdoor Temperature Operating Condition.* Calculate the total heat contribution from infiltration air for a single-duct or dual-duct theoretical comparable single-speed portable air conditioner at the 83 °F dry-bulb outdoor temperature operating condition, as follows:

For a single-duct theoretical comparable single-speed portable air conditioner:

$Q_{infiltration__SD__83__SS} = Q_{infiltration__SD__83__Full}$

For a dual-duct theoretical comparable single-speed portable air conditioner:

$Q_{infiltration__DD__83__SS} = Q_{infiltration__DD__83__Full}$

Where:

$Q_{infiltration__SD__83__SS}$ and $Q_{infiltration__DD__83__SS}$ = total infiltration air heat in cooling

mode for a single-duct and dual-duct theoretical comparable single-speed portable air conditioner, respectively at the 83 °F dry-bulb outdoor temperature operating condition (Test Conditions 2.E and 2.B, respectively), in Btu/h.

$Q_{infiltration__SD__83__Full}$ and $Q_{infiltration__DD__83__Full}$ = total infiltration air heat transfer of the sample unit in cooling mode for each duct configuration, temperature condition, and compressor speed, as calculated in section 4.1.4 of this appendix, in Btu/h.

5.5.4 *Adjusted Cooling Capacity for a Theoretical Comparable Single-Speed Portable Air Conditioner at the Lower Outdoor Temperature Operating Condition*. Calculate the adjusted cooling capacity without and with cycling losses for a single-duct or dual-duct theoretical comparable single-speed portable air conditioner at the 83 °F dry-bulb outdoor temperature operating condition, in Btu/h, according to the following equations:

For a single-duct theoretical comparable single-speed portable air conditioner:

$$ACC_{SD__83__SS} = Capacity_{SD__83__SS} - Q_{duct__SD__83__SS} - Q_{infiltration__SD__83__SS}$$

$$ACC_{SD__83__SS__CF} = Capacity_{SD__83__SS__CF} - Q_{duct__SD__83__SS} - Q_{infiltration__SD__83__SS}$$

For a dual-duct theoretical comparable single-speed portable air conditioner:

$$ACC_{DD__83__SS} = Capacity_{83__SS} - Q_{duct__DD__83__SS} - Q_{infiltration__DD__83__SS}$$

$$ACC_{DD__83__SS__CF} = Capacity_{DD__83__SS__CF} - Q_{duct__DD__83__SS} - Q_{infiltration__DD__83__SS}$$

Where:

$ACC_{SD__83__SS}$, $ACC_{SD__83__SS__CF}$, $ACC_{DD__83__SS}$, and $ACC_{DD__83__SS__CF}$ = adjusted cooling capacity for a single-duct and dual-duct theoretical comparable single-speed portable air conditioner at the 83 °F dry-bulb outdoor temperature operating condition (Test Conditions 2.E and 2.B, respectively) without and with cycling losses, respectively, in Btu/h.

$Capacity_{SD__83__SS}$ and $Capacity_{SD__83__SS__CF}$ = cooling capacity of a single-duct theoretical comparable single-speed portable air conditioner without and with cycling losses, respectively, at Test Conditions 2.E and 2.B (the 83 °F dry-bulb outdoor temperature operating condition), respectively, calculated in section 5.5.1 of this appendix, in Btu/h.

$Capacity_{DD__83__SS}$ and $Capacity_{DD__83__SS__CF}$ = cooling capacity of a dual-duct theoretical comparable single-speed portable air conditioner without and with cycling losses, respectively, at Test Conditions 2.E and 2.B (the 83 °F dry-bulb outdoor temperature operating condition), respectively, calculated in section 5.5.1 of this appendix, in Btu/h.

$Q_{duct__SD__83__SS}$ and $Q_{duct__DD__83__SS}$ = total heat transferred from the ducts to the indoor conditioned space in cooling mode for a single-duct and dual-duct theoretical comparable single-speed portable air conditioner, at Test Conditions 2.E and 2.B (the 83 °F dry-bulb outdoor temperature operating condition), respectively, calculated in section 5.5.2 of this appendix, in Btu/h.

$Q_{infiltration__SD__83__SS}$ and $Q_{infiltration__DD__83__SS}$ = total infiltration air heat in cooling mode for a single-duct and dual-duct theoretical comparable single-speed portable air conditioner, respectively, at Test Conditions 2.E and 2.B (the 83 °F dry-bulb outdoor temperature operating condition), respectively, calculated in section 5.5.3 of this appendix, in Btu/h.

5.5.5 *Annual Energy Consumption in Cooling Mode for a Theoretical Comparable Single-Speed Portable Air Conditioner at the Lower Outdoor Temperature Operating Condition*. Calculate the annual energy consumption in cooling mode for a single-duct or dual-duct theoretical comparable single-speed portable air conditioner at the 83 °F dry-bulb outdoor temperature operating condition, in kWh/year, according to the following equations:

For a single-duct theoretical comparable single-speed portable air conditioner:

$$AEC_{SD__83__SS} = P_{SD__83__SS} \times 0.750$$

For a dual-duct theoretical comparable single-speed portable air conditioner:

$$AEC_{DD__83__SS} = P_{DD__83__SS} \times 0.750$$

Where:

$AEC_{SD__83__SS}$ and $AEC_{DD__83__SS}$ = annual energy consumption for a single-duct and dual-duct theoretical comparable single-speed portable air conditioner, respectively, in cooling mode at the 83 °F dry-bulb outdoor temperature operating condition (Test Conditions 2.E and 2.B, respectively), in kWh/year.

$P_{SD__83__SS}$ and $P_{DD__83__SS}$ = electrical power input for a single-duct and dual-duct theoretical comparable single-speed portable air conditioner, respectively, at the 83 °F dry-bulb outdoor temperature operating condition (Test Conditions 2.E and 2.B, respectively) as calculated in section 5.5.1 of this appendix, in watts.

0.750 = number of cooling mode hours per year, 750, multiplied by the conversion factor for watt-hours to kilowatt-hours, 0.001 kWh/Wh.

5.5.6 *Combined Energy Efficiency Ratio for a Theoretical Comparable Single-Speed Portable Air Conditioner*. Calculate the combined energy efficiency ratios for a theoretical comparable single-speed portable air conditioner without cycling losses, $CEER_{SD__SS}$ and $CEER_{DD__SS}$, and with cycling losses, $CEER_{SD__SS__CF}$ and $CEER_{DD__SS__CF}$, in Btu/Wh, according to the following equations:

For a single-duct portable air conditioner:

$$CEER_{SD_SS} = \left[\frac{ACC_{SD_95}}{\left(\frac{AEC_{SD_95_Full} + AEC_T}{0.750}\right)}\right] \times 0.2 + \left[\frac{ACC_{SD_83_SS}}{\left(\frac{AEC_{SD_83_SS} + AEC_T}{0.750}\right)}\right] \times 0.8$$

$$CEER_{SD_SS_CF} = \left[\frac{ACC_{SD_95}}{\left(\frac{AEC_{SD_95_Full} + AEC_T}{0.750}\right)}\right] \times 0.2 + \left[\frac{ACC_{SD_83_SS_CF}}{\left(\frac{AEC_{SD_83_SS} + AEC_T}{0.750}\right)}\right] \times 0.8$$

For a dual-duct portable air conditioner:

$$CEER_{DD_SS} = \left[\frac{ACC_{DD_95}}{\left(\frac{AEC_{DD_95_Full} + AEC_T}{0.750}\right)}\right] \times 0.2 + \left[\frac{ACC_{DD_83_SS}}{\left(\frac{AEC_{DD_83_SS} + AEC_T}{0.750}\right)}\right] \times 0.8$$

$$CEER_{DD_SS_CF} = \left[\frac{ACC_{DD_95}}{\left(\frac{AEC_{DD_95_Full} + AEC_T}{0.750}\right)}\right] \times 0.2 + \left[\frac{ACC_{DD_83_SS_CF}}{\left(\frac{AEC_{DD_83_SS} + AEC_T}{0.750}\right)}\right] \times 0.8$$

Where:

$CEER_{SD__SS}$ and $CEER_{SD__CF__SS}$ = combined energy efficiency ratio for a single-duct theoretical comparable single-speed portable air conditioner without and with cycling losses, respectively, in Btu/Wh.

$CEER_{DD__SS}$ and $CEER_{DD__CF__SS}$ = combined energy efficiency ratio for a dual-duct theoretical comparable single-speed portable air conditioner without and with cycling losses, respectively, in Btu/Wh.

$ACC_{SD__95}$ and $ACC_{DD__95}$ = adjusted cooling capacity of the sample unit, as calculated in section 5.1.2 of this appendix, when tested at Test Conditions 2.D and 2.A, respectively, in Btu/h.

$ACC_{SD__83__SS}$ and $ACC_{SD__83__SS__CF}$ = adjusted cooling capacity for a single-duct theoretical comparable single-speed portable air conditioner at the 83 °F dry-bulb outdoor temperature operating condition (Test Conditions 2.E) without and with cycling losses, respectively, as calculated in section 5.5.4 of this appendix, in Btu/h.

$ACC_{DD__83__SS}$ and $ACC_{DD__83__SS__CF}$ = adjusted cooling capacity for a dual-duct theoretical comparable single-speed portable air conditioner at the 83 °F dry-bulb outdoor temperature operating condition (Test Condition 2.B) without and with cycling losses, respectively, as calculated in section 5.5.4 of this appendix, in Btu/h.

$AEC_{SD__Full}$ = annual energy consumption of the single-duct sample unit, as calculated in section 5.4.2.1 of this appendix, in kWh/year.

$AEC_{DD__95__Full}$ = annual energy consumption for the dual-duct sample unit, as calculated in section 5.4.2.1 of this appendix, in kWh/year.

$AEC_{SD__83__SS}$ and $AEC_{DD__83__SS}$ = annual energy consumption for a single-duct and dual-duct theoretical comparable single-speed portable air conditioner, respectively, in cooling mode at the 83 °F dry-bulb outdoor temperature operating condition (Test Conditions 2.E and 2.B, respectively), calculated in section 5.5.5 of this appendix, in kWh/year.

AEC_T = total annual energy consumption attributed to all operating modes except cooling for the sample unit, calculated in section 5.3 of this appendix, in kWh/year.

0.750 as defined previously in this section.

0.2 = weighting factor for the 95 °F dry-bulb outdoor temperature operating condition.

0.8 = weighting factor for the 83 °F dry-bulb outdoor temperature operating condition.

5.5.7 *Performance Adjustment Factor.* Calculate the sample unit's performance adjustment factor, F_p, as follows:

For a single-duct unit:

$$F_{p_SD} = \frac{\left(CEER_{SD_SS} - CEER_{SD_SS_CF}\right)}{CEER_{SD_SS_CF}}$$

For a dual-duct unit:

$$F_{p_DD} = \frac{\left(CEER_{DD_SS} - CEER_{DD_SS_CF}\right)}{CEER_{DD_SS_CF}}$$

Where:

$CEER_{SD_SS}$ and $CEER_{SD_SS_CF}$ = combined energy efficiency ratio for a single-duct theoretical comparable single-speed portable air conditioner without and with cycling losses considered, respectively, calculated in section 5.5.6 of this appendix, in Btu/Wh.

$CEER_{DD_SS}$ and $CEER_{DD_SS_CF}$ = combined energy efficiency ratio for a dual-duct theoretical comparable single-speed portable air conditioner without and with cycling losses considered, respectively, calculated in section 5.5.6 of this appendix, in Btu/Wh.

5.5.8 *Single-Duct and Dual-Duct Variable-Speed Portable Air Conditioner Combined Energy Efficiency Ratio.* Calculate the sample unit's final combined energy efficiency ratio, CEER, in Btu/Wh, as follows:

For a single-duct portable air conditioner:

$$CEER_{SD} = CEER_{SD_UA} \times (1 + F_{p_SD})$$

For a dual-duct portable air conditioner:

$$CEER_{DD} = CEER_{DD_UA} \times (1 + F_{p_DD})$$

Where:

$CEER_{SD}$ and $CEER_{DD}$ = combined energy efficiency ratio for a single-duct and dual-duct sample unit, in Btu/Wh, respectively.

$CEER_{SD_UA}$ and $CEER_{DD_UA}$ = unadjusted combined energy efficiency ratio for a single-duct and dual-duct sample unit, respectively, calculated in section 5.4.2.1 of this appendix, in Btu/Wh.

F_{p_SD} and F_{p_DD} = single-duct and dual-duct sample unit's performance adjustment factor, respectively, calculated in section 5.5.7 of this appendix.

[81 FR 35265, June 1, 2016, as amended at 81 FR 70923, Oct. 14, 2016; 85 FR 21746, Apr. 20, 2020; 88 FR 31127, May 15, 2023]

APPENDIX CC1 TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF PORTABLE AIR CONDITIONERS

NOTE: Manufacturers must use the results of testing under this appendix CC1 to determine compliance with any standards that amend the portable air conditioners standard at §430.32(cc) with which compliance is required on January 10, 2025 and that use the Annualized Energy Efficiency Ratio (AEER) metric. Any representation related to energy also must be made in accordance with the appendix that applies (*i.e.*, appendix CC to this subpart or this appendix CC1). Manufacturers may also use this appendix CC1 to certify compliance with any amended standards before the compliance date for those standards.

0. Incorporation by Reference

DOE incorporated by reference in §430.3, the entire standard for AHAM PAC–1–2022, ANSI/AMCA 210–99, ASHRAE 37–2009, ASHRAE 41.1–1986, ASHRAE 41.6–1994, and IEC 62301; however, only enumerated provisions of AHAM PAC–1–2022, ANSI/AMCA 210–99, ASHRAE 37–2009, and IEC 62301 are applicable to this appendix CC1, as follows. Treat ''should'' in IEC 62301 as mandatory. When there is a conflict, the language of this appendix takes precedence over those documents.

0.1 AHAM PAC–1–2022

(a) Section 4 ''Definitions,'' as specified in section 2 of this appendix;

(b) Section 7 ''Test Setup,'' as specified in sections 3 and 4 of this appendix;

(c) Section 8 ''Test Conduct,'' as specified in section 4 of this appendix;

(d) Section 8.1 ''Cooling Mode,'' as specified in sections 5.1 and 5.3 of this appendix;

(e) Section 9 ''Calculation of Derived Results from Test Measurements,'' as specified in section 5 of this appendix;

(f) Section 9.1 ''Duct Heat Transfer,'' as specified in section 5.1 of this appendix;

(g) Section 9.2 ''Infiltration Air Heat Transfer,'' as specified in section 5.1 of this appendix.

0.2 ANSI/AMCA 210–99 (''ANSI/AMCA 210'')

(a) Figure 12, ''Outlet chamber Setup—Multiple Nozzles in Chamber,'' as specified in section 4 of this appendix;

(b) Figure 12 Notes, as specified in section 4 of this appendix.

0.3 ASHRAE 37–2009

(a) Section 5.1 ''Temperature Measuring Instruments,'' as specified in section 3 of this appendix;

(b) Section 5.3 ''Air Differential Pressure and Airflow Measurements,'' as specified in section 3 of this appendix;

(c) Section 5.4 ''Electrical Instruments,'' as specified in section 4 of this appendix;

(d) Section 6.2 ''Nozzle Airflow Measuring Apparatus,'' as specified in section 4 of this appendix;

(e) Section 6.3 ''Nozzles,'' as specified in section 4 of this appendix;
(f) Section 7.3 ''Indoor and Outdoor Air Enthalpy Methods,'' as specified in section 4 of this appendix;
(g) Section 7.7 ''Airflow Rate Measurement,'' as specified in section 4 of this appendix;
(h) Section 8.7 ''Test Procedure for Cooling Capacity Tests,'' as specified in section 4 of this appendix;
(i) Section 9 ''Data to be Recorded,'' as specified in section 4 of this appendix;
(j) Section 10 ''Test Results,'' as specified in section 4 of this appendix;
(k) Section 11.1 ''Symbols Used In Equations,'' as specified in section 4 of this appendix.

0.4 IEC 62301

(a) Paragraph 4.2 ''Test room'' as specified in section 3 of this appendix;
(b) Paragraph 4.3.2 ''Supply voltage waveform,'' as specified in section 3 of this appendix;
(c) Paragraph 4.4 ''Power measuring instruments,'' as specified in section 3 of this appendix;
(d) Paragraph 5.1, ''General,'' Note 1 as specified in section 4 of this appendix;
(e)Paragraph 5.2 ''Preparation of product,'' as specified in section 3 of this appendix;
(f) Paragraph 5.3.2 ''Sampling method,'' as specified in section 4 of this appendix;
(g) Annex D, ''Determination of Uncertainty of Measurement,'' as specified in section 3 of this appendix.

1. Scope

Establishes test requirements to measure the energy performance of single-duct and dual-duct, and single-speed and variable-speed portable air conditioners in accordance with AHAM PAC–1–2022, unless otherwise specified.

2. Definitions

Definitions for industry standards, terms, modes, calculations, etc. are in accordance with AHAM PAC–1–2022, section 4, with the following added definition:
Annualized Energy Efficiency Ratio means the energy efficiency of a portable air conditioner as measured in accordance with this test procedure as the total annual cooling delivered divided by the total annual energy consumption in per watt-hours (Btu/Wh) and determined in section 5.4.

3. Test Apparatus and General Instructions

Follow requirements and instructions for test conduct and test setup in accordance with AHAM PAC–1–2022, section 7, excluding section 7.1.3, including references to ASHRAE 37–2009, sections 5.1 and 5.3, and IEC 62301 sections 4.2, 4.3.2, 4.4, and 5.2, and Annex D. If the portable air conditioner has network functions, disable all network functions throughout testing if possible. If an end-user cannot disable a network function or the product's user manual does not provide instruction for disabling a network function, test the unit with that network function in the factory default configuration for the duration of the test.

3.1 *Duct temperature measurements.* Install any insulation and sealing provided by the manufacturer. For a dual-duct or single-duct unit, adhere four thermocouples per duct, spaced along the entire length equally, to the outer surface of the duct. Measure the surface temperatures of each duct. For a combined-duct unit, adhere sixteen thermocouples to the outer surface of the duct, spaced evenly around the circumference (four thermocouples, each 90 degrees apart, radially) and down the entire length of the duct (four sets of four thermocouples, evenly spaced along the entire length of the duct), ensuring that the thermocouples are spaced along the entire length equally, on the surface of the combined duct. Place at least one thermocouple preferably adjacent to, but otherwise as close as possible to, the condenser inlet aperture and at least one thermocouple on the duct surface preferably adjacent to, but otherwise as close as possible to, the condenser outlet aperture. Measure the surface temperature of the combined duct at each thermocouple. Temperature measurements must have an error no greater than ±0.5 °F over the range being measured.

4. Test Measurement

Follow requirements for test conduct in active and inactive modes of operation in accordance with AHAM PAC–1–2022, section 8, except section 8.1.b, including references to sections 5.4, 6.2, 6.3, 7.3, 7.7, 8.7, 9, 10, and 11 of ASHRAE 37–2009, referring to Figure 12 and Figure 12 Notes of ANSI/AMCA 210 to determine placement of static pressure taps, and including references to ASHRAE 41.1–1986 and ASHRAE 41.6–1994. When conducting cooling mode testing for a variable-speed dual-duct portable air conditioner, use test configurations 1C and 1E in Table 2 of AHAM PAC–1–2022. Conduct the first test in accordance with ambient conditions for test configuration 1C in Table 2 of AHAM PAC–1–2022, and measure cooling capacity ($Capacity_{DD__95__Full}$) and input power ($P_{DD__95__Full}$). Conduct the second test in accordance with the ambient conditions for test configuration 1E in Table 2 of AHAM PAC–1–2022, with the compressor speed set to low for the duration of cooling mode testing (in accordance with the manufacturer instructions as described in section 7.1.10), and measure cooling capacity ($Capacity_{DD__83__Low}$) and input

power ($P_{DD__83__Low}$). When conducting standby power testing using the sampling method described in section 5.3.2 of IEC 62301, if the standby mode is cyclic and irregular or unstable, collect 10 cycles worth of data. As discussed in Paragraph 5.1, Note 1 of IEC 62301, allow sufficient time for the unit to reach the lowest power state before proceeding with the test measurement.

5. Calculation of Derived Results From Test Measurements

Perform calculations from test measurements to determine Seasonally Adjusted Cooling Capacity (SACC) and Annualized Energy Efficiency Ratio (AEER) in accordance with AHAM PAC–1–2022, section 9 unless otherwise specified in this section.

5.1 *Adjusted Cooling Capacity*. Calculate the adjusted cooling capacities at the 95 °F and 83 °F operating conditions specified below of the sample unit, in Btu/h, according to the following equations.

For a single-duct single-speed unit:

$$ACC_{95} = Capacity_{SD} - Q_{duct__SD} - Q_{infiltration__95}$$

$$ACC_{83} = 0.6000 \times (Capacity_{SD} - Q_{duct__SD} - Q_{infiltration__95})$$

For a single-duct variable-speed unit:

$$ACC_{95} = Capacity_{SD__Full} - Q_{duct__SD__Full} - Q_{infiltration__95}$$

$$ACC_{83} = Capacity_{SD__Low} - Q_{duct__SD__Low} - Q_{infiltration__83__Low}$$

For a dual-duct single-speed unit:

$$ACC_{95} = Capacity_{DD__95} - Q_{duct__DD__95} - Q_{infiltration__95}$$

$$ACC_{83} = 0.5363 \times (Capacity_{DD__83} - Q_{duct__DD__83} - Q_{infiltration__83})$$

For a dual-duct variable-speed unit:

$$ACC_{95} = Capacity_{DD__95__Full} - Q_{duct__DD__95__Full} - Q_{infiltration__95}$$

$$ACC_{83} = Capacity_{DD_____Low} - Q_{duct__DD__83__Low} - Q_{infiltration__83__Low}$$

Where:

ACC_{95} and ACC_{83} = adjusted cooling capacity of the sample unit, in Btu/h, calculated from testing at:

For a single-duct single-speed unit, test configuration 2A in Table 2 of AHAM PAC–1–2022.

For a single-duct variable-speed unit, test configurations 2B and 2C in Table 2 of AHAM PAC–1–2022.

For a dual-duct single-speed unit, test configurations 1A and 1B in Table 2 of AHAM PAC–1–2022.

For a dual-duct variable-speed unit: test configurations 1C and 1E in Table 2 of AHAM PAC–1–2022.

$Capacity_{SD}$, $Capacity_{SD__Full}$, $Capacity_{SD__Low}$, $Capacity_{DD__95}$, $Capacity_{DD__83}$, $Capacity_{DD__95__Full}$, and $Capacity_{DD__83__Low}$ = cooling capacity, in Btu/h, measured in testing at test configuration 2A, 2B, 2C, 1A, 1B, 1C, and 1E of Table 2 in section 8.1 of AHAM PAC–1–2022, respectively.

$Q_{duct__SD}$, $Q_{duct__SD__Full}$, $Q_{duct__SD__Low}$, $Q_{duct__DD__95}$, $Q_{duct__DD__83}$, $Q_{duct__DD__95__Full}$, and $Q_{duct__DD__83__Low}$ = duct heat transfer while operating in cooling mode for each duct configuration, compressor speed (where applicable) and temperature condition (where applicable), calculated in section 9.1 of AHAM PAC–1–2022, in Btu/h.

$Q_{infiltration__95}$, $Q_{infiltration__83}$, and $Q_{infiltration__83__Low}$ = total infiltration air heat transfer in cooling mode, in Btu/h, for each of the following compressor speed and duct configuration combinations:

For a single-duct single-speed unit, use $Q_{infiltration__95}$ as calculated for a single-duct single-speed unit in section 9.2 of AHAM PAC–1–2022.

For a single-duct variable-speed unit, use $Q_{infiltration__95}$ and $Q_{infiltration__83__Low}$ as calculated for a single-duct variable-speed unit in section 9.2 of AHAM PAC–1–2022.

For a dual-duct single-speed unit, use $Q_{infiltration__95}$ and $Q_{infiltration__83}$ as calculated for a dual-duct single-speed unit in section 9.2 of AHAM PAC–1–2022.

For a dual-duct variable-speed unit, use $Q_{infiltration__95}$ and $Q_{infiltration__83__Low}$ as calculated for a dual-duct variable-speed unit in section 9.2 of AHAM PAC–1–2022.

0.6000 and 0.5363 = empirically-derived load-based capacity adjustment factor for a single-duct and dual-duct single-speed unit, respectively, when operating at test conditions 2A and 1B.

5.2 *Seasonally Adjusted Cooling Capacity*. Calculate the seasonally adjusted cooling capacity for the sample unit, SACC, in Btu/h, according to:

$$SACC = ACC_{95} \times 0.144 + ACC_{83} \times 0.856$$

Where:

ACC_{95} and ACC_{83} = adjusted cooling capacities at the 95 °F and 83 °F outdoor temperature conditions, respectively, in Btu/h, calculated in section 5.1 of this appendix.

0.144 = empirically-derived weighting factor for ACC_{95}.

0.856 = empirically-derived weighting factor for ACC_{83}.

5.3 *Annual Energy Consumption*. Calculate the annual energy consumption in each operating mode, AECm, in kilowatt-hours per year (kWh/year). Use the following annual hours of operation for each mode:

TABLE 1—ANNUAL OPERATING HOURS

Operating mode	Annual operating hours
Cooling Mode Test Configurations 1A, 1C, 2A (95), 2B	164
Cooling Mode Test Configurations 1B, 2A (83)	586
Cooling Mode Test Configuration 1E, 2C	977
Off-Cycle, Single-Speed	391
Off-Cycle, Variable-Speed	0
Total Cooling and Off-cycle Mode	1,141
Inactive or Off Mode	1,844

Calculate total annual energy consumption in all modes according to the following equations:

$AEC_{ia/om} = P_{ia/om} \times t_{ia/om} \times k$

For a single-duct single-speed unit:

$AEC_{95} = P_{SD__95} \times t_{SD__95} \times k$

$$AEC_{83} = \frac{P_{SD_83} \times t_{SD_83} \times k}{0.82}$$

For a single-duct variable-speed unit:

$AEC_{95} = P_{SD__Full} \times t_{SD__Full} \times k$

$AEC_{83} = P_{SD__Low} \times t_{SD__Low} \times k$

For a dual-duct single-speed unit:

$AEC_{95} = P_{DD__95} \times t_{DD__95} \times k$

$$AEC_{83} = \frac{P_{DD_83} \times t_{DD_83} \times k}{0.77}$$

For a dual-duct variable-speed unit:

$AEC_{95} = P_{DD__95__Full} \times t_{DD__95__Full} \times k$

$AEC_{83} = P_{DD__83__Low} \times t_{DD__83__Low} \times k$

Where:

AEC_{95} and AEC_{83} = total annual energy consumption attributed to all modes representative of either the 95 °F and 83 °F operating condition, respectively, in kWh/year.

P_m = average power in each mode, in watts, as determined in sections 4.1.1 and 4.1.2.

t_m = number of annual operating time in each mode, in hours.

k = 0.001 kWh/Wh conversion factor from watt-hours to kilowatt-hours.

0.82 = empirically-derived factor representing efficiency losses due to compressor cycling outside of fan operation for single-duct units

0.77 = empirically-derived factor representing efficiency losses due to compressor cycling outside of fan operation for dual-duct units

m represents the operating mode:

—''DD__95'' and ''DD__83'' correspond to cooling mode in Test Configurations 1A and 1B in Table 2 of AHAM PAC–1–2022, respectively, for dual-duct single-speed units,

—''DD__95__Full'', ''DD__83__Low'' correspond to cooling mode in Test Configurations 1C and 1E in Table 2 of AHAM PAC–1–2022, respectively, for dual-duct variable-speed units,

—''SD__95'' corresponds to cooling mode in Test Configuration 2A in Table 2 of AHAM PAC–1–2022 for single-duct single-speed units, for use when calculating AEC at the 95 °F outdoor temperature condition,

—''SD__83'' corresponds to cooling mode in Test Configuration 2A in Table 2 of AHAM PAC–1–2022 for single-duct single-speed units, for use when calculating AEC at the 83 °F outdoor temperature condition,

—''SD__Full'' and ''SD__Low'' correspond to cooling mode in Test Configurations 2B and 2C in Table 2 of AHAM PAC–1–2022, respectively, for single-duct variable-speed units,

—''oc'' corresponds to off-cycle,

—''ia/om'' corresponds to inactive or off mode,

5.4 *Annualized Cooling and Energy Ratio.* Calculate the annualized energy efficiency ratio, AEER, in Btu/Wh, according to the following equation:

$$AEER = 0.001 \times \frac{(ACC_{95} \times 164) + (ACC_{83} \times 977)}{AEC_{95} + AEC_{83} + AEC_{oc} + AEC_{ia/om}}$$

Where:

AEER = the annualized energy efficiency ratio of the sample unit in Btu/Wh.

ACC_{95} and ACC_{83} = adjusted cooling capacity at the 95 °F and 83 °F outdoor temperature conditions, respectively, calculated in section 5.1 of this appendix.

AEC_{95}, AEC_{83}, AEC_{oc}, and $AEC_{ia/om}$ = total annual energy consumption attributed to all modes representative the 95 °F operating condition, the 83 °F operating condition, off-cycle mode, and inactive or off mode respectively, in kWh/year, calculated in section 5.3 of this appendix.

$t_{cm__95}$ = number of annual hours spent in cooling mode at the 95 °F operating condition, $t_{DD__95}$ for dual-duct single-speed units, $t_{DD__95__Full}$ for dual-duct variable-speed units, $t_{SD__95}$ for single-duct single-speed units, or $t_{SD__Full}$ for single-duct variable-speed units, defined in section 5.3 of this appendix.

164 = number of annual hours spent in cooling mode at the 95 °F operating condition, as shown in Table III.2

977 = number of annual hours spent in cooling mode and off-cycle mode at the 83 °F operating condition, defined in section 5.3 of this appendix. 0.001 = kWh/Wh conversion factor for watt-hours to kilowatt-hours.

[88 FR 31136, May 15, 2023

Appendix DD to Subpart B of Part 430—Uniform Test Method for Measuring the Energy Consumption and Energy Efficiency of General Service Lamps That Are Not General Service Incandescent Lamps, Compact Fluorescent Lamps, or Integrated LED Lamps

Note: On or after April 19, 2017, any representations, including certifications of compliance (if required), made with respect to the energy use or efficiency of general service lamps that are not general service incandescent lamps, compact fluorescent lamps, or integrated LED lamps must be made in accordance with the results of testing pursuant to this appendix DD.

1. *Scope:* This appendix DD specifies the test methods required to measure the initial lumen output, input power, lamp efficacy, power factor, and standby mode energy consumption of general service lamps that are not general service incandescent lamps, compact fluorescent lamps, or integrated LED lamps.

2. *Definitions:*

Measured initial input power means the input power to the lamp, measured after the lamp is stabilized and seasoned (if applicable), and expressed in watts (W).

Measured initial lumen output means the lumen output of the lamp, measured after the lamp is stabilized and seasoned (if applicable), and expressed in lumens (lm).

Power factor means the measured initial input power (watts) divided by the product of the input voltage (volts) and the input current (amps) measured at the same time as the initial input power.

3. Active Mode Test Procedures

3.1. Take measurements at full light output.

3.2. Do not use a goniophotometer.

3.3. For single base OLED and non-integrated LED lamps, position a lamp in either the base-up and base-down orientation throughout testing. Test an equal number of lamps in the sample in the base-up and base-down orientations, except that, if the manufacturer restricts the orientation, test all of the units in the sample in the manufacturer-specified orientation. For double base OLED and non-integrated LED lamps, test all units in the horizontal orientation except that, if the manufacturer restricts the orientation, test all of the units in the sample in the manufacturer-specified orientation.

3.4. Operate the lamp at the rated voltage throughout testing. For lamps with multiple rated voltages including 120 volts, operate the lamp at 120 volts. If a lamp is not rated for 120 volts, operate the lamp at the highest rated input voltage. For non-integrated LED lamps, operate the lamp at the manufacturer-declared input voltage and current.

3.5. Operate the lamp at the maximum input power. If multiple modes occur at the same maximum input power (such as variable CCT or CRI), the manufacturer may select any of these modes for testing; however, all measurements must be taken at the same selected mode. The manufacturer must indicate in the test report which mode was selected for testing and include detail such that another laboratory could operate the lamp in the same mode.

3.6. To measure initial lumen output, input power, input voltage, and input current use the test procedures in the table in this section.

TABLE 3.1—REFERENCES TO INDUSTRY STANDARD TEST PROCEDURES

Lamp type	Referenced test procedure
General service incandescent lamps	Appendix R to subpart B of 10 CFR part 430.
Compact fluorescent lamps	Appendix W to subpart B of 10 CFR part 430.
Integrated LED lamps	Appendix BB to subpart B of 10 CFR part 430.
Other incandescent lamps that are not reflector lamps	IES LM–45–15, sections 4–6, and section 7.1.*
Other incandescent lamps that are reflector lamps	IES LM–20–13, sections 4–6, and section 8.*
Other fluorescent lamps	IES LM–9–09–DD, sections 4–6, and section 7.5.*
OLED lamps	IES LM–79–08–DD, sections 1.3 (except 1.3f), 2.0, 3.0, 5.0, 7.0, 8.0, 9.1 and 9.2.*
Non-integrated LED lamps	IES LM–79–08–DD, sections 1.3 (except 1.3f), 2.0, 3.0, 5.0, 7.0, 8.0, 9.1 and 9.2.*

*Incorporated by reference, see §430.3.

3.7. Determine initial lamp efficacy by dividing the measured initial lumen output (lumens) by the measured initial input power (watts).

3.8. Determine power factor by dividing the measured initial input power (watts) by the product of the measured input voltage (volts) and measured input current (amps).

4. Standby Mode Test Procedure

4.1. Measure standby mode power only for lamps that are capable of standby mode operation.

4.2. Maintain lamp orientation as specified in section 3.3 of this appendix.

4.3. Connect the lamp to the manufacturer-specified wireless control network (if applicable) and configure the lamp in standby mode by sending a signal to the lamp instructing it to have zero light output. Lamp must remain connected to the network throughout testing.

4.4. Operate the lamp at the rated voltage throughout testing. For lamps with multiple rated voltages including 120 volts, operate the lamp at 120 volts. If a lamp is not rated for 120 volts, operate the lamp at the highest rated input voltage.

4.5. Stabilize the lamp prior to measurement as specified in section 5 of IEC 62301–DD (incorporated by reference; see §430.3).

4.6. Measure the standby mode power in watts as specified in section 5 of IEC 62301–DD (incorporated by reference; see §430.3).

[81 FR 72504, Oct. 20, 2016]

APPENDIX EE TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF CONSUMER BOILERS

0. *Incorporation by reference*

DOE incorporated by reference in §430.3, the entire standard for ASHRAE 103–2017, ASHRAE 41.6–2014, ASTM D2156–09 (R2018), and IEC 62301. However, only enumerated provisions of ASHRAE 103–2017 are applicable to this appendix, as follows. In cases where there is a conflict, the language of the test procedure in this appendix takes precedence over the incorporated standards.

0.1 ASHRAE 103–2017

(a) Section 2 ''Scope'' as referenced in section 1 of this appendix;

(b) Section 3 ''Definitions'' as referenced in section 2 of this appendix;

(c) Section 4 ''Classifications'' as referenced in section 3 of this appendix;

(d) Section 5 ''Requirements'' as referenced in section 4 of this appendix;

(e) Section 6 ''Instruments'' as referenced in sections 5 and 8 of this appendix;

(f) Section 7 ''Apparatus'' (except for sections 7.1 and 7.8) as referenced in sections 6, 7.7, and 8.6 of this appendix;

(g) Section 8 ''Methods of Testing'' (except for sections 8.3.1.3, 8.3.3.1, 8.4.1.1, 8.4.1.1.1, 8.4.1.2, 8.6.1.1, 8.7.2, and 8.8.3) as referenced in sections 7 and 8 of this appendix;

(h) Section 9 ''Test Procedure'' (except for 9.1.2.2.1, 9.1.2.2.2, 9.5.2.1, 9.7.4, and 9.10) as referenced in sections 7.3, 8, and 10.4 of this appendix;

(i) Section 10 ''Nomenclature'' as referenced in section 9 of this appendix; and

(j) Section 11 ''Calculations'' as referenced in sections 8.8 and 10 of this appendix.

0.2 [Reserved]

1. *Scope.* The scope of this appendix is as specified in section 2 of ASHRAE 103–2017 as it pertains to low pressure steam or hot water boiler and electric boilers.

2. *Definitions.* Definitions include those specified in section 3 of ASHRAE 103–2017 and the following additional and modified definitions.

Active mode means the condition in which the boiler is connected to the power source, and at least one of the burner, electric resistance elements, or any electrical auxiliaries such as blowers or pumps, are activated.

Boiler pump means a pump installed on a boiler that maintains adequate water flow through the boiler heat exchanger and that is separate from the circulating water pump.

Draft inducer means a fan incorporated in the boiler that either draws or forces air into the combustion chamber.

Gas valve means an automatic or semi-automatic device consisting essentially of a

valve and operator that controls the gas supply to the burner(s) during normal operation of an appliance. The operator may be actuated by application of gas pressure on a flexible diaphragm, by electrical means, by mechanical means or by other means.

Installation and operation (I&O) manual means instructions for installing, commissioning, and operating the boiler, which are supplied with the product when shipped by the manufacturer.

Off mode means a mode in which the boiler is connected to a mains power source and is not providing any active mode or standby mode function, and where the mode may persist for an indefinite time. The existence of an off switch in off position (a disconnected circuit) is included within the classification of off mode.

Off switch means the switch on the boiler that, when activated, results in a measurable change in energy consumption between the standby and off modes.

Oil control valve means an automatically or manually operated device consisting of an oil valve for controlling the fuel supply to a burner to regulate burner input.

Standard cubic foot of gas means the amount of gas that would occupy 1 cubic foot when at a temperature of 60 °F and under a pressure equivalent to that of 30 inches Hg if saturated with water vapor.

Standby mode means any mode in which the boiler is connected to a mains power source and offers one or more of the following space heating functions that may persist:

(a) To facilitate the activation of other modes (including activation or deactivation of active mode) by remote switch (including thermostat or remote control), internal or external sensors, or timer;

(b) Continuous functions, including information or status displays or sensor-based functions.

Thermal stack damper means a type of stack damper that relies exclusively upon the changes in temperature in the stack gases to open or close the damper.

3. *Classifications*. Classifications are as specified in section 4 of ASHRAE 103–2017.

4. *Requirements*. Requirements are as specified in section 5 of ASHRAE 103–2017.

5. *Instruments*. Instruments must be as specified in section 6 of ASHRAE 103–2017. In addition to the requirements in Section 6.3 of ASHRAE 103–2017, instruments for oil pressure shall be calibrated so that the error is no greater than ±0.5 psi.

6. *Apparatus*. The apparatus used in conjunction with the boiler during the testing must be as specified in section 7 of ASHRAE 103–2017 except for sections 7.1 and 7.8; and as specified in sections 6.1 and 6.2 of this appendix. In section 7.2.3.1 of ASHRAE 103–2017, substitute ''in accordance with the I&O manual'' for ''in accordance with manufacturer instructions'' with regard to installing the stack damper.

6.1 *General*.

(a) Install the boiler in the test room in accordance with the I&O manual, as defined in section 2.5 of this appendix, except that if provisions within this appendix are specified, then the provisions herein drafted and prescribed by DOE govern. If the I&O manual and any additional provisions of this appendix are not sufficient for testing a boiler, the manufacturer must request a waiver from the test procedure pursuant to §430.27.

(b) The apparatuses described in section 6 of this appendix are used in conjunction with the boiler during testing. Each piece of apparatus shall conform to material and construction specifications listed in this appendix and in ASHRAE 103–2017, and the reference standards cited in this appendix and in ASHRAE 103–2017.

(c) Test rooms containing equipment must have suitable facilities for providing the utilities (including but not limited to environmental controls, sufficient fluid source(s), applicable measurement equipment, and any other technology or tools) necessary for performance of the test and must be able to maintain conditions within the limits specified in section 6 of this appendix.

6.2 *Condensate collection*. Attach condensate drain lines to the unit as specified in the I&O manual. Maintain a continuous downward slope of drain lines from the unit. Additional precautions (such as eliminating any line configuration or position that would otherwise restrict or block the flow of condensate or checking to ensure a proper connection with condensate drain spout that allows for unobstructed flow) must be taken to facilitate uninterrupted flow of condensate during the test. Collection containers must be glass or polished stainless steel to facilitate removal of interior deposits. The collection container must have a vent opening to the atmosphere.

7. *Testing conditions*. The testing conditions must be as specified in section 8 of ASHRAE 103–2017 (except for the excluded sub-sections as enumerated in section 0.1(g) of this appendix); and as specified in sections 7.1 to 7.8 of this appendix, respectively. For condensing furnaces and boilers, the relative humidity of the room air shall be measured in accordance with one of the methods described in ASHRAE 41.6–2014 (see section 8.5 of ASHRAE 103–2017).

7.1 *Fuel supply, gas*. In conducting the tests specified herein, gases with characteristics as shown in Table 1 of ASHRAE 103–2017 shall be used. Maintain the gas supply, ahead of all controls for a boiler, at a test pressure between the normal and increased values shown in Table 1 of ASHRAE 103–2017. Maintain the regulator outlet pressure at a level approximating that recommended in

the I&O manual, as defined in section 2.5 of this appendix, or, in the absence of such recommendation, to the regulator settings used when the product is shipped by the manufacturer. Use a gas having a specific gravity of approximately that shown in Table 1 of ASHRAE 103–2017 and with a higher heating value within ±5% of the higher heating value shown in Table 1 of ASHRAE 103–2017. Determine the actual higher heating value in Btu per standard cubic foot of gas (defined in section 2 of this appendix) to be used in the test within an error no greater than 1%.

7.2 *Installation of piping.* Install piping equipment in accordance with the I&O manual. In the absence of such specification, install piping in accordance with section 8.3.1.1 of ASHRAE 103–2017.

7.3 *Gas burner.* Adjust the burners of gas-fired boilers to their maximum Btu input ratings at the normal test pressure specified by section 7.1 of this appendix. Correct the burner input rate to reflect gas characteristics at a temperature of 60 °F and atmospheric pressure of 30 in of Hg and adjust to within ±2 percent of the hourly Btu nameplate input rating specified by the manufacturer as measured at the maximum input rate during the steady-state performance test in section 8 of this appendix. Set the primary air shutters in accordance with the I&O manual to give a good flame at this condition. If, however, the setting results in the deposit of carbon on the burners during any test specified herein, the tester shall adjust the shutters and burners until no more carbon is deposited and shall perform the tests again with the new settings (*see* Figure 9 of ASHRAE 103–2017). After the steady-state performance test has been started, do not make additional adjustments to the burners during the required series of performance tests specified in section 9 of ASHRAE 103–2017. If a vent-limiting means is provided on a gas pressure regulator, keep it in place during all tests.

7.4 *Modulating gas burner adjustment at reduced input rate.* For gas-fired boilers equipped with modulating-type controls, adjust the controls to operate the unit at the nameplate minimum input rate. If the modulating control is of a non-automatic type, adjust the control to the setting recommended in the I&O manual. In the absence of such recommendation, the midpoint setting of the non-automatic control shall be used as the setting for determining the reduced fuel input rate. Start the boiler by turning the safety control valve to the ''ON'' position. Use a supply water temperature that will allow for continuous operation without shut-off by the control. If necessary to achieve such continuous operation, supply water may be increased above 120 °F; in such cases, gradually increase the supply water temperature to determine what minimum supply water temperature, with a 20 °F temperature rise across the boiler, will be needed to adjust for the minimum input rate at the reduced input rate control setting. Monitor regulated gas pressure out of the modulating control valve (or entering the burner) to determine when no further reduction of gas pressure results. The flow rate of water through the boiler shall be adjusted to achieve a 20 °F temperature rise.

7.5 *Oil burner.* Adjust the burners of oil-fired boilers to give a CO_2 reading specified in the I&O manual and an hourly Btu input within ±2% of the hourly Btu nameplate input rating as specified in the I&O manual and as measured at maximum input rate during steady-state performance test as described in section 8 of this appendix. Smoke in the flue may not exceed a No. 1 smoke during the steady-state performance test as measured by the procedure in ASTM D2156–09 (R2018). Maintain the average draft over the fire and in the flue during the steady-state performance test at the value specified in the I&O manual. Do not allow draft fluctuations exceeding 0.005 in. water. Do not make additional adjustments to the burner during the required series of performance tests. The instruments and measuring apparatus for this test are described in section 6 of this appendix and shown in Figure 8 of ASHRAE 103–2017.

7.6 *Measurement of jacket surface temperature.* Divide the jacket of the boiler into 6-inch squares when practical, and otherwise into 36-square-inch regions comprising 4 inch by 9 inch or 3 inch by 12 inch sections, and determine the surface temperature at the center of each square or section with a surface thermocouple. Record the surface temperature of the 36-square-inch areas in groups where the temperature differential of the 36-square-inch areas is less than 10 °F for temperature up to 100 °F above room temperature, and less than 20 °F for temperatures more than 100 °F above room temperature.

7.7 *Installation of vent system.* Keep the vent or air intake system supplied by the manufacturer in place during all tests. Test units intended for installation with a variety of vent pipe lengths with the minimum vent length as specified in the I&O manual, or a 5-ft. flue pipe if there are no recommendations in the I&O manual. Do not connect a boiler employing a direct vent system to a chimney or induced-draft source. Vent combustion products solely by using the venting incorporated in the boiler and the vent or air intake system supplied by the manufacturer. For units that are not designed to significantly preheat the incoming air, see section 7.5 of this appendix and Figure 4a or 4b in section 7 of ASHRAE 103–2017. For units that do significantly preheat the incoming air, *see* Figure 4c or 4d in section 7 of ASHRAE 103–2017.

7.8 *Additional optional method of testing for determining D_P and D_F.* On units whose design is such that there is no measurable airflow through the combustion chamber and heat exchanger when the burner(s) is (are) off as determined by the optional test procedure in section 7.8.1 of this appendix, D_F and D_P may be set equal to 0.05.

7.8.1 *Optional test method for indicating the absence of flow through the heat exchanger.* Manufacturers may use the following test protocol to determine whether air flows through the combustion chamber and heat exchanger when the burner(s) is (are) off. The minimum default draft factor may be used only for units determined pursuant to this protocol to have no airflow through the combustion chamber and heat exchanger.

7.8.1.1 *Test apparatus.* Use a smoke stick that produces smoke that is easily visible and has a density less than or approximately equal to air. Use a smoke stick that produces smoke that is non-toxic to the test personnel and produces gas that is unreactive with the environment in the test chamber.

7.8.1.2 *Test conditions.* Minimize all air currents and drafts in the test chamber, including turning off ventilation if the test chamber is mechanically ventilated. Wait at least two minutes following the termination of the boiler on-cycle before beginning the optional test method for indicating the absence of flow through the heat exchanger.

7.8.1.3 *Location of the test apparatus.* After all air currents and drafts in the test chamber have been eliminated or minimized, position the smoke stick based on the following equipment configuration:

(a) For horizontal combustion air intakes, approximately 4 inches from the vertical plane at the termination of the intake vent and 4 inches below the bottom edge of the combustion air intake; or

(b) for vertical combustion air intakes, approximately 4 inches horizontal from vent perimeter at the termination of the intake vent and 4 inches down (parallel to the vertical axis of the vent). In the instance where the boiler combustion air intake is closer than 4 inches to the floor, place the smoke device directly on the floor without impeding the flow of smoke.

7.8.1.4 *Duration of test.* Establish the presence of smoke from the smoke stick and then monitor the direction of the smoke flow for no less than 30 seconds.

7.8.1.5 *Test results.* During visual assessment, determine whether there is any draw of smoke into the combustion air intake vent.

If absolutely no smoke is drawn into the combustion air intake, the boiler meets the requirements to allow use of the minimum default draft factor provided in section 7.8 of this appendix.

If there is any smoke drawn into the intake, proceed with the methods of testing as prescribed in section 8.8 of ASHRAE 103–2017.

7.8.2 [Reserved]

8. *Test procedure.* Conduct testing and measurements as specified in Section 9 of ASHRAE 103–2017 (except for the excluded sub-sections as enumerated in section 0.1(h) of this appendix); and as specified in sections 8.1 through 8.9 of this appendix. Section 8.4 of this appendix may be used in lieu of section 9.2 of ASHRAE 103–2017.

8.1 *Fuel input.* For gas units, measure and record the steady-state gas input rate in Btu/h, including pilot gas, corrected to standard conditions of 60 °F and 30 in. Hg. Use measured values of gas temperature and pressure at the meter and barometric pressure to correct the metered gas flow rate to the above standard conditions. For oil units, measure and record the steady-state fuel input rate. For maximum input rate, the measured burner input rate shall be within ±2% of the hourly Btu nameplate input rating (Q_{IN}) specified by the manufacturer. For modulating furnaces and boilers operating at reduced input rate, the measured reduced heat input rate ($Q_{IN,R}$) shall be recorded. At the discretion of the one testing, the hourly Btu nameplate minimum input rating specified by the manufacturer may be used in the calculations in place of $Q_{IN,R}$ if the measured rate is within ±2% of the nameplate rating.

8.2 *Electrical input.* During the steady-state test, perform a single measurement of all of the electrical power involved in burner operation (PE), including energizing the ignition system, controls, gas valve or oil control valve, and draft inducer, if applicable. For boilers, the measurement of PE must include the boiler pump if so equipped. If the boiler pump does not operate during the measurement of PE, add the boiler pump nameplate power to the measurement of PE. If the boiler pump nameplate power is not available, use 0.13 kW. For hot water boilers, use the circulating water pump nameplate power for BE, or if the pump nameplate power is not available, use 0.13 kW.

8.3 *Input to interrupted ignition device.* For burners equipped with an interrupted ignition device, record the nameplate electric power used by the ignition device, PE_{IG}, or record that PE_{IG} = 0.4 kW if no nameplate power input is provided. Record the nameplate ignition device on-time interval, t_{IG}, or, if the nameplate does not provide the ignition device on-time interval, measure the on-time interval with a stopwatch at the beginning of the test, starting when the burner is turned on. Set t_{IG} = 0 and PE_{IG} = 0 if the device on-time interval is less than or equal to 5 seconds after the burner is on.

8.4 *Cycling Test Requirements.* For the measurement of condensate heat loss under cyclic conditions (for condensing boilers), section 9.8 of ASHRAE 103–2017 shall apply.

Cycle times calculated from Table 7 of ASHRAE 103–2017 shall be rounded to the nearest second.

8.5 *Optional test procedures for condensing boilers, measurement of condensate during the establishment of steady-state conditions.* For units with step-modulating or two-stage controls, conduct the test at both the maximum and reduced inputs. In lieu of collecting the condensate immediately after the steady state conditions have been reached as required by section 9.2 of ASHRAE 103–2017, condensate may be collected during the establishment of steady state conditions as defined by section 9.1.2.1 of ASHRAE 103–2017. Perform condensate collection for at least 30 minutes. Measure condensate mass immediately at the end of the collection period to prevent evaporation loss from the sample. Record fuel input for the 30-minute condensate collection test period. Observe and record fuel higher heating value (HHV), temperature, and pressures necessary for determining fuel energy input ($Q_{C,SS}$). Measure the fuel quantity and HHV with errors no greater than 1%. The humidity for the room air shall at no time exceed 80%. Determine the mass of condensate for the establishment of steady state conditions ($M_{C,SS}$) in pounds by subtracting the tare container weight from the total container and condensate weight measured at the end of the 30-minute condensate collection test period.

8.6 *Cool-down test for gas- and oil-fueled boilers without stack dampers.* After steady-state testing has been completed, turn the main burner(s) ''OFF'' and measure the flue gas temperature at 3.75 minutes (temperature designated as $T_{F,OFF}(t_3)$) and 22.5 minutes (temperature designated as $T_{F,OFF}(t_4)$) after the burner shut-off using the thermocouple grid described in section 7.6 of ASHRAE 103–2017.

a. During this off-period, for units that do not have pump delay after shut-off, do not allow any water to circulate through the hot water boilers.

b. For units that have pump delay on shut-off, except those having pump controls sensing water temperature, the unit control must stop the pump. Measure and record the time between burner shut-off and pump shut-off (t^+) to the nearest second.

c. For units having pump delay controls that sense water temperature, operate the pump for 15 minutes and record t^+ as 15 minutes. While the pump is operating, maintain the inlet water temperature and flow rate at the same values as used during the steady-state test, as specified in sections 9.1 and 8.4.2.3 of ASHRAE 103–2017.

d. For boilers that employ post-purge, measure the length of the post-purge period with a stopwatch. Record the time from burner ''OFF'' to combustion blower ''OFF'' (electrically de-energized) as t_P. Measure the flue gas temperature by means of the thermocouple grid described in section 7.6 of ASHRAE 103–2017 at the end of the post-purge period t_P ($T_{F,OFF}(t_P)$) and at (3.75 + t_P) minutes ($T_{F,OFF}(t_3)$) and (22.5 + t_P) minutes ($T_{F,OFF}(t_4)$) after the main burner shuts off. If t_P is prescribed by the I&O manual or measured to be greater than 3 minutes, also measure the flue gas temperature at the midpoint of the post-purge period $t_P/2$ ($T_{F,OFF}(t_P/2)$). If the measured t_P is less than or equal to 30 seconds, record t_P as 0 and conduct the cool-down test as if there is no post-purge.

8.7 [Reserved]

8.8 *Calculation options.* The rate of the flue gas mass flow through the boiler and the factors D_P, D_F, and D_S are calculated by the equations in sections 11.6.1, 11.6.2, 11.6.3, 11.6.4, 11.7.1, and 11.7.2 of ASHRAE 103–2017. On units whose design is such that there is no measurable airflow through the combustion chamber and heat exchanger when the burner(s) is (are) off (as determined by the optional test procedure in section 7.8 of this appendix), D_F and D_P may be set equal to 0.05.

8.9 *Optional test procedures for condensing boilers that have no off-period flue losses.* For units that have applied the test method in section 7.8 of this appendix to determine that no measurable airflow exists through the combustion chamber and heat exchanger during the burner off-period and having post-purge periods of less than 30 seconds, the cool-down and heat-up tests specified in sections 9.5 and 9.6 of ASHRAE 103–2017 may be omitted. In lieu of conducting the cool-down and heat-up tests, the tester may use the losses determined during the steady-state test described in section 9.1 of ASHRAE 103–2017 when calculating heating seasonal efficiency, $Effy_{HS}$.

8.10 *Measurement of electrical standby and off mode power.*

8.10.1 *Standby power measurement.* With all electrical auxiliaries of the boiler not activated, measure the standby power ($P_{W,SB}$) in accordance with the procedures in IEC 62301, except that section 8.5, *Room Ambient Temperature,* of ASHRAE 103–2017 and the voltage provision of section 8.2.1.4, *Electrical Supply,* of ASHRAE 103–2017 shall apply in lieu of the corresponding provisions of IEC 62301 at section 4.2, *Test room,* and the voltage specification of section 4.3, *Power supply.* Frequency shall be 60Hz. Clarifying further, IEC 62301 section 4.4, *Power measurement instruments,* and section 5, *Measurements,* apply in lieu of ASHRAE 103–2017 section 6.10, *Energy Flow Rate.* Measure the wattage so that all possible standby mode wattage for the entire appliance is recorded, not just the standby mode wattage of a single auxiliary. Round the recorded standby power ($P_{W,SB}$) to the second decimal place, except for loads greater than or equal to 10W, which must be recorded to at least three significant figures.

8.10.2 *Off mode power measurement.* If the unit is equipped with an off switch or there

is an expected difference between off mode power and standby mode power, measure off mode power ($P_{W,OFF}$) in accordance with the standby power procedures in IEC 62301, except that section 8.5, *Room Ambient Temperature*, of ASHRAE 103–2017 and the voltage provision of section 8.2.1.4, *Electrical Supply*, of ASHRAE 103–2017 shall apply in lieu of the corresponding provisions of IEC 62301 at section 4.2, *Test room*, and the voltage specification of section 4.3, *Power supply*. Frequency shall be 60Hz. Clarifying further, IEC 62301 section 4.4, *Power measurement instruments*, and section 5, *Measurements*, apply for this measurement in lieu of SHRAE 103–2017 section 6.10, *Energy Flow Rate*. Measure the wattage so that all possible off mode wattage for the entire appliance is recorded, not just the off mode wattage of a single auxiliary. If there is no expected difference in off mode power and standby mode power, let $P_{W,OFF} = P_{W,SB}$, in which case no separate measurement of off mode power is necessary. Round the recorded off mode power ($P_{W,OFF}$) to the second decimal place, except for loads greater than or equal to 10W, in which case round the recorded value to at least three significant figures.

9. *Nomenclature*. Nomenclature includes the nomenclature specified in Section 10 of ASHRAE 103–2017 and the following additional variables:

Eff_{motor} = Efficiency of power burner motor
PE_{IG} = Electrical power to the interrupted ignition device, kW
$R_{T,a} = R_{T,F}$ if flue gas is measured
$= R_{T,S}$ if stack gas is measured
$R_{T,F}$ = Ratio of combustion air mass flow rate to stoichiometric air mass flow rate
$R_{T,S}$ = Ratio of the sum of combustion air and relief air mass flow rate to stoichiometric air mass flow rate
t_{IG} = Electrical interrupted ignition device on-time, min.
$T_{a,SS,X} = T_{F,SS,X}$ if flue gas temperature is measured, °F
$= T_{S,SS,X}$ if stack gas temperature is measured, °F
y_{IG} = Ratio of electrical interrupted ignition device on-time to average burner on-time
y_P = Ratio of power burner combustion blower on-time to average burner on-time
E_{SO} = Average annual electric standby mode and off mode energy consumption, in kilowatt-hours
$P_{W,OFF}$ = Boiler off mode power, in watts
$P_{W,SB}$ = Boiler standby mode power, in watts

10. *Calculation of derived results from test measurements*. Perform calculations as specified in section 11 of ASHRAE 103–2017, except for appendices B and C; and as specified in sections 10.1 through 10.7 and Figure 1 of this appendix.

10.1 *Annual fuel utilization efficiency*. The annual fuel utilization efficiency (AFUE) is as defined in sections 11.2.12 (non-condensing systems), 11.3.12 (condensing systems), 11.4.12 (non-condensing modulating systems) and 11.5.12 (condensing modulating systems) of ASHRAE 103–2017, except for the following:

10.1.1 *Off-cycle Infiltration Heat Loss*. The off-cycle infiltration heat loss ($L_{I,OFF1}$) is as defined in sections 11.2.10.8 (non-condensing systems), 11.3.10.8 (condensing systems), 11.4.10.8 (non-condensing modulating systems) and 11.5.10.8 (condensing modulating systems) of ASHREAE 103–2017, with the following exception. For systems numbered 2, 3, and 4, with a post-purge time of 3 minutes or less, $L_{I,OFF1}$ shall be determined as follows:

$$L_{I,OFF1} = 100 \times C_P \times M_{F,ON} \times t_P \times \left(T_{F,SS} + T_{abs}\right) \times \left(\frac{1}{t_{ON} \times Q_{IN}/60}\right)$$

$$\times \left\{\frac{T_{IA} - T_{OA}}{C_{T,OFF} \times \left[T_{F,SS} - T_{F,OFF}(t_P)\right]}\right.$$

$$\left. \times \ln\left[\frac{T_{RA} + T_{abs} + C_{T,OFF} \times \left(T_{F,SS} - T_{RA}\right)}{T_{RA} + T_{abs} + C_{T,OFF} \times \left(T_{F,OFF}(t_P) - T_{RA}\right)}\right]\right\}$$

10.1.2 *Determination of $Effy_{HS}$ in the Defining Equation for AFUE*. $Effy_{HS}$ is defined as:

$Effy_{HS}$ = heating seasonal efficiency as defined in sections 11.2.11 (non-condensing systems), 11.3.11 (condensing systems), 11.4.11 (non-condensing modulating systems) and 11.5.11 (condensing modulating systems) of ASHRAE 103–2017, and is based

on the assumptions that weatherized boilers are located outdoors and that non-weatherized boilers are installed indoors.

10.1.3 *Balance Point Temperature for Condensing Modulating Boilers.* Calculate the balance point temperature (T_C) for condensing, modulating boilers by using the following equation in place of that referenced by section 11.5.8.4 of ASHRAE 103–2017: T_C =

$$T_{SH} - \left[\left(T_{SH} - T_{OA,T}\right)(1+\alpha)\left(\frac{Q_{IN,R}(100-L_{L,A}-L_{S,SSR}}{Q_{IN}\left(100-L_{L,A}-L_{S,SS}\right)}\right)\right]$$

Where:

T_{SH} = typical average outdoor temperature at which a boiler starts operating, 65 °F

$T_{OA,T}$ = the typical outdoor design temperature, 5 °F

α = oversize factor, as defined in 11.4.8.2

Q_{IN} = steady-state nameplate maximum fuel input rate

$Q_{IN,R}$ = steady-state reduced input fuel input rate

$L_{S,SSR}$ = average sensible heat loss at steady state, reduced input operation

$L_{S,SS}$ = average sensible heat loss at steady state, maximum input operation

10.2 *National average burner operating hours, average annual fuel energy consumption, and average annual auxiliary electrical energy consumption for gas or oil boilers.*

10.2.1 *National average number of burner operating hours.*

10.2.1.1 For boilers equipped with single-stage controls, the national average number of burner operating hours is defined as:

BOH_{SS} = 2,080 (0.77) (A) [(Q_{OUT}/1000)/(1+α)] − 2,080 (B)

Where:

2,080 = national average heating load hours

0.77 = adjustment factor to adjust the calculated design heating requirement and heating load hours to the actual heating load experienced by the heating system

A = 100,000/[341,200 (y_P PE + y_{IG} PE_{IG} + y BE) + ($Q_{IN} - Q_P$) $Effy_{HS}$], for forced draft unit, indoors

= 100,000/[341,200 (y_P PE (1 − Eff_{motor}) + y_{IG} PE_{IG} + y BE) + ($Q_{IN} - Q_P$) $Effy_{HS}$], for induced draft unit, indoors, and

Q_{OUT} = value as defined in section 11.2.8.1 of ASHRAE 103–2017.

α = value as defined in section 11.2.8.2 of ASHRAE 103–2017.

B = 2 Q_P ($Effy_{HS}$) (A)/100,000

Where:

Eff_{motor} = nameplate power burner motor efficiency provided by the manufacturer,

= 0.50, an assumed default power burner efficiency if not provided by the manufacturer.

100,000 = factor that accounts for percent and kBtu

y_P = ratio of induced or forced draft blower on-time to average burner on-time, as follows:

1 for units without post-purge;

1 + (t_P/t_{ON}) for single stage boilers with post purge; or

PE = all electrical power related to burner operation at full load steady-state operation, including electrical ignition device if energized, controls, gas valve or oil control valve, draft inducer, and boiler pump, as determined in section 8.2 of this appendix.

y_{IG} = ratio of burner interrupted ignition device on-time to average burner on-time, as follows:

0 for burners not equipped with interrupted ignition device;

(t_{IG}/t_{ON}) for single stage boilers

PE_{IG} = electrical input rate to the interrupted ignition device on burner (if employed), as defined in section 8.3 of this appendix

y = ratio of pump on-time to average burner on-time, as follows:

1 for boilers without a pump delay;

1 + (t^+/t_{ON}) for single-stage boilers with pump delay;

BE = circulating water pump electrical energy input rate at full-load steady-state operation as defined in section 8.2 of this appendix.

t_P = post-purge time as defined in section 8.5 of this appendix

= 0 if t_P is equal to or less than 30 seconds

t_{IG} = on-time of the burner interrupted ignition device, as defined in section 8.3 of this appendix

Q_{IN} = as defined in section 11.2.8.1 of ASHRAE 103–2017

Q_P = as defined in section 11.2.11 of ASHRAE 103–2017

$Effy_{HS}$ = as defined in section 11.2.11 (non-condensing systems) or section 11.3.11.3 (condensing systems) of ASHRAE 103–2017, percent, and calculated on the basis of:

indoor installation, for non-weatherized boilers; or outdoor installation, for boilers that are weatherized.

2 = ratio of the average length of the heating season in hours to the average heating load hours

t^+ = delay time between burner shutoff and the pump shutoff measured as defined in section 8.5 of this appendix.
t_{ON} = value as defined in Table 7 of ASHRAE 103–2017.

10.2.1.2 For boilers equipped with two-stage or step-modulating controls, the national average number of burner operating hours at the reduced operating mode (BOH_R) is defined as:

$BOH_R = X_R (2080)(0.77)[(Q_{OUT}/1{,}000)/(1+\alpha)](A_R) - 2080(B_R)$

Where:

X_R = as defined in section 11.4.8.6 of SHRAE 103–2017
2080 = as defined in section 10.2.1.1 of this appendix
0.77 = as defined in section 10.2.1.1 of this appendix
Q_{OUT} = as defined in section 11.4.8.1.1 or 11.5.8.1.1 of ASHRAE 103–2017
α = as defined in section 11.4.8.2 of ASHRAE 103–2017
A_R = $100{,}000/[341{,}200(y_{P,R}PE_R + y_{IG,R}PE_{IG} + y_RBE_R) + (Q_{IN,R} - Q_P)\ Effy_{U,R}]$ for forced draft unit, indoors; and
= $100{,}000/[341{,}200(y_{P,R}PE_R\ (1 - Eff_{motor}) + y_{IG,R}PE_{IG} + y_RBE_R) + (Q_{IN,R} - Q_P)\ Effy_{U,R}]$ for induced draft unit, indoors
$B_R = 2Q_P\ (Effy_{U,R})\ (A_R)/100{,}000$
100,000 = conversion factor accounting for percent and 1,000 Btu/kBtu
341,200 = conversion factor accounting for percent and 3412 Btu/h/kW
$y_{P,R} = 1 + (t_p/t_{ON,R})$ for two-stage and step modulating boilers with post purge
PE_R = as defined in section 8.2 of this appendix and measured at the reduced fuel input rate
$y_{IG,R} = t_{IG}/t_{ON,R}$
PE_{IG} = as defined in section 8.3 of this appendix
$y_R = 1 + (t^+)/t_{ON,R}$ for two-stage and step modulating boilers with fan delay
BE_R = as defined in section 8.2 of this appendix and measured at the reduced fuel input rate
$Q_{IN,R}$ = as defined in section 11.4.8.1.2 of ASHRAE 103–2017
Q_P = as defined in section 11.4.12 of ASHRAE 103–2017
$Effy_{U,R}$ = as defined in section 11.4.11.1 or 11.5.11.1 of ASHRAE 103–2017, and calculated on the basis of:
indoor installation, for non-weatherized boilers; or
outdoor installation, for boilers that are weatherized.
Eff_{motor} = nameplate power burner motor efficiency provided by the manufacturer,
= 0.50, an assumed default power burner efficiency if not provided by the manufacturer.

10.2.1.3 For boilers equipped with two-stage controls, the national average number of burner operating hours at the maximum operating mode (BOH_H) is defined as:

$BOH_H = X_H (2080)(0.77)[(Q_{OUT}/1{,}000)/(1+\alpha)](A_H) — 2080(B_H)$

Where:

X_H = as defined in section 11.4.8.5 of SHRAE 103–2017
2080 = as defined in section 10.2.1.1 of this appendix
0.77 = as defined in section 10.2.1.1 of this appendix
Q_{OUT} = as defined in section 11.4.8.1.1 or 11.5.8.1.1 ofASHRAE 103–2017
α = as defined in section 11.4.8.2 of ASHRAE 103–2017
A_H = $100{,}000/[341{,}200(y_{P,H}PE_H + y_{IG,H}PE_{IG} + y_HBE_H) + (Q_{IN,H} — Q_P)\ Effy_{U,H}]$ for forced draft unit, indoors; and
= $100{,}000/[341{,}200(y_{P,H}PE_H\ (1 — Eff_{motor}) + y_{IG,H}PE_{IG} + y_HBE_H) + (Q_{IN,H} — Q_P)\ Effy_{U,H}]$ for induced draft unit, indoors
$B_H = 2Q_P\ (Effy_{U,H})\ (A_H)/100{,}000$
100,000 = conversion factor accounting for percent and 1,000 Btu/kBtu
341,200 = conversion factor accounting for percent and 3412 Btu/h/kW
$y_{P,H} = 1 + (t_p/t_{ON,H})$ for two-stage and step modulating boilers with post purge
PE_H = as defined in section 8.2 of this appendix and measured at the maximum fuel input rate
$y_{IG,H} = t_{IG}/t_{ON,H}$
PE_{IG} = as defined in section 8.3 of this appendix
$y_H = 1 + (t^+)/t_{ON,H}$ for two-stage and step modulating boilers with fan delay
BE_H = as defined in section 8.2 of this appendix and measured at the maximum fuel input rate
$Q_{IN,H}$ = as defined in section 11.4.8.1.1 of ASHRAE 103–2017
Q_P = as defined in section 11.4.12 of ASHRAE 103–2017
$Effy_{U,H}$ = as defined in section 11.4.11.2 or 11.5.11.2 of ASHRAE 103–2017, and calculated on the basis of:
indoor installation, for non-weatherized boilers; or
outdoor installation, for boilers that are weatherized.
Eff_{motor} = nameplate power burner motor efficiency provided by the manufacturer,
= 0.50, an assumed default power burner efficiency if not provided by the manufacturer.

10.2.1.4 For boilers equipped with step-modulating controls, the national average number of burner operating hours at the modulating operating mode (BOH_M) is defined as:

$BOH_M = X_H (2080)(0.77)[(Q_{OUT}/1{,}000)/(1+\alpha)](A_M) — 2080(B_M)$

Where:

X_H = as defined in section 11.4.8.5 of ASHRAE 103–2017

2080 = as defined in section 10.2.1.1 of this appendix
0.77 = as defined in section 10.2.1.1 of this appendix
Q_{OUT} = as defined in section 11.4.8.1.1 or 11.5.8.1.1 of ASHRAE 103–2017
α = as defined in section 11.4.8.2 of ASHRAE 103–2017
A_M = $100{,}000/[341{,}200(y_{P,H}PE_H + y_{IG,H}PE_{IG} + y_HBE_H) + (Q_{IN,M}—Q_P)\ Effy_{U,M}]$ for forced draft unit, indoors; and
= $100{,}000/[341{,}200(y_{P,H}PE_H\ (1—Eff_{motor}) + y_{IG,H}PE_{IG} + y_HBE_H) + (Q_{IN,M}—Q_P)\ Effy_{U,M}]$ for induced draft unit, indoors
$B_M = 2Q_P\ (Effy_{U,M})\ (A_M)/100{,}000$
100,000 = conversion factor accounting for percent and 1,000 Btu/kBtu
341,200 = conversion factor accounting for percent and 3412 Btu/h/kW
$y_{P,H} = 1 + (t_p/t_{ON,H})$ for two-stage and step modulating boilers with post purge
PE_H = as defined in section 8.2 of this appendix and measured at the maximum fuel input rate
$y_{IG,H} = t_{IG}/t_{ON,H}$
PE_{IG} = as defined in section 8.3 of this appendix
$y_H = 1 + (t^+)/t_{ON,H}$ for two-stage and step modulating boilers with fan delay
BE_H = as defined in section 8.2 of this appendix and measured at the maximum fuel input rate
$Q_{IN,M} = (100)(Q_{OUT,M}/Effy_{SS,M})$
$Q_{OUT,M}$ = as defined in section 11.4.8.9 or 11.5.8.9 of ASHRAE 103–2017
$Effy_{SS,M}$ = value as defined in section 11.4.8.7 or 11.5.8.7 of ASHRAE 103–2017
Q_P = as defined in section 11.4.12 of ASHRAE 103–2017
$Effy_{U,M}$ = as defined in section 11.4.9.2.3 or 11.5.9.2.3 of ASHRAE 103–2017, and calculated on the basis of:
indoor installation, for non-weatherized boilers; or
outdoor installation, for boilers that are weatherized.
Eff_{motor} = nameplate power burner motor efficiency provided by the manufacturer,
= 0.50, an assumed default power burner efficiency if not provided by the manufacturer.

10.2.2 *Average annual fuel energy consumption for gas or oil fueled boilers.*

10.2.2.1 For boilers equipped with single-stage controls, the average annual fuel energy consumption (E_F) is expressed in Btu per year and defined as:

$E_F = BOH_{SS}\ (Q_{IN} - Q_P) + 8{,}760\ Q_P$

Where:

BOH_{SS} = as defined in section 10.2.1.1 of this appendix
Q_{IN} = as defined in section 11.2.8.1 of ASHRAE 103–2017
Q_P = as defined in section 11.2.11 of ASHRAE 103–2017
8,760 = total number of hours per year.

10.2.2.2 For boilers equipped with either two-stage or step modulating controls, E_F is defined as follows. For two-stage control:

$E_F = (BOH_H)(Q_{IN}) + (BOH_R)(Q_{IN,R}) + [8760 - (BOH_H + BOH_R)]Q_P$

For step-modulating control:

$E_F = (BOH_M)(Q_{IN,M}) + (BOH_R)(Q_{IN,R}) + [8760 - (BOH_H + BOH_R)]Q_P$

Where:

BOH_H = as defined in section 10.2.1.3 of this appendix
BOH_R = as defined in section 10.2.1.2 of this appendix
BOH_M = as defined in section 10.2.1.4 of this appendix
Q_{IN} = as defined in section 11.2.8.1 of ASHRAE 103–2017
$Q_{IN,R}$ = as defined in section 11.4.8.1.2 of ASHRAE 103–2017
$Q_{IN,M}$ = as defined in section 10.2.1.4 of this appendix
8,760 = total number of hours per year
Q_P = as defined in section 11.2.11 of ASHRAE 103–2017.

10.2.3 *Average annual auxiliary electrical energy consumption for gas or oil-fueled boilers.*

10.2.3.1 For boilers equipped with single-stage controls, the average annual auxiliary electrical consumption (E_{AE}) is expressed in kilowatt-hours and defined as:

$E_{AE} = BOH_{SS}\ (y_P\ PE + y_{IG}\ PE_{IG} + yBE) + E_{SO}$

Where:

BOH_{SS} = as defined in section 10.2.1.1 of this appendix
y_P = as defined in section 10.2.1.1 of this appendix
PE = as defined in section 10.2.1.1 of this appendix
y_{IG} = as defined in section 10.2.1.1 of this appendix
PE_{IG} = as defined in section 10.2.1.1 of this appendix
y = as defined in section 10.2.1.1 of this appendix
BE = as defined in section 10.2.1.1 of this appendix
E_{SO} = as defined in section 10.7 of this appendix.

10.2.3.2 For boilers equipped with two-stage controls, E_{AE} is defined as:

$E_{AE} = BOH_R\ (y_{P,R}\ PE_R + y_{IG,R}\ PE_{IG} + y_RBE_R) + BOH_H\ (y_{P,H}\ PE_H + y_{IG,H}\ PE_{IG} + y_HBE_H) + E_{SO}$

Where:

BOH_R = as defined in section 10.2.1.2 of this appendix
$y_{P,R}$ = as defined in section 10.2.1.2 of this appendix
PE_R = as defined in section 8.2 of this appendix and measured at the reduced fuel input rate

$y_{IG,R}$ = as defined in section 10.2.1.2 of this appendix
PE_{IG} = as defined in section 10.2.1.1 of this appendix
y_R = as defined in section 10.2.1.2 of this appendix
BE_R = as defined in section 8.2 of this appendix and measured at the reduced fuel input rate
BOH_H = as defined in section 10.2.1.3 of this appendix
PE_H = as defined in section 8.2 of this appendix and measured at the maximum fuel input rate
$y_{P,H}$ = as defined in section 10.2.1.3 of this appendix
$y_{IG,H}$ = as defined in section 10.2.1.3 of this appendix
BE_H = as defined in section 8.2 of this appendix and measured at the maximum fuel input rate
y_H = as defined in section 10.2.1.3 of this appendix
E_{SO} = as defined in section 10.7 of this appendix.

10.2.3.3 For boilers equipped with step-modulating controls, E_{AE} is defined as:

$$E_{AE} = BOH_R (y_{P,R} PE_R + y_{IG,R} PE_{IG} + y_R BE_R) + BOH_M (y_{P,H} PE_H + y_{IG,H} PE_{IG} + y_H BE_H) + E_{SO}$$

Where:

BOH_R = as defined in section 10.2.1.2 of this appendix
$y_{P,R}$ = as defined in section 10.2.1.2 of this appendix
PE_R = as defined in section 8.2 of this appendix and measured at the reduced fuel input rate
$y_{IG,R}$ = as defined in section 10.2.1.2 of this appendix
PE_{IG} = as defined in section 10.2.1 of this appendix
y_R = as defined in section 10.2.1.2 of this appendix
BE_R = as defined in section 8.2 of this appendix and measured at the reduced fuel input rate
BOH_M = as defined in 10.2.1.4 of this appendix
$y_{P,H}$ = as defined in section 10.2.1.3 of this appendix
PE_H = as defined in section 8.2 of this appendix and measured at the maximum fuel input rate
$y_{IG,H}$ = as defined in section 10.2.1.3 of this appendix
y_H = as defined in section 10.2.1.3 of this appendix
BE_H = as defined in section 8.2 of this appendix and measured at the maximum fuel input rate
E_{SO} = as defined in section 10.7 of this appendix.

10.3 *Average annual electric energy consumption for electric boilers.* For electric boilers, the average annual electrical energy consumption (E_E) is expressed in kilowatt-hours and defined as:

$$E_E = 100 (2{,}080) (0.77) [Q_{OUT}/(1+\alpha)]/(3412 \text{ AFUE}) + E_{SO}$$

Where:

100 = to express a percent as a decimal
2,080 = as defined in section 10.2.1.1 of this appendix
0.77 = as defined in section 10.2.1.1 of this appendix
Q_{OUT} = as defined in section 11.2.8 of ASHRAE 103–2017
α = as defined in section 11.2.8.2 of ASHRAE 103–2017
3412 = conversion factor from kilowatt-hours to Btu
AFUE = as defined in section 11.1 of ASHRAE 103–2017, in percent, and calculated on the basis of:
indoor installation, for non-weatherized boilers; or
outdoor installation, for boilers that are weatherized.
E_{SO} = as defined in section 10.7 of this appendix.

10.4 *Energy factor.*

10.4.1 *Energy factor for gas or oil boilers.* Calculate the energy factor, EF, for gas or oil boilers defined as, in percent:

$$EF = (E_F - 4{,}600 (Q_P))(Effy_{HS})/(E_F + 3{,}412 (E_{AE}))$$

Where:

E_F = average annual fuel consumption as defined in section 10.2.2 of this appendix
4,600 = as defined in section 11.4.12 of ASHRAE 103–2017
Q_P = pilot fuel input rate determined in accordance with section 9.2 of ASHRAE 103–2017 in Btu/h
$Effy_{HS}$ = annual fuel utilization efficiency as defined in sections 11.2.11, 11.3.11, 11.4.11 or 11.5.11 of ASHRAE 103–2017, in percent, and calculated on the basis of:
indoor installation, for non-weatherized boilers; or
outdoor installation, for boilers that are weatherized.
3,412 = conversion factor from kW to Btu/h
E_{AE} = as defined in section 10.2.3 of this appendix.

10.4.2 *Energy factor for electric boilers.* The energy factor, EF, for electric boilers is defined as:

EF = AFUE

Where:

AFUE = annual fuel utilization efficiency as defined in section 10.3 of this appendix, in percent.

10.5 *Average annual energy consumption for boilers located in a different geographic region of the United States and in buildings with different design heating requirements.*

10.5.1 *Average annual fuel energy consumption for gas or oil-fueled boilers located in a different geographic region of the United States and in buildings with different design heating requirements.* For gas or oil-fueled boilers, the average annual fuel energy consumption for a specific geographic region and a specific typical design heating requirement (E_{FR}) is expressed in Btu per year and defined as:

$E_{FR} = (E_F - 8{,}760\ Q_P)\ (HLH/2{,}080) + 8{,}760\ Q_P$

Where:

E_F = as defined in section 10.2.2 of this appendix

8,760 = as defined in section 10.2.2 of this appendix

Q_P = as defined in section 11.2.11 of ASHRAE 103–2017

HLH = heating load hours for a specific geographic region determined from the heating load hour map in Figure 1 of this appendix

2,080 = as defined in section 10.2.1.1 of this appendix.

10.5.2 *Average annual auxiliary electrical energy consumption for gas or oil-fueled boilers located in a different geographic region of the United States and in buildings with different design heating requirements.* For gas or oil-fueled boilers, the average annual auxiliary electrical energy consumption for a specific geographic region and a specific typical design heating requirement (E_{AER}) is expressed in kilowatt-hours and defined as:

$E_{AER} = (E_{AE} - E_{SO})\ (HLH/2080) + E_{SOR}$

Where:

E_{AE} = as defined in section 10.2.3 of this appendix

E_{SO} = as defined in section 10.7 of this appendix

HLH = as defined in section 10.5.1 of this appendix

2,080 = as defined in section 10.2.1.1 of this appendix

E_{SOR} = as defined in section 10.5.3 of this appendix.

10.5.3 *Average annual electric energy consumption for electric boilers located in a different geographic region of the United States and in buildings with different design heating requirements.* For electric boilers, the average annual electric energy consumption for a specific geographic region and a specific typical design heating requirement (E_{ER}) is expressed in kilowatt-hours and defined as:

$E_{ER} = 100\ (0.77)\ [Q_{OUT}/(1+\alpha)]\ HLH/(3.412\ AFUE) + E_{SOR}$

Where:

100 = as defined in section 10.2.3 of this appendix

0.77 = as defined in section 10.2.1.1 of this appendix

Q_{OUT} = as defined in section 11.2.8.1 of ASHRAE 103–2017

α = as defined in section 11.2.8.2 of ASHRAE 103–2017

HLH = as defined in section 10.5.1 of this appendix

3.412 = as defined in section 10.2.3 of this appendix

AFUE = as defined in section 10.2.3 of this appendix

E_{SOR} = E_{SO} as defined in section 10.7 of this appendix, except that in the equation for E_{SO}, the term BOH is multiplied by the expression (HLH/2080) to get the appropriate regional accounting of standby mode and off mode loss.

10.6 [Reserved]

10.7 *Average annual electrical standby mode and off mode energy consumption.* Calculate the annual electrical standby mode and off mode energy consumption (E_{SO}) in kilowatt-hours, defined as:

$E_{SO} = (P_{W,SB}\ (4160 - BOH) + 4600\ P_{W,OFF})\ K$

Where:

$P_{W,SB}$ = boiler standby mode power, in watts, as measured in section 8.9.1 of this appendix

4,160 = average heating season hours per year

BOH = total burner operating hours as calculated in section 10.2 of this appendix for gas or oil-fueled boilers. Where for gas or oil-fueled boilers equipped with single-stage controls, BOH = BOH_{SS}; for gas or oil-fueled boilers equipped with two-stage controls, BOH = (BOH_R + BOH_H); and for gas or oil-fueled boilers equipped with step-modulating controls, BOH = (BOH_R + BOH_M). For electric boilers, BOH = $100(2080)(0.77)[Q_{OUT}/(1+\alpha)]/(E_{in}\ 3412(AFUE))$

4,600 = as defined in section 11.4.12 of ASHRAE 103–2017

$P_{W,OFF}$ = boiler off mode power, in watts, as measured in section 8.9.2 of this appendix

K = 0.001 kWh/Wh, conversion factor from watt-hours to kilowatt-hours

Where:

100 = to express a percent as a decimal

2,080 = as defined in section 10.2.1.1 of this appendix

0.77 = as defined in section 10.2.1.1 of this appendix


Q_{OUT} = as defined in section 11.2.8 of ASHRAE 103–2017

α = as defined in section 11.2.8.2 of ASHRAE 103–2017

E_{in} = steady-state electric rated power, in kilowatts, from section 9.3 of ASHRAE 103–2017

3412 = as defined in section 10.3 of this appendix

AFUE = as defined in section 11.1 of ASHRAE 103–2017 in percent.



This map is reasonably accurate for most parts of the United States but is necessarily generalized, and consequently not too accurate in mountainous regions, particularly in the rockies.

FIGURE 1- HEATING LOAD HOURS (HLH) FOR THE UNITED STATES

[88 FR 15547, Mar. 13, 2023]

APPENDIX FF TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF AIR CLEANERS

NOTE: Beginning on the compliance date of any energy conservation standards for air cleaners, any representations made with respect to the energy use or efficiency of these products, including those made for certification purposes, must be made in accordance with the results of testing pursuant to this appendix. Manufacturers may choose to test in accordance with this appendix to certify compliance with any energy conservation standards prior to the applicable compliance date for those standards.

0. Incorporation by Reference

DOE incorporated by reference in §430.3 the entire standard for AHAM AC–1–2020, AHAM AC–7–2022, ASTM E741–11(2017), and IEC 62301. However, only enumerated provisions of AHAM AC–1–2020, AHAM AC–7–2022, and IEC 62301 apply to this appendix, as follows:

0.1 AHAM AC–1–2020

(a) Sections 4.2 through 4.6;
(b) Sections 5 through 7;
(c) Section 8.1;
(d) Annex A;
(e) Annex I; and
(f) AHAM Standard Interpretation.

0.2 AHAM AC–7–2022

(a) Sections 2.2 and 2.3, sections 2.4.1 through 2.4.2.4, and sections 2.6 through 2.9;
(b) Sections 3.1 through 3.6.3;
(c) Section 4;
(d) Sections 5.3 through 5.7.4; and
(e) Sections 6 and 7.

0.3 IEC 62301: Household Electrical Appliances—Measurement of Standby Power

(a) Sections 4.4.1 through 4.4.3; and
(b) Section 5.3.

1. Scope of Coverage

This appendix contains the test requirements to measure the energy performance of a conventional room air cleaner, as defined at §430.2, with smoke CADR and dust CADR between 10 to 600 cubic feet per minute (cfm), inclusive.

2. Definitions

The definitions in sections 2.2, 2.3, 2.4.1 through 2.4.2.4, 2.6 through 2.8, and 2.9 of AHAM AC–7–2022 apply to this test procedure, including the applicable provisions of Annex I of AHAM AC–1–2020 as referenced in section 2.9 of AHAM AC–7–2022.

3. Test Conditions

Testing conditions shall be as specified in sections 3.1 through 3.6.3 of AHAM AC–7–2022, including the applicable provisions of sections 4.2 through 4.6 and Annex A of AHAM AC–1–2020 as referenced in sections 3.2.1, 3.3, 3.4, 3.5, and 3.6.2 of AHAM AC–7–2022 and the applicable provisions of ASTM E 741–11(2017) as referenced in section 3.3 of AHAM AC–7–2022. Additionally, the following requirements are also applicable:

3.1. *Placement for Testing*. The air cleaner test unit shall be placed in the test chamber as specified in section 3.6.2 of AHAM AC–7–2022. Additionally, the placement instructions specified in AHAM Standard Interpretation in AHAM AC–1–2020 are also applicable.

3.2. *Air Cleaners with Network Mode Capability*. The air cleaner software update requirements specified in section 3.6.3.8 of AHAM AC–7–2022 are applicable. Additionally, software updates shall be conducted, if available, prior to initiating any testing. Software updates shall not be bypassed, even if the unit will operate without updates.

4. Instrumentation

Test instruments shall be as specified in section 4 of AHAM AC–7–2022, including the applicable provisions of sections 4.4.1 through 4.4.3 of IEC 62301.

5. Active Mode CADR and Power Measurement

Measurement of smoke CADR, dust CADR, and pollen CADR shall be as specified in sections 5 through 7 of AHAM AC–1–2020, respectively. Measurement of active mode power shall be as specified in sections 5.3 through 5.7.4 of AHAM AC–7–2022, including the applicable provisions of sections 5.2.5 and 6.2.5 of AHAM AC–1–2020 as referenced in section 5.7.1 of AHAM AC–7–2022. Additionally, the following requirement is also applicable:

5.1. *Calculation of $PM_{2.5}$ CADR*.

5.1.1 $PM_{2.5}$ CADR should be calculated as specified in section 2.9 of AHAM AC–7–2022.

5.1.2. For determining compliance only with the standards specified in §430.32(ee)(1), $PM_{2.5}$ CADR may alternately be calculated using the smoke CADR and dust CADR values determined according to Sections 5 and 6, respectively, of AHAM AC–1–2020, according to the following equation:

$$PM_{2.5}CADR = \sqrt{Smoke\ CADR\ (0.1 - 1\ \mu m) \times Dust\ CADR\ (0.5 - 3\ \mu m)}$$

6. Standby Mode Power Measurement

Standby mode power consumption shall be measured as specified in section 6 of AHAM AC–7–2022, including the applicable provisions of section 5.3 of IEC 62301.

7. Total Energy Calculation

Annual energy consumption, expressed in kilowatt-hours per year, and integrated energy factor, expressed in CADR per watt, shall be calculated as specified in section 7 of AHAM AC–7–2022.

[88 FR 14044, Mar. 6, 2023, as amended at 88 FR 53371, Aug. 8, 2023; 88 FR 21814, Apr. 11, 2023]

APPENDIX GG TO SUBPART B OF PART 430—UNIFORM TEST METHOD FOR MEASURING THE ENERGY CONSUMPTION OF PORTABLE ELECTRIC SPAS

NOTE: Beginning on the compliance date of any energy conservation standards for portable electric spas specified in §430.32, all representations of fill volume, energy efficiency, and energy use of portable electric spas, including those made on marketing materials and product labels, must be made in accordance with this test procedure.

0. Incorporation by Reference

DOE incorporated by reference in §430.3, the entire standard for ANSI/APSP/ICC–14 2019 and CSA C374:11 (R2021). However, only enumerated provisions of ANSI/APSP/ICC–14 2019 and CSA C374:11 (R2021), as listed in this section 0 are required. To the extent there is a conflict between the terms or provisions of a referenced industry standard and the CFR, the CFR provisions control. Non-enumerated provisions of ANSI/APSP/ICC–14 2019 are specifically excluded.

0.1. ANSI/APSP/ICC–14 2019

(a) Section 3—Definitions (excluding the definitions for *cover*, *specified; fill volume; rated volume; and standby mode*), as specified in section 2.1 of this appendix;

(b) Section 5—Test Method (excluding Sections 5.1, 5.2, 5.5.2, 5.5.4, 5.5.5, and 5.7), as specified in sections 3, 3.1.6, 3.2.2, and 3.2.3 of this appendix;

(c) Appendix A—Minimum Chamber Requirements (excluding section titled *Chamber floor*), as specified in section 3.1.1 of this appendix.

0.2. CSA C374:11 (R2021)

(a) Clause 5.1.1—Test room, as specified in section 3.1.2 of this appendix;
(b) Figure 1—Test platform, as specified in section 3.1.2 of this appendix.

1. Scope

This appendix provides the test procedure for measuring the standby loss in watts and the fill volume in gallons of portable electric spas.

2. Definitions

2.1. Section 3, Definitions, of ANSI/APSP/ICC–14 2019 applies to this test procedure. In case of conflicting terms between ANSI/APSP/ICC–14 2019 and DOE's definitions in this appendix or in §430.2, DOE's definitions take priority.

2.2. *Combination spa* means a portable electric spa with two separate and distinct reservoirs, where—
(a) One reservoir is an exercise spa;
(b) The second reservoir is a standard spa; and
(c) Each reservoir has an independent water temperature setting control.

2.3. *Exercise spa* means a variant of a portable electric spa in which the design and construction includes specific features and equipment to produce a water flow intended to allow recreational physical activity including, but not limited to, swimming in place. An exercise spa is also known as a swim spa.

2.4. *Exercise spa portion* means the reservoir of a combination spa that is an exercise spa.

2.5. *Fill volume* means the volume of water held by the portable electric spa when it is filled as specified in section 3.1.4 of this appendix.

2.6. *Inflatable spa* means a portable electric spa where the structure is collapsible and is designed to be filled with air to form the body of the spa.

2.7. *Standard spa* means a portable electric spa that is not an inflatable spa, an exercise spa, or the exercise spa portion of a combination spa.

2.8. *Standard spa portion* means the reservoir of a combination spa that is a standard spa.

2.9. *Standby loss* means the mean normalized power required to operate the portable electric spa in default operation mode with the cover on, as calculated in section 3.3 of this appendix.

3. Test Method

Determine the standby loss in watts and fill volume in gallons for portable electric spas in accordance with section 5, *Test Method,* of ANSI/APSP/ICC–14 2019, except as follows.

3.1. Test Setup

3.1.1. Chamber

Install the portable electric spa in a chamber satisfying the requirements specified for *Chamber internal dimensions*, *Air flow*, and *Chamber insulation* in appendix A, *Minimum Chamber Requirements,* to ANSI/APSP/ICC–14 2019.

3.1.2. Chamber Floor

Install the portable electric spa on a platform as specified in Clause 5.1.1(b) and Figure 1 of CSA C374:11 (R2021).

3.1.3. Electrical Supply Voltage and Amperage Configuration

3.1.3.1. General

If the portable electric spa can be installed or configured with multiple options of voltage, maximum amperage, or both, use the hierarchy in section 3.1.3.2 of this appendix to determine the configuration for testing.

3.1.3.2. Hierarchy

Use the as-shipped configuration, if such a configuration is provided.

If no configuration is provided in the as-shipped condition, use the option specified in the manufacturer's instructions as the recommended configuration for normal consumer use.

If no configuration is provided in the as-shipped condition and the manufacturer's instructions do not provide a recommended configuration for normal consumer use, use the maximum voltage specified in the manufacturer's installation instructions and maximum amperage that the manufacturer's installation instructions specify for use with the maximum voltage.

3.1.4. Fill Volume

Follow the manufacturer's instructions for filling the portable electric spa with water, connecting and/or priming the pump(s), and starting up the spa. After verifying that the spa is operating normally and that all water lines are filled, power off the spa and adjust the fill level as needed to meet the following specifications before starting the test.

If the manufacturer's instructions specify a single fill level, fill to that level with a tolerance of ±0.125 inches.

If the manufacturer's instructions specify a range of fill levels and not a single fill level, fill to the middle of that range with a tolerance of ±0.125 inches.

If the manufacturer's instructions do not specify a fill level or range of fill levels, fill to the halfway point between the bottom of

the skimmer opening and the top of the skimmer opening with a tolerance of ±0.125 inches.

If the manufacturer's instructions do not specify a fill level or range of fill levels, and there is no wall skimmer, fill to 6.0 inches ±0.125 inches below the overflow level of the spa.

Measure the volume of water added to the spa with a water meter while filling the spa. Measure any water removed from the spa using a water meter, graduated container, or scale, each with an accuracy of ±2 percent of the quantity measured. The fill volume is the volume of water held by the spa when the spa is filled as specified above.

3.1.5. Spa Cover

3.1.5.1. Cover Is Designated by the Spa Manufacturer

Install the spa cover following the manufacturer's instructions.

3.1.5.2. No Cover Is Designated by the Spa Manufacturer

If no cover is designated by the spa manufacturer for use with the spa, cover the portable electric spa with a single layer of 6 mil thickness (0.006 inches; 0.15 mm) plastic film. Cut the plastic to cover the entire top surface of the spa and extend over the edge of the spa approximately 6 inches below the top surface of the spa. Use fasteners or weights to keep the plastic in place during the test, but do not seal the edges of the plastic to the spa (by using tape, for example).

3.1.6. Ambient Temperature Measurement Location

The ambient air temperature measurement point specified in section 5.6.3 of ANSI/APSP/ICC–14 2019 must be located above the center of the spa.

3.2. Test Conditions and Conduct

3.2.1. Ambient Air Temperature

Maintain the ambient air temperature at a maximum of 63.0 °F for the duration of the test. This requirement applies to each individual ambient air temperature measurement taken for the duration of the stabilization period and test period.

3.2.2. Water Temperature Settings

Adjust the spa water temperature settings to meet the applicable temperature requirements in section 5.6.1 of ANSI/APSP/ICC–14 2019. The spa water temperature settings must not be adjusted between the start of the stabilizing period specified in section 5.6.1 of ANSI/APSP/ICC–14 2019 and the end of the test period specified in section 5.6.4.7 of ANSI/APSP/ICC–14 2019.

3.2.3. Water Temperature Requirements

Each individual water temperature measurement taken during the stabilization period and test period must meet the applicable water temperature requirements specified in section 5.6.1 of ANSI/APSP/ICC–14 2019.

3.3. Standby Loss Calculation

Calculate standby loss in watts by calculating the measured standby loss using Equation 1 of this appendix, calculating the measured temperature difference using Equation 2 of this appendix, and normalizing the standby loss using Equation 3 of this appendix. Use the standby loss calculated in Equation 3 as the standby loss value for the test.

Equation 1

$$SL_{meas} = \frac{E}{t}$$

Equation 2

$$\Delta T_{meas} = T_{water\ avg} - T_{air\ avg}$$

Equation 3

$$SL = SL_{meas} \times \frac{\Delta T_{std}}{\Delta T_{meas}}$$

Where:

SL_{meas} = Measured standby loss (watts)
E = Total energy use during the test (watt-hours)
t = Length of test (hours)
ΔT_{meas} = Measured temperature difference (°F)
$T_{water\ avg}$ = Average water temperature during test (°F)
$T_{air\ avg}$ = Average air temperature during test (°F)
SL = Standby loss (W)
ΔT_{std} = Normalized temperature difference (°F), as follows:

46.0 °F for all inflatable spas, standard spas, standard spa portions of a combination spa, exercise spas, and exercise spa portions of a combination spa tested to a minimum water temperature of 100 °F; or 31.0 °F for all exercise spas or exercise spa portions of a combination spa tested to a minimum water temperature of 85 °F.

[88 FR 38627, June 13, 2023]

Subpart C—Energy and Water Conservation Standards

§ 430.31 Purpose and scope.

This subpart contains energy conservation standards and water conservation standards (in the case of faucets, showerheads, water closets, and urinals) for classes of covered products that are required to be administered by the Department of Energy pursuant to the Energy Conservation Program for Consumer Products Other Than Automobiles under the Energy Policy and Conservation Act, as amended (42 U.S.C. 6291 *et seq.*).

[63 FR 13317, Mar. 18, 1998, as amended at 78 FR 62993, Oct. 23, 2013]

§ 430.32 Energy and water conservation standards and their compliance dates.

The energy and water (in the case of faucets, showerheads, water closets, and urinals) conservation standards for the covered product classes are:

(a) *Refrigerators/refrigerator-freezers/freezers.* These standards do not apply to refrigerators and refrigerator-freezers with total refrigerated volume exceeding 39 cubic feet (1104 liters) or freezers with total refrigerated volume exceeding 30 cubic feet (850 liters). The energy standards as determined by the equations of the following table(s) shall be rounded off to the nearest kWh per year. If the equation calculation is halfway between the nearest two kWh per year values, the standard shall be rounded up to the higher of these values.

(1) The following standards apply to products manufactured on or before September 15, 2014, and before the 2029/2030 compliance dates depending on product class (see paragraphs (a)(2) and (3) of this section).

TABLE 1 TO PARAGRAPH (a)(1)

Product class	Equations for maximum energy use (kWh/yr)	
	based on AV (ft^3)	based on av (L)
1. Refrigerators and refrigerator-freezers with manual defrost	7.99AV + 225.0	0.282av + 225.0.
1A. All-refrigerators—manual defrost	6.79AV + 193.6	0.240av + 193.6.
2. Refrigerator-freezers—partial automatic defrost	7.99AV + 225.0	0.282av + 225.0.
3. Refrigerator-freezers—automatic defrost with top-mounted freezer without an automatic icemaker.	8.07AV + 233.7	0.285av + 233.7.
3–BI. Built-in refrigerator-freezer—automatic defrost with top-mounted freezer without an automatic icemaker.	9.15AV + 264.9	0.323av + 264.9.
3I. Refrigerator-freezers—automatic defrost with top-mounted freezer with an automatic icemaker without through-the-door ice service.	8.07AV + 317.7	0.285av + 317.7.
3I–BI. Built-in refrigerator-freezers—automatic defrost with top-mounted freezer with an automatic icemaker without through-the-door ice service.	9.15AV + 348.9	0.323av + 348.9.
3A. All-refrigerators—automatic defrost	7.07AV + 201.6	0.250av + 201.6.
3A–BI. Built-in All-refrigerators—automatic defrost	8.02AV + 228.5	0.283av + 228.5.
4. Refrigerator-freezers—automatic defrost with side-mounted freezer without an automatic icemaker.	8.51AV + 297.8	0.301av + 297.8.
4–BI. Built-In Refrigerator-freezers—automatic defrost with side-mounted freezer without an automatic icemaker.	10.22AV + 357.4	0.361av + 357.4.
4I. Refrigerator-freezers—automatic defrost with side-mounted freezer with an automatic icemaker without through-the-door ice service.	8.51AV + 381.8	0.301av + 381.8.

TABLE 1 TO PARAGRAPH (a)(1)—Continued

Product class	Equations for maximum energy use (kWh/yr)	
	based on AV (ft^3)	based on av (L)
4I–BI. Built-In Refrigerator-freezers—automatic defrost with side-mounted freezer with an automatic icemaker without through-the-door ice service.	10.22AV + 441.4.2	0.361av + 441.4.
5. Refrigerator-freezers—automatic defrost with bottom-mounted freezer without an automatic icemaker.	8.85AV + 317.0	0.312av + 317.0.
5–BI. Built-In Refrigerator-freezers—automatic defrost with bottom-mounted freezer without an automatic icemaker.	9.40AV + 336.9	0.332av + 336.9.
5I. Refrigerator-freezers—automatic defrost with bottom-mounted freezer with an automatic icemaker without through-the-door ice service.	8.85AV + 401.0	0.312av + 401.0.
5I–BI. Built-In Refrigerator-freezers—automatic defrost with bottom-mounted freezer with an automatic icemaker without through-the-door ice service.	9.40AV + 420.9	0.332av + 420.9.
5A. Refrigerator-freezer—automatic defrost with bottom-mounted freezer with through-the-door ice service.	9.25AV + 475.4	0.327av + 475.4.
5A–BI. Built-in refrigerator-freezer—automatic defrost with bottom-mounted freezer with through-the-door ice service.	9.83AV + 499.9	0.347av + 499.9.
6. Refrigerator-freezers—automatic defrost with top-mounted freezer with through-the-door ice service.	8.40AV + 385.4	0.297av + 385.4.
7. Refrigerator-freezers—automatic defrost with side-mounted freezer with through-the-door ice service.	8.54AV + 432.8	0.302av + 431.1.
7–BI. Built-In Refrigerator-freezers—automatic defrost with side-mounted freezer with through-the-door ice service.	10.25AV + 502.6	0.362av + 502.6.
8. Upright freezers with manual defrost	5.57AV + 193.7	0.197av + 193.7.
9. Upright freezers with automatic defrost without an automatic icemaker.	8.62AV + 228.3	0.305av + 228.3.
9I. Upright freezers with automatic defrost with an automatic icemaker.	8.62AV + 312.3	0.305av + 312.3.
9–BI. Built-In Upright freezers with automatic defrost without an automatic icemaker.	9.86AV + 260.9	0.348av + 260.6.
9I–BI. Built-In Upright freezers with automatic defrost with an automatic icemaker.	9.86AV + 344.9	0.348av + 344.9.
10. Chest freezers and all other freezers except compact freezers	7.29AV + 107.8	0.257av + 107.8.
10A. Chest freezers with automatic defrost	10.24AV + 148.1	0.362av + 148.1.
11. Compact refrigerators and refrigerator-freezers with manual defrost.	9.03AV + 252.3	0.319av + 252.3.
11A.Compact refrigerators and refrigerator-freezers with manual defrost.	7.84AV + 219.1	0.277av + 219.1.
12. Compact refrigerator-freezers—partial automatic defrost	5.91AV + 335.8	0.209av + 335.8.
13. Compact refrigerator-freezers—automatic defrost with top-mounted freezer.	11.80AV + 339.2	0.417av + 339.2.
13I. Compact refrigerator-freezers—automatic defrost with top-mounted freezer with an automatic icemaker.	11.80AV + 423.2	0.417av + 423.2.
13A. Compact all-refrigerator—automatic defrost	9.17AV + 259.3	0.324av + 259.3.
14. Compact refrigerator-freezers—automatic defrost with side-mounted freezer.	6.82AV + 456.9	0.241av + 456.9.
14I. Compact refrigerator-freezers—automatic defrost with side-mounted freezer with an automatic icemaker.	6.82AV + 540.9	0.241av + 540.9.
15. Compact refrigerator-freezers—automatic defrost with bottom-mounted freezer.	11.80AV + 339.2	0.417av + 339.2.
15I. Compact refrigerator-freezers—automatic defrost with bottom-mounted freezer with an automatic icemaker.	11.80AV + 423.2	0.417av + 423.2.
16. Compact upright freezers with manual defrost	8.65AV + 225.7	0.306av + 225.7.
17. Compact upright freezers with automatic defrost	10.17AV + 351.9	0.359av + 351.9.
18. Compact chest freezers	9.25AV + 136.8	0.327av + 136.8.

AV = Total adjusted volume, expressed in ft^3, as determined in appendices A and B to subpart B of this part.
av = Total adjusted volume, expressed in Liters.

(2) The following standards apply to products manufactured on or after January 31, 2029.

TABLE 2 TO PARAGRAPH (a)(2)

Product class	Equations for maximum energy use (kWh/yr)	
	Based on AV (ft^3)	Based on av (L)
3–BI. Built-in refrigerator-freezer—automatic defrost with top-mounted freezer.	8.24AV + 238.4 + 28I	0.291av + 238.4 + 28I.
3A–BI. Built-in All-refrigerators—automatic defrost	(7.22AV + 205.7) * K3ABI	(0.255av + 205.7) * K3ABI.
4–BI. Built-In Refrigerator-freezers—automatic defrost with side-mounted freezer.	(8.79AV + 307.4) * K4BI + 28I.	(0.310av + 307.4) * K4BI + 28I.
5–BI. Built-In Refrigerator-freezers—automatic defrost with bottom-mounted freezer.	(8.65AV + 309.9) * K5BI + 28I.	(0.305av + 309.9) * K5BI + 28I.
5A. Refrigerator-freezer—automatic defrost with bottom-mounted freezer with through-the-door ice service.	(7.76AV + 351.9) * K5A	(0.274av + 351.9) * K5A.
5A–BI. Built-in refrigerator–freezer—automatic defrost with bottom-mounted freezer with through-the-door ice service.	(8.21AV + 370.7) * K5ABI	(0.290av + 370.7) * K5ABI.
7–BI. Built-In Refrigerator-freezers—automatic defrost with side-mounted freezer with through-the-door ice service.	(8.82AV + 384.1) * K7BI	(0.311av + 384.1) * K7BI.
8. Upright freezers with manual defrost	5.57AV + 193.7	0.197av + 193.7.
9–BI. Built-In Upright freezers with automatic defrost	(9.37AV + 247.9) * K9BI + 28I.	(0.331av + 247.9) * K9BI + 28I.
9A–BI. Built-In Upright freezers with automatic defrost with through-the-door ice service.	9.86AV + 288.9	0.348av + 288.9.
10. Chest freezers and all other freezers except compact freezers	7.29AV + 107.8	0.257av + 107.8.
10A. Chest freezers with automatic defrost	10.24AV + 148.1	0.362av + 148.1.
11. Compact refrigerator-freezers and refrigerators other than all-refrigerators with manual defrost.	7.68AV + 214.5	0.271av + 214.5.
11A. Compact all-refrigerators—manual defrost	6.66AV + 186.2	0.235av + 186.2.
12. Compact refrigerator-freezers—partial automatic defrost	(5.32AV + 302.2) * K12	(0.188av + 302.2) * K12.
13. Compact refrigerator-freezers—automatic defrost with top-mounted freezer.	10.62AV + 305.3 + 28I	0.375av + 305.3 + 28I.
13A. Compact all-refrigerators—automatic defrost	(8.25AV + 233.4) * K13A	(0.291av + 233.4) * K13A.
14. Compact refrigerator-freezers—automatic defrost with side-mounted freezer.	6.14AV + 411.2 + 28I	0.217av + 411.2 + 28I.
15. Compact refrigerator-freezers—automatic defrost with bottom-mounted freezer.	10.62AV + 305.3 + 28I	0.375av + 305.3 + 28I.
16. Compact upright freezers with manual defrost	7.35AV + 191.8	0.260av + 191.8.
17. Compact upright freezers with automatic defrost	9.15AV + 316.7	0.323av + 316.7.
18. Compact chest freezers	7.86AV + 107.8	0.278av + 107.8.

AV = Total adjusted volume, expressed in ft^3, as determined in appendices A and B to subpart B of this part.
av = Total adjusted volume, expressed in Liters.
I = 1 for a product with an automatic icemaker and = 0 for a product without an automatic icemaker. Door Coefficients (*e.g.,* K3ABI) are as defined in the following table.

TABLE 3 TO PARAGRAPH (a)(2)

Door coefficient	Products with a transparent door	Products without a transparent door with a door-in-door	Products without a transparent door or door-in-door with added external doors
K3ABI	1.10	1.0	1.0.
K4BI	1.10	1.06	1 + 0.02 * (N_d – 2).
K5BI	1.10	1.06	1 + 0.02 * (N_d – 2).
K5A	1.10	1.06	1 + 0.02 * (N_d – 3).
K5ABI	1.10	1.06	1 + 0.02 * (N_d – 3).
K7BI	1.10	1.06	1 + 0.02 * (N_d – 2).
K9BI	1.0	1.0	1 + 0.02 * (N_d – 1).
K12	1.0	1.0	1 + 0.02 * (N_d – 1).
K13A	1.10	1.0	1.0.

Notes:
[1] N_d is the number of external doors.
[2] The maximum N_d values are 2 for K12, 3 for K9BI, and 5 for all other K values.

(3) The following standards apply to products manufactured on or after January 31, 2030.

TABLE 4 TO PARAGRAPH (a)(3)

Product class	Equations for maximum energy use (kWh/yr)	
	Based on AV (ft^3)	Based on av (L)
1. Refrigerator-freezers and refrigerators other than all-refrigerators with manual defrost.	6.79AV + 191.3	0.240av + 191.3.
1A. All-refrigerators—manual defrost	5.77AV + 164.6	0.204av + 164.6.
2. Refrigerator-freezers—partial automatic defrost	(6.79AV + 191.3) * K2	(0.240av + 191.3) * K2.
3. Refrigerator-freezers—automatic defrost with top-mounted freezer	6.86AV + 198.6 + 28I	0.242av + 198.6 + 28I.
3A. All-refrigerators—automatic defrost	(6.01AV + 171.4) * K3A	(0.212av + 171.4) * K3A.
4. Refrigerator-freezers—automatic defrost with side-mounted freezer	(7.28AV + 254.9) * K4 + 28I.	(0.257av + 254.9) * K4 + 28I.
5. Refrigerator-freezers—automatic defrost with bottom-mounted freezer.	(7.61AV + 272.6) * K5 + 28I.	(0.269av + 272.6) * K5 + 28I.
6. Refrigerator-freezers—automatic defrost with top-mounted freezer with through-the-door ice service.	7.14AV + 280.0	0.252av + 280.0.
7. Refrigerator-freezers—automatic defrost with side-mounted freezer with through-the-door ice service.	(7.31AV + 322.5) * K7	(0.258av + 322.5) * K7.
9. Upright freezers with automatic defrost	(7.33AV + 194.1) * K9 + 28I.	(0.259av + 194.1) * K9 + 28I.

AV = Total adjusted volume, expressed in ft^3, as determined in appendices A and B to subpart B of this part.
av = Total adjusted volume, expressed in Liters.
I = 1 for a product with an automatic icemaker and = 0 for a product without an automatic icemaker. Door Coefficients (*e.g.,* K3A) are as defined in the following table.

TABLE 5 TO PARAGRAPH (a)(3)

Door coefficient	Products with a transparent door	Products without a transparent door with a door-in-door	Products without a transparent door or door-in-door with added external doors
K2	1.0	1.0	$1 + 0.02 * (N_d - 1)$.
K3A	1.10	1.0	1.0.
K4	1.10	1.06	$1 + 0.02 * (N_d - 2)$.
K5	1.10	1.06	$1 + 0.02 * (N_d - 2)$.
K7	1.10	1.06	$1 + 0.02 * (N_d - 2)$.
K9	1.0	1.0	$1 + 0.02 * (N_d - 1)$.

Notes:
[1] N_d is the number of external doors.
[2] The maximum N_d values are 2 for K2, and 5 for all other K values.

(b) *Room air conditioners.* (1) The following standards remain in effect from June 1, 2014, until May 26, 2026:

TABLE 6 TO PARAGRAPH (b)(1)

Equipment class	Combined energy efficiency ratio
1. Without reverse cycle, with louvered sides, and with a certified cooling capacity [1] less than 6,000 Btu/h	11.0
2. Without reverse cycle, with louvered sides and with a certified cooling capacity of 6,000 to 7,999 Btu/h	11.0
3. Without reverse cycle, with louvered sides and with a certified cooling capacity of 8,000 to 13,999 Btu/h	10.9
4. Without reverse cycle, with louvered sides and with a certified cooling capacity of 14,000 to 19,999 Btu/h	10.7
5a. Without reverse cycle, with louvered sides and with a certified cooling capacity of 20,000 Btu/h to 27,999 Btu/h	9.4
5b. Without reverse cycle, with louvered sides and with a certified cooling capacity of 28,000 Btu/h or more	9.0
6. Without reverse cycle, without louvered sides, and with a certified cooling capacity less than 6,000 Btu/h	10.0
7. Without reverse cycle, without louvered sides and with a certified cooling capacity of 6,000 to 7,999 Btu/h	10.0
8a. Without reverse cycle, without louvered sides and with a certified cooling capacity of 8,000 to 10,999 Btu/h	9.6
8b. Without reverse cycle, without louvered sides and with a certified cooling capacity of 11,000 to 13,999 Btu/h	9.5
9. Without reverse cycle, without louvered sides and with a certified cooling capacity of 14,000 to 19,999 Btu/h	9.3
10. Without reverse cycle, without louvered sides and with a certified cooling capacity of 20,000 Btu/h or more	9.4
11. With reverse cycle, with louvered sides, and with a certified cooling capacity less than 20,000 Btu/h	9.8
12. With reverse cycle, without louvered sides, and with a certified cooling capacity less than 14,000 Btu/h	9.3

TABLE 6 TO PARAGRAPH (b)(1)—Continued

Equipment class	Combined energy efficiency ratio
13. With reverse cycle, with louvered sides, and with a certified cooling capacity of 20,000 Btu/h or more	9.3
14. With reverse cycle, without louvered sides, and with a certified cooling capacity of 14,000 Btu/h or more	8.7
15. Casement-Only	9.5
16. Casement-Slider	10.4

[1] The certified cooling capacity is determined by the manufacturer in accordance with 10 CFR 429.15(a)(3).

(2) The following standards apply to products manufactured starting May 26, 2026:

TABLE 7 TO PARAGRAPH (b)(2)

Equipment class	Combined energy efficiency ratio
1. Without reverse cycle, with louvered sides, and with a certified cooling capacity [1] less than 6,000 Btu/h	13.1
2. Without reverse cycle, with louvered sides and with a certified cooling capacity of 6,000 to 7,900 Btu/h	13.7
3. Without reverse cycle, with louvered sides and with a certified cooling capacity of 8,000 to 13,900 Btu/h	16.0
4. Without reverse cycle, with louvered sides and with a certified cooling capacity of 14,000 to 19,900 Btu/h	16.0
5a. Without reverse cycle, with louvered sides and with a certified cooling capacity of 20,000 Btu/h to 27,900 Btu/h	13.8
5b. Without reverse cycle, with louvered sides and with a certified cooling capacity of 28,000 Btu/h or more	13.2
6. Without reverse cycle, without louvered sides, and with a certified cooling capacity less than 6,000 Btu/h	12.8
7. Without reverse cycle, without louvered sides and with a certified cooling capacity of 6,000 to 7,900 Btu/h	12.8
8a. Without reverse cycle, without louvered sides and with a certified cooling capacity of 8,000 to 10,900 Btu/h	14.1
8b. Without reverse cycle, without louvered sides and with a certified cooling capacity of 11,000 to 13,900 Btu/h	13.9
9. Without reverse cycle, without louvered sides and with a certified cooling capacity of 14,000 to 19,900 Btu/h	13.7
10. Without reverse cycle, without louvered sides and with a certified cooling capacity of 20,000 Btu/h or more	13.8
11. With reverse cycle, with louvered sides, and with a certified cooling capacity less than 20,000 Btu/h	14.4
12. With reverse cycle, without louvered sides, and with a certified cooling capacity less than 14,000 Btu/h	13.7
13. With reverse cycle, with louvered sides, and with a certified cooling capacity of 20,000 Btu/h or more	13.7
14. With reverse cycle, without louvered sides, and with a certified cooling capacity of 14,000 Btu/h or more	12.8
15. Casement-Only	13.9
16. Casement-Slider	15.3

[1] The certified cooling capacity is determined by the manufacturer in accordance with 10 CFR 429.15(a)(3).

(c) *Central air conditioners and heat pumps.* The energy conservation standards defined in terms of the heating seasonal performance factor are based on Region IV, the minimum standardized design heating requirement, and the provisions of 10 CFR 429.16.

(1) Central air conditioners and central air conditioning heat pumps manufactured on or after January 1, 2015, and before January 1, 2023, must have Seasonal Energy Efficiency Ratio and Heating Seasonal Performance Factor not less than:

Product class	Seasonal energy efficiency ratio (SEER)	Heating seasonal performance factor (HSPF)
(i) Split systems—air conditioners	13	
(ii) Split systems—heat pumps	14	8.2
(iii) Single package units—air conditioners	14	
(iv) Single package units—heat pumps	14	8.0
(v) Small-duct, high-velocity systems	12	7.2
(vi)(A) Space-constrained products—air conditioners	12	
(vi)(B) Space-constrained products—heat pumps	12	7.4

(2) In addition to meeting the applicable requirements in paragraph (c)(1) of this section, products in product

class (i) of paragraph (c)(1) of this section (*i.e.*, split-systems—air conditioners) that are installed on or after January 1, 2015, and before January 1, 2023, in the States of Alabama, Arkansas, Delaware, Florida, Georgia, Hawaii, Kentucky, Louisiana, Maryland, Mississippi, North Carolina, Oklahoma, South Carolina, Tennessee, Texas, or Virginia, or in the District of Columbia, must have a Seasonal Energy Efficiency Ratio (SEER) of 14 or higher. Any outdoor unit model that has a certified combination with a rating below 14 SEER cannot be installed in these States. The least efficient combination of each basic model must comply with this standard.

(3)(i) In addition to meeting the applicable requirements in paragraph (c)(1) of this section, products in product classes (i) and (iii) of paragraph (c)(1) of this section (*i.e.*, split systems—air conditioners and single-package units—air conditioners) that are installed on or after January 1, 2015, and before January 1, 2023, in the States of Arizona, California, Nevada, or New Mexico must have a Seasonal Energy Efficiency Ratio (SEER) of 14 or higher and have an Energy Efficiency Ratio (EER) (at a standard rating of 95 °F dry bulb outdoor temperature) not less than the following:

Product class	Energy efficiency ratio (EER)
(i) Split systems—air conditioners with rated cooling capacity less than 45,000 Btu/hr	12.2
(ii) Split systems—air conditioners with rated cooling capacity equal to or greater than 45,000 Btu/hr	11.7
(iii) Single-package units—air conditioners	11.0

(ii) Any outdoor unit model that has a certified combination with a rating below 14 SEER or the applicable EER cannot be installed in this region. The least-efficient combination of each basic model must comply with this standard.

(4) Each basic model of single-package central air conditioners and central air conditioning heat pumps and each individual combination of split-system central air conditioners and central air conditioning heat pumps manufactured on or after January 1, 2015, shall have an average off mode electrical power consumption not more than the following:

Product class	Average off mode power consumption $P_{W,OFF}$ (watts)
(i) Split-system air conditioners	30
(ii) Split-system heat pumps	33
(iii) Single-package air conditioners	30
(iv) Single-package heat pumps	33
(v) Small-duct, high-velocity systems	30
(vi) Space-constrained air conditioners	30
(vii) Space-constrained heat pumps	33

(5) Central air conditioners and central air conditioning heat pumps manufactured on or after January 1, 2023, must have a Seasonal Energy Efficiency Ratio 2 and a Heating Seasonal Performance Factor 2 not less than:

Product class	Seasonal energy efficiency ratio 2 (SEER2)	Heating seasonal performance factor 2 (HSPF2)
(i)(A) Split systems—air conditioners with a certified cooling capacity less than 45,000 Btu/hr	13.4	
(i)(B) Split systems—air conditioners with a certified cooling capacity equal to or greater than 45,000 Btu/hr	13.4	
(ii) Split systems—heat pumps	14.3	7.5
(iii) Single-package units—air conditioners	13.4	
(iv) Single-package units—heat pumps	13.4	6.7
(v) Small-duct, high-velocity systems	12	6.1
(vi)(A) Space-constrained products—air conditioners	11.7	
(vi)(B) Space-constrained products—heat pumps	11.9	6.3

(6)(i) In addition to meeting the applicable requirements in paragraph (c)(5) of this section, products in product classes (i) and (iii) of paragraph (c)(5) of this section (*i.e.*, split systems—air conditioners and single-package units—air conditioners) that are installed on or after January 1, 2023, in the southeast or southwest must have a Seasonal Energy Efficiency Ratio 2 and a Energy Efficiency Ratio 2 not less than:

Product class	Southeast *	Southwest **	
	SEER2	SEER2	EER2 ***
(i)(A) Split-systems—air conditioners with a certified cooling capacity less than 45,000 Btu/hr	14.3	14.3	11.7/9.8 †
(i)(B) Split-systems—air conditioners with a certified cooling capacity equal to or greater than 45,000 Btu/hr	13.8	13.8	11.2/9.8 ††
(iii) Single-package units—air conditioners	.....	.....	10.6

* ''Southeast'' includes the States of Alabama, Arkansas, Delaware, Florida, Georgia, Hawaii, Kentucky, Louisiana, Maryland, Mississippi, North Carolina, Oklahoma, Puerto Rico, South Carolina, Tennessee, Texas, Virginia, the District of Columbia, and the U.S. Territories.
** ''Southwest'' includes the States of Arizona, California, Nevada, and New Mexico.
*** EER refers to the energy efficiency ratio at a standard rating of 95 °F dry bulb outdoor temperature.
† The 11.7 EER2 standard applies to products with a certified SEER2 less than 15.2. The 9.8 EER2 standard applies to products with a certified SEER2 greater than or equal to 15.2.
†† The 11.2 EER2 standard applies to products with a certified SEER2 less than 15.2. The 9.8 EER2 standard applies to products with a certified SEER2 greater than or equal to 15.2.

(ii) Any model of outdoor unit that has a certified combination with a rating below the applicable standard level(s) for a region cannot be installed in that region. The least-efficient combination of each basic model, which for single-split-system air conditioner (AC) with single-stage or two-stage compressor (including space-constrained and small-duct high velocity systems (SDHV)) must be a coil-only combination, must comply with the applicable standard. See 10 CFR 429.16(a)(1) and (a)(4)(i).

(d) *Water Heaters.* (1) The uniform energy factor of water heaters manufactured May 6, 2029 shall not be less than the following:

Product class	Rated storage volume and input rating (*if applicable*)	Draw pattern	Uniform energy factor [1]
Gas-fired Storage Water Heater	≥20 gal and ≤55 gal	Very Small	$0.3456 - (0.0020 \times V_r)$
		Low	$0.5982 - (0.0019 \times V_r)$
		Medium	$0.6483 - (0.0017 \times V_r)$
		High	$0.6920 - (0.0013 \times V_r)$
	>55 gal and ≤100 gal	Very Small	$0.6470 - (0.0006 \times V_r)$
		Low	$0.7689 - (0.0005 \times V_r)$
		Medium	$0.7897 - (0.0004 \times V_r)$
		High	$0.8072 - (0.0003 \times V_r)$
Oil-fired Storage Water Heater	≤50 gal	Very Small	$0.2509 - (0.0012 \times V_r)$
		Low	$0.5330 - (0.0016 \times V_r)$
		Medium	$0.6078 - (0.0016 \times V_r)$
		High	$0.6815 - (0.0014 \times V_r)$
Electric Storage Water Heaters	≥20 gal and ≤55 gal	Very Small	$0.8808 - (0.0008 \times V_r)$
		Low	$0.9254 - (0.0003 \times V_r)$
		Medium	$0.9307 - (0.0002 \times V_r)$
		High	$0.9349 - (0.0001 \times V_r)$
	>55 gal and ≤120 gal	Very Small	$1.9236 - (0.0011 \times V_r)$
		Low	$2.0440 - (0.0011 \times V_r)$
		Medium	$2.1171 - (0.0011 \times V_r)$
		High	$2.2418 - (0.0011 \times V_r)$
Tabletop Water Heater	≥20 gal and ≤120 gal	Very Small	$0.6323 - (0.0058 \times V_r)$
		Low	$0.9188 - (0.0031 \times V_r)$
		Medium	$0.9577 - (0.0023 \times V_r)$
		High	$0.9884 - (0.0016 \times V_r)$
Instantaneous Gas-fired Water Heater.	<2 gal and >50,000 Btu/h	Very Small	0.80
		Low	0.81
		Medium	0.81
		High	0.81
Instantaneous Electric Water Heater.	<2 gal	Very Small	0.91
		Low	0.91
		Medium	0.91
		High	0.92
Grid-enabled Water Heater	>75 gal	Very Small	$1.0136 - (0.0028 \times V_r)$
		Low	$0.9984 - (0.0014 \times V_r)$
		Medium	$0.9853 - (0.0010 \times V_r)$
		High	$0.9720 - (0.0007 \times V_r)$

[1] V_r is the rated storage volume (in gallons), as determined pursuant to § 429.17 of this chapter.

(2) The uniform energy factor of water heaters manufactured on or after May 6, 2029 shall not be less than the following:

Product class	Rated storage volume and input rating (*if applicable*)	Draw pattern	Uniform energy factor [1]
Gas-fired Storage Water Heater	<20 gal	Very Small	$0.2062 - (0.0020 \times V_{eff})$
		Low	$0.4893 - (0.0027 \times V_{eff})$
		Medium	$0.5758 - (0.0023 \times V_{eff})$
		High	$0.6586 - (0.0020 \times V_{eff})$
	≥20 gal and ≤55 gal	Very Small	$0.3925 - (0.0020 \times V_{eff})$
		Low	$0.6451 - (0.0019 \times V_{eff})$
		Medium	$0.7046 - (0.0017 \times V_{eff})$
		High	$0.7424 - (0.0013 \times V_{eff})$
	>55 gal and ≤100 gal	Very Small	$0.6470 - (0.0006 \times V_{eff})$
		Low	$0.7689 - (0.0005 \times V_{eff})$
		Medium	$0.7897 - (0.0004 \times V_{eff})$
		High	$0.8072 - (0.0003 \times V_{eff})$
	>100 gal	Very Small	$0.1482 - (0.0007 \times V_{eff})$
		Low	$0.4342 - (0.0017 \times V_{eff})$
		Medium	$0.5596 - (0.0020 \times V_{eff})$
		High	$0.6658 - (0.0019 \times V_{eff})$
Oil-fired Storage Water Heater	≤50 gal	Very Small	$0.2909 - (0.0012 \times V_{eff})$
		Low	$0.5730 - (0.0016 \times V_{eff})$
		Medium	$0.6478 - (0.0016 \times V_{eff})$
		High	$0.7215 - (0.0014 \times V_{eff})$
	> 50 gal	Very Small	$0.1580 - (0.0009 \times V_{eff})$
		Low	$0.4390 - (0.0020 \times V_{eff})$
		Medium	$0.5389 - (0.0021 \times V_{eff})$
		High	$0.6172 - (0.0018 \times V_{eff})$
Very Small Electric Storage Water Heater.	< 20 gal	Very Small	$0.5925 - (0.0059 \times V_{eff})$
		Low	$0.8642 - (0.0030 \times V_{eff})$
		Medium	$0.9096 - (0.0020 \times V_{eff})$
		High	$0.9430 - (0.0012 \times V_{eff})$
Small Electric Storage Water Heater.	≥20 gal and ≤35 gal	Very Small	$0.8808 - (0.0008 \times V_{eff})$
		Low	$0.9254 - (0.0003 \times V_{eff})$
Electric Storage Water Heaters	>20 and ≤55 gal (excluding small electric storage water heaters).	Very Small	2.30
		Low	2.30
		Medium	2.30
		High	2.30
	>55 gal and ≤120 gal	Very Small	2.50
		Low	2.50
		Medium	2.50
		High	2.50
	>120 gal	Very Small	$0.3574 - (0.0012 \times V_{eff})$
		Low	$0.7897 - (0.0019 \times V_{eff})$
		Medium	$0.8884 - (0.0017 \times V_{eff})$
		High	$0.9575 - (0.0013 \times V_{eff})$
Tabletop Water Heater	<20 gal	Very Small	$0.5925 - (0.0059 \times V_{eff})$
		Low	$0.8642 - (0.0030 \times V_{eff})$
	≥20 gal	Very Small	$0.6323 - (0.0058 \times V_{eff})$
		Low	$0.9188 - (0.0031 \times V_{eff})$
Instantaneous Oil-fired Water Heater.	<2 gal and ≤210,000 Btu/h	Very Small	0.61
		Low	0.61
		Medium	0.61
		High	0.61
	≥2 gal and ≤210,000 Btu/h	Very Small	$0.2780 - (0.0022 \times V_{eff})$
		Low	$0.5151 - (0.0023 \times V_{eff})$
		Medium	$0.5687 - (0.0021 \times V_{eff})$
		High	$0.6147 - (0.0017 \times V_{eff})$
Instantaneous Electric Water Heater.	<2 gal	Very Small	0.91
		Low	0.91
		Medium	0.91
		High	0.92
	≥2 gal	Very Small	$0.8086 - (0.0050 \times V_{eff})$
		Low	$0.9123 - (0.0020 \times V_{eff})$
		Medium	$0.9252 - (0.0015 \times V_{eff})$
		High	$0.9350 - (0.0011 \times V_{eff})$
Grid-Enabled Water Heater	>75 gal	Very Small	$1.0136 - (0.0028 \times V_{eff})$
		Low	$0.9984 - (0.0014 \times V_{eff})$

Product class	Rated storage volume and input rating (*if applicable*)	Draw pattern	Uniform energy factor [1]
	.....	Medium	$0.9853 - (0.0010 \times V_{eff})$
	.....	High	$0.9720 - (0.0007 \times V_{eff})$

[1] V_{eff} is the Effective Storage Volume (in gallons), as determined pursuant to § 429.17 of this chapter.

(3) The provisions of paragraph (d) of this section are separate and severable from one another. Should a court of competent jurisdiction hold any provision(s) of paragraph (d) of this section to be stayed or invalid, such action shall not affect any other provision of paragraph (d) of this section.

(e) *Furnaces and boilers*—(1) *Furnaces.* (i) The Annual Fuel Utilization Efficiency (AFUE) of residential furnaces shall not be less than the following for non-weatherized gas furnaces manufactured before November 19, 2015, non-weatherized oil furnaces manufactured before May 1, 2013, and weatherized furnaces manufactured before January 1, 2015:

Product class	AFUE (percent) [1]
(A) Furnaces (excluding classes noted below)	78
(B) Mobile Home furnaces	75
(C) Small furnaces (other than those designed solely for installation in mobile homes) having an input rate of less than 45,000 Btu/hr.	
(*1*) Weatherized (outdoor)	78
(*2*) Non-weatherized (indoor)	78

[1] Annual Fuel Utilization Efficiency, as determined in § 430.23(n)(2) of this part.

(ii) The AFUE for non-weatherized gas furnaces (not including mobile home gas furnaces) manufactured on or after November 19, 2015, but before December 18, 2028; mobile home gas furnaces manufactured on or after November 19, 2015, but before December 18, 2028; non-weatherized oil-fired furnaces (not including mobile home furnaces) manufactured on or after May 1, 2013, mobile home oil-fired furnaces manufactured on or after September 1, 1990; weatherized gas-fired furnaces manufactured on or after January 1, 2015; weatherized oil-fired furnaces manufactured on or after January 1, 1992; and electric furnaces manufactured on or after January 1, 1992; shall not be less than the following:

Product class	AFUE (percent) [1]
(A) Non-weatherized gas furnaces (not including mobile home furnaces)	80.0
(B) Mobile home gas furnaces	80.0
(C) Non-weatherized oil-fired furnaces (not including mobile home furnaces)	83.0
(D) Mobile home oil-fired furnaces	75.0
(E) Weatherized gas furnaces	81.0
(F) Weatherized oil-fired furnaces	78.0
(G) Electric furnaces	78.0

[1] Annual Fuel Utilization Efficiency, as determined in § 430.23(n)(2).

(iii) The AFUE for non-weatherized gas (not including mobile home gas furnaces) manufactured on and after December 18, 2028; and mobile home gas furnaces manufactured on and after December 18, 2028, shall not be less than the following:

Product class	AFUE (percent) [1]
(A) Non-weatherized gas furnaces (not including mobile home gas furnaces)	95.0

Product class	AFUE (percent) [1]
(B) Mobile home gas furnaces	95.0

[1] Annual Fuel Utilization Efficiency, as determined in § 430.23(n)(2).

(iv) Furnaces manufactured on or after May 1, 2013, shall have an electrical standby mode power consumption ($P_{W,SB}$) and electrical off mode power consumption ($P_{W,OFF}$) not more than the following:

Product class	Maximum standby mode electrical power consumption, $P_{W,SB}$ (watts)	Maximum off mode electrical power consumption, $P_{W,OFF}$ (watts)
(A) Non-weatherized oil-fired furnaces (including mobile home furnaces)	11	11
(B) Electric furnaces	10	10

(2) *Boilers.* (i) The AFUE of residential boilers manufactured before September 1, 2012, shall not be less than the following:

Product class	AFUE [1] (percent)
(A) Boilers (excluding gas steam)	80
(B) Gas steam boilers	75

[1] Annual Fuel Utilization Efficiency, as determined in § 430.22(n)(2) of this part.

(ii) Except as provided in paragraph (e)(2)(iv) of this section, the AFUE of residential boilers, manufactured on or after September 1, 2012, and before January 15, 2021, shall not be less than the following and must comply with the design requirements as follows:

Product class	AFUE [1] (percent)	Design requirements
(A) Gas-fired hot water boiler.	82	Constant burning pilot not permitted. Automatic means for adjusting water temperature required (except for boilers equipped with tankless domestic water heating coils).
(B) Gas-fired steam boiler.	80	Constant burning pilot not permitted.
(C) Oil-fired hot water boiler.	84	Automatic means for adjusting temperature required (except for boilers equipped with tankless domestic water heating coils).
(D) Oil-fired steam boiler.	82	None.
(E) Electric hot water boiler.	None	Automatic means for adjusting temperature required (except for boilers equipped with tankless domestic water heating coils).

[1] Annual Fuel Utilization Efficiency, as determined in § 430.22(n)(2) of this part.

(iii)(A) Except as provided in paragraph (e)(2)(v) of this section, the AFUE of residential boilers, manufactured on and after January 15, 2021, shall not be less than the following and must comply with the design requirements as follows:

Product class	AFUE [1] (percent)	Design requirements
(*1*) Gas-fired hot water boiler	84	Constant-burning pilot not permitted. Automatic means for adjusting water temperature required (except for boilers equipped with tankless domestic water heating coils).
(*2*) Gas-fired steam boiler	82	Constant-burning pilot not permitted.
(*3*) Oil-fired hot water boiler	86	Automatic means for adjusting temperature required (except for boilers equipped with tankless domestic water heating coils).
(*4*) Oil-fired steam boiler	85	None.
(*5*) Electric hot water boiler	None	Automatic means for adjusting temperature required (except for boilers equipped with tankless domestic water heating coils).
(*6*) Electric steam boiler	None	None.

[1] Annual Fuel Utilization Efficiency, as determined in § 430.23(n)(2) of this part.

(B) Except as provided in paragraph (e)(2)(v) of this section, the standby mode power consumption ($P_{W,SB}$) and off mode power consumption ($P_{W,OFF}$) of

residential boilers, manufactured on and after January 15, 2021, shall not be more than the following:

Product class	$P_{W,SB}$ (watts)	$P_{W,OFF}$ (watts)
(*1*) Gas-fired hot water boiler	9	9
(*2*) Gas-fired steam boiler	8	8
(*3*) Oil-fired hot water boiler	11	11
(*4*) Oil-fired steam boiler	11	11
(*5*) Electric hot water boiler	8	8
(*6*) Electric steam boiler	8	8

(iv) *Automatic means for adjusting water temperature.* (A) The automatic means for adjusting water temperature as required under paragraph (e)(2)(ii) of this section must automatically adjust the temperature of the water supplied by the boiler to ensure that an incremental change in inferred heat load produces a corresponding incremental change in the temperature of water supplied.

(B) For boilers that fire at a single input rate, the automatic means for adjusting water temperature requirement may be satisfied by providing an automatic means that allows the burner or heating element to fire only when the means has determined that the inferred heat load cannot be met by the residual heat of the water in the system.

(C) When there is no inferred heat load with respect to a hot water boiler, the automatic means described in this paragraph shall limit the temperature of the water in the boiler to not more than 140 degrees Fahrenheit.

(D) A boiler for which an automatic means for adjusting water temperature is required shall be operable only when the automatic means is installed.

(v) A boiler that is manufactured to operate without any need for electricity or any electric connection, electric gauges, electric pumps, electric wires, or electric devices is not required to meet the AFUE or design requirements applicable to the boiler requirements of paragraph (e)(2)(ii) of this section, but must meet the requirements of paragraph (e)(2)(i) of this section, as applicable.

(f) *Dishwashers.* (1) All dishwashers manufactured on or after May 30, 2013, shall meet the following standard—

(i) Standard size dishwashers shall not exceed 307 kwh/year and 5.0 gallons per cycle. Standard size dishwashers have a capacity equal to or greater than eight place settings plus six serving pieces as specified in AHAM DW–1–2020 (incorporated by reference, see § 430.3) using the test load specified in section 2.3 of appendix C1 or section 2.4 of appendix C2 to subpart B of this part, as applicable.

(ii) Compact size dishwashers shall not exceed 222 kwh/year and 3.5 gallons per cycle. Compact size dishwashers have a capacity less than eight place settings plus six serving pieces as specified in AHAM DW–1–2020 (incorporated by reference, see § 430.3) using the test load specified in section 2.3 of appendix C1 or section 2.4 of appendix C2 to subpart B of this part, as applicable.

(2) All dishwashers manufactured on or after April 23, 2027, shall not exceed the following standard—

Product class	Estimated annual energy use (kWh/year)	Maximum per-cycle water consumption (gal/cycle)
(i) Standard-size [1] (≥8 place settings plus 6 serving pieces) [2]	223	3.3
(ii) Compact-size (<8 place settings plus 6 serving pieces) [2]	174	3.1

[1] The energy conservation standards in this table do not apply to standard-size dishwashers with a cycle time for the normal cycle of 60 minutes or less.

[2] Place settings are as specified in AHAM DW–1–2020 (incorporated by reference, see § 430.3) and the test load is as specified in section 2.4 of appendix C2 to subpart B of this part.

(3) The provisions of paragraph (f)(2) of this section are separate and severable from one another. Should a court of competent jurisdiction hold any provision(s) of this section to be stayed or invalid, such action shall not affect any other provision of this section.

(g) *Clothes washers.* (1) Clothes washers manufactured on or after January

1, 2018, shall have an Integrated Modified Energy Factor no less than, and an Integrated Water Factor no greater than:

Product class	Integrated modified energy factor (cu.ft./kWh/cycle)	Integrated water factor (gal/cycle/cu.ft.)
(i) Top-loading, Compact (less than 1.6 ft^3 capacity)	1.15	12.0
(ii) Top-loading, Standard (1.6 ft^3 or greater capacity)	1.57	6.5
(iii) Front-loading, Compact (less than 1.6 ft^3 capacity)	1.13	8.3
(iv) Front-loading, Standard (1.6 ft^3 or greater capacity)	1.84	4.7

(2) Clothes washers manufactured on or after March 1, 2028:

(i) Shall have an Energy Efficiency Ratio and a Water Efficiency Ratio no less than:

Product class	Energy efficiency ratio (lb/kWh/cycle)	Water efficiency ratio (lb/gal/cycle)
(A) Automatic Clothes Washers:.		
(*1*) Top-Loading Ultra-Compact (less than 1.6 ft^3 capacity)	3.79	0.29
(*2*) Top-Loading Standard-Size (1.6 ft^3 or greater capacity) [1]	4.27	0.57
(*3*) Front-Loading Compact (less than 3.0 ft^3 capacity) [2]	5.02	0.71
(*4*) Front-Loading Standard-Size (3.0 ft^3 or greater capacity) [3]	5.52	0.77
(B) Semi-Automatic Clothes Washers	2.12	0.27

[1] The energy conservation standards in this table do not apply to top-loading standard-size clothes washers with an average cycle time less than 30 minutes.
[2] The energy conservation standards in this table do not apply to front-loading clothes washers with a capacity greater than or equal to 1.6 ft^3 and less than 3.0 ft^3 with an average cycle time of less than 45 minutes.
[3] The energy conservation standards in this table do not apply to front-loading standard-size clothes washers with an average cycle time less than 45 minutes.

(ii) The provisions of this paragraph (g)(2) are separate and severable from one another. Should a court of competent jurisdiction hold any provision(s) of this section to be stayed or invalid, such action shall not affect any other provisions of this section.

(h) *Clothes dryers.* (1) Gas clothes dryers manufactured after January 1, 1988 shall not be equipped with a constant burning pilot.

(2) Clothes dryers manufactured on or after May 14, 1994 and before January 1, 2015, shall have an energy factor no less than:

Product class	Energy factor (lbs/kWh)
i. Electric, Standard (4.4 ft^3 or greater capacity)	3.01
ii. Electric, Compact (120V) (less than 4.4 ft^3 capacity)	3.13
iii. Electric, Compact (240V) (less than 4.4 ft^3 capacity)	2.90
iv. Gas	2.67

(3) Clothes dryers manufactured on or after January 1, 2015, shall have a combined energy factor no less than:

Product class	Combined energy factor (lbs/kWh)
(i) Vented Electric, Standard (4.4 ft^3 or greater capacity)	3.73
(ii) Vented Electric, Compact (120V) (less than 4.4 ft^3 capacity)	3.61
(iii) Vented Electric, Compact (240V) (less than 4.4 ft^3 capacity)	3.27
(iv) Vented Gas	3.30
(v) Ventless Electric, Compact (240V) (less than 4.4 ft^3 capacity)	2.55
(vi) Ventless Electric, Combination Washer-Dryer	2.08

(4) Clothes dryers manufactured on or after March 1, 2028, shall have a combined energy factor, determined in accordance with appendix D2 of this subpart, no less than:

Product class	CEF_{D2} (lb/kWh)
(i) Electric, Standard (4.4 ft^3 or greater capacity)*	3.93
(ii) Electric, Compact (120V) (less than 4.4 ft^3 capacity)	4.33
(iii) Vented Electric, Compact (240V) (less than 4.4 ft^3 capacity)	3.57
(iv) Vented Gas, Standard (4.4 ft^3 or greater capacity)**	3.48
(v) Vented Gas, Compact (less than 4.4 ft^3 capacity)	2.02
(vi) Ventless Electric, Compact (240V) (less than 4.4 ft^3 capacity)	2.68
(vii) Ventless Electric, Combination Washer-Dryer	2.33

*The energy conservation standards in this product class do not apply to Vented Electric, Standard clothes dryers with a cycle time of less than 30 minutes, when tested according to appendix D2 in subpart B of this part.

**The energy conservation standards in this product class do not apply to Vented Gas, Standard clothes dryers with a cycle time of less than 30 minutes, when tested according to appendix D2 in subpart B of this part.

(i) *Direct heating equipment.* (1) Vented home heating equipment manufactured on or after January 1, 1990 and before April 16, 2013, shall have an annual fuel utilization efficiency no less than:

Product class	Annual fuel utilization efficiency, Jan. 1, 1990 (percent)
1. Gas wall fan type up to 42,000 Btu/h	73
2. Gas wall fan type over 42,000 Btu/h	74
3. Gas wall gravity type up to 10,000 Btu/h	59
4. Gas wall gravity type over 10,000 Btu/h up to 12, 000 Btu/h	60
5. Gas wall gravity type over 12,000 Btu/h up to 15,000 Btu/h	61
6. Gas wall gravity type over 15,000 Btu/h up to 19,000 Btu/h	62
7. Gas wall gravity type over 19,000 Btu/h and up to 27,000 Btu/h	63
8. Gas wall gravity type over 27,000 Btu/h and up to 46,000 Btu/h	64
9. Gas wall gravity type over 46,000 Btu/h	65
10. Gas floor up to 37,000 Btu/h	56
11. Gas floor over 37,000 Btu/h	57
12. Gas room up to 18,000 Btu/h	57
13. Gas room over 18,000 Btu/h up to 20,000 Btu/h	58
14. Gas room over 20,000 Btu/h up to 27,000 Btu/h	63
15. Gas room over 27,000 Btu/h up to 46,000 Btu/h	64
16. Gas room over 46,000 Btu/h	65

(2) Vented home heating equipment manufactured on or after April 16, 2013, shall have an annual fuel utilization efficiency no less than:

Product class	Annual fuel utilization efficiency, April 16, 2013 (percent)
Gas wall fan type up to 42,000 Btu/h	75
Gas wall fan type over 42,000 Btu/h	76
Gas wall gravity type up to 27,000 Btu/h	65
Gas wall gravity type over 27,000 Btu/h up to 46,000 Btu/h	66
Gas wall gravity type over 46,000 Btu/h	67
Gas floor up to 37,000 Btu/h	57
Gas floor over 37,000 Btu/h	58
Gas room up to 20,000 Btu/h	61
Gas room over 20,000 Btu/h up to 27,000 Btu/h	66
Gas room over 27,000 Btu/h up to 46,000 Btu/h	67
Gas room over 46,000 Btu/h	68

(j) *Cooking Products* (1) *Conventional cooking tops.* (i) Gas cooking tops, other than gas portable indoor conventional cooking tops, manufactured on or after April 9, 2012, and before January 31, 2028, shall not be equipped with a constant burning pilot light.

(ii) Gas portable indoor conventional cooking tops, manufactured on or after April 9, 2012, shall not be equipped with a constant burning pilot light.

(iii) Conventional cooking tops, other than portable indoor conventional cooking tops, manufactured on or after

January 31, 2028, shall have an integrated annual energy consumption (IAEC), excluding any downdraft venting system energy consumption, no greater than:

Product class	Maximum integrated annual energy consumption (IAEC)
(A) Electric Smooth Element Standalone Cooking Tops	207 kWh/year.
(B) Electric Smooth Element Cooking Top Component of Combined Cooking Products	207 kWh/year.
(C) Gas Standalone Cooking Tops	1,770 kBtu/year.
(D) Gas Cooking Top Component of Combined Cooking Products	1,770 kBtu/year.

(2) *Conventional ovens.* The control system of a conventional oven shall:

(i) Not be equipped with a constant burning pilot light, for gas ovens manufactured on or after April 9, 2012; and

(ii) Not be equipped with a linear power supply, for electric and gas ovens manufactured on or after January 31, 2028.

(3) *Microwave ovens.*

(i) Microwave-only ovens and countertop convection microwave ovens manufactured on or after June 17, 2016, and before June 22, 2026, shall have an average standby power not more than 1.0 watt. Built-in and over-the-range convection microwave ovens manufactured on or after June 17, 2016, and before June 22, 2026, shall have an average standby power not more than 2.2 watts.

(ii) Microwave-only ovens and countertop convection microwave ovens manufactured on or after June 22, 2026, shall have an average standby power not more than 0.6 watts. Built-in and over-the-range convection microwave ovens manufactured on or after June 22, 2026, shall have an average standby power not more than 1.0 watt.

(k) *Pool heaters.* (1) Gas-fired pool heaters manufactured on and after April 16, 2013 and before May 30, 2028, shall have a thermal efficiency not less than 82%.

(2) Gas-fired pool heaters and electric pool heaters manufactured on and after May 30, 2028, shall have an integrated thermal efficiency not less than the following:

Product Class	Integrated Thermal Efficiency (percent)
Gas-fired Pool Heater	$\frac{84(Q_{IN}+491)}{Q_{IN}+2,536}$
Electric Pool Heater	$\frac{600PE}{PE+1,619}$

where Q_{IN} is the certified input capacity of a gas-fired pool heater basic model, in Btu/h, and PE is the certified active electrical power of an electric pool heater, in Btu/h.

(l) *Television sets.* [Reserved]

(m) *Fluorescent lamp ballasts*—(1) *Standards for fluorescent lamp ballasts (other than dimming ballasts).* Except as provided in paragraphs (m)(2) and (3) of this section, each fluorescent lamp ballast manufactured on or after November 14, 2014,

(i) Designed and marketed—

(A) To operate at nominal input voltages at or between 120 and 277 volts;

(B) To operate with an input current frequency of 60 Hertz; and

(C) For use in connection with fluorescent lamps (as defined in § 430.2)

(ii) Must have—

(A) A power factor of:

(*1*) 0.9 or greater for ballasts that are not residential ballasts; or

(*2*) 0.5 or greater for residential ballasts; and

(B) A ballast luminous efficiency not less than the following:

BLE = A/(1 + B × average total lamp arc power ^ −C) Where A, B, and C are as follows:			
Description	A	B	C
Instant start and rapid start ballasts (not classified as residential ballasts) that are designed and marketed to operate: 4-foot medium bipin lamps; 2-foot U-shaped lamps; or 8-foot slimline lamps.	0.993	0.27	0.25
Programmed start ballasts (not classified as residential ballasts) that are designed and marketed to operate: 4-foot medium bipin lamps; 2-foot U-shaped lamps; 4-foot miniature bipin standard output lamps; or 4-foot miniature bipin high output lamps.	0.993	0.51	0.37
Instant start and rapid start ballasts (not classified as sign ballasts) that are designed and marketed to operate 8-foot high output lamps	0.993	0.38	0.25
Programmed start ballasts (not classified as sign ballasts) that are designed and marketed to operate 8-foot high output lamps	0.973	0.70	0.37
Sign ballasts that are designed and marketed to operate 8-foot high output lamps	0.993	0.47	0.25
Instant start and rapid start residential ballasts that are designed and marketed to operate: 4-foot medium bipin lamps; 2-foot U-shaped lamps; or 8-foot slimline lamps.	0.993	0.41	0.25
Programmed start residential ballasts that are designed and marketed to operate: 4-foot medium bipin lamps or 2-foot U-shaped lamps.	0.973	0.71	0.37

(2) *Standards for certain dimming ballasts.* Except as provided in paragraph (m)(3) of this section, each dimming ballast manufactured on or after November 14, 2014; designed and marketed to operate one F34T12, two F34T12, two F96T12/ES, or two F96T12HO/ES lamps; and

(i) Designed and marketed—

(A) To operate at nominal input voltages at or between 120 and 277 volts;

(B) To operate with an input current frequency of 60 Hertz; and

(C) For use in connection with fluorescent lamps (as defined in § 430.2)

(ii) Must have—

(A) A power factor of:

(*1*) 0.9 or greater for ballasts that are not residential ballasts; or

(*2*) 0.5 or greater for residential ballasts; and

(B) A ballast luminous efficiency not less than the following:

Designed and marketed for operation of a maximum of	Nominal input voltage	Total nominal lamp watts	Ballast luminous efficiency	
			Low frequency ballasts	High frequency ballasts
One F34T12 lamp	120/277	34	0.777	0.778
Two F34T12 lamps	120/277	68	0.804	0.805
Two F96T12/ES lamps	120/277	120	0.876	0.884
Two F96T12HO/ES lamps	120/277	190	0.711	0.713

(3) *Exemptions.* The power factor and ballast luminous efficiency standards described in paragraph (m)(1)(ii) and (m)(2)(ii) of this section do not apply to:

(i) A dimming ballast designed and marketed to operate exclusively lamp types other than one F34T12, two F34T12, two F96T12/ES, or two F96T12HO/ES lamps;

(ii) A low frequency ballast that is designed and marketed to operate T8 diameter lamps; is designed and marketed for use in electromagnetic-interference-sensitive-environments only; and is shipped by the manufacturer in packages containing 10 or fewer ballasts; or

(iii) A programmed start ballast that operates 4-foot medium bipin T8 lamps and delivers on average less than 140 milliamperes to each lamp.

(4) For the purposes of this paragraph (m), the definitions found in appendix Q of subpart B of this part apply.

(n) *General service fluorescent lamps and incandescent reflector lamps.* (1) Each of the following general service

fluorescent lamps manufactured after the effective dates specified in the table must meet or exceed the following color rendering index standards:

Lamp type	Nominal lamp watts *	Minimum color rendering index	Effective date
(i) 4-foot medium bipin	>35 W	69	Nov. 1, 1995.
	≤35 W	45	Nov. 1, 1995.
(ii) 2-foot U-shaped	>35 W	69	Nov. 1, 1995.
	≤35 W	45	Nov. 1, 1995.
(iii) 8-foot slimline	>65 W	69	May 1, 1994.
	≤65 W	45	May 1, 1994.
(iv) 8-foot high output	>100 W	69	May 1, 1994.
	≤100 W	45	May 1, 1994.

* Nominal lamp watts means the wattage at which a fluorescent lamp is designed to operate. 42 U.S.C. 6291(29)(H)

(2) The standards described in paragraph (n)(1) of this section do not apply to:

(i) Any 4-foot medium bipin lamp or 2-foot U-shaped lamp with a rated wattage less than 28 watts;

(ii) Any 8-foot high output lamp not defined in ANSI C78.81–2010 (incorporated by reference; see § 430.3) or related supplements, or not 0.800 nominal amperes; or

(iii) Any 8-foot slimline lamp not defined in ANSI C78.3 (incorporated by reference; see § 430.3).

(3) Each of the following general service fluorescent lamps manufactured on or after January 26, 2018, must meet or exceed the following lamp efficacy standards shown in the table:

Lamp type	Correlated color temperature	Minimum average lamp efficacy lm/W
(i) 4-foot medium bipin lamps (straight-shaped lamp with medium bipin base, nominal overall length of 48 inches, and rated wattage of 25 or more).	≤4,500K	92.4
	>4,500K and ≤7,000K	88.7
(ii) 2-foot U-shaped lamps (U-shaped lamp with medium bipin base, nominal overall length between 22 and 25 inches, and rated wattage of 25 or more).	≤4,500K	85.0
	>4,500K and ≤7,000K	83.3
(iii) 8-foot slimline lamps (instant start lamp with single pin base, nominal overall length of 96 inches, and rated wattage of 49 or more).	≤4,500K	97.0
	>4,500K and ≤7,000K	93.0
(iv) 8-foot high output lamps (rapid start lamp with recessed double contact base, nominal overall length of 96 inches).	≤4,500K	92.0
	>4,500K and ≤7,000K	88.0
(v) 4-foot miniature bipin standard output lamps (straight-shaped lamp with miniature bipin base, nominal overall length between 45 and 48 inches, and rated wattage of 25 or more).	≤4,500K	95.0
	>4,500K and ≤7,000K	89.3
(vi) 4-foot miniature bipin high output lamps (straight-shaped lamp with miniature bipin base, nominal overall length between 45 and 48 inches, and rated wattage of 44 or more).	≤4,500K	82.7
	>4,500K and ≤7,000K	76.9

NOTE 1 TO PARAGRAPH (n)(3): For paragraphs (n)(3)(i) through (vi), rated wattage is defined with respect to fluorescent lamps and general service fluorescent lamps in § 430.2.

(4) Subject to the sales prohibition in paragraph (dd) of this section, each of the following incandescent reflector lamps manufactured after July 14, 2012, must meet or exceed the lamp efficacy standards shown in the table:

Rated wattage	Lamp spectrum	Lamp diameter inches	Rated voltage of lamp	Minimum average lamp efficacy lm/W
(i) 40–205	Standard Spectrum	>2.5	≥125 V	$6.8*P^{0.27}$
			<125 V	$5.9*P^{0.27}$
		≤2.5	≥125 V	$5.7*P^{0.27}$
			<125 V	$5.0*P^{0.27}$
(ii) 40–205	Modified Spectrum	>2.5	≥125 V	$5.8*P^{0.27}$
			<125 V	$5.0*P^{0.27}$

Rated wattage	Lamp spectrum	Lamp diameter inches	Rated voltage of lamp	Minimum average lamp efficacy lm/W
		≤2.5	≥125 V <125 V	$4.9*P^{0.27}$ $4.2*P^{0.27}$

NOTE 2 TO PARAGRAPH (n)(4): P is equal to the rated wattage, in watts. Rated wattage is defined with respect to incandescent reflector lamps in § 430.2.

NOTE 3 TO PARAGRAPH (n)(4): Standard Spectrum means any incandescent reflector lamp that does not meet the definition of modified spectrum in § 430.2.

(5) The standards specified in this section do not apply to the following types of incandescent reflector lamps:

(i) Lamps rated at 50 watts or less that are ER30, BR30, BR40, or ER40 lamps;

(ii) Lamps rated at 65 watts that are BR30, BR40, or ER40 lamps; or

(iii) R20 incandescent reflector lamps rated 45 watts or less.

(o) *Faucets.* The maximum water use allowed for any of the following faucets manufactured after January 1, 1994, when measured at a flowing water pressure of 60 pounds per square inch (414 kilopascals), shall be as follows:

Faucet type	Maximum flow rate (gpm (L/min)) or (gal/cycle (L/cycle))
Lavatory faucets	2.2 gpm (8.3 L/min) [1] [2]
Lavatory replacement aerators.	2.2 gpm (8.3 L/min)
Kitchen faucets	2.2 gpm (8.3 L/min)
Kitchen replacement aerators.	2.2 gpm (8.3 L/min)
Metering faucets	0.25 gal/cycle (0.95 L/cycle) [3] [4]

NOTE:

[1] Sprayheads with independently-controlled orifices and manual controls.

The maximum flow rate of each orifice that manually turns on or off shall not exceed the maximum flow rate for a lavatory faucet.

[2] Sprayheads with collectively controlled orifices and manual controls.

The maximum flow rate of a sprayhead that manually turns on or off shall be the product of (a) the maximum flow rate for a lavatory faucet and (b) the number of component lavatories (rim space of the lavatory in inches (millimeters) divided by 20 inches (508 millimeters)).

[3] Sprayheads with independently controlled orifices and metered controls.

The maximum flow rate of each orifice that delivers a preset volume of water before gradually shutting itself off shall not exceed the maximum flow rate for a metering faucet.

[4] Sprayheads with collectively-controlled orifices and metered controls.

The maximum flow rate of a sprayhead that delivers a preset volume of water before gradually shutting itself off shall be the product of (a) the maximum flow rate for a metering faucet and (b) the number of component lavatories (rim space of the lavatory in inches (millimeters) divided by 20 inches (508 millimeters)).

(p) *Showerheads.* The maximum water use allowed for any showerheads manufactured after January 1, 1994, shall be 2.5 gallons per minute (9.5 liters per minute) when measured at a flowing pressure of 80 pounds per square inch gage (552 kilopascals). When used as a component of any such showerhead, the flow-restricting insert shall be mechanically retained at the point of manufacture such that a force of 8.0 pounds force (36 Newtons) or more is required to remove the flow-restricting insert, except that this requirement shall not apply to showerheads for which removal of the flow-restricting insert would cause water to leak significantly from areas other than the spray face.

(q) *Water closets.* The maximum water use allowed in gallons per flush for any of the following water closets is as follows:

Water closet type	Maximum flush rate (gpf (Lpf))	
	Manufactured after January 1, 1994	Manufactured after January 1, 1997
(1) Gravity flush tank water closet	1.6 (6.0)	1.6 (6.0)
(2) Flushometer tank water closet	1.6 (6.0)	1.6 (6.0)
(3) Electromechanical hydraulic water closet	1.6 (6.0)	1.6 (6.0)
(4) Blowout bowl water closet	3.5 (13.2)	3.5 (13.2)
(5) Flushometer valve water closets, other than those with blowout bowls	.....	1.6 (6.0)

(r) *Urinals.* The maximum water use allowed for any urinals manufactured after January 1, 1994, shall be 1.0 gallons per flush (3.8 liters per flush). The

maximum water use allowed for a trough-type urinal shall be the product of:

(1) The maximum flow rate for a urinal and

(2) The length of the trough-type urinal in inches (millimeter) divided by 16 inches (406 millimeters).

(s) *Ceiling fans and ceiling fan light kits.* (1) All ceiling fans manufactured on or after January 1, 2007, shall have the following features:

(i) Fan speed controls separate from any lighting controls;

(ii) Adjustable speed controls (either more than 1 speed or variable speed);

(iii) The capability of reversible fan action, except for—

(A) Fans sold for industrial applications;

(B) Fans sold for outdoor applications; and

(C) Cases in which safety standards would be violated by the use of the reversible mode.

(2)(i) Ceiling fans manufactured on or after January 21, 2020, shall meet the requirements shows in the table:

Product class as defined in Appendix U	Minimum efficiency (CFM/W) [1]
Very small-diameter (VSD)	D ≤ 12 in.: 21. D > 12 in.: 3.16 D–17.04.
Standard	0.65 D + 38.03.
Hugger	0.29 D + 34.46.
High-speed small-diameter (HSSD).	4.16 D + 0.02.

[1] D is the ceiling fan's blade span, in inches, as determined in Appendix U of this part.

(ii) Large-diameter ceiling fans, as defined in appendix U to subpart B of this part, manufactured on or after January 21, 2020, shall have a CFEI greater than or equal to –

(A) 1.00 at high speed; and

(B) 1.31 at 40 percent speed or the nearest speed that is not less than 40 percent speed.

(iii) The provisions in this appendix apply to ceiling fans except:

(A) Ceiling fans where the plane of rotation of a ceiling fan's blades is not less than or equal to 45 degrees from horizontal, or cannot be adjusted based on the manufacturer's specifications to be less than or equal to 45 degrees from horizontal;

(B) Centrifugal ceiling fans, as defined in Appendix U of this part;

(C) Belt-driven ceiling fans, as defined in Appendix U of this part;

(D) Oscillating ceiling fans, as defined in Appendix U of this part; and

(E) Highly-decorative ceiling fans, as defined in Appendix U of this part.

(3) Ceiling fan light kits manufactured on or after January 1, 2007, and prior to January 21, 2020, with medium screw base sockets must be packaged with medium screw base lamps to fill all sockets. These medium screw base lamps must—

(i) Be compact fluorescent lamps that meet or exceed the following requirements or be as described in paragraph (s)(3)(ii) of this section:

Factor	Requirements
Rated Wattage (Watts) & Configuration [1].	Minimum Initial Lamp Efficacy (lumens per watt) [2]
Bare Lamp:	
Lamp Power <15 ..	45.0
Lamp Power ≥15 ..	60.0
Covered Lamp (no reflector):	
Lamp Power <15 ..	40.0
15≤Lamp Power <19.	48.0
19≤Lamp Power <25.	50.0
Lamp Power ≥25 ..	55.0
With Reflector:	
Lamp Power <20 ..	33.0
Lamp Power ≥20 ..	40.0
Lumen Maintenance at 1,000 hours.	≥ 90.0%
Lumen Maintenance at 40 Percent of Lifetime.	≥ 80.0%
Rapid Cycle Stress Test.	Each lamp must be cycled once for every 2 hours of lifetime. At least 5 lamps must meet or exceed the minimum number of cycles.
Lifetime	≥ 6,000 hours for the sample of lamps.

[1] Use rated wattage to determine the appropriate minimum efficacy requirements in this table.

[2] Calculate efficacy using measured wattage, rather than rated wattage, and measured lumens to determine product compliance. Wattage and lumen values indicated on products or packaging may not be used in calculation.

(ii) Be light sources other than compact fluorescent lamps that have lumens per watt performance at least equivalent to comparably configured compact fluorescent lamps meeting the energy conservation standards in paragraph (s)(3)(i) of this section.

(4) Ceiling fan light kits manufactured on or after January 1, 2007, and prior January 21, 2020, with pin-based sockets for fluorescent lamps must use an electronic ballast and be packaged

with lamps to fill all sockets. These lamp ballast platforms must meet the following requirements:

Factor	Requirement
System Efficacy Per Lamp Ballast Platform in Lumens Per Watt (lm/w).	≥50 lm/w for all lamps below 30 total listed lamp watts.
	≥60 lm/w for all lamps that are ≤ 24 inches and ≥30 total listed lamp watts.
	≥70 lm/w for all lamps that are > 24 inches and ≥30 total listed lamp watts.

(5) Ceiling fan light kits manufactured on or after January 1, 2009, and prior to January 21, 2020, with socket types other than those covered in paragraph (s)(3) or (4) of this section, including candelabra screw base sockets, must be packaged with lamps to fill all sockets and must not be capable of operating with lamps that total more than 190 watts.

(6) Ceiling fan light kits manufactured on or after January 21, 2020 must be packaged with lamps to fill all sockets, and each basic model of lamp packaged with the basic model of CFLK, each basic model of consumer-replaceable SSL packaged with the basic model of CFLK, and each basic model of non-consumer-replaceable SSL in the CFLK basic model shall meet the requirements shown in paragraphs (s)(6)(i) and (ii) of this section:

Lumens [1]	Minimum required efficacy (lm/W)
(i) <120	50.
(ii) ≥120	$(74.0 - 29.42 \times 0.9983^{lumens})$.

[1] Use the lumen output for each basic model of lamp packaged with the basic model of CFLK, each basic model of consumer-replaceable SSL packaged with the basic model of CFLK, or each basic model of non-consumer-replaceable SSL in the CFLK basic model to determine the applicable standard.

(i) Ceiling fan light kits with medium screw base sockets manufactured on or after January 21, 2020 and packaged with compact fluorescent lamps must include lamps that also meet the following requirements:

Lumen Maintenance at 1,000 hours	≥90.0%.
Lumen Maintenance at 40 Percent of Lifetime	≥80.0%.
Rapid Cycle Stress Test	Each lamp must be cycled once for every 2 hours of lifetime of compact fluorescent lamp as defined in § 430.2. At least 5 lamps must meet or exceed the minimum number of cycles.
Lifetime	≥6,000 hours for the sample of lamps.

(ii) Ceiling fan light kits with pin based sockets for fluorescent lamps, manufactured on or after January 21, 2020, must also use an electronic ballast.

(t) *Torchieres.* A torchiere manufactured on or after January 1, 2006 shall:

(1) Consume not more than 190 watts of power; and

(2) Not be capable of operating with lamps that total more than 190 watts.

(u) [Reserved]

(v) *Dehumidifiers.* (1) Dehumidifiers manufactured on or after October 1, 2012, shall have an energy factor that meets or exceeds the following values:

Product capacity (pints/day)	Minimum energy factor (liters/kWh)
Up to 35.00	1.35
35.01–45.00	1.50
45.01–54.00	1.60
54.01–75.00	1.70
75.01 or more	2.5

(2) Dehumidifiers manufactured on or after June 13, 2019, shall have an integrated energy factor that meets or exceeds the following values:

Portable dehumidifier product capacity (pints/day)	Minimum integrated energy factor (liters/kWh)
25.00 or less	1.30
25.01–50.00	1.60
50.01 or more	2.80

Portable dehumidifier product capacity (pints/day)	Minimum integrated energy factor (liters/kWh)
Whole-home dehumidifier product case volume (cubic feet)	
8.0 or less	1.77
More than 8.0	2.41

(w) *External power supplies.* (1)(i) Except as provided in paragraphs (w)(2) and (5) of this section, all class A external power supplies manufactured on or after July 1, 2008, shall meet the following standards:

Active mode	
Nameplate output	Required efficiency (decimal equivalent of a percentage)
Less than 1 watt	0.5 times the Nameplate output.
From 1 watt to not more than 51 watts	The sum of 0.09 times the Natural Logarithm of the Nameplate Output and 0.5.
Greater than 51 watts	0.85.
No-load mode	
Nameplate output	Maximum consumption
Not more than 250 watts	0.5 watts.

(ii) Except as provided in paragraphs (w)(5), (w)(6), and (w)(7) of this section, all direct operation external power supplies manufactured on or after February 10, 2016, shall meet the following standards:

Single-Voltage External AC-DC Power Supply, Basic-Voltage		
Nameplate Output Power (P_{out})	**Minimum Average Efficiency in Active Mode** *(expressed as a decimal)*	**Maximum Power in No-Load Mode [W]**
$P_{out} \leq 1$ W	$\geq 0.5 \times P_{out} + 0.16$	≤ 0.100
1 W < $P_{out} \leq 49$ W	$\geq 0.071 \times \ln(P_{out}) - 0.0014 \times P_{out} + 0.67$	≤ 0.100
49 W < $P_{out} \leq 250$ W	≥ 0.880	≤ 0.210
$P_{out} > 250$ W	≥ 0.875	≤ 0.500
Single-Voltage External AC-DC Power Supply, Low-Voltage		
Nameplate Output Power (P_{out})	**Minimum Average Efficiency in Active Mode** *(expressed as a decimal)*	**Maximum Power in No-Load Mode [W]**
$P_{out} \leq 1$ W	$\geq 0.517 \times P_{out} + 0.087$	≤ 0.100
1 W < $P_{out} \leq 49$ W	$\geq 0.0834 \times \ln(P_{out}) - 0.0014 \times P_{out} + 0.609$	≤ 0.100
49 W < $P_{out} \leq 250$ W	≥ 0.870	≤ 0.210
$P_{out} > 250$ W	≥ 0.875	≤ 0.500
Single-Voltage External AC-AC Power Supply, Basic-Voltage		
Nameplate Output Power (P_{out})	**Minimum Average Efficiency in Active Mode** *(expressed as a decimal)*	**Maximum Power in No-Load Mode [W]**
$P_{out} \leq 1$ W	$\geq 0.5 \times P_{out} + 0.16$	≤ 0.210
1 W < $P_{out} \leq 49$ W	$\geq 0.071 \times \ln(P_{out}) - 0.0014 \times P_{out} + 0.67$	≤ 0.210
49 W < $P_{out} \leq 250$ W	≥ 0.880	≤ 0.210
$P_{out} > 250$ W	≥ 0.875	≤ 0.500
Single-Voltage External AC-AC Power Supply, Low-Voltage		
Nameplate Output Power (P_{out})	**Minimum Average Efficiency in Active Mode** *(expressed as a decimal)*	**Maximum Power in No-Load Mode [W]**
$P_{out} \leq 1$ W	$\geq 0.517 \times P_{out} + 0.087$	≤ 0.210
1 W < $P_{out} \leq 49$ W	$\geq 0.0834 \times \ln(P_{out}) - 0.0014 \times P_{out} + 0.609$	≤ 0.210

49 W < P_{out} ≤ 250 W	≥ 0.870	≤ 0.210
P_{out} > 250 W	≥ 0.875	≤ 0.500
Multiple-Voltage External Power Supply		
Nameplate Output Power (P_{out})	**Minimum Average Efficiency in Active Mode** *(expressed as a decimal)*	**Maximum Power in No-Load Mode [W]**
P_{out} ≤ 1 W	≥ 0.497 × P_{out} + 0.067	≤ 0.300
1 W < P_{out} ≤ 49 W	≥ 0.075 × ln(P_{out}) + 0.561	≤ 0.300
P_{out} > 49 W	≥ 0.860	≤ 0.300

(iii) Except as provided in paragraphs (w)(5), (w)(6), and (w)(7) of this section, all external power supplies manufactured on or after February 10, 2016, shall meet the following standards:

	Class A EPS	Non-Class A EPS
Direct Operation EPS	Level VI: 10 CFR 430.32(w)(1)(ii)	Level VI: 10 CFR 430.32(w)(1)(ii).
Indirect Operation EPS	Level IV: 10 CFR 430.32(w)(1)(i)	No Standards.

(2) A basic model of external power supply is not subject to the energy conservation standards of paragraph (w)(1)(ii) of this section if the external power supply—

(i) Is manufactured during the period beginning on February 10, 2016, and ending on February 10, 2020;

(ii) Is marked in accordance with the External Power Supply International Efficiency Marking Protocol, as in effect on February 10, 2016;

(iii) Meets, where applicable, the standards under paragraph (w)(1)(i) of this section, and has been certified to the Secretary as meeting those standards; and

(iv) Is made available by the manufacturer only as a service part or a spare part for an end-use product that—

(A) Constitutes the primary load; and

(B) Was manufactured before February 10, 2016.

(3) The standards described in paragraph (w)(1) of this section shall not constitute an energy conservation standard for the separate end-use product to which the external power supply is connected.

(4) Any external power supply subject to the standards in paragraph (w)(1) of this section shall be clearly and permanently marked in accordance with the International Efficiency Marking Protocol for External Power Supplies (incorporated by reference; see § 430.3), published by the U.S. Department of Energy.

(5) *Non-application of no-load mode requirements.* The no-load mode energy efficiency standards established in paragraph (w)(1) of this section shall not apply to an external power supply that—

(i) Is an AC-to-AC external power supply;

(ii) Has a nameplate output of 20 watts or more;

(iii) Is certified to the Secretary as being designed to be connected to a security or life safety alarm or surveillance system component; and

(iv) On establishment within the External Power Supply International Efficiency Marking Protocol, as referenced in the ''Energy Star Program

Requirements for Single Voltage External Ac-Dc and Ac-Ac Power Supplies'' (incorporated by reference, see § 430.3), published by the Environmental Protection Agency, of a distinguishing mark for products described in this clause, is permanently marked with the distinguishing mark.

(6) An external power supply shall not be subject to the standards in paragraph (w)(1) of this section if it is a device that requires Federal Food and Drug Administration (FDA) listing and approval as a medical device in accordance with section 513 of the Federal Food, Drug, and Cosmetic Act (21 U.S.C. 360(c)).

(7) A direct operation, AC–DC external power supply with nameplate output voltage less than 3 volts and nameplate output current greater than or equal to 1,000 milliamps that charges the battery of a product that is fully or primarily motor operated shall not be subject to the standards in paragraph (w)(1)(ii) of this section.

(x) *Intermediate base incandescent lamps and candelabra base incandescent lamps.* (1) Subject to the sales prohibition in paragraph (dd) of this section, each candelabra base incandescent lamp shall not exceed 60 rated watts.

(2) Subject to the sales prohibition in paragraph (dd) of this section, each intermediate base incandescent lamp shall not exceed 40 rated watts.

(y) *Residential furnace fans.* Residential furnace fans incorporated in the products listed in Table 1 of this paragraph and manufactured on and after July 3, 2019, shall have a fan energy rating (FER) value that meets or is less than the following values:

TABLE 1—ENERGY CONSERVATION STANDARDS FOR COVERED RESIDENTIAL FURNACE FANS*

Product class	FER** (Watts/1000 cfm)
Non-Weatherized, Non-Condensing Gas Furnace Fan (NWG–NC)	FER = 0.044 × Q_{Max} + 182
Non-Weatherized, Condensing Gas Furnace Fan (NWG–C)	FER = 0.044 × Q_{Max} + 195
Weatherized Non-Condensing Gas Furnace Fan (WG–NC)	FER = 0.044 × Q_{Max} + 199
Non-Weatherized, Non-Condensing Oil Furnace Fan (NWO–NC)	FER = 0.071 × Q_{Max} + 382
Non-Weatherized Electric Furnace/Modular Blower Fan (NWEF/NWMB)	FER = 0.044 × Q_{Max} + 165
Mobile Home Non-Weatherized, Non-Condensing Gas Furnace Fan (MH–NWG–NC).	FER = 0.071 × Q_{Max} + 222
Mobile Home Non-Weatherized, Condensing Gas Furnace Fan (MH–NWG–C)	FER = 0.071 × Q_{Max} + 240
Mobile Home Electric Furnace/Modular Blower Fan (MH–EF/MB)	FER = 0.044 × Q_{Max} + 101
Mobile Home Non-Weatherized Oil Furnace Fan (MH–NWO)	Reserved
Mobile Home Weatherized Gas Furnace Fan (MH–WG)**	Reserved

* Furnace fans incorporated into hydronic air handlers, SDHV modular blowers, SDHV electric furnaces, and CAC/HP indoor units are not subject to the standards listed in this table.

** Q_{Max} is the airflow, in cfm, at the maximum airflow-control setting measured using the final DOE test procedure at 10 CFR part 430, subpart B, appendix AA.

(z) *Battery chargers.* (1) Battery chargers manufactured on or after June 13, 2018, must have a unit energy consumption (UEC) less than or equal to the prescribed ''Maximum UEC'' standard when using the equations for the appropriate product class and corresponding rated battery energy as shown in the following table:

Product class	Product class description	Rated battery energy (Ebatt**)	Special characteristic or battery voltage	Maximum UEC (kWh/yr) (as a function of Ebatt**)
1	Low-Energy	≤5 Wh	Inductive Connection*	3.04
2	Low-Energy, Low-Voltage	<100 Wh	<4 V	0.1440 * E_{batt} + 2.95
3	Low-Energy, Medium-Voltage		4–10 V	For E_{batt} <10 Wh, 1.42 kWh/y E_{batt} ≥10 Wh, 0.0255 * E_{batt} + 1.16
4	Low-Energy, High-Voltage		>10 V	0.11 * E_{batt} + 3.18
5	Medium-Energy, Low-Voltage	100–3000 Wh.	<20 V	0.0257 * E_{batt} + .815
6	Medium-Energy, High-Voltage		≥20 V	0.0778 * E_{batt} + 2.4
7	High-Energy	>3000 Wh		0.0502 * E_{batt} + 4.53

* Inductive connection and designed for use in a wet environment (*e.g.* electric toothbrushes).

** E_{batt} = Rated battery energy as determined in 10 CFR part 429.39(a).

(2) A battery charger shall not be subject to the standards in paragraph (z)(1) of this section if it is a device that requires Federal Food and Drug Administration (FDA) listing and approval as a life-sustaining or life-supporting device in accordance with section 513 of the Federal Food, Drug, and Cosmetic Act (21 U.S.C. 360(c)).

(3) All uninterruptible power supplies (UPS) manufactured on and after January 10, 2022, that utilize a NEMA 1–15P or 5–15P input plug and have an AC output shall have an average load adjusted efficiency that meets or exceeds the values shown in the table in this paragraph (z)(3) based on the rated output power (P_{rated}) of the UPS.

Battery charger product class	Rated output power	Minimum efficiency
10a (VFD UPSs)	$0W < P_{rated} \leq 300\ W$	$-1.20E{-}06 * P^2_{rated} + 7.17E{-}04 * P_{rated} + 0.862$.
	$300\ W < P_{rated} \leq 700\ W$	$-7.85E{-}08 * P^2_{rated} + 1.01E{-}04 * P_{rated} + 0.946$.
	$P_{rated} > 700\ W$	$-7.23E{-}09 * P^2_{rated} + 7.52E{-}06 * P_{rated} + 0.977$.
10b (VI UPSs)	$0W < P_{rated} \leq 300\ W$	$-1.20E{-}06 * P^2_{rated} + 7.19E{-}04 * P_{rated} + 0.863$.
	$300\ W < P_{rated} \leq 700\ W$	$-7.67E{-}08 * P^2_{rated} + 1.05E{-}04 * P_{rated} + 0.947$.
	$P_{rated} > 700\ W$	$-4.62E{-}09 * P^2_{rated} + 8.54E{-}06 * P_{rated} + 0.979$.
10c (VFI UPSs)	$0W < P_{rated} \leq 300\ W$	$-3.13E{-}06 * P^2_{rated} + 1.96E{-}03 * P_{rated} + 0.543$.
	$300\ W < P_{rated} \leq 700\ W$	$-2.60E{-}07 * P^2_{rated} + 3.65E{-}04 * P_{rated} + 0.764$.
	$P_{rated} > 700\ W$	$-1.70E{-}08 * P^2_{rated} + 3.85E{-}05 * P_{rated} + 0.876$.

(aa) *Miscellaneous refrigeration products.* The energy standards as determined by the equations of the following table(s) shall be rounded off to the nearest kWh per year. If the equation calculation is halfway between the nearest two kWh per year values, the standard shall be rounded up to the higher of these values.

(1) *Coolers.* (i) Coolers manufactured on or after October 28, 2019, and before January 31, 2029, shall have an Annual Energy Use (AEU) no more than:

Product class	AEU (kWh/yr)
(A) Freestanding compact.	7.88AV + 155.8
(B) Freestanding.	7.88AV + 155.8
(C) Built-in compact.	7.88AV + 155.8
(D) Built-in.	7.88AV + 155.8

Note: AV = Total adjusted volume, expressed in ft^3, as determined in appendix A to subpart B of this part.

(ii) Coolers manufactured on or after January 31, 2029, shall have an Annual Energy Use (AEU) no more than:

Product class	AEU (kWh/yr)
(A) Freestanding compact.	5.52AV + 109.1
(B) Freestanding.	5.52AV + 109.1
(C) Built-in compact.	5.52AV + 109.1
(D) Built-in.	6.30AV + 124.6

Note: AV = Total adjusted volume, expressed in ft^3, as determined in appendix A to subpart B of this part.

(2) *Combination cooler refrigeration products.* (i) Combination cooler refrigeration products manufactured on or after October 28, 2019, and before January 31, 2029, shall have an Annual Energy Use (AEU) no more than:

Product class	AEU (kWh/yr)
(A) C–3A. Cooler with all-refrigerator—automatic defrost	4.57AV + 130.4
(B) C–3A–BI. Built-in cooler with all-refrigerator—automatic defrost	5.19AV + 147.8
(C) C–9. Cooler with upright freezer with automatic defrost without an automatic icemaker	5.58AV + 147.7
(D) C–9–BI. Built-in cooler with upright freezer with automatic defrost without an automatic icemaker	6.38AV + 168.8
(E) C–9I. Cooler with upright freezer with automatic defrost with an automatic icemaker	5.58AV + 231.7
(F) C–9I–BI. Built-in cooler with upright freezer with automatic defrost with an automatic icemaker	6.38AV + 252.8
(G) C–13A. Compact cooler with all-refrigerator—automatic defrost	5.93AV + 193.7
(H) C–13A–BI. Built-in compact cooler with all-refrigerator—automatic defrost	6.52AV + 213.1

Note: AV = Total adjusted volume, expressed in ft^3, as determined in appendix A to subpart B of this part.

(ii) Combination cooler refrigeration products manufactured on or after January 31, 2029, shall have an Annual Energy Use (AEU) no more than:

Product class	AEU (kWh/yr)
C–3A. Cooler with all-refrigerator—automatic defrost	4.11AV + 117.4.
C–3A–BI. Built-in cooler with all-refrigerator—automatic defrost	4.67AV + 133.0.
C–5–BI. Built-in cooler with refrigerator-freezer with automatic defrost with bottom-mounted freezer.	5.47AV + 196.2 + 28I.

Product class	AEU (kWh/yr)
C–9. Cooler with upright freezer with automatic defrost	5.58AV + 147.7 + 28I.
C–9–BI. Built-in cooler with upright freezer with automatic defrost	6.38AV + 168.8 + 28I.
C–13A. Compact cooler with all-refrigerator—automatic defrost	4.74AV + 155.0.
C–13A–BI. Built-in compact cooler with all-refrigerator—automatic defrost	5.22AV + 170.5.

AV = Total adjusted volume, expressed in ft^3, as determined in appendix A to subpart B of this part.
I = 1 for a product with an automatic icemaker and = 0 for a product without an automatic icemaker.

(bb) *Rough service lamps and vibration service lamps.* (1) Subject to the sales prohibition in paragraph (dd) of this section, rough service lamps manufactured on or after January 25, 2018 must:

(i) Have a shatter-proof coating or equivalent technology that is compliant with NSF/ANSI 51 (incorporated by reference; see § 430.3) and is designed to contain the glass if the glass envelope of the lamp is broken and to provide effective containment over the life of the lamp;

(ii) Have a rated wattage not greater than 40 watts; and

(iii) Be sold at retail only in a package containing one lamp.

(2) Subject to the sales prohibition in paragraph (dd) of this section, vibration service lamps manufactured on or after January 25, 2018 must:

(i) Have a rated wattage no greater than 40 watts; and

(ii) Be sold at retail only in a package containing one lamp.

(cc) *Portable air conditioners.* Single-duct portable air conditioners and dual-duct portable air conditioners manufactured on or after January 10, 2025 must have a combined energy efficiency ratio (CEER) in Btu/Wh no less than:

$$CEER = 1.04 \times \frac{SACC}{(3.7117 \times SACC^{0.6384})}$$

SACC: For single-speed portable air conditioners, SACC is seasonally adjusted cooling capacity in Btu/h, as determined in appendix CC of subpart B of this part. For variable-speed portable air conditioners, SACC shall be $SACC_{Full}$ in Btu/h, as determined in appendix CC of subpart B of this part.

(dd) *General service lamps.* Beginning July 25, 2022, the sale of any general service lamp that does not meet a minimum efficacy standard of 45 lumens per watt is prohibited.

(1) Energy conservation standards for general service lamps:

(i) General service incandescent lamps manufactured after the dates specified in the following tables, except as described in paragraph (dd)(1)(ii) of this section, shall have a color rendering index greater than or equal to 80 and shall have a rated wattage no greater than, and a lifetime no less than the values shown in the table as follows:

GENERAL SERVICE INCANDESCENT LAMPS

Rated lumen ranges	Minimum lifetime* (hrs)	Maximum rate wattage	Compliance date
(A) 1490–2600	1,000	72	1/1/2012
(B) 1050–1489	1,000	53	1/1/2013
(C) 750–1049	1,000	43	1/1/2014
(D) 310–749	1,000	29	1/1/2014

*Use lifetime determined in accordance with § 429.66 of this chapter to determine compliance with this standard.

(ii) Modified spectrum general service incandescent lamps manufactured after the dates specified in the following table shall have a color rendering index greater than or equal to 75 and shall have a rated wattage no greater than, and a lifetime no less than the values shown in the table as follows:

MODIFIED SPECTRUM GENERAL SERVICE INCANDESCENT LAMPS

Rated lumen ranges	Minimum lifetime [1] (hrs)	Maximum rate wattage	Compliance date
(A) 1118–1950	1,000	72	1/1/2012
(B) 788–1117	1,000	53	1/1/2013
(C) 563–787	1,000	43	1/1/2014
(D) 232–562	1,000	29	1/1/2014

[1] Use lifetime determined in accordance with § 429.66 of this chapter to determine compliance with this standard.

(iii) A bare or covered (no reflector) medium base compact fluorescent lamp manufactured on or after January 1, 2006, must meet or exceed the following requirements:

Factor		Requirements
Configuration [1]	Labeled wattage (watts)	Minimum initial lamp efficacy (lumens per watt) must be at least:
(A) *Bare Lamp:*		
	(*1*) Labeled Wattage <15	45.0
	(*2*) Labeled Wattage ≥15	60.0
(B) *Covered Lamp (no reflector):*		
	(*1*) Labeled Wattage <15	40.0
	(*2*) 15≤ Labeled Wattage <19	48.0
	(*3*) 19≤ Labeled Wattage <25	50.0
	(*4*) Labeled Wattage ≥25	55.0

[1] Use labeled wattage to determine the appropriate efficacy requirements in this table; do not use measured wattage for this purpose.

(iv) Each general service lamp manufactured on or after July 25, 2028 must have:

(A) A power factor greater than or equal to 0.7 for integrated LED lamps (as defined in § 430.2) and 0.5 for medium base compact fluorescent lamps (as defined in § 430.2); and

(B) A lamp efficacy greater than or equal to the values shown in the table as follows:

Lamp type	Length	Standby mode operation [3]	Efficacy (lm/W)
(*1*) Integrated Omnidirectional.	Short (<45 inches)	No Standby Mode Operation.	$123/(1.2+e^{-0.005*(\text{Lumens }200)})+25.9$
(*2*) Integrated Omnidirectional.	Long (≥45 inches)	No Standby Mode Operation.	$123/(1.2+e^{-0.005*(\text{Lumens }200)})+71.7$
(*3*) [1] Integrated Directional.	All Lengths	No Standby Mode Operation.	$73/(0.5+e^{-0.0021*(\text{Lumens}+1000)})-47.2$
(*4*) [2] Non-integrated Omnidirectional.	Short (<45 inches)	No Standby Mode Operation.	$122/(0.55+e^{-0.003*(\text{Lumens}+250)})-83.4$
(*5*) [1] Non-integrated Directional.	All Lengths	No Standby Mode Operation.	$67/(0.45+e^{-0.00176*(\text{Lumens}+1310)})-53.1$
(*6*) Integrated Omnidirectional.	Short (<45 inches)	Standby Mode Operation.	$123/(1.2+e^{-0.005*(\text{Lumens }200)})+17.1$
(*7*) [1] Integrated Directional.	All Lengths	Standby Mode Operation.	$73/(0.5+e^{-0.0021*(\text{Lumens}+1000)})-50.9$
(*8*) Non-integrated Omnidirectional.	Long (≥45 inches)	No Standby Mode Operation.	$123/(1.2+e^{-0.005*(\text{Lumens }200)})+93.0$

[1] This lamp type comprises of directional lamps. A directional lamp is a lamp that meets the definition of reflector lamp as defined in § 430.2.

[2] This lamp type comprises of, but is not limited to, lamps that are pin base compact fluorescent lamps ("CFLs") and pin base light-emitting diode ("LED") lamps designed and marketed as replacements of pin base CFLs.
[3] Indicates whether or not lamps are capable of operating in standby mode operation.

(C) The standards described in paragraph (dd)(1)(iv) of this section do not apply to a general service lamp that:

(*1*) Is a general service organic light-emitting diode (OLED) lamps (as defined in § 430.2);

(*2*) Is a non-integrated lamp that is capable of operating in standby mode and is sold in packages of two lamps or less;

(*3*) Is designed and marketed as a lamp that has at least one setting that allows the user to change the lamp's correlated color temperature (CCT) and has no setting in which the lamp meets the definition of a colored lamp (as defined in § 430.2); and is sold in packages of two lamps or less;

(*4*) Is designed and marketed as a lamp that has at least one setting in which the lamp meets the definition of a colored lamp (as defined in § 430.2) and at least one other setting in which it does not meet the definition of colored lamp (as defined in § 430.2) and is sold in packages of two lamps or less; or

(*5*) Is designed and marketed as a lamp that has one or more component(s) offering a completely different functionality (*e.g.*, a speaker, a camera, an air purifier, etc.) where each component is integrated into the lamp but does not affect the light output of the lamp (*e.g.*, does not turn the light on/off, dim the light, change the color of the light, etc.), is capable of operating in standby mode, and is sold in packages of two lamps or less.

(2) Medium base CFLs (as defined in § 430.2) manufactured on or after the dates specified in the following table shall meet or exceed the following standards:

Metrics	Requirements for MBCFLs manufactured on or after January 1, 2006	Requirements for MBCFLs manufactured on or after July 25, 2028
(i) Lumen Maintenance at 1,000 Hours.	≥90.0%	≥90.0%.
(ii) Lumen Maintenance at 40 Percent of Lifetime[1].	≥80.0%	≥80.0%.
(iii) Rapid Cycle Stress Test	At least 5 lamps must meet or exceed the minimum number of cycles. All MBCFLs: Cycle once per every two hours of lifetime[1].	At least 5 lamps must meet or exceed the minimum number of cycles. MBCFLs with start time >100 ms: Cycle once per hour of lifetime[1] or a maximum of 15,000 cycles. MBCFLs with a start time of ≤100 ms: Cycle once per every two hours of lifetime.[1]
(iv) Lifetime[1]	≥6,000 hours	≥10,000 hours.
(v) Start time	No requirement	The time needed for a MBCFL to remain continuously illuminated must be within: {1} one second of application of electrical power for lamp with standby mode power {2} 750 milliseconds of application of electrical power for lamp without standby mode power.

[1] Lifetime refers to lifetime of a compact fluorescent lamp as defined in § 430.2.

(ee) *Air cleaners.* (1) Conventional room air cleaners as defined in § 430.2 with a $PM_{2.5}$ clean air delivery rate (CADR) between 10 and 600 (both inclusive) cubic feet per minute (cfm) and manufactured on or after December 31, 2023, and before December 31, 2025, shall have an integrated energy factor (IEF) in $PM_{2.5}$ CADR/W, as determined in § 430.23(hh)(4) that meets or exceeds the following values:

Product capacity	IEF ($PM_{2.5}$ CADR/W)
(i) 10 ≤$PM_{2.5}$ CADR <100	1.7
(ii) 100 ≤$PM_{2.5}$ CADR <150	1.9
(iii) $PM_{2.5}$ CADR ≥150	2.0

(2) Conventional room air cleaners as defined in § 430.2 with a $PM_{2.5}$ clean air delivery rate (CADR) between 10 and 600 (both inclusive) cubic feet per minute (cfm) and manufactured on or after December 31, 2025, shall have an

integrated energy factor (IEF) in $PM_{2.5}$ CADR/W, as determined in § 430.23(hh)(4) that meets or exceeds the following values:

Product capacity	IEF ($PM_{2.5}$ CADR/W)
(i) 10 ≤$PM_{2.5}$ CADR <100	1.9
(ii) 100 ≤$PM_{2.5}$ CADR <150	2.4
(iii) $PM_{2.5}$ CADR ≥150	2.9

[54 FR 6077, Feb. 7, 1989]

EDITORIAL NOTE: For FEDERAL REGISTER citations affecting § 430.32, see the List of CFR Sections Affected, which appears in the Finding Aids section of the printed volume and at *www.govinfo.gov*.

EFFECTIVE DATE NOTE: At 89 FR 105285, Dec. 26, 2024, § 430.32 was amended by revising paragraph (d)(3) and adding (d)(4), effective Mar. 11, 2025. For the convenience of the user, the revised text is set forth as follows:

§ 430.32 Energy and water conservation standards and their compliance dates.

* * * * *

(d) * * *

(3) The uniform energy factor of water heaters manufactured on or after December 26, 2029 shall not be less than the following:

TABLE 15 TO PARAGRAPH (d)(3)

Product class	Effective storage volume (V_{eff})* and input rating	Draw pattern	UEF*
Gas-fired Instantaneous Water Heater.	<2 gallons ("gal") and ≤50,000 Btu/h.	Very Small	0.64.
		Low	0.64.
		Medium	0.64.
		High	0.64.
	<2 gal and >50,000 Btu/h	Very Small	0.89.
		Low	0.91.
		Medium	0.91.
		High	0.93.
	≥2 gal and ≤200,000 Btu/h	Very Small	$0.2534 - (0.0018 \times V_{eff})$.
		Low	$0.5226 - (0.0022 \times V_{eff})$.
		Medium	$0.5919 - (0.0020 \times V_{eff})$.
		High	$0.6540 - (0.0017 \times V_{eff})$.

*V_{eff} is the Effective Storage Volume (in gallons), as determined pursuant to § 429.17 of this chapter.

(4) The provisions of paragraph (d) of this section are separate and severable from one another. Should a court of competent jurisdiction hold any provision(s) of paragraph (d) of this section to be stayed or invalid, such action shall not affect any other provision of paragraph (d) of this section.

§ 430.33 Preemption of State regulations.

(a) Any State regulation providing for any energy conservation standard, or water conservation standard (in the case of faucets, showerheads, water closets, and urinals), or other requirement with respect to the energy efficiency, energy use, or water use (in the case of faucets, showerheads, water closets, or urinals) of a covered product that is not identical to a Federal standard in effect under this subpart is preempted by that standard, except as provided for in sections 325(i)(6)(A)(vi), 327(b) and (c) of the Act.

(b) No State regulation, or revision thereof, concerning the energy efficiency, energy use, or water use of the covered product shall be effective with respect to such covered product, unless the State regulation or revision in the case of any portion of any regulation that establishes requirements for general service incandescent lamps, intermediate base incandescent lamps, or candelabra base lamps, was enacted or adopted by the State of California or Nevada before December 4, 2007, except that—

(1) The regulation adopted by the California Energy Commission with an effective date of January 1, 2008, shall only be effective until the effective date of the Federal standard for the applicable lamp category under paragraphs (A), (B), and (C) of section 325(i)(1) of EPCA; and

(2) The States of California and Nevada may, at any time, modify or adopt a State standard for general service lamps to conform with Federal standards with effective dates no earlier than 12 months prior to the Federal effective dates prescribed under paragraphs (A), (B), and (C) of section

325(i)(1) of EPCA, at which time any prior regulations adopted by the State of California or Nevada shall no longer be effective.

[63 FR 13318, Mar. 18, 1998, as amended at 74 FR 12070, Mar. 23, 2009; 78 FR 62993, Oct. 23, 2013]

§ 430.34 Energy and water conservation standards amendments

The Department of Energy may not prescribe any amended standard which increases the maximum allowable energy use or, in the case of showerheads, faucets, water closets or urinals, the maximum allowable water use, or which decreases the minimum required energy efficiency of a covered product.

[67 FR 36406, May 23, 2002]

§ 430.35 Petitions with respect to general service lamps.

(a) Any person may petition the Secretary for an exemption for a type of general service lamp from the requirements of this subpart. The Secretary may grant an exemption only to the extent that the Secretary finds, after a hearing and opportunity for public comment, that it is not technically feasible to serve a specialized lighting application (such as a military, medical, public safety or certified historic lighting application) using a lamp that meets the requirements of this subpart. To grant an exemption for a product under this paragraph, the Secretary shall include, as an additional criterion, that the exempted product is unlikely to be used in a general service lighting application.

(b) Any person may petition the Secretary to establish standards for lamp shapes or bases that are excluded from the definition of general service lamps. The petition shall include evidence that the availability or sales of exempted lamps have increased significantly since December 19, 2007. The Secretary shall grant a petition if the Secretary finds that:

(1) The petition presents evidence that demonstrates that commercial availability or sales of exempted incandescent lamp types have increased significantly since December 19, 2007 and are being widely used in general lighting applications; and

(2) Significant energy savings could be achieved by covering exempted products, as determined by the Secretary based on sales data provided to the Secretary from manufacturers and importers.

[74 FR 12070, Mar. 23, 2009]

APPENDIX A TO SUBPART C OF PART 430—PROCEDURES, INTERPRETATIONS, AND POLICIES FOR CONSIDERATION OF NEW OR REVISED ENERGY CONSERVATION STANDARDS AND TEST PROCEDURES FOR CONSUMER PRODUCTS AND CERTAIN COMMERCIAL/INDUSTRIAL EQUIPMENT

1. Objectives
2. Scope
3. Application
4. Setting Priorities for Rulemaking Activity
5. Coverage Determination Rulemakings
6. Process for Developing Energy Conservation Standards
7. Policies on Selection of Standards
8. Test Procedures
9. ASHRAE Equipment
10. Direct Final Rules
11. Principles for Distinguishing Between Effective and Compliance Dates
12. Principles for the Conduct of the Engineering Analysis
13. Principles for the Analysis of Impacts on Manufacturers
14. Principles for the Analysis of Impacts on Consumers
15. Consideration of Non-Regulatory Approaches
16. Cross-Cutting Analytical Assumptions

1. OBJECTIVES

This appendix establishes procedures, interpretations, and policies to guide the Department of Energy (''DOE'' or the ''Department'') in the consideration and promulgation of new or revised appliance energy conservation standards and test procedures under the Energy Policy and Conservation Act (EPCA). This appendix applies to both covered consumer products and covered commercial/industrial equipment. The Department's objectives in establishing these procedures include:

(a) *Provide for early input from stakeholders.* The Department seeks to provide opportunities for public input early in the rulemaking process so that the initiation and direction of rulemakings isinformed by comment from interested parties. DOE will be able to seek early input from interested parties in determining whether establishing new or amending existing energy conservation standards will result in significant savings of energy

and is economically justified and technologically feasible. In the context of test procedure rulemakings, DOE will be able to seek early input from interested parties in determining whether—

(1) Establishing a new or amending an existing test procedure will better measure the energy efficiency, energy use, water use (as specified in EPCA), or estimated annual operating cost of a covered product/equipment during a representative average use cycle or period of use (for consumer products); and

(2) Will not be unduly burdensome to conduct.

(b) *Increase predictability of the rulemaking timetable.* The Department seeks to make informed, strategic decisions about how to deploy its resources on the range of possible standards and test procedure development activities, and to announce these prioritization decisions so that all interested parties have a common expectation about the timing of different rulemaking activities. Further, DOE will offer the opportunity to provide input on the prioritization of rulemakings through a request for comment as DOE begins preparation of its Regulatory Agenda each spring.

(c) *Eliminate problematic design options early in the process.* The Department seeks to eliminate from consideration, early in the process, any design options that present unacceptable problems with respect to manufacturability, consumer utility, or safety, so that the detailed analysis can focus only on viable design options. DOE will be able to eliminate from consideration design options if it concludes that manufacture, installation or service of the design will be impractical, or that the design option will have a material adverse impact on the utility of the product, or if the design option will have a material adverse impact on safety or health. DOE will also be able to eliminate from consideration proprietary design options that represent a unique pathway toachieving a given efficiency level. This screening will be done at the outset of a rulemaking.

(d) *Fully consider non-regulatory approaches.* The Department seeks to understand the effects of market forces and voluntary programs on encouraging the purchase of energy efficient products so that the incremental impacts of a new or revised standard can be accurately assessed and the Department can make informed decisions about where standards and voluntary programs can be used most effectively. DOE will continue to be able to support voluntary efforts by manufacturers, retailers, utilities, and others to increase product/equipment efficiency.

(e) *Conduct thorough analysis of impacts.* In addition to understanding the aggregate social and private costs and benefits of standards, the Department seeks to understand the distribution of those costs and benefits among consumers, manufacturers, and others, as well as the uncertainty associated with these analyses of costs and benefits, so that any adverse impacts on subgroups and uncertainty concerning any adverse impacts can be fully considered in selecting a standard. DOE will be able to consider the variability of impacts on significant groups of manufacturers and consumers in addition to aggregate social and private costs and benefits, report the range of uncertainty associated with these impacts, and take into account cumulative impacts of regulation on manufacturers. The Department will also be able to conduct appropriate analyses to assess the impact that new or amended test procedures will have on manufacturers and consumers.

(f) *Use transparent and robust analytical methods.* The Department seeks to use qualitative and quantitative analytical methods that are fully documented for the public and that produce results that can be explained and reproduced, so that the analytical underpinnings for policy decisions on standards are as sound and well-accepted as possible.

(g) *Support efforts to build consensus on standards.* The Department seeks to encourage development of consensus proposals, including proposals developed in accordance with the Negotiated Rulemaking Act (5 U.S.C. 561 *et seq.*), for new or revised standards because standards with such broad-based support are likely to balance effectively the various interests affected by such standards.

2. Scope

The procedures, interpretations, and policies described in this appendix apply to rulemakings concerning new or revised Federal energy conservation standards and test procedures, and related rule documents (*i.e.*, coverage determinations) for consumer products in Part A and commercial and industrial equipment under Part A–1 of the Energy Policy and Conservation Act (EPCA), as amended, except covered ASHRAE equipment in Part A–1 are governed separately under section 9 in this appendix.

3. Application

(a) This appendix contains procedures, interpretations, and policies that are generally applicable to the development of energy conservation standards and test procedures. The Department may, as necessary, deviate from this appendix to account for the specific circumstances of a particular rulemaking. In those instances where the Department may find it necessary or appropriate to deviate from these procedures, interpretations or policies, DOE will provide interested parties with notice of the deviation and an explanation.

(b) If the Department concludes that changes to the procedures, interpretations or policies in this appendix are necessary or appropriate, DOE will provide notice in the FEDERAL REGISTER of modifications to this appendix with an accompanying explanation. DOE expects to consult with interested parties prior to any such modification.

(c) This appendix is not intended to, and does not, create any right or benefit, substantive or procedural, enforceable at law or in equity.

4. SETTING PRIORITIES FOR RULEMAKING ACTIVITY

(a) In establishing its priorities for undertaking energy conservation standards and test procedure rulemakings, DOE will consider the following factors, consistent with applicable legal obligations:

(1) Potential energy savings;

(2) Potential social and private, including environmental or energy security, benefits;

(3) Applicable deadlines for rulemakings;

(4) Incremental DOE resources required to complete the rulemaking process;

(5) Other relevant regulatory actions affecting the products/equipment;

(6) Stakeholder recommendations;

(7) Evidence of energy efficiency gains in the market absent new or revised standards;

(8) Status of required changes to test procedures; and

(9) Other relevant factors.

(b) DOE will offer the opportunity to provide input on prioritization of rulemakings through a request for comment as DOE begins preparation of its Regulatory Agenda each spring.

5. COVERAGE DETERMINATION RULEMAKINGS

DOE has discretion to conduct proceedings to determine whether additional consumer products and commercial/industrial equipment should be covered under EPCA if certain statutory criteria are met. (42 U.S.C. 6292(b) and 42 U.S.C. 6295(l) for consumer products; 42 U.S.C. 6312(b) for commercial/industrial equipment). This section describes the process to be used in establishing coverage for consumer products and commercial/industrial equipment.

(a) *Pre-notice of proposed rulemaking (''NOPR'') stage.* In determining whether to consider establishing coverage for a consumer product or commercial/industrial equipment, DOE may publish one or more preliminary documents in the FEDERAL REGISTER intended to gather information on key issues. Such document(s) will be published in the FEDERAL REGISTER, with accompanying documents referenced and posted in the appropriate docket.

(b) *NOPR stage.* If DOE determines to proceed with a coverage determination process, the Department will publish a notice of proposed determination, providing an opportunity for public comment of not less than 60 days, in which DOE will explain how such products/equipment that it seeks to designate as ''covered'' meet the statutory criteria for coverage and why such coverage is ''necessary or appropriate'' to carry out the purposes of EPCA. In the case of commercial equipment, DOE will follow the same process, except that the Department must demonstrate that coverage of the equipment type is ''necessary'' to carry out the purposes of EPCA.

(c) *Final rule.* DOE will publish a final rule in the FEDERAL REGISTER that establishes the scope of coverage for the product/equipment, responds to public comments received on the NOPR, and explains how inclusion of the newly covered product/equipment meets the statutory criteria for coverage and why such coverage is necessary or appropriate to carry out the purposes of EPCA. DOE will finalize coverage for a product/equipment prior to publication of a proposed rule to establish a test procedure.

(d) *Scope of coverage revisions.* If, during the substantive rulemaking proceedings to establish test procedures or energy conservation standards after completing a coverage determination, DOE finds it necessary and appropriate to amend the scope of coverage, DOE will propose an amended coverage determination and finalize coverage prior to moving forward with the test procedure or standards rulemaking.

6. PROCESS FOR DEVELOPING ENERGY CONSERVATION STANDARDS

This section describes the process to be used in developing energy conservation standards for covered products and equipment other than those covered equipment subject to ASHRAE/IES Standard 90.1.

(a) *Pre-NOPR stage*—(1) *General.* In determining whether to consider establishing or amending any energy conservation standard, DOE will publish one or more preliminary, pre-NOPR documents in the FEDERAL REGISTER intended to gather information on key issues. Such document(s) could take several forms depending upon the specific proceeding, including a framework document, request for information (RFI), notice of data availability (NODA), preliminary analysis, or advance notice of proposed rulemaking (ANOPR). Such document(s) will be published in the FEDERAL REGISTER, with any accompanying documents referenced and posted in the appropriate docket.

(2) *Satisfaction of statutory criteria.* As part of such pre-NOPR-stage document(s), DOE will solicit submission of comments, data, and information on whether DOE should proceed with the rulemaking, including whether any new or amended rule would satisfy the relevant statutory criteria to be cost-effective, economically justified, technologically

feasible, and result in a significant savings of energy. Based on the information received in response to such request and its own analysis, DOE will determine whether to proceed with a rulemaking for a new or amended energy conservation standard. If DOE determines at any point in the pre-NOPR stage that no candidate standard level for a new or amended standard is likely to satisfy all of the applicable statutory criteria (*i.e.*, to be technologically feasible and economically justified and result in significant energy savings), DOE will announce that conclusion in the FEDERAL REGISTER and proceed with notice-and-comment rulemaking that proposes a determination not to adopt new or amended standards. DOE notes that it will, consistent with its statutory obligations, consider both cost effectiveness and economic justification when issuing a determination not to amend a standard. If DOE receives sufficient information suggesting it could justify a new or amended standard or the information received is inconclusive with regard to the statutory criteria, DOE will move forward with the rulemaking to issue or amend an energy conservation standard. In those instances where the available information either suggested that a new or amended energy conservation standard might be justified or in which the information was inconclusive on this point, and DOE undertakes a rulemaking to establish or amend an energy conservation standard, DOE may still ultimately determine that such a standard is not economically justified, technologically feasible or would not result in a significant savings of energy at a later stage of the rulemaking.

(3) *Design options*—(i) *General.* Once the Department has initiated a rulemaking for a specific product/equipment but before publishing a proposed rule to establish or amend standards, DOE will typically identify the product/equipment categories and design options to be analyzed in detail, as well as those design options to be eliminated from further consideration. During the pre-NOPR stage of the rulemaking, interested parties may be consulted to provide information on key issues, including potential design options, through a variety of rulemaking documents.

(ii) *Identification and screening of design options.* During the pre-NOPR phase of the rulemaking process, the Department will typically develop a list of design options for consideration. Initially, the candidate design options will encompass all those technologies considered to be technologically feasible. Following the development of this initial list of design options, DOE will review each design option based on the factors described in paragraph (a)(3)(iii) of this section and the policies stated in section 7 of this appendix (*i.e.*, Policies on Selection of Standards). The reasons for eliminating or retaining any design option at this stage of the process will be fully documented and published as part of the NOPR and as appropriate for a given rule, in the pre-NOPR document(s). The technologically feasible design options that are not eliminated in this screening analysis will be considered further in the Engineering Analysis described in paragraph (a)(4) of this section.

(iii) *Factors for screening of design options.* The factors for screening design options include:

(A) *Technological feasibility.* Technologies incorporated in commercial products (or equipment) or in working prototypes will be considered technologically feasible.

(B) *Practicability to manufacture, install and service.* If mass production of a technology under consideration for use in commercially-available products (or equipment) and reliable installation and servicing of the technology could be achieved on the scale necessary to serve the relevant market at the time of the effective date of the standard, then that technology will be considered practicable to manufacture, install, and service.

(C) Adverse impacts on product utility or product availability.

(D) Adverse impacts on health or safety.

(E) *Unique-pathway proprietary technologies.* If a design option utilizes proprietary technology that represents a unique pathway to achieving a given efficiency level, that technology will not be considered further.

(4) *Engineering analysis of design options and selection of candidate standard levels.* After design options are identified and screened, DOE will perform the engineering analysis and the benefit/cost analysis and select the candidate standard levels based on these analyses. The results of the analyses will be published in a Technical Support Document (TSD) to accompany the appropriate rulemaking documents.

(i) *Identification of engineering analytical methods and tools.* DOE will select the specific engineering analysis tools (or multiple tools, if necessary, to address uncertainty) to be used in the analysis of the design options identified as a result of the screening analysis.

(ii) *Engineering and life-cycle cost analysis of design options.* DOE and its contractors will perform engineering and life-cycle cost analyses of the design options.

(iii) *Review by stakeholders.* Interested parties will have the opportunity to review the results of the engineering and life-cycle cost analyses. If appropriate, a public workshop will be conducted to review these results. The analyses will be revised as appropriate on the basis of this input.

(iv) *New information relating to the factors used for screening design options.* If further information or analysis leads to a determination that a design option, or a combination of design options, has unacceptable impacts,

that design option or combination of design options will not be included in a candidate standard level.

(v) *Selection of candidate standard levels.* Based on the results of the engineering and life-cycle cost analysis of design options and the policies stated in paragraph (a)(3)(iii) of this section, DOE will select the candidate standard levels for further analysis.

(5) *Analysis of impacts and selection of proposed standard level.* If DOE has determined preliminarily that a candidate standard level is likely to produce the maximum improvement in energy efficiency that is both technologically feasible and economically justified and constitutes significant energy savings, economic analyses of the impacts of the candidate standard levels will be conducted. The Department will propose new or amended standards in a subsequent NOPR based on the results of the impact analysis.

(i) *Identification of issues for analysis.* The Department, in consideration of comments received, will identify issues that will be examined in the impacts analysis.

(ii) *Identification of analytical methods and tools.* DOE will select the specific economic analysis tools (or multiple tools, if necessary, to address uncertainty) to be used in the analysis of the candidate standard levels.

(iii) *Analysis of impacts.* DOE will conduct the analysis of the impacts of candidate standard levels.

(iv) *Factors to be considered in selecting a proposed standard.* The factors to be considered in selection of a proposed standard include:

(A) *Impacts on manufacturers.* The analysis of manufacturer impacts will include: Estimated impacts on cash flow; assessment of impacts on manufacturers of specific categories of products/equipment and small manufacturers; assessment of impacts on manufacturers of multiple product-specific Federal regulatory requirements, including efficiency standards for other products and regulations of other agencies; and impacts on manufacturing capacity, employment, and capital investment.

(B) *Private impacts on consumers.* The analysis of consumer impacts will include: Estimated private energy savings impacts on consumers based on regional average energy prices and energy usage; assessments of the variability of impacts on subgroups of consumers based on major regional differences in usage or energy prices and significant variations in installation costs or performance; consideration of changes to product utility, changes to purchase rate and/or costs of products, and other impacts of likely concern to all or some consumers, based to the extent practicable on direct input from consumers; estimated life-cycle cost with sensitivity analysis; and consideration of the increased first cost to consumers and the time required for energy cost savings to pay back these first costs.

(C) Impacts on competition, including industry concentration analysis.

(D) *Impacts on utilities.* The analysis of utility impacts will include estimated marginal impacts on electric and gas utility generation and capacity.

(E) *National energy, economic, and employment impacts.* The analysis of national energy, economic, and employment impacts will include: estimated energy savings by fuel type; estimated net present value of benefits to all consumers; sensitivity analyses using high and low discount rates reflecting both private transactions and social discount rates and high and low energy price forecasts; and estimates of the direct and indirect impacts on employment by appliance manufacturers, relevant service industries, energy suppliers, suppliers of complementary and substitution products, and the economy in general.

(F) *Impacts on the environment.* The analysis of environmental impacts will include estimated impacts on emissions of carbon and relevant criteria pollutants.

(G) *Impacts of non-regulatory approaches.* The analysis of energy savings and consumer impacts will incorporate an assessment of the impacts of market forces and existing voluntary programs in promoting product/equipment efficiency, usage, and related characteristics in the absence of updated efficiency standards.

(H) New information relating to the factors used for screening design options.

(6) *Public comment and hearing.* The length of the public comment period for pre-NOPR rulemaking documents will be determined on a case-by-case basis and may vary depending upon the circumstances of the particular rulemaking. For pre-NOPR documents, DOE will determine whether a public hearing is appropriate.

(7) *Revisions based on comments.* Based on consideration of the comments received, any necessary changes to the engineering analysis, life-cycle cost analysis, or the candidate standard levels will be made.

(b) *NOPR stage*—(1) *Documentation of decisions on proposed standard selection.* The Department will publish a NOPR in the FEDERAL REGISTER that proposes standard levels and explains the basis for the selection of those proposed levels, and DOE will post on its website a draft TSD documenting the analysis of impacts. The draft TSD will also be posted in the appropriate docket at *www.regulations.gov*. As required by 42 U.S.C. 6295(p)(1) of EPCA, the NOPR also will describe the maximum improvement in energy efficiency or maximum reduction in energy use that is technologically feasible and, if the proposed standards would not achieve these levels, the reasons for proposing different standards.

(2) *Public comment and hearing.* There will be not less than 60 days for public comment on the NOPR, with at least one public hearing or workshop. (42 U.S.C. 6295(p)(2) and 42 U.S.C. 6306)

(3) *Revisions to impact analyses and selection of final standard.* Based on the public comments received, DOE will review the proposed standard and impact analyses, and make modifications as necessary. If major changes to the analyses are required at this stage, DOE will publish a supplemental notice of proposed rulemaking (SNOPR), when required. DOE may also publish a NODA or RFI, where appropriate.

(c) *Final rule stage.* The Department will publish a final rule in the FEDERAL REGISTER that promulgates standard levels, responds to public comments received on the NOPR (and SNOPR if applicable), and explains how the selection of those standards meets the statutory requirement that any new or amended energy conservation standard produces the maximum improvement in energy efficiency that is both technologically feasible and economically justified and constitutes significant energy savings, accompanied by a final TSD.

7. POLICIES ON SELECTION OF STANDARDS

(a) *Purpose.* Section 6 describes the process that will be used to consider new or revised energy efficiency standards and lists a number of factors and analyses that will be considered at specified points in the process. Department policies concerning the selection of new or revised standards, and decisions preliminary thereto, are described in this section. These policies are intended to elaborate on the statutory criteria provided in 42 U.S.C. 6295. The procedures described in this section are intended to assist the Department in making the determinations required by EPCA and do not preclude DOE's consideration of any other information consistent with the relevant statutory criteria. The Department will consider pertinent information in determining whether a new or revised standard is consistent with the statutory criteria.

(b) *Screening design options.* These factors will be considered as follows in determining whether a design option will receive any further consideration:

(1) *Technological feasibility.* Technologies that are not incorporated in commercial products or in commercially-viable, existing prototypes will not be considered further.

(2) *Practicability to manufacture, install and service.* If it is determined that mass production of a technology in commercial products and reliable installation and servicing of the technology could not be achieved on the scale necessary to serve the relevant market at the time of the compliance date of the standard, then that technology will not be considered further.

(3) *Impacts on product utility.* If a technology is determined to have significant adverse impact on the utility of the product/equipment to subgroups of consumers, or result in the unavailability of any covered product type with performance characteristics (including reliability), features, sizes, capacities, and volumes that are substantially the same as products generally available in the U.S. at the time, it will not be considered further.

(4) *Safety of technologies.* If it is determined that a technology will have significant adverse impacts on health or safety, it will not be considered further.

(5) *Unique-pathway proprietary technologies.* If a technology has proprietary protection and represents a unique pathway to achieving a given efficiency level, it will not be considered further, due to the potential for monopolistic concerns.

(c) *Identification of candidate standard levels.* Based on the results of the engineering and cost/benefit analyses of design options, DOE will identify the candidate standard levels for further analysis. Candidate standard levels will be selected as follows:

(1) *Costs and savings of design options.* Design options that have payback periods that exceed the median life of the product or which result in life-cycle cost increases relative to the base case, using typical fuel costs, usage, and private discount rates, will not be used as the basis for candidate standard levels.

(2) *Further information on factors used for screening design options.* If further information or analysis leads to a determination that a design option, or a combination of design options, has unacceptable impacts under the policies stated in this Appendix, that design option or combination of design options will not be included in a candidate standard level.

(3) *Selection of candidate standard levels.* Candidate standard levels, which will be identified in the pre-NOPR documents and on which impact analyses will be conducted, will be based on the remaining design options.

(i) The range of candidate standard levels will typically include:

(A) The most energy-efficient combination of design options;

(B) The combination of design options with the lowest life-cycle cost; and

(C) A combination of design options with a payback period of not more than three years.

(ii) Candidate standard levels that incorporate noteworthy technologies or fill in large gaps between efficiency levels of other candidate standard levels also may be selected.

(d) *Pre-NOPR Stage.* New information provided in public comments on any pre-NOPR documents will be considered to determine

whether any changes to the candidate standard levels are needed before proceeding to the analysis of impacts.

(e)(1) *Selection of proposed standard.* Based on the results of the analysis of impacts, DOE will select a standard level to be proposed for public comment in the NOPR. As required under 42 U.S.C. 6295(o)(2)(A), any new or revised standard must be designed to achieve the maximum improvement in energy efficiency that is determined to be both technologically feasible and economically justified.

(2) *Statutory policies.* The fundamental policies concerning the selection of standards include:

(i) A trial standard level will not be proposed or promulgated if the Department determines that it is not both technologically feasible and economically justified. (42 U.S.C. 6295(o)(2)(A) and 42 U.S.C. 6295(o)(3)(B)) For a trial standard level to be economically justified, the Secretary must determine that the benefits of the standard exceed its burdens by, to the greatest extent practicable, considering the factors listed in 42 U.S.C. 6295(o)(2)(B)(i). A standard level is subject to a rebuttable presumption that it is economically justified if the payback period is three years or less. (42 U.S.C. 6295(o)(2)(B)(iii))

(ii) If the Department determines that interested persons have established by a preponderance of the evidence that a standard level is likely to result in the unavailability in the United States of any covered product/equipment type (or class) with performance characteristics (including reliability), features, sizes, capacities, and volumes that are substantially the same as products generally available in the U.S. at the time of the determination, then that standard level will not be proposed. (42 U.S.C. 6295(o)(4))

(iii) If the Department determines that a standard level would not result in significant conservation of energy, that standard level will not be proposed. (42 U.S.C. 6295(o)(3)(B))

(f) *Selection of a final standard.* New information provided in the public comments on the NOPR and any analysis by the Department of Justice concerning impacts on competition of the proposed standard will be considered to determine whether issuance of a new or amended energy conservation standard produces the maximum improvement in energy efficiency that is both technologically feasible and economically justified and still constitutes significant energy savings or whether any change to the proposed standard level is needed before proceeding to the final rule. The same policies used to select the proposed standard level, as described in this section, will be used to guide the selection of the final standard level or a determination that no new or amended standard is justified.

8. TEST PROCEDURES

(a) *Pre-NOPR stage*—(1) *General.* In determining whether to consider establishing or amending any test procedure, DOE will publish one or more preliminary documents in the FEDERAL REGISTER (*e.g.*, an RFI or NODA) intended to gather information on key issues.

(2) *Satisfaction of statutory criteria.* As part of such document(s), DOE will solicit submission of comments, data, and information on whether DOE should proceed with the rulemaking, including whether: a new test procedure would satisfy the relevant statutory criteria that test procedures be reasonably designed to produce test results which measure energy efficiency, energy use, water use (in the case of showerheads, faucets, water closets and urinals), or estimated annual operating cost of a covered product during a representative average use cycle or period of use, as determined by the Secretary, and shall not be unduly burdensome to conduct; or an amended test procedure would more fully or accurately comply with the aforementioned statutory criteria. Based on the information received in response to such request and its own analysis, DOE will determine whether to proceed with a rulemaking for a new or amended test procedure.

(3) If DOE determines that a new or amended test procedure would not satisfy the applicable statutory criteria, DOE will engage in notice-and-comment rulemaking to issue a determination that a new or amended test procedure is not warranted.

(4) If DOE receives sufficient information suggesting a new or amended test procedure may satisfy the applicable statutory criteria or the information received is inconclusive with regard to the statutory criteria, DOE will move forward with the rulemaking to issue or amend a test procedure.

(5) In those instances where the available information either suggested that a new or amended test procedure might be warranted or in which the information was inconclusive on this point, and DOE undertakes a rulemaking to establish or amend a test procedure, DOE may still ultimately determine that such a test procedure does not satisfy the applicable statutory criteria at a later stage of the rulemaking.

(6) *Public comment and hearing.* The length of the public comment period for pre-NOPR rulemaking documents will be determined on a case-by-case basis and may vary depending upon the circumstances of the particular rulemaking. For pre-NOPR documents, DOE will determine whether a public hearing is appropriate.

(b) *NOPR stage*—(1) *Documentation of decisions on proposed test procedure.* The Department will publish a NOPR in the FEDERAL REGISTER that proposes a new or amended

test procedure and explains how the test procedure satisfies the applicable statutory criteria.

(2) *Public comment and hearing.* There will be not less than 60 days for public comment on the NOPR, with at least one public hearing or workshop. (42 U.S.C. 6293(b)(2) and 42 U.S.C. 6306)

(3) *Revisions to the analyses and establishment of a final test procedure.* Based on the public comments received, DOE will review the proposed test procedure, and make modifications as necessary. As part of this process, DOE may issue an RFI, NODA, SNOPR, or other rulemaking document, as appropriate.

(c) *Final rule stage.* The Department will publish a final rule in the FEDERAL REGISTER that establishes or amends a test procedure, responds to public comments received on the NOPR (and any subsequent rulemaking documents), and explains how the new or amended test procedure meets the applicable statutory requirements.

(d) *Adoption of industry test methods.* DOE will adopt industry test procedure standards as DOE test procedures for covered products and equipment, but only if DOE determines that such procedures would not be unduly burdensome to conduct and would produce test results that reflect the energy efficiency, energy use, water use (as specified in EPCA) or estimated operating costs of that equipment during a representative average use cycle. DOE may also adopt industry test procedure standards with modifications or craft its own procedures as necessary to ensure compatibility with the relevant statutory requirements, as well as DOE's compliance, certification, and enforcement requirements.

(e) *Issuing final test procedure*—(1) *Process.* Test procedure rulemakings establishing methodologies used to evaluate proposed energy conservation standards will be finalized prior to publication of a NOPR proposing new or amended energy conservation standards. Except as provided in paragraph (e)(2) of this section, new test procedures and amended test procedures that impact measured energy use or efficiency will be finalized at least 180 days prior to the close of the comment period for:

(i) A NOPR proposing new or amended energy conservation standards; or

(ii) A notice of proposed determination that standards do not need to be amended. With regards to amended test procedures, DOE will state in the test procedure final rule whether the amendments impact measured energy use or efficiency.

(2) *Exceptions.* The 180-day period for new test procedures and amended test procedures that impact measured energy use or efficiency specified in paragraph (e)(1) of this section is not applicable to:

(i) Test procedures developed in accordance with the Negotiated Rulemaking Act or by interested persons that are fairly representative of relevant points of view (including representatives of manufacturers of covered products, States, and efficiency advocates), as determined by the Secretary; or

(ii) Test procedure amendments limited to calculation changes (*e.g.*, use factor or adder). Parties submitting a consensus recommendation in accordance with paragraph (e)(2)(i) of this section may specify a time period between finalization of the test procedure and the close of the comment for a NOPR proposing new or amended energy conservation standards or a notice of proposed determination that standards do not need to be amended.

(f) *Effective date of test procedures.* If required only for the evaluation and issuance of updated efficiency standards, use of the modified test procedures typically will not be required until the implementation date of updated standards.

9. ASHRAE EQUIPMENT

EPCA provides unique statutory requirements and a specific set of timelines for certain enumerated types of commercial and industrial equipment (generally, commercial water heaters, commercial packaged boilers, commercial air-conditioning and heating equipment, and packaged terminal air conditioners and heat pumps (*i.e.*, ''ASHRAE equipment'')).

(a) *ASHRAE trigger rulemakings for energy conservation standards.* Pursuant to EPCA's statutory scheme for covered ASHRAE equipment, DOE is required to consider amending the existing Federal energy conservation standards for ASHRAE equipment when ASHRAE Standard 90.1 is amended with respect to standards or design requirements applicable to such equipment.

(1) Not later than 180 days after the amendment of ASHRAE Standard 90.1, DOE will publish in the FEDERAL REGISTER for public comment an analysis of the energy savings potential of amended energy efficiency standards for the affected equipment.

(2) Not later than 18 months after the amendment of ASHRAE Standard 90.1, DOE must adopt amended energy conservation standards at the new efficiency level in ASHRAE Standard 90.1 as the uniform national standard for the affected equipment, unless DOE determines by rule, and supported by clear and convincing evidence, that a more-stringent standard would result in significant additional conservation of energy and is technologically feasible and economically justified. In such case, DOE must adopt the more-stringent standard for the affected equipment not later than 30 months after amendment of ASHRAE Standard 90.1.

(3) Regarding amendments to ASHRAE Standard 90.1 involving energy conservation

standards, DOE considers an amendment of a standard level to occur when an updated version of ASHRAE Standard 90.1 publishes (*i.e.*, not at the time that an addendum to ASHRAE Standard 90.1 is released or approved). In addition, DOE considers an amendment of standard levels in ASHRAE Standard 90.1 to be only those changes resulting in an increase in stringency of standard levels relative to the current Federal standards or the adoption of a design requirement.

(b) *ASHRAE trigger rulemakings for test procedures.* Pursuant to EPCA's statutory scheme for covered ASHRAE equipment, DOE is required to consider amending the existing Federal test procedures for such equipment when ASHRAE Standard 90.1 is amended with respect to test procedures applicable to such equipment.

(1) DOE shall amend the test procedure for ASHRAE equipment, as necessary, to be consistent with the amended ASHRAE Standard 90.1, unless DOE determines by rule, and supported by clear and convincing evidence, that to do so would not meet the requirements in 42 U.S.C. 6314(a)(2)–(3), which generally provide that the test procedure must produce results which reflect energy efficiency, energy use, and estimated operating costs during a representative average use cycle and not be unduly burdensome to conduct. If DOE makes such a determination, DOE may establish an amended test procedure for such equipment that meets the requirements in 42 U.S.C. 6314(a)(2)–(3).

(2) With regard to test procedures for ASHRAE equipment, EPCA requires DOE to adopt test procedures consistent with applicable industry test standards.

(c) *ASHRAE lookback rulemakings for standards.* EPCA also requires that DOE periodically consider amending energy conservation standards for ASHRAE equipment.

(1) Every 6 years, DOE shall conduct an evaluation of each class of covered equipment. DOE shall publish either a notice of determination that standards do not need to be amended (because they would not result in significant additional conservation of energy and/or would not be technologically feasible and/or economically justified) or a notice of proposed rulemaking including new proposed standards (based on the criteria and procedures in 42 U.S.C. 6313(a)(6)(B) and supported by clear and convincing evidence).

(2) If DOE issues a notice of proposed rulemaking, it shall publish a final rule no more than 2 years later.

(3) If DOE determines that a standard does not need to be amended, not later than 3 years after such a determination, DOE must publish either a notice of determination that standards do not need to be amended (because they would not result in significant additional conservation of energy and/or would not be technologically feasible and/or economically justified) or a notice of proposed rulemaking including new proposed standards (based on the criteria and procedures in 42 U.S.C. 6313(a)(6)(B) and supported by clear and convincing evidence).

(d) *ASHRAE lookback rulemakings for test procedures.* EPCA also requires that DOE periodically consider amending test procedures for ASHRAE equipment. At least once every 7 years, DOE shall conduct an evaluation, and if DOE determines, that amended test procedures would more accurately or fully comply with the requirements in 42 U.S.C. 6314(a)(2)–(3), it shall prescribe test procedures for the applicable equipment. Otherwise, DOE shall publish a notice of determination not to amend a test procedure.

10. Direct Final Rules

In accordance with 42 U.S.C. 6295(p)(4), on receipt of a joint proposal, including a consensus recommendation developed in accordance with the Negotiated Rulemaking Act (5 U.S.C. 561 *et seq.*), that is submitted by interested persons that are fairly representative of relevant points of view, DOE may issue a direct final rule (DFR) establishing energy conservation standards for a covered product or equipment if DOE determines the recommended standard is in accordance with 42 U.S.C. 6295(o) or 42 U.S.C. 6313(a)(6)(B) as applicable. To be ''fairly representative of relevant points of view'' the group submitting a joint statement must, where appropriate, include larger concerns and small businesses in the regulated industry/manufacturer community, energy advocates, energy utilities, consumers, and States. However, it will be necessary to evaluate the meaning of ''fairly representative'' on a case-by-case basis, subject to the circumstances of a particular rulemaking, to determine whether fewer or additional parties must be part of a joint statement in order to be ''fairly representative of relevant points of view.''

11. Principles for Distinguishing Between Effective and Compliance Dates

(a) *Dates, generally.* The effective and compliance dates for either DOE test procedures or DOE energy conservation standards are typically not identical, and these terms should not be used interchangeably.

(b) *Effective date.* The effective date is the date a rule is legally operative after being published in the Federal Register.

(c) *Compliance date.* (1) For test procedures, the compliance date is the specific date when manufacturers are required to use the new or amended test procedure requirements to make representations concerning the energy efficiency or use of a product, including certification that the covered product/equipment meets an applicable energy conservation standard.

(2) For energy conservation standards, the compliance date is the specific date upon which manufacturers are required to meet the new or amended standards for applicable covered products/equipment that are distributed in interstate commerce.

12. PRINCIPLES FOR THE CONDUCT OF THE ENGINEERING ANALYSIS

(a) The purpose of the engineering analysis is to develop the relationship between efficiency and cost of the subject product/equipment. The Department will use the most appropriate means available to determine the efficiency/cost relationship, including an overall system approach or engineering modeling to predict the reduction in energy use or improvement in energy efficiency that can be expected from individual design options as discussed in paragraphs (b) and (c) of this section. From this efficiency/cost relationship, measures such as payback, lifecycle cost, and energy savings can be developed. The Department will identify issues that will be examined in the engineering analysis and the types of specialized expertise that may be required. DOE will select appropriate contractors, subcontractors, and expert consultants, as necessary, to perform the engineering analysis and the impact analysis. Also, the Department will consider data, information, and analyses received from interested parties for use in the analysis wherever feasible.

(b) The engineering analysis begins with the list of design options developed in consultation with the interested parties as a result of the screening process. The Department will establish the likely cost and performance improvement of each design option. Ranges and uncertainties of cost and performance will be established, although efforts will be made to minimize uncertainties by using measures such as test data or component or material supplier information where available. Estimated uncertainties will be carried forward in subsequent analyses. The use of quantitative models will be supplemented by qualitative assessments as appropriate.

(c) The next step includes identifying, modifying, or developing any engineering models necessary to predict the efficiency impact of any one or combination of design options on the product/equipment. A base case configuration or starting point will be established, as well as the order and combination/blending of the design options to be evaluated. DOE will then perform the engineering analysis and develop the cost-efficiency curve for the product/equipment. The cost efficiency curve and any necessary models will be available to stakeholders during the pre-NOPR stage of the rulemaking.

13. PRINCIPLES FOR THE ANALYSIS OF IMPACTS ON MANUFACTURERS

(a) *Purpose.* The purpose of the manufacturer analysis is to identify the likely private impacts of efficiency standards on manufacturers. The Department will analyze the impact of standards on manufacturers with substantial input from manufacturers and other interested parties. This section describes the principles that will be used in conducting future manufacturing impact analyses.

(b) *Issue identification.* In the impact analysis stage, the Department will identify issues that will require greater consideration in the detailed manufacturer impact analysis. Possible issues may include identification of specific types or groups of manufacturers and concerns over access to technology. Specialized contractor expertise, empirical data requirements, and analytical tools required to perform the manufacturer impact analysis also would be identified at this stage.

(c) *Industry characterization.* Prior to initiating detailed impact studies, the Department will seek input on the present and past industry structure and market characteristics. Input on the following issues will be sought:

(1) Manufacturers and their current and historical relative market shares;

(2) Manufacturer characteristics, such as whether manufacturers make a full line of models or serve a niche market;

(3) Trends in the number of manufacturers;

(4) Financial situation of manufacturers;

(5) Trends in product/equipment characteristics and retail markets including manufacturer market shares and market concentration; and

(6) Identification of other relevant regulatory actions and a description of the nature and timing of any likely impacts.

(d) *Cost impacts on manufacturers.* The costs of labor, material, engineering, tooling, and capital are difficult to estimate, manufacturer-specific, and usually proprietary. The Department will seek input from interested parties on the treatment of cost issues. Manufacturers will be encouraged to offer suggestions as to possible sources of data and appropriate data collection methodologies. Costing issues to be addressed include:

(1) Estimates of total private cost impacts, including product/equipment-specific costs (based on cost impacts estimated for the engineering analysis) and front-end investment/conversion costs for the full range of product/equipment models.

(2) Range of uncertainties in estimates of average cost, considering alternative designs and technologies which may vary cost impacts and changes in costs of material, labor, and other inputs which may vary costs.

(3) Variable cost impacts on particular types of manufacturers, considering factors such as atypical sunk costs or characteristics of specific models which may increase or decrease costs.

(e) *Impacts on product/equipment sales, features, prices, and cost recovery.* In order to make manufacturer cash-flow calculations, it is necessary to predict the number of products/equipment sold and their sale price. This requires an assessment of the likely impacts of price changes on the number of products/equipment sold and on typical features of models sold. Past analyses have relied on price and shipment data generated by economic models. The Department will develop additional estimates of prices and shipments by drawing on multiple sources of data and experience including: Actual shipment and pricing experience; data from manufacturers, retailers, and other market experts; financial models, and sensitivity analyses. The possible impacts of candidate/trial standard levels on consumer choices among competing fuels will be explicitly considered where relevant.

(f) *Measures of impact.* The manufacturer impact analysis will estimate the impacts of candidate/trial standard levels on the net cash flow of manufacturers. Computations will be performed for the industry as a whole and for typical and atypical manufacturers. The exact nature and the process by which the analysis will be conducted will be determined by DOE, with input from interested parties, as appropriate. Impacts to be analyzed include:

(1) Industry net present value, with sensitivity analyses based on uncertainty of costs, sales prices, and sales volumes;

(2) Cash flows, by year; and

(3) Other measures of impact, such as revenue, net income, and return on equity, as appropriate. DOE also notes that the characteristics of a typical manufacturers worthy of special consideration will be determined in consultation with manufacturers and other interested parties and may include: Manufacturers incurring higher or lower than average costs; and manufacturers experiencing greater or fewer adverse impacts on sales. Alternative scenarios based on other methods of estimating cost or sales impacts also will be performed, as needed.

(g) *Cumulative Impacts of Other Federal Regulatory Actions.* (1) The Department will recognize and seek to mitigate the overlapping effects on manufacturers of new or revised DOE standards and other regulatory actions affecting the same products or equipment. DOE will analyze and consider the impact on manufacturers of multiple product/equipment-specific regulatory actions. These factors will be considered in setting rulemaking priorities, conducting the early assessment as to whether DOE should proceed with a standards rulemaking, assessing manufacturer impacts of a particular standard, and establishing compliance dates for a new or revised standard that, consistent with any statutory requirements, are appropriately coordinated with other regulatory actions to mitigate any cumulative burden.

(2) If the Department determines that a proposed standard would impose a significant impact on product or equipment manufacturers within approximately three years of the compliance date of another DOE standard that imposes significant impacts on the same manufacturers (or divisions thereof, as appropriate), the Department will, in addition to evaluating the impact on manufacturers of the proposed standard, assess the joint impacts of both standards on manufacturers.

(3) If the Department is directed to establish or revise standards for products/equipment that are components of other products/equipment subject to standards, the Department will consider the interaction between such standards in setting rulemaking priorities and assessing manufacturer impacts of a particular standard. The Department will assess, as part of the engineering and impact analyses, the cost of components subject to efficiency standards.

(h) *Summary of quantitative and qualitative assessments.* The summary of quantitative and qualitative assessments will contain a description and discussion of uncertainties. Alternative estimates of impacts, resulting from the different potential scenarios developed throughout the analysis, will be explicitly presented in the final analysis results.

(1) Key modeling and analytical tools. In its assessment of the likely impacts of standards on manufacturers, the Department will use models that are clear and understandable, feature accessible calculations, and have clearly explained assumptions. As a starting point, the Department will use the Government Regulatory Impact Model (GRIM). The Department will also support the development of economic models for price and volume forecasting. Research required to update key economic data will be considered.

(2) [Reserved]

14. Principles for the Analysis of Impacts on Consumers

(a) *Early consideration of impacts on consumer utility.* The Department will consider at the earliest stages of the development of a standard whether particular design options will lessen the utility of the covered products/equipment to the consumer. See paragraph (b) of section 6.

(b) *Impacts on product/equipment availability.* The Department will determine, based on consideration of information submitted during the standard development process, whether a proposed standard is likely to result in the unavailability of any covered

product/equipment type with performance characteristics (including reliability), features, sizes, capacities, and volumes that are substantially the same as products/equipment generally available in the U.S. at the time. DOE will not promulgate a standard if it concludes that it would result in such unavailability.

(c) *Department of Justice review.* As required by law, the Department will solicit the views of the Department of Justice on any lessening of competition likely to result from the imposition of a proposed standard and will give the views provided full consideration in assessing economic justification of a proposed standard. In addition, DOE may consult with the Department of Justice at earlier stages in the standards development process to seek its preliminary views on competitive impacts.

(d) *Variation in consumer impacts.* The Department will use regional analysis and sensitivity analysis tools, as appropriate, to evaluate the potential distribution of impacts of candidate/trial standard levels among different subgroups of consumers. The Department will consider impacts on significant segments of consumers in determining standards levels. Where there are significant negative impacts on identifiable subgroups, DOE will consider the efficacy of voluntary approaches as a means to achieve potential energy savings.

(e) *Payback period and first cost.* (1) In the assessment of consumer impacts of standards, the Department will consider Life-Cycle Cost, Payback Period, and Cost of Conserved Energy to evaluate the savings in operating expenses relative to increases in purchase price. The Department also performs sensitivity and scenario analyses when appropriate. The results of these analyses will be carried throughout the analysis and the ensuing uncertainty described.

(2) If, in the analysis of consumer impacts, the Department determines that a candidate/trial standard level would result in a substantial increase in product/equipment first costs to consumers or would not pay back such additional first costs through energy cost savings in less than three years, Department will assess the likely impacts of such a standard on low-income households, product/equipment sales and fuel switching, as appropriate.

15. Consideration of Non-Regulatory Approaches

The Department recognizes that non-regulatory efforts by manufacturers, utilities, and other interested parties can result in substantial efficiency improvements. The Department intends to consider the likely effects of non-regulatory initiatives on product/equipment energy use, consumer utility and life-cycle costs, manufacturers, competition, utilities, and the environment, as well as the distribution of these impacts among different regions, consumers, manufacturers, and utilities. DOE will attempt to base its assessment on the actual impacts of such initiatives to date, but also will consider information presented regarding the impacts that any existing initiative might have in the future. Such information is likely to include a demonstration of the strong commitment of manufacturers, distribution channels, utilities, or others to such non-regulatory efficiency improvements. This information will be used in assessing the likely incremental impacts of establishing or revising standards, in assessing—where possible—appropriate compliance dates for new or revised standards, and in considering DOE support of non-regulatory initiatives.

16. Cross-Cutting Analytical Assumptions

In selecting values for certain cross-cutting analytical assumptions, DOE expects to continue relying upon the following sources and general principles:

(a) *Underlying economic assumptions.* The appliance standards analyses will generally use the same economic growth and development assumptions that underlie the most current *Annual Energy Outlook* (*AEO*) published by the Energy Information Administration (EIA).

(b) *Analytic time length.* The appliance standards analyses will use two time lengths—30 years and another time length that is specific to the standard being considered such as the useful lifetime of the product under consideration. As a sensitivity case, the analyses will also use a 9-year regulatory timeline in analyzing the effects of the standard.

(c) *Energy price and demand trends.* Analyses of the likely impact of appliance standards on typical users will generally adopt the mid-range energy price and demand scenario of the EIA's most current *AEO*. The sensitivity of such estimated impacts to possible variations in future energy prices are likely to be examined using the EIA's high and low energy price scenarios.

(d) *Product/equipment-specific energy-efficiency trends, without updated standards.* Product/equipment-specific energy-efficiency trends will be based on a combination of the efficiency trends forecast by the EIA's residential and commercial demand model of the National Energy Modeling System (NEMS) and product-specific assessments by DOE and its contractors with input from interested parties.

(e) *Price forecasting.* DOE will endeavor to use robust price forecasting techniques in projecting future prices of products.

(f) *Private Discount rates.* For residential and commercial consumers, ranges of three different real discount rates will be used. For

residential consumers, the mid-range discount rate will represent DOE's approximation of the average financing cost (or opportunity costs of reduced savings) experienced by typical consumers. Sensitivity analyses will be performed using discount rates reflecting the costs more likely to be experienced by residential consumers with little or no savings and credit card financing and consumers with substantial savings. For commercial users, a mid-range discount rate reflecting DOE's approximation of the average real rate of return on commercial investment will be used, with sensitivity analyses being performed using values indicative of the range of real rates of return likely to be experienced by typical commercial businesses. For national net present value calculations, DOE would use the Administration's approximation of the average real rate of return on private investment in the U.S. economy. For manufacturer impacts, DOE typically uses a range of real discount rates which are representative of the real rates of return experienced by typical U.S. manufacturers affected by the program.

(g) *Social discount rates.* Social discount rates as specified in OMB Circular A–4 will be used in assessing social effects such as costs and benefits.

(h) *Environmental impacts.* (1) DOE calculates emission reductions of carbon dioxide, sulfur dioxide, nitrogen oxides, methane, nitrous oxides, and mercury likely to be avoided by candidate/trial standard levels based on an emissions analysis that includes the two components described in paragraphs (h)(2) and (3) of this section.

(2) The first component estimates the effect of potential candidate/trial standard levels on power sector and site combustion emissions of carbon dioxide, nitrogen oxides, sulfur dioxide, mercury, methane, and nitrous oxide. DOE develops the power sector emissions analysis using a methodology based on DOE's latest *Annual Energy Outlook*. For site combustion of natural gas or petroleum fuels, the combustion emissions of carbon dioxide and nitrogen oxides are estimated using emission intensity factors from the Environmental Protection Agency.

(3) The second component of DOE's emissions analysis estimates the effect of potential candidate/trial standard levels on emissions of carbon dioxide, nitrogen oxides, sulfur dioxide, mercury, methane, and nitrous oxide due to ''upstream activities'' in the fuel production chain. These upstream activities include the emissions related to extracting, processing, and transporting fuels to the site of combustion as detailed in DOE's Fuel-Fuel-Cycle Statement of Policy (76 FR 51281 (August 18, 2011)). DOE will consider the effects of the candidate/trial standard levels on these emissions after assessing the seven factors required to demonstrate economic justification under EPCA. Consistent with Executive Order 13783, dated March 28, 2017, when monetizing the value of changes in reductions in CO_2 and nitrous oxides emissions resulting from its energy conservation standards regulations, including with respect to the consideration of domestic versus international impacts and the consideration of appropriate discount rates, DOE ensures, to the extent permitted by law, that any such estimates are consistent with the guidance contained in OMB Circular A–4 of September 17, 2003 (Regulatory Analysis).

[86 FR 70924, Dec. 13, 2021, as amended at 89 FR 24359, Apr. 8, 2024]

Subpart D—Petitions To Exempt State Regulation From Preemption; Petitions To Withdraw Exemption of State Regulation

SOURCE: 54 FR 6078, Feb. 7, 1989, unless otherwise noted.

§ 430.40 Purpose and scope.

(a) This subpart prescribes the procedures to be followed in connection with petitions requesting a rule that a State regulation prescribing an energy conservation standard, water conservation standard (in the case of faucets, showerheads, water closets, and urinals), or other requirement respecting energy efficiency, energy use, or water use (in the case of faucets, showerheads, water closets, and urinals) of a type (or class) of covered product not be preempted.

(b) This subpart also prescribes the procedures to be followed in connection with petitions to withdraw a rule exempting a State regulation prescribing an energy conservation standard, water conservation standard (in the case of faucets, showerheads, water closets, and urinals), or other requirement respecting energy efficiency, energy use, or water use (in the case of faucets, showerheads, water closets, and urinals) of a type (or class) of covered product.

[63 FR 13318, Mar. 18, 1998]

§ 430.41 Prescriptions of a rule.

(a) *Criteria for exemption from preemption.* Upon petition by a State which has prescribed an energy conservation standard, water conservation standard (in the case of faucets, showerheads,

water closets, and urinals), or other requirement for a type or class of covered equipment for which a Federal energy conservation standard or water conservation standard is applicable, the Secretary shall prescribe a rule that such standard not be preempted if he determines that the State has established by a preponderance of evidence that such requirement is needed to meet unusual and compelling State or local energy interests or water interests. For the purposes of this section, the term ''unusual and compelling State or local energy interests or water interests'' means interests which are substantially different in nature or magnitude than those prevailing in the U.S. generally, and are such that when evaluated within the context of the State's energy plan and forecast, or water plan and forecast the costs, benefits, burdens, and reliability of energy savings or water savings resulting from the State regulation make such regulation preferable or necessary when measured against the costs, benefits, burdens, and reliability of alternative approaches to energy savings or water savings or production, including reliance on reasonably predictable market-induced improvements in efficiency of all equipment subject to the State regulation. The Secretary may not prescribe such a rule if he finds that interested persons have established, by a preponderance of the evidence, that the State's regulation will significantly burden manufacturing, marketing, distribution, sale or servicing of the covered equipment on a national basis. In determining whether to make such a finding, the Secretary shall evaluate all relevant factors including: the extent to which the State regulation will increase manufacturing or distribution costs of manufacturers, distributors, and others; the extent to which the State regulation will disadvantage smaller manufacturers, distributors, or dealers or lessen competition in the sale of the covered product in the State; the extent to which the State regulation would cause a burden to manufacturers to redesign and produce the covered product type (or class), taking into consideration the extent to which the regulation would result in a reduction in the current models, or in the projected availability of models, that could be shipped on the effective date of the regulation to the State and within the U.S., or in the current or projected sales volume of the covered product type (or class) in the State and the U.S.; and the extent to which the State regulation is likely to contribute significantly to a proliferation of State appliance efficiency requirements and the cumulative impact such requirements would have. The Secretary may not prescribe such a rule if he finds that such a rule will result in the unavailability in the State of any covered product (or class) of performance characteristics (including reliability), features, sizes, capacities, and volumes that are substantially the same as those generally available in the State at the time of the Secretary's finding. The failure of some classes (or types) to meet this criterion shall not affect the Secretary's determination of whether to prescribe a rule for other classes (or types).

(1) *Requirements of petition for exemption from preemption.* A petition from a State for a rule for exemption from preemption shall include the information listed in paragraphs (a)(1)(i) through (a)(1)(vi) of this section. A petition for a rule and correspondence relating to such petition shall be available for public review except for confidential or proprietary information submitted in accordance with the Department of Energy's Freedom of Information Regulations set forth in 10 CFR part 1004:

(i) The name, address, and telephone number of the petitioner;

(ii) A copy of the State standard for which a rule exempting such standard is sought;

(iii) A copy of the State's energy plan or water plan and forecast;

(iv) Specification of each type or class of covered product for which a rule exempting a standard is sought;

(v) Other information, if any, believed to be pertinent by the petitioner; and

(vi) Such other information as the Secretary may require.

(2) [Reserved]

(b) *Criteria for exemption from preemption when energy emergency conditions or*

water emergency conditions (in the case of faucets, showerheads, water closets, and urinals) exist within State. Upon petition by a State which has prescribed an energy conservation standard or water conservation standard (in the case of faucets, showerheads, water closets, and urinals) or other requirement for a type or class of covered product for which a Federal energy conservation standard or water conservation standard is applicable, the Secretary may prescribe a rule, effective upon publication in the FEDERAL REGISTER, that such State regulation not be preempted if he determines that in addition to meeting the requirements of paragraph (a) of this section the State has established that: an energy emergency condition or water emergency condition exists within the State that imperils the health, safety, and welfare of its residents because of the inability of the State or utilities within the State to provide adequate quantities of gas, electric energy, or water to its residents at less than prohibitive costs; and cannot be substantially alleviated by the importation of energy or water or the use of interconnection agreements; and the State regulation is necessary to alleviate substantially such condition.

(1) *Requirements of petition for exemption from preemption when energy emergency conditions or water emergency conditions (in the case of faucets, showerheads, water closets, and urinals) exist within a State.* A petition from a State for a rule for exemption from preemption when energy emergency conditions or water emergency conditions exist within a State shall include the information listed in paragraphs (a)(1)(i) through (a)(1)(vi) of this section. A petition shall also include the information prescribed in paragraphs (b)(1)(i) through (b)(1)(iv) of this section, and shall be available for public review except for confidential or proprietary information submitted in accordance with the Department of Energy's Freedom of Information Regulations set forth in 10 CFR part 1004:

(i) A description of the energy emergency condition or water emergency condition (in the case of faucets, showerheads, water closets, and urinals) which exists within the State, including causes and impacts.

(ii) A description of emergency response actions taken by the State and utilities within the State to alleviate the emergency condition;

(iii) An analysis of why the emergency condition cannot be alleviated substantially by importation of energy or water or the use of interconnection agreements; and

(iv) An analysis of how the State standard can alleviate substantially such emergency condition.

(2) [Reserved]

(c) *Criteria for withdrawal of a rule exempting a State standard.* Any person subject to a State standard which, by rule, has been exempted from Federal preemption and which prescribes an energy conservation standard or water conservation standard (in the case of faucets, showerheads, water closets, and urinals) or other requirement for a type or class of a covered product, when the Federal energy conservation standard or water conservation standard (in the case of faucets, showerheads, water closets, and urinals) for such product subsequently is amended, may petition the Secretary requesting that the exemption rule be withdrawn. The Secretary shall consider such petition in accordance with the requirements of paragraph (a) of this section, except that the burden shall be on the petitioner to demonstrate that the exemption rule received by the State should be withdrawn as a result of the amendment to the Federal standard. The Secretary shall withdraw such rule if he determines that the petitioner has shown the rule should be withdrawn.

(1) *Requirements of petition to withdraw a rule exempting a State standard.* A petition for a rule to withdraw a rule exempting a State standard shall include the information prescribed in paragraphs (c)(1)(i) through (c)(1)(vii) of this section, and shall be available for public review, except for confidential or proprietary information submitted in accordance with the Department of Energy's Freedom of Information Regulations set forth in 10 CFR part 1004:

(i) The name, address and telephone number of the petitioner;

(ii) A statement of the interest of the petitioner for which a rule withdrawing an exemption is sought;

(iii) A copy of the State standard for which a rule withdrawing an exemption is sought;

(iv) Specification of each type or class of covered product for which a rule withdrawing an exemption is sought;

(v) A discussion of the factors contained in paragraph (a) of this section;

(vi) Such other information, if any, believed to be pertinent by the petitioner; and

(vii) Such other information as the Secretary may require.

(2) [Reserved]

[63 FR 13318, Mar. 18, 1998]

§ 430.42 Filing requirements.

(a) *Service.* All documents required to be served under this subpart shall, if mailed, be served by first class mail. Service upon a person's duly authorized representative shall constitute service upon that person.

(b) *Obligation to supply information.* A person or State submitting a petition is under a continuing obligation to provide any new or newly discovered information relevant to that petition. Such information includes, but is not limited to, information regarding any other petition or request for action subsequently submitted by that person or State.

(c) *The same or related matters.* A person or State submitting a petition or other request for action shall state whether to the best knowledge of that petitioner the same or related issue, act, or transaction has been or presently is being considered or investigated by any State agency, department, or instrumentality.

(d) *Computation of time.* (1) Computing any period of time prescribed by or allowed under this subpart, the day of the action from which the designated period of time begins to run is not to be included. If the last day of the period is Saturday, or Sunday, or Federal legal holiday, the period runs until the end of the next day that is neither a Saturday, or Sunday or Federal legal holiday.

(2) Saturdays, Sundays, and intervening Federal legal holidays shall be excluded from the computation of time when the period of time allowed or prescribed is 7 days or less.

(3) When a submission is required to be made within a prescribed time, DOE may grant an extension of time upon good cause shown.

(4) Documents received after regular business hours are deemed to have been submitted on the next regular business day. Regular business hours for the DOE's National Office, Washington, DC, are 8:30 a.m. to 4:30 p.m.

(5) DOE reserves the right to refuse to accept, and not to consider, untimely submissions.

(e) *Filing of petitions.* (1) A petition for a rule shall be submitted in triplicate to: The Assistant Secretary for Conservation and Renewable Energy, U.S. Department of Energy, Section 327 Petitions, Appliance Efficiency Standards, Forrestal Building, 1000 Independence Avenue, SW., Washington, DC 20585.

(2) A petition may be submitted on behalf of more than one person. A joint petition shall indicate each person participating in the submission. A joint petition shall provide the information required by § 430.41 for each person on whose behalf the petition is submitted.

(3) All petitions shall be signed by the person(s) submitting the petition or by a duly authorized representative. If submitted by a duly authorized representative, the petition shall certify this authorization.

(4) A petition for a rule to withdraw a rule exempting a State regulation, all supporting documents, and all future submissions shall be served on each State agency, department, or instrumentality whose regulation the petitioner seeks to supersede. The petition shall contain a certification of this service which states the name and mailing address of the served parties, and the date of service.

(f) *Acceptance for filing.* (1) Within fifteen (15) days of the receipt of a petition, the Secretary will either accept it for filing or reject it, and the petitioner will be so notified in writing. The Secretary will serve a copy of this notification on each other party served by the petitioner. Only such petitions which conform to the requirements of

this subpart and which contain sufficient information for the purposes of a substantive decision will be accepted for filing. Petitions which do not so conform will be rejected and an explanation provided to petitioner in writing.

(2) For purposes of the Act and this subpart, a petition is deemed to be filed on the date it is accepted for filing.

(g) *Docket.* A petition accepted for filing will be assigned an appropriate docket designation. Petitioner shall use the docket designation in all subsequent submissions.

§ 430.43 Notice of petition.

(a) Promptly after receipt of a petition and its acceptance for filing, notice of such petition shall be published in the FEDERAL REGISTER. The notice shall set forth the availability for public review of all data and information available, and shall solicit comments, data and information with respect to the determination on the petition. Except as may otherwise be specified, the period for public comment shall be 60 days after the notice appears in the FEDERAL REGISTER.

(b) In addition to the material required under paragraph (a) of this section, each notice shall contain a summary of the State regulation at issue and the petitioner's reasons for the rule sought.

§ 430.44 Consolidation.

DOE may consolidate any or all matters at issue in two or more proceedings docketed where there exist common parties, common questions of fact and law, and where such consolidation would expedite or simplify consideration of the issues. Consolidation shall not affect the right of any party to raise issues that could have been raised if consolidation had not occurred.

§ 430.45 Hearing.

The Secretary may hold a public hearing, and publish notice in the FEDERAL REGISTER of the date and location of the hearing, when he determines that such a hearing is necessary and likely to result in a timely and effective resolution of the issues. A transcript shall be kept of any such hearing.

§ 430.46 Disposition of petitions.

(a) After the submission of public comments under § 430.42(a), the Secretary shall prescribe a final rule or deny the petition within 6 months after the date the petition is filed.

(b) The final rule issued by the Secretary or a determination by the Secretary to deny the petition shall include a written statement setting forth his findings and conclusions, and the reasons and basis therefor. A copy of the Secretary's decision shall be sent to the petitioner and the affected State agency. The Secretary shall publish in the FEDERAL REGISTER a notice of the final rule granting or denying the petition and the reasons and basis therefor.

(c) If the Secretary finds that he cannot issue a final rule within the 6-month period pursuant to paragraph (a) of this section, he shall publish a notice in the FEDERAL REGISTER extending such period to a date certain, but no longer than one year after the date on which the petition was filed. Such notice shall include the reasons for the delay.

§ 430.47 Effective dates of final rules.

(a) A final rule exempting a State standard from Federal preemption will be effective:

(1) Upon publication in the FEDERAL REGISTER if the Secretary determines that such rule is needed to meet an ''energy emergency condition or water emergency condition (in the case of faucets, showerheads, water closets, and urinals)'' within the State.

(2) Three years after such rule is published in the FEDERAL REGISTER; or

(3) Five years after such rule is published in the FEDERAL REGISTER if the Secretary determines that such additional time is necessary due to the burdens of retooling, redesign or distribution.

(b) A final rule withdrawing a rule exempting a State standard will be effective upon publication in the FEDERAL REGISTER.

[54 FR 6078, Feb. 7, 1989, as amended at 63 FR 13319, Mar. 18, 1998]