

§ 95.01-1

95.60-5 Number required.
95.60-10 Location.

EFFECTIVE DATE NOTE: By 89 FR 76699, Sept. 18, 2024, the authority citation to part 95 was revised, effective Oct. 18, 2024. For the convenience of the user, the revised text is set forth as follows:

AUTHORITY: 46 U.S.C. 3306; E.O. 12234, 45 FR 58801, 3 CFR, 1980 Comp., p. 277; DHS Delegation No. 00170.1, Revision No. 01.4.

SOURCE: CGFR 65-50, 30 FR 17001, Dec. 30, 1965, unless otherwise noted.

Subpart 95.01—Application

§ 95.01-1 General.

(a) The provisions of this part apply to all vessels except as specifically noted in this part.

(b) Equipment installed prior to August 22, 2016 as required by this paragraph (b) may remain in service so long as it is maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection.

[CGFR 65-50, 30 FR 17001, Dec. 30, 1965, as amended by USCG-2006-24797, 77 FR 33878, June 7, 2012; USCG-2012-0196, 81 FR 48262, July 22, 2016]

§ 95.01-2 Incorporation by reference.

(a) Certain material is incorporated by reference into this part with the approval of the Director of the Federal Register under 5 U.S.C. 552(a) and 1 CFR part 51. To enforce any edition other than that specified in this section, the Coast Guard must publish notice of change in the FEDERAL REGISTER and the material must be available to the public. All approved material is available for inspection at the National Archives and Records Administration (NARA). For information on the availability of this material at NARA, call 202-741-6030 or go to http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html. Also, it is available for inspection at Coast Guard Headquarters. Contact Commandant (CG-ENG), Attn: Office of Design and Engineering Systems, U.S. Coast Guard Stop 7509, 2703 Martin Luther King Jr. Avenue SE., Washington, DC 20593-7509; telephone 202-372-1405. The material is also available from the sources listed in paragraphs (b) and (c) of this section.

46 CFR Ch. I (10-1-24 Edition)

(b) ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959, 877-909-2786, <http://www.astm.org>.

(1) ASTM F1121-87 (Reapproved 2010), Standard Specification for International Shore Connections for Marine Fire Applications, (approved March 1, 2010), incorporation by reference approved for § 95.10-10.

(2) [Reserved]

(c) International Maritime Organization (IMO) Publishing, 4 Albert Embankment, London SE1 7SR, United Kingdom, +44 (0)20 7735 7611, <http://www.imo.org>.

(1) FSS Code, International Code for Fire Safety Systems, Second Edition, 2007 Edition (Resolution MSC.98(73)), IBR approved for § 95.05-3(a) and (b).

(2) [Reserved]

(d) National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02169, 617-770-3000, <http://www.nfpa.org>.

(1) NFPA 13, Standard for the Installation of Sprinkler Systems, 2010 Edition, effective August 26, 2009, IBR approved for § 95.30-1.

(2) [Reserved]

(e) UL (formerly Underwriters Laboratories), 12 Laboratory Drive, P.O. Box 13995, Research Triangle Park, NC 27709, 919-549-1400, <http://www.ul.com>.

(1) UL 19, Standard for Safety for Lined Fire Hose and Hose Assemblies, Twelfth Edition, approved November 30, 2001, IBR approved for § 95.10-10(n).

(2) [Reserved]

[USCG-2009-0702, 74 FR 49232, Sept. 25, 2009, as amended by USCG-2012-0832, 77 FR 59780, Oct. 1, 2012; USCG-2012-0866, 78 FR 13251, Feb. 27, 2013; USCG-2013-0671, 78 FR 60151, Sept. 30, 2013; USCG-2012-0196, 81 FR 48262, July 22, 2016]

§ 95.01-5 Equipment installed but not required.

(a) Where fire extinguishing systems or equipment are not required, but are installed, the system or equipment and its installation must meet the requirements of this part.

(b) Use of non-approved fire detection systems may be acceptable as excess equipment provided that—

(1) Components are listed and labeled by an independent, nationally recognized testing laboratory as set forth in